

Hobbs, Darren

From: Strong, Michael J
Sent: Thursday, March 3, 2022 7:30 AM
To: CodesStandards, DAS
Cc: Nezames, Theodore H; Barakat, Rabih M; Fox, Adam G.; LeBlanc, Michael M
Subject: 2022 Connecticut Fire Safety Code - Public Comments related to NFPA 502

On behalf of the Connecticut Department of Transportation (Department) I would like to offer the following comments (underlined):

Comment 1

(Add) 403.10.6 Road tunnels. Newly-constructed road tunnels shall comply with Chapter 7 of NFPA 502. Renovations to existing road tunnels are not required to comply with Chapter 7 of NFPA 502.

The purpose of the comment is to clarify the applicability of the new code provisions.

Comment 2

Chapter 80 references NFPA 502 with a link to 403.11.6 but the correct reference should be 403.10.6.

Contact me if you have any questions or require additional information.

Michael J. Strong, P.E.
Trans. Supervising Engineer
CT DOT - Office of Facilities Design
(P) (860) 594-3306
(F) (860) 594-3375
(Cell) (860) 221-5129
E-Mail Michael.Strong@ct.gov

Please use E-Mail or Cell # to reach me while I am working outside the office