

# Certification Submission Form

This form must be completed, signed, and sent along with any required certification and/or viable sampling report submitted.



	<u>COMMENTS</u>		
1. Have all cleanrooms, laminar airflow workbenches, BSCs, CAIs, CACIs, and barrier isolators been certified?	Yes	No	
2. List the number of individuals documented as being present during dynamic comprehensive viable environmental monitoring:	Anteroom: # _____	Buffer room: # _____	HD buffer room: # _____
3. Does the cleanroom have an ISO Class 5 shielded laminar workflow area built into the room?	Yes	No	
4. Is certification performed at least every 6 months, whenever the PECs are replaced or relocated; the physical structure of the buffer room or anteroom has been altered; or when any airflow or air quality is affected?	Yes	No	
4a. Are certification reports available?	Yes	No	
4b. Note the date(s) of certification failure, if applicable.			
5. Has the cleanroom been independently certified using the requirements of USP Chapter 797 and when applicable, manufacturer specifications?	Yes	No	
5a. Indicate the standards used as cited in the report:			
6. Is the equipment used by the certifier calibrated and is the calibration in date?	Yes	No	
7. Does each test on the certification report have a clear indication of pass or fail?	Yes	No	

COMMENTS

- |     |  |     |    |
|-----|--|-----|----|
| 8.  | Are the HEPA filtered air changes per hour (ACPH) measured for the compounding rooms?  | Yes | No |
| 8a. | Are ISO Class 7 rooms certified as having a minimum of 30 ACPH with at least 15 ACPH of the total air change rate in the room from the HVAC through HEPA filters located in the ceiling?   | Yes | No |
| 8b. | Are ISO Class 8 rooms certified as having a minimum of 20 ACPH with at least 15 ACPH of the total air change rate in the room from the HVAC through HEPA filters located in the ceiling?   | Yes | No |
| 9.  | Was air pattern analysis using smoke testing performed in each PEC?  | Yes | No |
| 10. | Is smoke flow in the PEC described in the report for the various tests such as turbulent, sluggish, smooth, etc.?  | Yes | No |
| 11. | Was a dynamic airflow smoke pattern test conducted inside each PEC (i.e., the direct compounding area) to demonstrate unidirectional airflow and sweeping action over and away from the preparations under dynamic operating conditions?   | Yes | No |
| 12. | Was a visual smoke study test performed in the SECs to verify the absence of stagnant airflow?   | Yes | No |
| 13. | If the cleanroom has an ISO Class 5 shielded laminar workflow area, are both static and dynamic smoke studies documented verifying continuous flow of HEPA-filtered air void of turbulence, dead air zones, and refluxing from the HEPA filters to and across the entire work area and to the air returns? | Yes | No |

COMMENTS

- |     |   |     |    |
|-----|---|-----|----|
| 14. | Was air pattern analysis conducted to confirm differential pressure at all points around all openings, doorways, and passthroughs?  | Yes | No |
| 15. | Was air pattern analysis conducted around particle generating equipment while the equipment was in operation to confirm air flow?   | Yes | No |
| 16. | Was the differential pressure measured to be at least 0.02" water column positive from the non-hazardous buffer room to the anteroom and from the anteroom to unclassified areas? | Yes | No |
| 17. | Was the differential pressure in the C-SCA/C-SEC measured to be between 0.01 and 0.03" water column negative to all adjacent areas?   | Yes | No |
| 18. | Were particle counts measured at greater than or equal to 0.5 micrometers?  | Yes | No |
| 19. | Were all particle counts taken during dynamic conditions and documented on certification reports?   | Yes | No |
| 20. | Are ISO Class 5 areas certified as having less than 3,520 particles per cubic meter of air?   | Yes | No |
| 21. | Are ISO Class 7 areas certified as having less than 352,000 particles per cubic meter of air?   | Yes | No |
| 22. | Are ISO Class 8 areas certified as having less than 3,520,000 particles per cubic meter of air?   | Yes | No |

COMMENTS

- |      |   |                      |                         |                            |
|------|---|----------------------|-------------------------|----------------------------|
| 23.  | List the number of HEPA filters in each ISO certified room:   | Anteroom:<br># _____ | Buffer room:<br># _____ | HD buffer room:<br># _____ |
| 23a. | Was HEPA filter leak testing performed in the ISO certified rooms?  | Yes                  | No                      |                            |
| 23b. | If leaks were identified, were they repaired?   | Yes                  | No                      |                            |
| 23c. | If a repair was performed, was a smoke study performed in front of the repaired area?                               | Yes                  | No                      |                            |
| 24.  | List the number of PECs in each ISO certified room:   | Anteroom:<br># _____ | Buffer room:<br># _____ | HD buffer room:<br># _____ |
| 24a. | Was HEPA filter leak testing performed in all PECs?   | Yes                  | No                      |                            |
| 24b. | If applicable, was the BSC/CACI exhaust HEPA filter leak tested?  | Yes                  | No                      |                            |
| 24c. | If leaks were identified, were they repaired?   | Yes                  | No                      |                            |
| 24d. | If a repair was performed, was a smoke study performed in front of the repaired area?                               | Yes                  | No                      |                            |
| 25.  | Were viable air and surface sampling tests conducted?   | Yes                  | No                      |                            |
| 26.  | Was a general microbiological growth media that supports the growth of bacteria and fungi used?<br>List media used. | Yes                  | No                      |                            |

COMMENTS

- |     |   |     |    |
|-----|---|-----|----|
| 27. | Was viable air sampling by active impaction using a volumetric air sampling device performed in all classified areas during dynamic operating conditions?   | Yes | No |
| 28. | Was each air sample taken in ISO classified areas at least 1,000 liters in volume?  | Yes | No |
| 29. | Was viable surface sampling performed in each classified area including each room, the interior of each ISO Class 5 PEC, and passthrough chambers connecting to classified areas using a risk-based approach? | Yes | No |
| 30. | Did any of the viable samples exceed action levels listed in USP Chapter <797>?   | Yes | No |
| 31. | If the levels measured during sampling exceed action levels, was the cause investigated? List the corrective actions were taken.  | Yes | No |
| 32. | If levels measured during sampling exceed action levels, was an attempt made to identify any microorganisms recovered to the genus level with the assistance of a microbiologist?                             | Yes | No |
| 33. | Do COAs from the manufacturer verify that the sampling media devices meet the expected growth promotion, pH and sterilization requirements?   | Yes | No |

COMMENTS

34. Did the testing results report include the following information:                      Yes                      No

- Media type
- Media lot number
- Media expiration date
- Signature of the laboratory analyst and/or reviewer
- Temperature of incubation
- Dates of incubation

Printed Name of Designated Pharmacist conducting review:

\_\_\_\_\_

Signature of Designated Pharmacist: \_\_\_\_\_

Date: \_\_\_\_\_

**Note: Performing incompetent or negligent work violates CGS Section 20-579(a)(15), and Section 21a-93(16) of the general statutes prohibits failing to demonstrate adherence to applicable provisions of United States Pharmacopeia, Chapter 797, Pharmaceutical Compounding – Sterile Preparations, as amended from time to time, concerning compounding or preparation of sterile drugs.**