

BUREAU OF AIR MANAGEMENT TITLE V OPERATING PERMIT

Issued pursuant to Title 22a of the Connecticut General Statutes (CGS) and Section 22a-174-33 of the Regulations of Connecticut State Agencies (RCSA) and pursuant to the Code of Federal Regulations (CFR), Title 40, Part 70.

Title V Permit Number	107-0043-TV
Client/Sequence/Town/Premises Numbers	8856/0003/107/0005
Date Issued	December 20, 2022
Modification Issue Date	January 25, 2024
Expiration Date	December 20, 2027

$\boldsymbol{\alpha}$		4 •	
('Ar	nar	ากเรีย	١.
Cor	DOI (auvi	ı.

Montville Power LLC

Premises Location:

74 Lathrop Road, Uncasville, CT 06382

Name of Responsible Official and Title:

Ali Khurrum, Senior Vice of Operations

All the following attached pages, 2 through 43, are hereby incorporated by reference into this Title V permit.

for Katheine S. Dykes Commissioner

January 25, 2024

Date

TABLE OF CONTENTS

		PAGE
List of Abbreviations/Ac	cronyms	4
Section I. Premises Infor	rmation/Description	
	Premises Information	6
В.	Premises Description.	6
Section II. Emissions Ur	nits Information	
	Emissions Units Description - Table II.A	Q
	Operating Scenario Identification - Table II.B	
D.	Operating Scenario Identification - Table II.B	9
	Requirements and Compliance Demonstration	
A.	Grouped Emissions Unit 1	
В.	Grouped Emissions Unit 2	18
C.	Grouped Emissions Unit 3	24
D.	Emissions Unit 7	
E.	Federal Acid Rain Permit Requirements	31
F.	Premises-Wide General Requirements	
Section IV. Compliance	Schedule - Table IV	34
Section V. State Enforce	able Terms and Conditions	35
Section VI. Title V Requ	viramento	
	Submittals to the Commissioner & Administrator	37
	Certifications [RCSA §22a-174-33(b)]	
	Signatory Responsibility [RCSA §22a-174-2a(a)]	
	Additional Information [RCSA §\$22a-174-2a(a)]	
E.		
F.	Premises Records [RCSA §22a-174-33(o)(1)]	
G.		
Н.		
I.	Permit Deviation Notifications [RCSA §22a-174-33(q)(2)]	
т. J.	Permit Renewal [RCSA §22a-174-33(j)(1)(B)]	
л. К.	Operate in Compliance [RCSA §22a-174-33(j)(1)(D)]	
_	Compliance with Permit [RCSA §22a-174-33(j)(1)(C)]	
L.	Inspection to Determine Compliance [RCSA §22a-174-33(j)(1)(M)]	
	<u> </u>	
	Permit Availability	
	Severability Clause [RCSA §22a-174-33(j)(1)(R)]	
Р.		
Q.	I	
	Property Rights [RCSA §22a-174-33(j)(1)(W)]	
S.	Alternative Operating Scenario Records [RCSA §22a-174-33(o)(3)]	
T.	Operational Flexibility and Off-Permit Changes [RCSA §22a-174-33(r)(2)]	
U.	Information for Notification [RCSA §22a-174-33(r)(2)(A)]	
V.	Transfers [RCSA §22a-174-2a(g)]	
	Revocation [RCSA §22a-174-2a(h)]	
	1 0 (/1	
\mathbf{v}	Cradible Evidence	13

Title V Operating Permit
All conditions in Sections III, IV, and VI of this Title V permit are enforceable by both the Administrator and the commissioner unless otherwise specified. Applicable requirements and compliance demonstration are set forth in Section III of this Title V permit. The Administrator or any citizen of the United States may bring an action to enforce all permit terms or conditions or requirements contained in Sections III, IV, and VI of this Title V permit in accordance with the Clean Air Act, as amended.

LIST OF ABBREVIATIONS/ACRONYMS

Abbreviation/Acronym Description

AEL Allowable Emission Rate
ASC Actual Stack Concentration

ASTM American Society for Testing and Material

bhp brake horse power
Btu British Thermal Unit

CAM Compliance Assurance Monitoring

CAIR Clean Air Interstate Rule

CEMS Continuous Emission Monitoring System

CFR Code of Federal Regulations
CGS Connecticut General Statutes
CI Compression Ignition
CO Carbon Monoxide

COMS Continuous Opacity Monitoring System

CO₂ Carbon Dioxide

DERC Discrete Emission Reduction Credit

EU Emissions Unit

EPA Environmental Protection Agency

ESP Electrostatic Precipitator

⁰F Degrees Fahrenheit

FLER Full Load Emission Rate

ft³ Cubic Feet gal Gallons

GEU Grouped Emissions Units

H₂SO₄ Sulfuric Acid

HAP Hazardous Air Pollutants

hr Hour lb Pound hp Horsepower

ISO-NE ISO – New England

kW Kilowatt

MATS Mercury and Air Toxics Standard

MMBtu Million Btu MW Megawatt

NESHAP National Emission Standards for Hazardous Air Pollutants

 $\begin{array}{cc} NO_x & Nitrogen \ Oxides \\ NSR & New \ Source \ Review \\ PM & Particulate \ Matter \end{array}$

PM₁₀ Particulate Matter less than 10 microns

ppm parts per million

QA/QC Quality Assurance and Quality Control
RACT Reasonable Available Control Technology
RCSA Regulations of Connecticut State Agencies
RICE Reciprocating Internal Combustion Engine

LIST OF ABBREVIATIONS/ACRONYMS, continued

Abbreviation/Acronym	Description
SIC	Standard Industrial Classification Code
SNCR	Selective Non-Catalytic Reduction
SO_2	Sulfur Dioxide
SOx	Sulfur Oxides
TA&O	Trading Agreement and Order
TBD	To Be Determined
TR	Transformer Rectifier
TSP	Total Suspended Particles
tpy	Tons per year
TSP	Total Suspended Particulate
ug/m^3	microgram per cubic meter
VOC	Volatile Organic Compound

Section I: Premises Information/Description

A. PREMISES INFORMATION

Nature of Business: Electric Power Generation

Primary SIC: 4911 Other SIC: None

Facility Mailing Address: Montville Power LLC

74 Lathrop Road, Montville, CT 06382

Telephone Number: (860) 848-9248

B. PREMISES DESCRIPTION

Montville Power LLC, is located on Lathrop Road in Uncasville, Connecticut. The station produces electricity for sale. The station consists of two steam electric generating boilers and two diesel generators for the production of electricity. Additional emissions units at the station include two auxiliary boilers for steam, and a diesel-fired fire pump. The total electrical output from the station is 488 megawatts (MW).

The steam electric generating boilers (Units 5 & 6) are Combustion Engineering (CE) tangentially fired boilers. They are located within the main power plant building.

Unit 5 (EU-1), Registration No. 107-0017-R, is rated at 905 million Btu/hr and is capable of producing 82 MW. Unit 5 can burn No. 6 oil and natural gas, on an interruptible basis. No. 2 oil is used for startup, shutdown and operational stabilization. It is equipped with an electrostatic precipitator for particulate emission control. Unit 5 is subject to Consent Order No. 1887 (Opacity), Consent Order 8377 Mod 1 and RCSA §22a-174-22c (CAIR). In accordance with Consent Order 8377 Mod 1, the unit and may use any of the following to control NOx emissions: Combustion Modification [Low-NOx burners, Excess Air Control, (i.e. Low-NOx vanes, Over-Fire Air)], and/or Urea Injection. Unit 5 is a Phase II Acid Rain Source and the CEM system has been certified in accordance with 40 CFR Part 75. Unit 5 is equipped with CEM for CO₂, NOx, SO₂ and opacity for compliance verification.

Unit 6 (EU-2), Registration No. 107-0020-R, is rated at 4,658 million Btu/hr and is capable of producing 402 MW. Unit 6 burns No. 6 oil as the primary fuel and No. 2 oil is used for startup, shutdown and operational stabilization. Unit 6 is subject to Consent Order No. 1887 (Opacity), Consent Order 8377 Mod 1 and RCSA §22a-174-22c (CAIR). In accordance with Consent Order 8377 Mod 1 the unit and may use any of the following to control NOx emissions: Combustion Modification [Low-NOx burners, Excess Air Control, (i.e. Low-NOx vanes, Over-Fire Air)], and/or Urea Injection. Unit 6 is also a Phase II Acid Rain Source and its CEM system is also certified in accordance with 40 CFR Part 75. Unit 6 is equipped with CEM for CO₂, NOx, SO₂ and opacity for compliance verification.

Units 5 and 6 are considered Electric Generating Units as defined by the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Coal and Oil Fired Electric Utility Steam Generating Units [also known as Mercury and Air Toxics Standards (MATS)], 40 CFR Part 63 Subpart UUUUU, for power plants.

Units 7 and 8 (EU-3 & EU-4), NSR Permit Nos. 107-0012 and 107-0013, are Foster Wheeler front-fired, dual fuel, auxiliary steam boilers. These units are used to provide steam for boiler warm-up. Both boilers are capable of burning No. 2 oil and natural gas. Since Montville Station is considered a major source of HAP emissions these units are subject to the NESHAP for Industrial, Commercial, and Institutional

Montville Power LLC Page 6 of 43 Permit No. 107-0043-TV

Section I: Premises Information/Description

Boilers and Process Heaters, 40 CFR Part 63 Subpart DDDDD. The boilers are operated under the *gas 1* subcategory with an oxygen trim system to maintain the air-to-fuel ratio. Therefore, they do not have emission limitations, but only work practice standards under Subpart DDDDD. The units are also subject to the New Source Performance Standards (NSPS) for Industrial, Commercial, and Institutional Steam Generating Units 40 CFR Part 60 Subpart Dc.

Units 10 and 11 (EU-5 & EU-6), Registrations Nos. 107-0021-R and R107-0022-R, are EMD 2.75 MW diesel engines. These units are subject to Consent Order No. 8377 Mod 1 for Alternative NOx RACT compliance. These units are located to the west of the main power plant building. These units are subject to collateral conditions in NSR Permit No. 107-0012 that limits the annual amount of combined fuel use and the sulfur content of the fuel. These units are existing stationary diesel engines located at a major source of HAP emissions and are subject to the NESHAP for Reciprocating Internal Combustion Engines (RICE) 40 CFR Part 63 Subpart ZZZZ and use oxidation catalyst for compliance.

Emissions Unit 7 (EU-7) is a Cummins diesel fire pump for emergency situations. This engine is located to the east of the main power plant building. The unit burns No. 2 oil with a fuel sulfur content of 0.0015%, by weight. The pump is tested for 15 minutes on a monthly basis to assure proper operation. This unit is currently operating under the provisions of RCSA §22a-174-3b(e). EU-7 is considered an existing emergency engine of less than 500 hp pursuant to 40 CFR Part 63 Subpart ZZZZ.

The Montville Station may receive, store, and blend No. 6 oil with > 1.0% sulfur. This activity has been determined to be less than 1.0 ton per year of potential emissions and thus is deemed an insignificant activity. However, the approval continues to be in effect given that Montville Power LLC complies with the terms and conditions listed for fuel blending in Section III.A.7.c.iii. of this Title V permit.

Montville Power LLC Page 7 of 43 Permit No. 107-0043-TV

Section II: Emissions Units Information

A. EMISSIONS UNITS DESCRIPTION

Emissions units are set forth in Table II.A. It is not intended to incorporate by reference these NSR Permits, Orders, Registrations, or Regulations into this Title V permit.

TABLE II.A: EMISSIONS UNIT DESCRIPTION						
Emissions Units/Grouped Emissions Units	Emissions Unit Description	Control Unit Description	Permit, Order, Registration, or Regulation Number			
EU-1	Unit 5: Combustion Engineering, Type R Dual fuel fired 905 MMBtu/hr, 82 MW electric utility steam boiler Installed 01/01/54	Electrostatic Precipitator Urea Injection Staged combustion Low NOx burners	Registration No. 107-0017-R Consent Order 8377 Mod 1 Consent Order No. 1887 40 CFR Part 63 Subpart UUUUU 40 CFR Parts 72-78, inclusive RCSA §22a-174-22c RCSA §22a-174-22e			
EU-2	Unit 6: Combustion Engineering, Type RRP No. 6 oil fired 4,658 MMBtu/hr, 402 MW electric utility steam boiler Installed 01/01/71	Staged combustion Low NOx burners Urea Injection	Registration No. 107-0020-R Consent Order 8377 Mod 1 Consent Order No. 1887 40 CFR Part 63 Subpart UUUUU 40 CFR Parts 72-78, inclusive RCSA §22a-174-22c RCSA §22a-174-22e			
EU-3	Unit 7: Dual fuel fired Foster Wheeler AG 560 auxiliary steam boiler Installed 04/01/91	None	Permit No. 107-0012 40 CFR Part 63 Subpart DDDDD 40 CFR Part 60 Subpart Dc RCSA §22a-174-22e			
EU-4	Unit 8: Dual fuel fired Foster Wheeler AG 560 auxiliary steam boiler Installed 01/01/91	None	Permit No. 107-0013 40 CFR Part 63 Subpart DDDDD 40 CFR Part 60 Subpart Dc RCSA §22a-174-22e			

Section II: Emissions Units Information

TABLE II.A: EMISSIONS UNIT DESCRIPTION						
Emissions Units/Grouped Emissions Units	Emissions Unit Description	Control Unit Description	Permit, Order, Registration, or Regulation Number			
EU-5	Unit 10: EMD#20645 2.75 MW diesel generator Installed 01/01/167	Oxidation Catalyst	Registration No. 107-0021-R Consent Order 8377 Mod 1 40 CFR Part 63 Subpart ZZZZ RCSA §22a-174-22e Collateral conditions in P107-0012			
EU-6	Unit 11; EMD#20645 2.75 MW diesel generator Installed 01/01/67	Oxidation Catalyst	Registration No. 107-0022-R Consent Order 8377 Mod 1 40 CFR Part 63 Subpart ZZZZ RCSA §22a-174-22e Collateral conditions in P107-0012			
EU-7	Cummins #NT855F5 diesel emergency fire pump; Installed 12/01/89	None	RCSA §22a-174-3b(e) RCSA §22a-174-22e 40 CFR Part 63 Subpart ZZZZ			
GEU-1	EU-1 and EU-2	None	See Above			
GEU-2	EU-3 and EU-4	None	See above			
GEU-3	EU-5 and EU-6	None	See above			

B. OPERATING SCENARIO IDENTIFICATION

The Permittee shall be allowed to operate under the following Standard Operating Scenarios and Alternative Operating Scenarios without notifying the commissioner, provided that such operations are explicitly provided for and described in Table II.B. There are no alternate operating scenarios.

TABLE II.B: OPERATING SCENARIO IDENTIFICATION			
Emissions Units Associated with the Scenario Description of Scenario			
All Emissions Units	All emissions units shall be operated in accordance with applicable permit or registration terms and conditions and in accordance with best management practices while combusting liquid fuels or natural gas as allowed.		

The following contains summaries of applicable regulations and compliance demonstration for each identified Emissions Unit and Operating Scenario, regulated by this Title V permit.

A. GROUPED EMISSIONS UNIT 1 (GEU-1): Two steam electric generating boilers: EU-1, Registration No. 107-0017-R and EU-2, Registration No. 107-0020-R; Consent Order No. 8377 Mod 1; Consent Order No. 1887; 40 CFR Part 63 Subpart UUUUU (MATS); 40 CFR Part 72-78, inclusive; RCSA §22a-174-22c (CAIR)

1. Nitrogen Oxides (NOx) - RCSA §22a-174-22e

- a. Limitation or Restriction
 - i. The Permittee shall not exceed the following emissions rates:
 - (A) No. 6 Oil (Daily Block Average): Less than or equal to 0.20 lb/MMBtu [RCSA §22a-174-22e(d)(2)(C)]
 - (B) No. 2 Oil (Daily Block Average): Less than or equal to 0.10 lb/MMBtu [RCSA §22a-174-22e(d)(2)(C)]
 - (C) Natural Gas (Daily Block Average) (EU-1 Only): Less than or equal to 0.10 lb/MMBtu [RCSA §22a-174-22e(d)(2)(C)]
 - (D) Non-Ozone Season Average (7 month average): Less than or equal to 0.15 lb/MMBtu during the period from October 1 through April 30, inclusive (All Fuels) [RCSA §22a-174-22e(d)(2)(D)]
 - ii. NOx Emissions Limits while combusting one or more fuels shall be determined in accordance with RCSA §22a-174-22e(d)(10). [RCSA §22a-174-22e(d)(10)]

b. Monitoring Requirements

- i. For each fuel combusted the Permittee shall monitor monthly and annual fuel consumption. [RCSA §22a-174-33(j)(1)(K)(ii)]
- ii. The Permittee shall install, calibrate, maintain, operate and certify a CEM for NOx and comply with the applicable monitoring specified in RCSA §22a-174-22e(m). [RCSA §22a-174-22e(m)]
- iii. The Permittee shall calculate the ozone season emission rate as the sum of the emissions unit's NOx emissions while firing the applicable fuel during the period from May 1 through September 30, inclusive, divided by the sum of the emission unit's heat input while firing the applicable fuel during the period from May 1 through September 30, inclusive. [RCSA §22a-174-22e(d)(20)]

Montville Power LLC Page 10 of 43 Permit No. 107-0043-TV

iv. The Permittee shall calculate the non-ozone season emission rate, for each unit in GEU-1, as the sum of the emissions unit's NOx emissions during the period from October 1 through April 30, inclusive, divided by the sum of the emissions unit's heat input during the period from October 1 through April 30, inclusive. [RCSA §22a-174-22e(d)(19)]

c. Record Keeping Requirements

- i. The Permittee shall comply with the applicable record keeping requirements specified in RCSA \$22a-174-22e(j). [RCSA \$22a-174-22e(j)]
- ii. The Permittee shall make and keep records in accordance with 40 CFR §§75.50-75.59. [40 CFR §§75.50-75.59]

d. Reporting Requirements

- i. The Permittee shall comply with the applicable reporting requirements specified in RCSA §22a-174-22e(k). [RCSA §22a-174-22e(k)]
- ii. The Permittee shall submit all required reports in accordance with 40 CFR §\$75.60-75.67. [40 CFR §\$75.60-75.67]

2. Case-by-Case NOx RACT Requirements - Consent Order No. 8377 Mod 1

a. Limitation or Restriction

i. Consent Order No. 8377 Mod 1 expires on May 1, 2028, at which time the Permittee shall operate the subject emissions units in compliance with the applicable emissions limits and other requirements of RCSA Section 22a-174-22e or cease operation. [CO No. 8377 Mod 1, para. C.14]

b. Recordkeeping and Reporting

- i. The Permittee shall by the close of each calendar day record the actual 24-hour average NOx emission rate, the actual fuel type and the actual quantity of each type of fuel in units of volume per day or MMBtu per day for each fuels used on the preceding day. [CO No. 8377 Mod 1, para. C.10.b]
- ii. The Permittee shall provide the records required by Section III.A.2.b.i. of this Title V permit to the commissioner within thirty (30) days of receipt of a written request from the commissioner. [CO No. 8377 Mod 1, para. C.10.e]
- iii. No later than March 1 of every year, the Permittee shall submit to the commissioner a written report containing copies of all records required by Section III.A.2.b.i. of this Title V permit. [CO No. 8377 Mod 1, para. C.10.f]

3. CAIR: NOx Ozone Season Trading

GEU-1 are CAIR NOx Ozone season units and therefore are subject to RCSA §22a-174-22c. The units shall comply with all applicable requirements stated in RCSA §22a-174-22c and the standard requirements of the CAIR permit application.

Montville Power LLC Page 11 of 43 Permit No. 107-0043-TV

4. Particulate Matter (PM)

- a. Limitation or Restriction
 - i. PM emissions shall be less than or equal to:
 - (A) 0.14 lb/MMBtu when operating on No. 6 oil [RCSA §22a-174-18(e)(2)(A)]
 - (B) 0.12 lb/MMBtu when operating on No. 2 oil [RCSA §22a-174-18(e)(2)(B)]
 - (C) 0.10 lb/MMBtu when operating on natural gas (EU-1 Only) [RCSA §22a-174-18(e)(2)(C)]

b. Monitoring Requirements

Record keeping specified in Section III.A.4.c. of this Title V permit shall be sufficient to meet other Monitoring and Testing Requirements pursuant to RCSA §22a-174-33. [RSCA §22a-174-33(j)(l)(K)(ii)]

c. Record Keeping Requirements

The Permittee shall maintain records sufficient to determine compliance with the limitation or restriction in Section III.A.4.a. of this Title V permit. [RSCA §22a-174-33(j)(l)(K)]

d. Reporting Requirements

The Permittee shall submit additional information in writing, at the commissioner's request, within 30 days of receipt of notice from the commissioner or by such other date specified by the commissioner, whichever is earlier. [RSCA §22a-174-33(j)(1)(X)]

5. Compliance Assurance Monitoring (CAM) Plan for EU-1 Only. [40 CFR Part 64] Hammon Research Cottrell Electrostatic Precipitator (ESP) Power Monitoring

a. CAM Plan Justification

The justification for using the proposed CAM approach is based upon the principle that adequate power must be applied to the ESP in order to develop the electrically charged field that drives the collection of particulate matter (PM) as it passes through the various fields. As power gets up to moderate to high levels, the relationship between power and performance becomes relatively "flat". This break point for EU-1 is 27 kW secondary power.

- b. Operational Restrictions
 - i. The total combined power input (in kilowatts) to all fields of the ESP system, for any hour when the emissions unit is in operation at 60 MW (Gross) or more, shall be no less than 27 secondary kilowatts.
 - ii. During periods when the boiler is at reduced load 0-70%, power deviations will not be noted.
 - iii. A CAM excursion will occur if the total combined power is found to be less than 27 secondary kilowatts and the emissions unit is operational at 60 MW (gross) or more. A CAM excursion for the COMS will occur if opacity levels exceed the limitations in Section III.A.6.a.i.(B) of this Title V permit. Under these conditions the Permittee shall:

- (A) Note that there is a problem;
- (B) Take necessary corrective actions to restore normal operation;
- (C) Submit required reports pursuant to 40 CFR §64.9; and
- (D) Submit any additional information in writing, at the commissioner's request, within 30 days of receipt of notice from the commissioner or by such other date specified by the commissioner, whichever is earlier.
- c. Monitoring and Record Keeping Requirements
 - i. The Permittee shall monitor and record the following on an hourly basis, except for opacity, during any operation of the boiler/ESP:
 - (A) The secondary kilowatts for each TR set in the ESP system;
 - (B) The total power in secondary kilowatts to the ESP system for each hour (add together the power for all the TR sets operating at the time of the reading); and
 - (C) Load in MW (Gross)
 - ii. The Permittee shall continuously monitor the opacity of the stack exhaust with a continuous opacity monitoring system (COMS). Opacity data shall be monitored and recorded continuously with the COMS.
 - iii. Quality Assurance and Quality Control (QA/QC):

In addition, the Permittee shall conduct the following monitoring and record keeping activities:

- (A) Daily inspections and monitoring of the ESP system to assure proper operation of the system include, testing alarms, making visual inspections of the critical components such as the rappers and particulate removal equipment to assure proper operation.
- (B) Hourly transformer-rectifier electrical readings will be recorded when the system is operating. The operator will check the recorded data, and compare the data with past data under similar operating conditions, looking for changes that signal developing problems in the ESP.
- (C) A weekly inspection of the rapper system, seal air system, and air filter condition will be conducted to assure these components are operating correctly, and the ESP is operating as designed.
- (D) Outage Inspections The following inspections will be conducted during each outage to assess the operation of the ESP in time. The particulate deposits on the discharge and collecting electrodes will be measured for comparison with past and future inspections. Rapper rod insulators, support bushing insulators, lower stabilizer insulators, gas distribution plates, the hopper trough, ash clinkers, access doors, shell seams, and alignment between collecting plates and discharge electrodes will be inspected to assure that each component is in good condition and operating correctly. All abnormalities or equipment failures will be recorded whether recorded during the outage or not. These records will be useful in identifying possible patterns of repetitive component failures and will be the basis for future outage inspections.

Montville Power LLC Page 13 of 43 Permit No. 107-0043-TV

- (E) A semi-annual inspection of the ESP and auxiliaries will be conducted to assess the general overall condition. The inspection will include a visual assessment of the condition of the pipes, guards, wires and plates. Pressure switches and flow switches will be checked for calibration. Alarms associated with rappers, transformer-rectifier controls and other equipment with alarm outputs will be simulated and tested for proper operation. Electrical safety interlocks (Transformer-Rectifier Shutdown) used in the system will be tested for proper operation.
- (F) An annual inspection of the ESP will be conducted to assess the general overall condition. The inspection will include visual assessment of the condition of the pipes, guards, wires and plates. In addition, a Megger meter will be used on the wiring system to check for faults, at which time all readings and results will be recorded.
- (G) In the event the semi-annual and/or annual ESP inspections cannot be conducted on the scheduled date due to plant operations, the permittee shall conduct these inspections with 30 calendar days after the date the unit is released for shutdown by ISO-NE.

6. Opacity

- a. Limitation or Restriction
 - i. GEU-1 shall comply with Consent Order No. 1887 at all times:
 - (A) Data from the opacity CEMS must be available for no less than 95% of the operating time of the unit being monitored. [Consent Order No. 1887, Section A.4]
 - (B) Opacity shall be less than or equal to:
 - (1) 20% during any six-minute block average [RCSA §22a-174-18(b)(2)(A); Consent Order No. 1887, Section A.6.a]
 - (2) 40% during any one-minute block average [RCSA §22a-174-18(b)(2)(b); Consent Order No. 1887, Section A.6.b]
 - (C) Pursuant to RCSA \$22a-174-18(j), the Permittee shall not be subject to the emissions standards found in Section III.A.6.a.i.(B) of this Title V permit during a period of startup, shutdown or malfunction, commissioner approved stack testing, or intentional soot blowing, fuel switching or sudden load changing done in accordance with good engineering practices provided that:
 - (1) The Permittee is required by permit, order or regulation to install, operate and maintain opacity CEMS equipment at such stationary source, and the Permittee is in compliance with such permit, order or regulation with regard to such opacity CEMS equipment; [RCSA §22a-174-18(j)(1)(A); Consent Order No. 1887, Section A.7.a]
 - (2) The Permittee operates and maintains such installed opacity CEMS equipment in compliance with the requirements of 40 CFR Part 60, Appendices B and F; [Consent Order No. 1887, Section A.7.b]

Montville Power LLC Page 14 of 43 Permit No. 107-0043-TV

- (3) The period of exception from the visible emissions standards of RCSA §22a-174-18(b)(2) does not exceed one-half of one percent (0.5%) of the total operating hours of such stationary source during any calendar quarter; and [RCSA §22a-174-18(j)(1)(B); Consent Order No. 1887, Section A.7.c]
- (4) The Permittee does not cause or allow visible emissions in excess of 60% opacity during any six-minute block average of the period of exception from the visible emissions standards of RCSA §22a-174-18(b)(2).

 [RCSA §22a-174-18(j)(1)(C); Consent Order No. 1887, Section A.7.d]
- ii. The Permittee shall perform annual, quarterly and daily quality assurance audits in accordance with RCSA §22a-174-4a(f)(2). [RCSA §22a-174-4a(f)(2)]

b. Monitoring Requirements

The Permittee shall operate two opacity continuous emissions monitoring systems ("CEMS") to monitor and record the opacity of visible emissions. [Consent Order No. 1887, Section A.3]

- c. Record Keeping Requirements
 - The Permittee shall make and keep records of the dates and times of all opacity exceedances including the operating conditions at the time of the exceedance using the CEMS.
 [RCSA §22a-174-33(j)(1)(K)(ii)]
 - ii. The Permittee shall comply with the testing annual RATA testing requirements in accordance with RCSA §22a-174-4a(i)(5). [RCSA §22a-174-4a(i)(5)]

d. Reporting Requirements

- i. Each calendar quarter, the Permittee shall submit the following information to the commissioner:
 - (A) An audit report, in accordance with the requirements specified in RCSA §22a-174-4a(f). [RCSA §22a-174-4a(i)(3)]
 - (B) A report summarizing the excess emissions and COMS performance in accordance with RCSA §22a-174-4a(i)(4). [RCSA §22a-174-4a(i)(4)]
 - (C) Quarterly reports summarizing the data recorded by the opacity CEMS and the operating time of the opacity CEMS versus the operating time of EU-1 and EU-2. [Consent Order No. 1887, Section A.5]
 - (D) On or before the fifteenth day of the month immediately following the close of each calendar quarter, the Permittee shall submit a progress report to the commissioner describing the actions that the Permittee has taken to date to comply with Consent Order No. 1887. Such report shall include, at least, the following: [Consent Order No. 1887, Section B.6]
 - (1) A list of approved corrective actions completed during the quarter in accordance with Paragraph B.4 of Consent Order No. 1887.

Montville Power LLC Page 15 of 43 Permit No. 107-0043-TV

- (2) A list of any other actions performed during the quarter for the purpose of reducing the frequency of the occurrence of visible emissions that exceed the standards of RCSA \$22a-174-18(b)(2).
- ii. Submissions made to comply with RCSA §§22a-174-4a(i)(3) and (i)(4) shall be made no later than 30 days following the end of each calendar quarter. [RCSA §§22a-174-4a(i)(3) & (i)(4)]

7. SO₂: RCSA §22a-174-19a

- a. Limitation or Restriction
 - i. The Permittee shall: [RCSA §22a-174-19a(e)]
 - (A) Combust liquid fuel, gaseous fuel or a combination of each provided that each fuel possess a fuel sulfur limit equal to or less than 0.3% sulfur, by weight (dry basis);
 - (B) Meet an average emission rate of equal to or less than 0.33 pounds SO₂ per MMBtu for each calendar quarter for an affected unit at the premises; or
 - (C) Meet an average emission rate of equal to or less than 0.3 pounds SO₂ per MMBtu calculated for each calendar quarter, if such owner or operator averages the emissions from two or more affected units at the premises.

b. Monitoring Requirements

The Permittee shall maintain and operate CEMS to monitor SO_2 emissions from this source. [RCSA §22a-174-19a(i)(2)(A)]

- c. Record Keeping Requirements
 - i. The Permittee shall obtain a fuel certification from the fuel supplier certifying the type of fuel and the weight percent of sulfur in the fuel (dry basis). [RCSA §22a-174-33(j)(1)(K)(ii)]
 - ii. The Permittee shall make and keep records that demonstrate the fuel sulfur content of each shipment of fuel received. [RCSA §22a-174-19a(i)(1)(A)]
 - iii. If fuel with sulfur content above any applicable limit is blended at the premises for combustion in an affected unit or units, the Permittee shall make and keep daily records demonstrating that all fuel combusted at the affected unit or units meets the applicable fuel sulfur limits of RCSA §22a-174-19a(e)(1). Fuel sulfur analysis shall be conducted in accordance with the American Society for Testing and Material (ASTM) test method D4294 and automatic sampling equipment shall conform to ASTM test method D4177-82. [RCSA §22a-174-19a(i)(1)(B)]

d. Reporting Requirements

The Permittee shall, as part of any compliance certification pursuant to RCSA §22a-174-33(q)(2) certify in writing to the commissioner compliance with the applicable provisions of such section. Such certification shall include actual quarterly SO₂ emissions in tons and either average quarterly fuel sulfur content or average quarterly emission rate, whichever is applicable, for each affected unit. [RCSA §22a-174-19a(j)(1)]

Montville Power LLC Page 16 of 43 Permit No. 107-0043-TV

8. National Emission Standards (NESHAP) for Hazardous Air Pollutants: Coal and Oil Fired Electric Utility Steam Generating Units, 40 CFR Part 63 Subpart UUUUU

- a. Limitation or Restriction
 - The Permittee shall comply with the applicable requirements found in 40 CFR §63.10000.
 - ii. The Permittee shall comply with the applicable fuel use requirements during periods of startup or shutdown found in 40 CFR §63.10011(f).
 - iii. The Permittee shall conduct tune-ups on GEU-1 pursuant to 40 CFR §63.10021(e). [40 CFR §63.9991(a)(1); 40 CFR Part 63 Subpart UUUUU, Table 3, Item 1]
- b. Monitoring Requirements

The Permittee shall comply with the applicable monitoring requirements found in 40 CFR §63.10020(e).

c. Record Keeping Requirements

The Permittee shall keep all applicable records in accordance with 40 CFR §63.10032.

- d. Reporting Requirements
 - i. The Permittee shall submit all applicable notifications, reports and records pursuant to 40 CFR §63.10030.
 - ii. The Permittee shall submit all applicable compliance reports pursuant to 40 CFR §63.10031(c).

9. Baseline Annual Emissions Analysis

- a. Limitation or Restriction
 - i. The representative actual annual emissions of PM_{2.5}, PM₁₀, SO₂, NOx, VOC, CO, and Pb shall not exceed the 2-year baseline average emissions, immediately preceding the installation of the urea injection and/or combustion modification equipment, on an annual basis for five (5) years after the installation of the control systems for each unit of GEU-1, based on the following startup dates:
 - (A) Unit 5 (EU-1): February 6, 2020 [Combustion Modification and Urea Injection]
 - (B) Unit 6 (EU-2):
 - (1) Combustion Modification Equipment: February, 16, 2022
 - (2) Urea Injection: TBD Not currently installed

- b. Monitoring and Testing Requirements
 - i. The Permittee shall conduct emissions testing on each unit of GEU-1 for PM_{2.5}, PM₁₀, and ammonia with and without the urea injection in operation (if applicable), for natural gas and No. 6 Oil. Emissions testing shall be conducted for each fuel within 240 operating hours on such fuel. Such testing timeframe shall begin with the initial startup of the urea injection control system.

[RCSA §22a-174-33(j)(1)(K)(ii)]

- ii. Emissions testing for CO shall be required for EU-2 (Unit 6) within 240 operating hours of the initial startup of the combustion modification equipment. [RCSA §22a-174-33(j)(1)(K)(ii)]
- c. Record Keeping Requirements

The Permittee shall calculate and record the monthly and consecutive 12 month PM_{2.5}, PM₁₀, SO₂, NOx, VOC, CO, Pb, and ammonia emissions in units of tons for each unit of GEU-1. The consecutive 12 month emissions shall be determined by adding the current month's emissions to that of the previous 11 months. Such records shall include a sample calculation. The Permittee shall make these calculations within 30 days of the end of the previous month. [RSCA §22a-174-33(j)(l)(K)]

- c. Reporting Requirements
 - i. The Permittee shall notify the commissioner, in writing, of the dates of commencement of construction, completion of construction, and initial startup of the urea injection and combustion modification equipment no later than 30 days after the subject event. [RCSA §22a-174-33(j)(1)(X)]
 - ii. No later than March 1 of each year the Permittee shall submit a written report of the actual annual emissions of PM_{2.5}, PM₁₀, SO₂, NOx, VOC, CO, Pb, and ammonia for the prior calendar year compared to the 2-year baseline average emissions, immediately preceding the installation of the urea injection and/or combustion modification equipment, on an annual basis for five (5) years after the installation of the control systems for each unit of GEU-1. Such report shall be submitted to Office of Director, Engineering, Bureau of Air Management, Department of Energy and Environmental Protection, 79 Elm Street, 5th Floor, Hartford, CT 06106-5127 [40 CFR §51.165(a)(1)(xii)(E)]
- B. GROUPED EMISSIONS UNIT 2 (GEU-2) Two dual fuel, fuel oil and natural gas, fired Foster Wheeler Auxiliary Steam Boilers, Permit Nos. 107-0012 and 107-0013; NESHAP for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR Part 63 Subpart DDDDD. The boilers are operated under the gas 1 subcategory with an oxygen trim system to maintain the air-to-fuel ratio. NSPS for Industrial, Commercial, and Institutional Steam Generating Units 40 CFR Part 60 Subpart Dc

1. Allowable Fuel Use and Operating Limitations

a. Limitation or Restriction

All fuel firing rates, hourly limits are per individual boiler and all annual limits are combined limits for EU-3 and EU-4.

- i. Maximum Firing Rate: [P107-0012; P107-0013]
 - (A) 468 gal/hr (ULSD)

- (B) $70,680 \text{ ft}^3/\text{hr} \text{ (Gas)}$
- ii. Maximum Heat Input (MMBtu/hr): [P107-0012; P107-0013]
 - (A) 68 (ULSD)
 - (B) 72.8 (Gas)
- iii. Maximum ULSD Sulfur Content (% by weight, dry basis): 0.0015 [RCSA §22a-174-19b(d); P107-0012; P107-0013]
- iv. Combined Maximum Annual Fuel Consumption for GEU-2 over any consecutive 12 month period: [P107-0012; P107-0013]
 - (A) 440 MMft³ (Gas)
 - (B) 1.452 MMgal (ULSD)
- v. The Permittee shall operate and maintain this equipment in accordance with the manufacturer's specifications and written recommendations. [P107-0012; P107-0013]
- vi. The Permittee shall properly operate the control equipment at all times that this equipment is in operation and emitting air pollutants. [P107-0012; P107-0013]
- b. Monitoring Requirements

The Permittee shall continuously monitor fuel consumption to each unit in GEU-2 using a non-resettable totalizing fuel meter.

[P107-0012; P107-0013]

- c. Record Keeping Requirements
 - i. The Permittee shall keep records of monthly and consecutive 12 month fuel consumption for each unit in GEU-2. The consecutive 12 month fuel consumption shall be determined by adding (for each fuel) the current month's fuel consumption to that of the previous 11 months. The Permittee shall make these calculations within 30 days of the end of the previous month. [P107-0012; P107-0013]
 - ii. The Permittee shall maintain records of the sulfur content of ULSD combusted. A written certification or a written contract with a fuel supplier is sufficient to satisfy this requirement if the certification or contract identifies: [P107-0012; P107-0013]
 - (A) The name of the fuel seller;
 - (B) The type of fuel purchased;
 - (C) The sulfur content of the fuel purchased; and
 - (D) The method used to determine the sulfur content of the fuel purchased.

d. Reporting Requirements

The Permittee shall submit additional information in writing, at the commissioner's request, within 30 days of receipt of notice from the commissioner or by such other date specified by the commissioner, whichever is earlier. [RCSA $\S 22a-174-33(j)(1)(X)$]

2. Pollutant Emissions

- a. Limitation or Restriction
 - i. The Permittee shall not exceed the following natural gas emission limits for each boiler (lb/hr): [P107-0012; 107-0013]
 - (A) PM: 0.54
 - (B) PM_{10} : 0.54
 - (C) $PM_{2.5}:0.54$
 - (D) NOx: 3.64
 - (E) SO_2 : 0.044
 - (F) VOC: 0.44
 - (G) CO: 5.97
 - (H) Lead: 3.5E-05
 - ii. The Permittee shall not exceed the following natural gas emission limits for each boiler (lb/MMBtu): [P107-0012; 107-0013]
 - (A) PM: 0.0074
 - (B) PM_{10} : 0.0074
 - (C) PM_{2.5}: 0.0074
 - (D) NOx: 0.05
 - (E) SOx: 0.0006
 - (F) VOC: 0.006
 - (G) CO: 0.082
 - (H) Lead: 4.8E-07
 - iii. The Permittee shall not exceed the following ULSD emission limits for each boiler (lb/hr): [P107-0012; 107-0013]

(A) PM: 0.95 (B) PM_{10} : 0.95 (C) $PM_{2.5}$: 0.95 (D) NOx: 6.8 (E) SO_2 : 0.10 (F) VOC: 0.12 (G) CO: 2.3 (H) Sulfuric Acid: 1.5E-03 Lead: 7.5E-04 (I) iv. The Permittee shall not exceed the following ULSD emission limits for each boiler (lb/MMBtu): [P107-0012; 107-0013] (A) PM: 0.014 (B) PM₁₀: 0.0014 (C) $PM_{2.5}$: 0.014 (D) NOx: 0.10 (E) SOx: 0.0015 VOC: 1.8E-03 (F) (G) CO: 0.034 (H) Sulfuric Acid: 2.14E-05 (I) Lead: 1.1E-05 v. The Permittee shall not exceed the following worst case annual emissions (tpy): Note: Annual Emission Limits are combined limits for EU-3 and EU-4 [P107-0012; 107-0013] (A) PM: 3.0 (B) PM_{10} : 3.0 (C) $PM_{2.5}$: 3.0

(D) NOx: 20.8

- (E) SOx: 0.27
- (F) VOC: 2.64
- (G) CO: 19.24
- (H) Lead: 2.1E-03
- (I) H_2SO_4 : 2.3E-03
- vi. Demonstration of compliance with the emission limits in Part III.B.2.a of this Title V permit may be met by calculating the emission rates using emission factors from the following sources: [P107-0012; 107-0013]
 - (A) NOx (Both Fuels): Latest Stack Test
 - (B) Natural Gas Firing: All Particulate Matter, SO₂, VOC, CO, and Pb AP-42 Fifth Edition, Volume I, Chapter 1, Tables 1.4-1 and 1.4-2, July 1998
 - (C) ULSD Firing: All Particulate Matter, SO₂, VOC, CO, and Pb AP-42 Fifth Edition, Volume I, Chapter 1, Tables 1.3-1 and 1.3-2, May 2010
 - (D) ULSD Firing: Sulfuric Acid Sulfur content of fuel, assumption of total conversion of SO₃ (David Nash Memo, dated 1987)
- b. Monitoring and Testing Requirements
 - i. The Permittee shall comply with the applicable monitoring requirements pursuant to RCSA Section 22a-174-22e. [P107-0012; P107-0013]
 - ii. Stack testing for NOx shall be conducted no later than June 1, 2025. Recurrent emission tests shall be conducted pursuant to RCSA Section 22a-174-22e(*l*)(5) within every 63 calendar months following the date the previous emission test was conducted or the date the previous emission test was required to be conducted, whichever is earlier. [P107-0012; 107-0013]
 - iii. The Permittee shall perform inspections of the Flue Gas Recirculation system as recommended by the manufacturer. [P107-0012; P107-0013]
 - iv. For all other pollutants, the record keeping specified in Section III.B.2.c. of this Title V permit shall be sufficient to meet other Monitoring Requirements pursuant to RCSA §22a-174-33.

[RCSA §22a-174-33(j)(1)(K)(ii)]

- c. Record Keeping Requirements
 - i. The Permittee shall comply with the applicable record keeping requirements specified in RCSA §22a-174-22e(j) for NOx emissions. [RCSA § 22a-174-22e(j)]

- ii. The Permittee shall calculate and record the monthly and consecutive 12 month PM, PM₁₀, PM_{2.5}, SO₂, NOx, VOC, and CO emissions in units of tons, for GEU-2 combined. The consecutive 12 month emissions shall be determined by adding (for each pollutant) the current month's emissions to that of the previous 11 months. Such records shall include a sample calculation for each pollutant. The Permittee shall make these calculations within 30 days of the end of the previous month. [P107-0012; P107-0013]
- iii. The Permittee shall keep records of all inspections of the Flue Gas Recirculation system. [P107-0012; P107-0013]

d. Reporting Requirements

- i. The Permittee shall comply with the applicable reporting requirements specified in RCSA §22a-174-22e. [P107-0012; P107-0013]
- ii. For all other pollutants, the Permittee shall submit additional information in writing, at the commissioner's request, within 30 days of receipt of notice from the commissioner or by such other date specified by the commissioner, whichever is earlier. [RCSA §22a-174-33(j)(1)(X)]

3. Opacity

- a. Limitation or Restriction
 - i. Visible emissions shall not exceed:
 - (A) 20% opacity during any six-minute block average as measured by 40 CFR Part 60, Appendix A, Reference Method 9. [P107-0012; 107-0013; RCSA §22a-174-18(b)(1)(A)]
- b. Monitoring and Testing Requirements
 - i. The Permittee shall conduct opacity testing on a recurring basis as required in accordance with 40 CFR §60.47c.
 - (A) Stack testing for opacity shall be conducted no later than June 1, 2025. Recurrent emission tests shall be conducted pursuant to RCSA Section 22a-174-22e(*l*)(5) within every 63 calendar months following the date the previous emission test was conducted or the date the previous emission test was required to be conducted, whichever is earlier [P107-0012; 107-0013]
- c. Record Keeping Requirements
 - i. The Permittee shall make and keep all applicable records pursuant to 40 CFR \(\) 60.48c, including:
 - (A) The operating conditions at the time of the exceedance; [RCSA §22a-174-33(j)(1)(K)(ii)]
 - (B) Dates and time intervals of all opacity observations periods; [40 CFR §60.48c(c)(1)(i)]
 - (C) Name, affiliation, and copy of current visible emission reading certification for each visible emission observer participating in the performance test; and [40 CFR §60.48c(c)(1)(ii)]
 - (D) Copies of all visible emission observer opacity field data sheets [40 CFR §60.48c(c)(1)(iii)]

Montville Power LLC Page 23 of 43 Permit No. 107-0043-TV

- d. Reporting Requirements
 - i. The Permittee shall submit all recurring performance test data pursuant to 40 CFR §60.48c(b)
 - ii. The Permittee shall submit excess emission reports pursuant to 40 CFR §60.48c(c).
- 4. National Emission Standards (NESHAP) for Hazardous Air Pollutants: Industrial, Commercial, and Institutional Boilers and Process Heaters, 40 CFR Part 63 Subpart DDDDD
 - a. Limitation or Restriction

The Permittee shall comply with the tune-up requirements for GEU-2 found in 40 CFR §63.7540(a)(12). [40 CFR §63.7500(e)]

b. Monitoring Requirements

The Permittee shall conduct subsequent tune-ups no more than 61 months after the previous tune-up. [40 CFR §63.7515(d)]

c. Record Keeping Requirements

The Permittee shall keep all applicable records in accordance with 40 CFR §63.7555(a) and (h).

- d. Reporting Requirements
 - i. The Permittee shall comply with the notification requirements in accordance with 40 CFR §§63.7545(f) and (h).
 - ii. The Permittee shall submit all applicable reports pursuant to 40 CFR §63.7540(b).
 - iii. The Permittee shall submit all applicable compliance reports pursuant to 40 CFR §63.7550(c).
- C. GROUPED EMISSIONS UNIT 3 (GEU-3) Two 2.75 MW diesel fired generators

Registration Nos. 107-0021-R & 107-0022-R; Consent Order 8377 Mod 1; National Emissions Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines (RICE) 40 CFR Part 63 Subpart ZZZZ: Non-Emergency, Existing CI, > 500 bhp; Collateral Conditions in P107-0012

- 1. Allowable Fuel Use and Operating Limitations
 - a. Limitation or Restriction
 - i. No. 2 ULSD
 - (A) Maximum Fuel Consumption for GEU-3, combined over any Consecutive 12 Month Period (gallons): 80,000 gallons [Collateral Condition in P107-0012]
 - (B) Maximum Fuel Sulfur Content (% by weight, dry basis): 0.0015 [40 CFR §63.6604; 40 CFR §80.510(b); Collateral Condition in P107-0012]

- ii. The Permittee shall operate and maintain this equipment in accordance with the manufacturer's specifications and written recommendations. [Collateral Condition in P107-0012]
- iii. The Permittee shall properly operate the control equipment at all times that this equipment is in operation and emitting air pollutants. [Collateral Condition in P107-0012]

b. Monitoring Requirements

The Permittee shall continuously monitor fuel consumption to each unit in GEU-3 using a non-resettable totalizing fuel meter. [Collateral Condition in P107-0012]

c. Record Keeping Requirements

- i. The Permittee shall keep records of monthly and consecutive 12 month fuel consumption for GEU-3 combined. The consecutive 12 month fuel consumption shall be determined by adding (for each fuel) the current month's fuel consumption to that of the previous 11 months. The Permittee shall make these calculations within 30 days of the end of the previous month.

 [Collateral Condition in P107-0012]
- ii. The Permittee shall maintain records of the sulfur content of ULSD combusted in GEU-3. A written certification or a written contract with a fuel supplier is sufficient to satisfy this requirement if the certification or contract identifies: [Collateral Condition in P107-0012]
 - (A) The name of the fuel seller;
 - (B) The type of fuel purchased;
 - (C) The sulfur content of the fuel purchased; and
 - (D) The method used to determine the sulfur content of the fuel purchased.
- iii. The Permittee shall keep records of monthly and consecutive 12 month fuel consumption. The consecutive 12 month fuel consumption shall be determined by adding the current month's fuel consumption to that of the previous 11 months. The Permittee shall make these calculations within 30 days of the end of the previous month. [CO 8377 Mod 1 para. C.10.d]
- ii. The Permittee shall by the close of each calendar day record the actual hours of operation and the actual quantity of fuel combusted in GEU-3 during the preceding day and shall calculate and record NOx emissions for each emissions unit. The Permittee shall calculate NOx emissions using the emissions rate determined during the latest emissions test performed in accordance with RSCA Section 22a-174-22e(1). [CO 8377 Mod 1 para. C.10.a]

d. Reporting Requirements

The Permittee shall submit additional information in writing, at the commissioner's request, within 30 days of receipt of notice from the commissioner or by such other date specified by the commissioner, whichever is earlier. [RCSA $\S 22a-174-33(j)(1)(X)$]

Montville Power LLC Page 25 of 43 Permit No. 107-0043-TV

2. Pollutant Emissions

a.

Lin	nitatio	n or Restriction
i.	The	Permittee shall not exceed the following emission limits for each engine (lb/hr):
	(A)	PM: 6.7
	(B)	PM ₁₀ : 6.7
	(C)	PM _{2.5} : 6.7
	(D)	NOx: 75.69 (Until May 1, 2028 [Consent Order No. 8377 Mod1])
	(E)	SOx: 0.04
	(F)	VOC: 6.41
	(G)	CO: 20.4
	(H)	H ₂ SO ₄ : 7.35E-3
ii.	The	Permittee shall not exceed the following emission limits for each engine (lb/MMBtu):
	(A)	PM: 0.23
	(B)	PM ₁₀ : 0.23
	(C)	PM _{2.5} : 0.23
	(D)	NOx: 2.61 (Until May 1, 2028 [Consent Order No. 8377 Mod1])
	(E)	SOx: 0.0015
	(F)	VOC: 0.22
	(G)	CO: 0.70
	(H)	H ₂ SO ₄ : 2.6E-05
iii.	The	Permittee shall not exceed the following annual emission limits for both engines (tpy):
	(A)	PM: 1.34
	(B)	PM ₁₀ : 1.34
	(C)	PM _{2.5} : 1.34
	(D)	NOx: 15 14

(E) SOx: 8E-03

- (F) VOC: 1.3
- (G) CO: 4.1
- (H) H_2SO_4 : 1.47E-03
- b. Monitoring and Testing Requirements
 - The Permittee shall conduct NOx emission testing of GEU-3 in accordance with RCSA §22a-174-22e.
 - (A) Stack testing for NOx emissions shall be conducted no later than June 1, 2025. Recurrent emission tests shall be conducted pursuant to RCSA §22a-174-22e(1)(5) within every 63 calendar months following the date the previous emission test was conducted or the date the previous emission test was required to be conducted, whichever is earlier. [Collateral Condition in P107-0012]
 - ii. The Permittee shall comply with the applicable record keeping requirements pursuant to RCSA §22a-174-22e. [Collateral Condition in P107-0012]
 - (A) For all other pollutants, the record keeping specified in Section III.C.2.c. of this Title V permit shall be sufficient to meet other Monitoring Requirements pursuant to RCSA §22a-174-33. [RCSA §22a-174-33(j)(1)(K)(ii)]
- c. Record Keeping Requirements
 - i. The Permittee shall calculate and record the monthly and consecutive 12 month PM, PM₁₀, PM_{2.5}, SO₂, NOx, VOC, and CO emissions in units of tons, for GEU-3 combined. The consecutive 12 month emissions shall be determined by adding (for each pollutant) the current month's emissions to that of the previous 11 months. Such records shall include a sample calculation for each pollutant. The Permittee shall make these calculations within 30 days of the end of the previous month.
- d. Reporting Requirements
 - i. The Permittee shall comply with the applicable reporting requirements specified in RCSA §22a-174-22e(k) for NOx emissions.
 - ii. For all other pollutants, the Permittee shall submit additional information in writing, at the commissioner's request, within 30 days of receipt of notice from the commissioner or by such other date specified by the commissioner, whichever is earlier. [RCSA §22a-174-33(j)(1)(X)]
- 3. National Emissions Standards for Hazardous Air Pollutants (NESHAP) for Reciprocating Internal Combustion Engine (RICE) 40 CFR Part 63 Subpart ZZZZ: Non-Emergency, Existing CI, > 500 bhp
 - a. Limitation or Restriction
 - i. The Permittee shall be in compliance with the applicable emission limitations, operating limitations, and other requirements at all times. [40 CFR §63.6605(a)]

- ii. The Permittee shall operate and maintain GEU-3, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. [40 CFR §63.6605(b)]
- iii. The Permittee shall maintain the catalyst so that the pressure drop across the catalyst does not change by more than 2 inches of water from the pressure drop across the catalyst that was measured during the initial performance test; and [40 CFR §63.6600(d), Table 2b, Item 2.a]
- iv. The Permittee shall maintain the exhaust temperature so that the catalyst inlet temperature is greater than or equal to 450°F and less than or equal to 1350°F. [40 CFR §63.6600(d), Table 2b, Item 2.b]
- v. The Permittee shall not exceed the following CO emissions: [40 CFR §63.6600(d), Table 2c, Item 5]
 - (A) Limit concentration of CO to 23 ppmvd or less at 15% O₂; or [40 CFR §63.6600(d), Table 2c, Item 5.a]
 - (B) Reduce CO emissions by 70% or more. [40 CFR §63.6600(d), Table 2c, Item 5.b]
- vi. The Permittee shall minimize the engine's time spent at idle and minimize the engine's startup time at startup to a period needed for appropriate and safe loading of the engine, to exceed 30 minutes, after which the non-startup emission limitations apply.

 [40 CFR §63.6600(d), Table 2c; 40 CFR §63.6625(h)]
- vii. Maximum fuel sulfur content: 15 ppm [40 CFR §63.6604(a); 40 CFR §80.510(b)]

b. Monitoring Requirements

- i. The Permittee shall conduct subsequent CO performance testing every 8,760 hours or 5 years, whichever comes first. [40 CFR §63.6615, Table 3, Item 5]
- ii. The Permittee shall conduct subsequent CO performance testing in accordance the applicable requirements pursuant to 40 CFR §63.6620.
- iii. The Permittee shall comply with the applicable monitoring requirements in accordance with 40 CFR §§63.6625(b) and 63.6635.
- c. Record Keeping Requirements

The Permittee shall comply with the applicable record keeping requirements in accordance with 40 CFR §§63.6645(a) and 63.6655(a) and (b).

d. Reporting Requirements

The Permittee shall comply with the applicable reporting requirements in accordance with 40 CFR §63.6650.

Montville Power LLC Page 28 of 43 Permit No. 107-0043-TV

D. EMISSIONS UNIT 7 (EU-7) – Cummins diesel fired emergency fire pump

[RCSA §22a-174-3b(e); RCSA §22a-174-22e; National Emissions Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines (RICE) 40 CFR Part 63 Subpart ZZZZ: Emergency, Existing CI, < 500 bhp]

- 1. RCSA §§22a-174-3b(e); 22a-174-19b; and 22a-174-22e
- a. Limitation or Restriction
 - Operation shall not exceed 300 hours during any twelve month rolling aggregate. [RCSA §22a-174-3b(e)(2)(C); [STATE ONLY REOUIREMENT]
 - ii. Maximum fuel sulfur content shall be less than 15 ppm. [RCSA §22a-174-3b(e)(2)(D) [STATE ONLY REQUIREMENT]; RCSA §22a-174-19b(d)(2)]
 - iii. The Permittee shall not operate EU-7 for routine, scheduled testing or maintenance on any day for which the commissioner has forecast that the ozone levels will be "moderate to unhealthy for sensitive groups" or greater. [RCSA §22a-174-22e(d)(14)]

b. Monitoring Requirements

- i. Record keeping specified in Section III.B.1.c. of this Title V permit shall be sufficient to meet other Monitoring Requirements pursuant to RCSA §22a-174-33. [RCSA §22a-174-33(j)(l)(K)(ii)]
- c. Record Keeping Requirements
 - The Permittee shall make and keep records of the hours of operation for each month and each twelve month rolling aggregate. [RCSA §22a-174-3b(e)(4); STATE ONLY REQUIREMENT]
 - ii. The Permittee shall keep records of the fuel certification for each delivery fuel from a bulk petroleum provider or a copy of the current contract with the fuel supplier supplying the fuel used by this equipment that includes the applicable sulfur content of the fuel as a condition of each shipment. Shipping receipt or contract shall include the date of delivery, the name of the fuel supplier, type of fuel delivered, the percentage of sulfur in such fuel, by weight, dry basis, and the method used to determine the sulfur content of such fuel.
 - [RCSA §22a-174-3b(h)(1); STATE ONLY REQUIREMENT]
 - iii. The Permittee shall maintain records of the sulfur content of the fuel combusted and the quantity purchased for combustion. A written certification or a written contract with a fuel supplier is sufficient if the certification or contract identifies: [RCSA §22a-174-19b(g)(3)(A) – (D)]
 - (A) The name of the fuel seller;
 - (B) The type of fuel purchased;
 - (C) The sulfur content of the fuel purchased; and
 - (D) The method used to determine the sulfur content of the fuel purchased.

d. Reporting Requirements

The Permittee shall provide any required records pursuant to Section III.D.1.c of this Title V permit to the commissioner upon request.

[RCSA §22a-174-3b(i) [STATE ONLY REQUIREMENT]; RCSA §22a-174-19b(4)(A)]

2. 40 CFR Part 63 Subpart ZZZZ

- a. Limitation or Restriction
 - i. The Permittee shall be in compliance with the applicable requirements of 40 CFR Part 63 Subpart ZZZZ at all times. [40 CFR §63.6605(a)]
 - ii. At all times the Permittee must operate and maintain the affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. [40 CFR §63.6605(b)]
 - iii. The Permittee shall comply with the requirements pursuant to 40 CFR §63.6602:
 - (A) Change oil and filter every 500 hours of operation or annually, whichever comes first. [40 CFR §63.6602, Table 2c, Item 1.a]
 - (B) Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first. [40 CFR §63.6602, Table 2c, Item 1.b]
 - (C) Inspect hoses and belts every 500 hours of operation or annually, whichever comes first. [40 CFR §63.6602, Table 2c, Item 1.c]
 - iv. Maximum fuel sulfur content: 15 ppm [40 CFR §63.6604(a); 40 CFR §80.510(b)]
 - v. Operation of the engine for readiness testing and maintenance checks shall not exceed 100 hours per year. [40 CFR §63.6640(f)(2)(i)]
 - vi. The Permittee shall operate and maintain EU-7 according to the manufacturer's emission related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

 [40 CFR §§63.6625(e)(2) and 63.6640, Table 6, Item 9]
 - vii. The Permittee shall install a non-resettable hour meter. [40 CFR §63.6625(f)]
 - viii. The Permittee shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable in 40 CFR Part 60 Subpart ZZZZ, Table 2c apply to all other than startup. [40 CFR §63.6625(h)]

Montville Power LLC Page 30 of 43 Permit No. 107-0043-TV

ix. The Permittee shall operate EU-7 according to the applicable requirements found in 40 CFR §63.6640(f) to be considered an emergency engine.

Note: Allowable operation pursuant to RCSA §22a-174-3b is more restrictive concerning the designation of EU-7 as an emergency engine.

b. Monitoring Requirements

i. The Permittee shall monitor the hours of operation during readiness testing, maintenance checks, non-emergency use and periods of startup for each month and each 12 month rolling aggregate. [40 CFR §63.6625(f)]

c. Record Keeping Requirements

- ii. The Permittee shall keep records of the maintenance conducted on EU-7 in accordance with 40 CFR §63.6655(e).
- iii. The Permittee shall make and keep records of all hours of operation including and designating hours of readiness testing, maintenance checks, and periods of startup for each month and each 12 month rolling aggregate. [40 CFR §63.6655(f)]

d. Reporting Requirements

The Permittee shall comply with the applicable reporting requirements in accordance with 40 CFR §63.6650.

E. FEDERAL ACID RAIN PERMIT REQUIREMENTS: EU-1 and EU-2

1. SO₂ Allowance Allocations and NO_x Requirements for Each Affected Unit

a. Affected Unit 1: Combustion Engineering, Type R Dual fuel fired 905 MMBtu/hr, 82 MW electric utility steam boiler

		2022	2023	2024	2025	2026
EU-1 (Unit 5)	SO ₂ Allowances under Tables 2, 3, or 4 of 40 CFR Part 73	1,208	1,208	1,208	1,208	1,208
	NO _x Limit	Not a	n Affected	Unit under	40 CFR Pa	art 76

b. Affected Unit 2: Combustion Engineering, Type RRP No.6 oil fired 4,658 MMBtu/hr, 402 MW electric utility steam boiler

		2022	2023	2024	2025	2026
EU-2 (Unit 6)	SO ₂ Allowances under Tables 2, 3, or 4 of 40 CFR Part 73	5,675	5,675	5,675	5,675	5,675
	NO _x Limit	Not a	an Affected	Unit under	40 CFR Pa	ırt 76

2. Phase II Acid Rain Permit Application

The attached Phase II Acid Rain Permit Application is hereby incorporated by reference into this Title V permit. If this Title V permit is in conflict with or inconsistent with the Phase II Acid Rain Permit Application, the Title V permit requirements, including any applicable requirement under 40 CFR Parts 72 through 78, inclusive, shall supersede the Phase II Acid Rain Permit Application and the Permittee shall be governed by and adhere to this Title V permit and any applicable requirement under 40 CFR Parts 72 through 78, inclusive.

F. PREMISES-WIDE GENERAL REQUIREMENTS

- **1. Annual Emission Statements:** The Permittee shall submit annual emission statements requested by the commissioner as set forth in RCSA §22a-174-4a(b)(1).
- **2. Emission Testing:** The Permittee shall comply with the procedures for sampling, emission testing, sample analysis, and reporting as set forth in RCSA §22a-174-5.
- **3. Emergency Episode Procedures:** The Permittee shall comply with the procedures for emergency episodes as set forth in RCSA §22a-174-6.
- **4. Reporting of Malfunctioning Control Equipment:** The Permittee shall comply with the reporting requirements of malfunctioning control equipment as set forth in RCSA §22a-174-7.
- **5. Prohibition of Air Pollution:** The Permittee shall comply with the requirement to prevent air pollution as set forth in RCSA §22a-174-9.
- **6. Public Availability of Information:** The public availability of information shall apply, as set forth in RCSA §22a-174-10.
- **7. Prohibition Against Concealment/Circumvention:** The Permittee shall comply with the prohibition against concealment or circumvention as set forth in RCSA §22a-174-11.
- **8. Violations and Enforcement:** The Permittee shall not violate or cause the violation of any applicable regulation as set forth in RCSA §22a-174-12.
- **9. Variances:** The Permittee may apply to the commissioner for a variance from one or more of the provisions of these regulations as set forth in RCSA §22a-174-13.
- **10. No Defense to Nuisance Claim:** The Permittee shall comply with the regulations as set forth in RCSA §22a-174-14.
- **11. Severability:** The Permittee shall comply with the severability requirements as set forth in RCSA §22a-174-15.
- **12. Responsibility to Comply:** The Permittee shall be responsible to comply with the applicable regulations as set forth in RCSA §22a-174-16.
- **13. Particulate Emissions:** The Permittee shall comply with the standards for control of particulate matter and visible emissions as set forth in RCSA §22a-174-18.

Montville Power LLC Page 32 of 43 Permit No. 107-0043-TV

- **14. Fuel Sulfur Content:** The Permittee shall not use No. 2 heating oil that exceeds fifteen parts per million of sulfur by weight as set forth in CGS §16a-21a(a)(2)(B).
- **15. Sulfur Dioxide Emissions:** The Permittee shall comply with the requirements for Control of Sulfur Dioxide Emissions from Power Plants and other large stationary sources of air pollution as set forth in RCSA §22a-174-19a.
- **16. Sulfur Compound Emissions:** The Permittee shall comply with the requirements for control of sulfur compound emissions as set forth in RCSA §§22a-174-19, 22a-174-19a and 22a-174-19b, as applicable.
- **17. Organic Compound Emissions:** The Permittee shall comply with the requirements for control of organic compound emissions as set forth in RCSA §22a-174-20.
- **18. Nitrogen Oxide Emissions:** The Permittee shall comply with the requirements for control of nitrogen oxide emissions as set forth in RCSA §22a-174-22e and §22a-174-22e.
- **19. Ambient Air Quality:** The Permittee shall not cause or contribute to a violation of an ambient air quality standard as set forth in RCSA §22a-174-24(b).
- **20. Open Burning:** The Permittee is prohibited from conducting open burning, except as may be allowed by CGS §22a-174(f).
- 21. Asbestos: Should the premises, as defined in 40 CFR §61.145, become subject to the national emission standard for asbestos regulations in 40 CFR Part 61 Subpart M when conducting any renovation or demolition at this premises, then the Permittee shall submit proper notification as described in 40 CFR §61.145(b) and shall comply with all other applicable requirements of 40 CFR Part 61 Subpart M.
- 22. Emission Fees: The Permittee shall pay an emission fee as set forth in RCSA §22a-174-26(d).

Montville Power LLC Page 33 of 43 Permit No. 107-0043-TV

Section IV: Compliance Schedule

	TABLE IV: COMPLIANCE SCHEDULE					
Emissions Unit	Applicable Regulations	Date by which Each Step is to be Completed	Dates for Monitoring, Record Keeping, and Reporting			
		No Steps are required for achieving compliance at this time				

Montville Power LLC Page 34 of 43 Permit No. 107-0043-TV

Section V: State Enforceable Terms and Conditions

Only the Commissioner of the Department of Energy and Environmental Protection has the authority to enforce the terms, conditions and limitations contained in this section.

SECTION V: STATE ENFORCEABLE TERMS AND CONDITIONS

- **A.** This Title V permit does not relieve the Permittee of the responsibility to conduct, maintain and operate the emissions units in compliance with all applicable requirements of any other Bureau of the Department of Energy and Environmental Protection or any federal, local or other state agency. Nothing in this Title V permit shall relieve the Permittee of other obligations under applicable federal, state and local law.
- **B.** Nothing in this Title V permit shall affect the commissioner's authority to institute any proceeding or take any other action to prevent or abate violations of law, prevent or abate pollution, investigate air pollution, recover costs and natural resource damages, and to impose penalties for violations of law, including but not limited to violations of this or any other permit issued to the Permittee by the commissioner.

C. Additional Emissions Units

- 1. The Permittee shall make and submit a written record, at the commissioner's request, within 30 days of receipt of notice from the commissioner, or by such other date specified by the commissioner, of each additional emissions unit or group of similar or identical emissions units at the premises.
- 2. Such record of additional emissions units shall include each emissions unit, or group of emissions units, at the premises which is not listed in Section II.A of this Title V permit, unless the emissions unit, or group of emissions units, is:
 - a. an insignificant emissions unit as defined in RCSA §22a-174-33; or
 - b. an emissions unit or activity listed in *White Paper for Streamlined Development of Part 70 Permit Applications, Attachment A* (EPA guidance memorandum dated July 10, 1995).
- **3.** For each emissions unit, or group of emissions units, on such record, the record shall include, as available:
 - a. Description, including make and model;
 - b. Year of construction/installation or if a group, range of years of construction/installation;
 - c. Maximum throughput or capacity; and
 - d. Fuel type, if applicable.
- **D.** Odors: The Permittee shall not cause or permit the emission of any substance or combination of substances which creates or contributes to an odor that constitutes a nuisance beyond the property boundary of the premises as set forth in RCSA §22a-174-23.
- **E.** Noise: The Permittee shall operate in compliance with the regulations for the control of noise as set forth in RCSA §§22a-69-1 through 22a-69-7.4, inclusive.

Section V: State Enforceable Terms and Conditions

F.	Hazardous Air Pollutants (HAPs): The Permittee shall operate in compliance with the regulations for the
	control of HAPs as set forth in RCSA §22a-174-29.

G.	The Permittee shall comply with the requirements for Control of Carbon Dioxide Emissions as set forth in
	RCSA §22a-174-31.

The Administrator of the United States Environmental Protection Agency and the Commissioner of the Department of Energy and Environmental Protection have the authority to enforce the terms and conditions contained in this section.

SECTION VI: TITLE V REQUIREMENTS

A. SUBMITTALS TO THE COMMISSIONER & ADMINISTRATOR

The date of submission to the commissioner of any document required by this Title V permit shall be the date such document is received by the commissioner. The date of any notice by the commissioner under this Title V permit, including, but not limited to notice of approval or disapproval of any document or other action, shall be the date such notice is delivered or the date three days after it is mailed by the commissioner, whichever is earlier. Except as otherwise specified in this Title V permit, the word "day" means calendar day. Any document or action which is required by this Title V permit to be submitted or performed by a date which falls on a Saturday, Sunday or legal holiday shall be submitted or performed by the next business day thereafter.

Any document required to be submitted to the commissioner under this Title V permit shall, unless otherwise specified in writing by the commissioner, be directed to: Compliance Analysis and Coordination Unit, Bureau of Air Management, Department of Energy and Environmental Protection; 79 Elm Street, 5th Floor; Hartford, Connecticut 06106-5127.

Any submittal to the Administrator of the Environmental Protection Agency shall be submitted per the procedure required by the applicable requirement or otherwise in a computer-readable format and addressed to: Director, Enforcement and Compliance Assurance Division, U.S. EPA Region I, 5 Post Office Square, Suite 100 (Mailcode: 04-02), Boston, Massachusetts 02109-3912, Attn: Air Compliance Clerk.

B. CERTIFICATIONS [RCSA §22a-174-33(b)]

In accordance with RCSA §22a-174-33(b), any report or other document required by this Title V permit and any other information submitted to the commissioner or Administrator shall be signed by an individual described in RCSA §22a-174-2a(a), or by a duly authorized representative of such individual. Any individual signing any document pursuant to RCSA §22a-174-33(b) shall examine and be familiar with the information submitted in the document and all attachments thereto, and shall make inquiry of those individuals responsible for obtaining the information to determine that the information is true, accurate, and complete, and shall also sign the following certification as provided in RCSA §22a-174-2a(a)(4):

"I have personally examined and am familiar with the information submitted in this document and all attachments thereto, and I certify that based on reasonable investigation, including my inquiry of those individuals responsible for obtaining the information, the submitted information is true, accurate and complete to the best of my knowledge and belief. I understand that any false statement made in the submitted information may be punishable as a criminal offense under Section 22a-175 of the Connecticut General Statutes, under Section 53a-157b of the Connecticut General Statutes, and in accordance with any applicable statute."

C. SIGNATORY RESPONSIBILITY [RCSA §22a-174-2a(a)]

For purposes of signing any Title V-related application, document, report or certification required by RCSA §22a-174-33, any corporation's duly authorized representative may be either a named individual or any individual occupying a named position. Such named individual or individual occupying a named position is a duly authorized representative if such individual is responsible for the overall operation of one or more manufacturing, production or operating facilities subject to RCSA §22a-174-33 and either:

- 1. The facilities employ more than 250 persons or have gross annual sales or expenditures exceeding 25 million dollars in second quarter 1980 dollars; or
- 2. The delegation of authority to the duly authorized representative has been given in writing by an officer of the corporation in accordance with corporate procedures and the following:
 - i. Such written authorization specifically authorizes a named individual, or a named position, having responsibility for the overall operation of the Title V premises or activity,
 - ii. Such written authorization is submitted to the commissioner and has been approved by the commissioner in advance of such delegation. Such approval does not constitute approval of corporate procedures, and
 - iii. If a duly authorized representative is a named individual in an authorization submitted under subclause ii. of this subparagraph and a different individual is assigned or has assumed the responsibilities of the duly authorized representative, or, if a duly authorized representative is a named position in an authorization submitted under subclause ii. of this subparagraph and a different named position is assigned or has assumed the duties of the duly authorized representative, a new written authorization shall be submitted to the commissioner prior to or together with the submission of any application, document, report or certification signed by such representative.

D. ADDITIONAL INFORMATION [RCSA §22a-174-33(j)(1)(X), RCSA §22a-174-33(h)(2)]

The Permittee shall submit additional information in writing, at the commissioner's request, within 30 days of receipt of notice from the commissioner or by such other date specified by the commissioner, whichever is earlier, including information to determine whether cause exists for modifying, revoking, reopening, reissuing, or suspending this Title V permit or to determine compliance with this Title V permit.

In addition, the Permittee shall submit information to address any requirements that become applicable to the subject source and shall submit correct, complete, and sufficient information within 15 days of the applicant's becoming aware of any incorrect, incomplete, or insufficient submittal, during the pendency of the application, or any time thereafter, with an explanation for such deficiency and a certification pursuant to RCSA §22a-174-2a(a)(5).

E. MONITORING REPORTS [RCSA §22a-174-33(o)(1)]

A Permittee, required to perform monitoring pursuant to this Title V permit, shall submit to the commissioner, on forms prescribed by the commissioner, written monitoring reports on March 1 and September 1 of each year or on a more frequent schedule if specified in such permit. Such monitoring reports shall include the date and description of each deviation from a permit requirement including, but not limited to:

- 1. Each deviation caused by upset or control equipment deficiencies; and
- **2.** Each deviation of a permit requirement that has been monitored by the monitoring systems required under this Title V permit, which has occurred since the date of the last monitoring report; and
- **3.** Each deviation caused by a failure of the monitoring system to provide reliable data.

F. PREMISES RECORDS [RCSA §22a-174-33(o)(2)]

Unless otherwise required by this Title V permit, the Permittee shall make and keep records of all required monitoring data and supporting information for at least five years from the date such data and information were obtained. The Permittee shall make such records available for inspection at the site of the subject source, and shall submit such records to the commissioner upon request. The following information, in addition to required monitoring data, shall be recorded for each permitted source:

- 1. The type of monitoring or records used to obtain such data, including record keeping;
- 2. The date, place, and time of sampling or measurement;
- **3.** The name of the individual who performed the sampling or the measurement and the name of such individual's employer;
- **4.** The date(s) on which analyses of such samples or measurements were performed;
- 5. The name and address of the entity that performed the analyses;
- **6.** The analytical techniques or methods used for such analyses;
- 7. The results of such analyses;
- 8. The operating conditions at the subject source at the time of such sampling or measurement; and
- **9.** All calibration and maintenance records relating to the instrumentation used in such sampling or measurements, all original strip-chart recordings or computer printouts generated by continuous monitoring instrumentation, and copies of all reports required by the subject permit.

G. PROGRESS REPORTS [RCSA §22a-174-33(q)(1)]

The Permittee shall, on March 1 and September 1 of each year, or on a more frequent schedule if specified in this Title V permit, submit to the commissioner a progress report on forms prescribed by the commissioner, and certified in accordance with RCSA §22a-174-2a(a)(5). Such report shall describe the Permittee's progress in achieving compliance under the compliance plan schedule contained in this Title V permit. Such progress report shall:

- 1. Identify those obligations under the compliance plan schedule in this Title V permit which the Permittee has met, and the dates on which they were met; and
- 2. Identify those obligations under the compliance plan schedule in this Title V permit which the Permittee has not timely met, explain why they were not timely met, describe all measures taken or to be taken to meet them and identify the date by which the Permittee expects to meet them.

Any progress report prepared and submitted pursuant to RCSA §22a-174-33(q)(1) shall be simultaneously submitted by the Permittee to the Administrator.

H. COMPLIANCE CERTIFICATIONS [RCSA §22a-174-33(q)(2)]

The Permittee shall, on March 1 of each year, or on a more frequent schedule if specified in this Title V permit, submit to the commissioner a written compliance certification certified in accordance with RCSA §22a-174-2a(a)(5) and which includes the information identified in 40 CFR §§70.6(c)(5)(iii)(A) to (C), inclusive.

Any compliance certification prepared and submitted pursuant to RCSA §22a-174-33(q)(2) shall be simultaneously submitted by the Permittee to the Administrator.

I. PERMIT DEVIATION NOTIFICATIONS [RCSA §22a-174-33(p)]

Notwithstanding Section VI.E. of this Title V permit, the Permittee shall notify the commissioner in writing, on forms prescribed by the commissioner, of any deviation from an emissions limitation, and shall identify the cause or likely cause of such deviation, all corrective actions and preventive measures taken with respect thereto, and the dates of such actions and measures as follows:

- 1. For any hazardous air pollutant, no later than 24 hours after such deviation commenced; and
- 2. For any other regulated air pollutant, no later than ten days after such deviation commenced.

J. PERMIT RENEWAL [RCSA §22a-174-33(j)(1)(B)]

All of the terms and conditions of this Title V permit shall remain in effect until the renewal permit is issued or denied provided that a timely renewal application is filed in accordance with RCSA §§22a-174-33(g), -33(h), and -33(i).

K. OPERATE IN COMPLIANCE [RCSA §22a-174-33(j)(1)(C)]

The Permittee shall operate the source in compliance with the terms of all applicable regulations, the terms of this Title V permit, and any other applicable provisions of law. In addition, any noncompliance constitutes a violation of the Clean Air Act and Chapter 446c of the Connecticut General Statutes and is grounds for federal and/or state enforcement action, permit termination, revocation and reissuance, or modification, and denial of a permit renewal application.

L. COMPLIANCE WITH PERMIT [RCSA §22a-174-33(j)(1)(G)]

This Title V permit shall not be deemed to:

- 1. Preclude the creation or use of emission reduction credits or allowances or the trading thereof in accordance with RCSA §§22a-174-33(j)(1)(I) and -33(j)(1)(P), provided that the commissioner's prior written approval of the creation, use, or trading is obtained;
- 2. Authorize emissions of an air pollutant so as to exceed levels prohibited pursuant to 40 CFR Part 72;
- **3.** Authorize the use of allowances pursuant to 40 CFR Parts 72 through 78, inclusive, as a defense to noncompliance with any other applicable requirement; or
- **4.** Impose limits on emissions from items or activities specified in RCSA §§22a-174-33(g)(3)(A) and -33(g)(3)(B) unless imposition of such limits is required by an applicable requirement.

M. INSPECTION TO DETERMINE COMPLIANCE [RCSA §22a-174-33(j)(1)(M)]

The commissioner may, for the purpose of determining compliance with this Title V permit and other applicable requirements, enter the premises at reasonable times to inspect any facilities, equipment, practices, or operations regulated or required under such permit; to sample or otherwise monitor substances or parameters; and to review and copy relevant records lawfully required to be maintained at such premises in accordance with this Title V permit. It shall be grounds for permit revocation should entry, inspection, sampling, or monitoring be denied or effectively denied, or if access to and the copying of relevant records is denied or effectively denied.

N. PERMIT AVAILABILITY

The Permittee shall have available at the facility at all times a copy of this Title V permit.

O. SEVERABILITY CLAUSE [RCSA §22a-174-33(j)(1)(R)]

The provisions of this Title V permit are severable. If any provision of this Title V permit or the application of any provision of this Title V permit to any circumstance is held invalid, the remainder of this Title V permit and the application of such provision to other circumstances shall not be affected.

P. NEED TO HALT OR REDUCE ACTIVITY [RCSA §22a-174-33(j)(1)(T)]

It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Title V permit.

Q. PERMIT REQUIREMENTS [RCSA §22a-174-33(j)(1)(V)]

The filing of an application or of a notification of planned changes or anticipated noncompliance does not stay the Permittee's obligation to comply with this Title V permit.

R. PROPERTY RIGHTS [RCSA §22a-174-33(j)(1)(W)]

This Title V permit does not convey any property rights or any exclusive privileges. This Title V permit is subject to, and in no way derogates from any present or future property rights or other rights or powers of the State of Connecticut, and is further subject to any and all public and private rights and to any federal, state or local laws or regulations pertinent to the facility or regulated activity affected thereby, including CGS §4-181a(b) and RCSA §22a-3a-5(b). This Title V permit shall neither create nor affect any rights of persons who are not parties to this Title V permit.

S. ALTERNATIVE OPERATING SCENARIO RECORDS [RCSA §22a-174-33(o)(3)]

The Permittee shall, contemporaneously with making a change authorized by this Title V permit from one alternative operating scenario to another, maintain a record at the premises indicating when changes are made from one operating scenario to another and shall maintain a record of the current alternative operating scenario.

T. OPERATIONAL FLEXIBILITY AND OFF-PERMIT CHANGES [RCSA §22a-174-33(r)(2)]

The Permittee may engage in any action allowed by the Administrator in accordance with 40 CFR §§70.4(b)(12)(i) to (iii)(B), inclusive, and 40 CFR §§70.4(b)(14)(i) to (iv), inclusive, without a Title V non-minor permit modification, minor permit modification or revision and without requesting a Title V non-minor permit modification, minor permit modification or revision provided such action does not:

- 1. Constitute a modification under 40 CFR Part 60, 61 or 63;
- **2.** Exceed emissions allowable under the subject permit;
- 3. Constitute an action which would subject the Permittee to any standard or other requirement pursuant to 40 CFR Parts 72 to 78, inclusive; or
- 4. Constitute a non-minor permit modification pursuant to RCSA §22a-174-2a(d)(4).

At least seven days before initiating an action specified in RCSA §22a-174-33(r)(2)(A), the Permittee shall notify the Administrator and the commissioner in writing of such intended action.

U. INFORMATION FOR NOTIFICATION [RCSA §22a-174-33(r)(2)(A)]

Written notification required under RCSA §22a-174-33(r)(2)(A) shall include a description of each change to be made, the date on which such change will occur, any change in emissions that may occur as a result of such change, any Title V permit terms and conditions that may be affected by such change, and any applicable requirement that would apply as a result of such change. The Permittee shall thereafter maintain a copy of such notice with the Title V permit. The commissioner and the Permittee shall each attach a copy of such notice to their copy of the Title V permit.

V. TRANSFERS [RCSA §22a-174-2a(g)]

No person other than the Permittee shall act or refrain from acting under the authority of this Title V permit unless such permit has been transferred to another person in accordance with RCSA §22a-174-2a(g).

The proposed transferor and transferee of a permit shall submit to the commissioner a request for a permit transfer on a form provided by the commissioner. A request for a permit transfer shall be accompanied by any fees required by any applicable provision of the general statutes or regulations adopted thereunder. The commissioner may also require the proposed transferee to submit with any such request, the information identified in CGS §22a-6o.

W. REVOCATION [RCSA §22a-174-2a(h)]

The commissioner may revoke this Title V permit on his own initiative or on the request of the Permittee or any other person, in accordance with CGS §4-182(c), RCSA §22a-3a-5(d), and any other applicable law. Any such request shall be in writing and contain facts and reasons supporting the request. The Permittee requesting revocation of this Title V permit shall state the requested date of revocation and provide evidence satisfactory to the commissioner that the subject source is no longer a Title V source.

Pursuant to the Clean Air Act, the Administrator has the power to revoke this Title V permit. Pursuant to the Clean Air Act, the Administrator also has the power to reissue this Title V permit if the Administrator has determined that the commissioner failed to act in a timely manner on a permit renewal application.

This Title V permit may be modified, revoked, reopened, reissued, or suspended by the commissioner, or the Administrator in accordance with RCSA §22a-174-33(r), CGS §22a-174c, or RCSA §22a-3a-5(d).

X. REOPENING FOR CAUSE [RCSA §22a-174-33(s)]

This Title V permit may be reopened by the commissioner, or the Administrator in accordance with RCSA §22a-174-33(s).

Y. CREDIBLE EVIDENCE

Notwithstanding any other provision of this Title V permit, for the purpose of determining compliance or establishing whether a Permittee has violated or is in violation of any permit condition, nothing in this Title V permit shall preclude the use, including the exclusive use, of any credible evidence or information.

Print for Compliance Certification or Enforcement

Click the button below to generate the appropriate checklist. Be aware that this macro does not work unless you have access to the DEEP D-Drive.

This macro takes anywhere from 2-5 minutes to run. Your computer will look like it is locked up but it is working. Unfortunately the new DEEP virtual computer system makes this process even slower. Please be patient.

Print Enforcement Checklist

Print Compliance Certification