



Operational Fuel-Security Analysis

*State Implementation Plan Revision Advisory
Committee (SIPRAC)*

Eric Johnson

DIRECTOR, EXTERNAL AFFAIRS

Norman Sproehnle

OUTAGE COORDINATION MANAGER



ISO New England (ISO) Has Two Decades of Experience Overseeing the Region's Restructured Electric Power System

- **Regulated** by the Federal Energy Regulatory Commission
- **Reliability Coordinator** for New England under the North American Electric Reliability Corporation
- **Independent** of companies in the marketplace and **neutral** on technology



ISO New England Performs Three Critical Roles to Ensure Reliable Electricity at Competitive Prices


Grid Operation

Coordinate and direct the flow of electricity over the region's high-voltage transmission system




Market Administration

Design, run, and oversee the markets where wholesale electricity is bought and sold



Power System Planning


Study, analyze, and plan to make sure New England's electricity needs will be met over the next 10 years



Dramatic Changes in the Energy Mix

The fuels used to produce the region's electric energy have shifted as a result of economic and environmental factors

Percent of Total **Electric Energy** Production by Fuel Type
(2000 vs. 2017)



Source: ISO New England [Net Energy and Peak Load by Source](#)

Renewables include landfill gas, biomass, other biomass gas, wind, solar, municipal solid waste, and miscellaneous fuels

Power Plant Emissions Have Declined with Changes in the Fuel Mix



Reduction in Aggregate Emissions (ktons/yr)

Year	NO _x	SO ₂	CO ₂
2001	59.73	200.01	52,991
2016	16.27	4.47	37,467
% Reduction, 2001–2016	↓ 73%	↓ 98%	↓ 29%

Reduction in Average Emission Rates (lb/MWh)

Year	NO _x	SO ₂	CO ₂
1999	1.36	4.52	1,009
2016	0.31	0.08	710
% Reduction, 1999–2016	↓ 77%	↓ 98%	↓ 30%

Source: [2016 ISO New England Electric Generator Air Emissions Report](#), December 2017 (draft)



Key Grid Challenge: Fuel Security

Ensuring the region's generators have adequate fuel to produce electricity, particularly in the winter

- ISO finalized and released its *Operational Fuel-Security Analysis* upon resolution of the U.S. Department of Energy (DOE) Notice of Proposed Rulemaking (NOPR) on Grid Resiliency Pricing

OPERATIONAL FUEL-SECURITY ANALYSIS:


Identification of fuel-security risks of multiple scenarios

- Study conducted to improve the ISO's and the region's understanding of operational risks and inform subsequent discussions with stakeholders
- The Operational Fuel-Security Analysis studied 23 possible resource combinations and outage scenarios during the 2024/2025 winter to illustrate a wide range of possible future power system conditions
 - Scenarios and results are not precise predictions of the future system or outcomes
 - Illustrates a range of potential operational risks that could confront a power system with fuel and energy constraints during an entire winter



Generation Mix Changes on Cold Days

2015 Annual Fuel Mix Compared with Day of Highest Coal and Oil Generation in 2015








Source: ISO New England, 2000-2015 Net Energy and Peak Load by Source and Daily Generation by Fuel Type 2015

Operational Fuel-Security Analysis Differs from Previous Studies

- Unlike the ISO's previous studies on fuel challenges, this study:
 - Quantifies *operational* risk by measuring energy shortfalls and system stress
 - Focuses on the availability of energy over an entire winter period rather than capacity availability on just peak days
 - Does not directly consider fuel costs or prices
 - Does not examine impacts of expanded natural gas pipeline capacity on a winter peak day
- As with all projections, the hypothetical resource combinations described may never materialize
 - Further, power systems conditions vary on a daily and hourly basis and may not behave exactly as predicted in study models


Key Fuel Variables

The study modeled a wide range of resource combinations that might be possible by winter 2024/2025 considering five key fuel variables:

-  1. Retirements of coal- and oil-fired generators
» The study assumes that New England will have no coal-fired plants in winter 2024/2025
-  2. Imports of electricity over transmission lines from New York and Canada
-  3. Oil tank inventories (i.e., how often on-site oil tanks at dual-fuel power plants are filled throughout the winter)
-  4. Level of liquefied natural gas (LNG) injections into the region's natural gas delivery and storage infrastructure
-  5. Level of renewable resources on the system

Demand and System Stress Measurements

- System stress was measured by several operational metrics including:
 - OP-4 actions
 - Depletion of ten-minute reserves
 - Load shedding



Key Fuel Security Assumptions

This section will summarize the assumptions used in the report for Winter 2024/2025:

- Fuel-security risk modeling
- Electricity demand
- Natural gas supply
- Natural gas demand
- No coal-fired generation
- Renewables
- Imports



Key Fuel Security Assumptions – Risk Modeling

Each scenario's future fuel-security risk is modeled by:

- Calculating the amount of electricity required to meet demand each hour of a 90-day winter (12/1/2024 through 2/28/2025)
- Calculating how much electric energy could be generated by each fuel type
- Calculating how much natural gas would be available, after all heating demand is met, as well as the levels of oil stored on site at oil-fired and dual-fuel power plants
- Comparing the amount of fuel required with the level of fuel the region's fuel-delivery system could supply in each scenario
- Assessing the magnitude and duration of emergency actions required if the fuels available were not sufficient to meet demand



Key Fuel Security Assumptions – Electricity Demand (Winters 2014/2015 and 2024/2025)

- Consumer demand in Winter 2014/2015 serves as a baseline because:
 - Winter 2014/2015 did not have the coldest days recorded in the last 10 years but had sustained cold, as measured by heating-degree days (four winters in the past 38 years were colder)
 - This level of sustained cold has a probability of occurring about once every eight years
 - It provides a wider perspective on cumulative use and replenishment of oil and LNG inventories over an entire winter
- While actual power grid conditions could change earlier or later, the study used Winter 2024/2025 for several reasons:
 - By winter 2024-2025, the outlook for power system reliability is uncertain
 - More retirements of the remaining oil, coal, and nuclear power plants are expected
 - Gives the region time to identify and address challenges by 2024, but no buffer to defer decisions about the region's fuel-security risks

Key Fuel Security Assumptions – Natural Gas Supplies: Pipeline

- The incremental pipeline expansions are expected to be used by natural gas utilities to serve their growing base of heating customers
- This study assumes that the **external** pipeline infrastructure capable of delivering natural gas into New England and the Maritimes in 2024/2025 would total **3.86 Bcf/d** over four pipelines:
 - 1.91 Bcf/d from the west through Algonquin
 - 1.39 Bcf/d from the west through Tennessee
 - 0.26 Bcf/d from the west through Iroquois
 - 0.30 Bcf/d from Quebec through Portland Natural Gas Transmission




Key Fuel Security Assumptions – Natural Gas Supplies: LNG

- Gas from LNG was modeled from three sources: Canaport, Distrigas, and the Northeast Gateway Deepwater offshore buoy
- Maximum LNG delivery (i.e., injection) to New England and the Maritimes was modeled at 2.04 Bcf/d:
 - 1.2 Bcf/d from the Canaport facility (limited by current levels of Canadian demand on the Maritimes and Northeast Pipeline)
 - 0.43 Bcf/d from Distrigas
 - 0.40 Bcf/d from the off-shore buoy
- However, the maximum observed coincident delivery of LNG was 1.25 Bcf/d on one day in December 2016
- Therefore, scenarios in this study used daily LNG injection caps ranging from 0.65 Bcf/d to 1.5 Bcf/d for winter 2024/2025 deliveries

Key Fuel Security Assumptions – Natural Gas Demand

- Key issue: How much natural gas will be left for power generators after LDCs serve their customers?
- 2025 LDC gas demand based on an ICF analysis (*New England LDC Gas Demand Forecast Through 2030*)
 - ICF study found winter natural gas demand for heating:
 - Totaled 4.4 Bcf/d on the winter peak day (calendar year 2014)
 - Forecasted peak demand from LDCs alone could reach 5.45 Bcf/d by 2025, leaving little if any gas for electric generators during near peak gas demand days.

- **Winter 2024/2025 Supply of Pipeline Gas and LNG Compared to Use (Reference Case)**







Note: LDC use includes the Maritimes' gas utility demand.

*Graph does not include the Mystic 8 and 9 gas-fired generators' fuel use or supply from the LNG facility.

**Per data from ICF International, *New England LDC Gas Demand Forecast Through 2030* (December 14, 2016, presentation to Planning Advisory Committee) and *The Future of Natural Gas Supply for Nova Scotia* (March 28, 2013, for Nova Scotia Department of Energy).

Key Fuel Security Assumptions – Renewables

Case Scenario	Renewables Total MW (rounded)	Breakdown MW			
		 Onshore Wind	 Offshore Wind	 PV	 Other Renewables
2017	4,600	1,200	30	2,400	960
Reference Case	6,600	1,200	30	4,430	960
More Renewables	8,000	1,200	1,400	4,430	960
Max Renewables	9,500	1,200	2,000	5,330	960


Key Fuel Security Assumptions – Imports

- New England imports power over 13 high-voltage lines connected to New York, Quebec, and New Brunswick
 - 2,500 MW of imports in the Reference Case
 - 2,000 MW of imports in scenarios where imports are reduced
 - 3,000 MW and 3,500 MW of imports were assumed in scenarios incorporating the New England states' goals for more clean energy
 - Increases are assumed to be clean energy delivered over a hypothetical new transmission line from New York or Canada
- 500 MW of emergency imports when OP-4 actions are implemented were assumed in all scenarios
- New England and its neighbors experience winter weather at the same time and demand in Quebec and New Brunswick peaks in winter, possibly limiting exports to New England below the level of imports assumed in some of the scenarios studied


STUDY RESULTS



Reference Case (i.e., Current Trends) and Single-Variable Scenarios



Combination Scenarios



1. Once reserves are depleted, any resource loss or transmission line trip that cuts imports would trigger load shedding.
2. Count assumed tanks were filled before winter, plus refilled during winter. For example, "2x" counted the initial full tank, plus one refill.
3. Cases with increased renewables also included increased imports to reflect expected additions of clean energy imports from Canada or New York.
4. On average, one megawatt (MW) of electricity can serve about 860 homes in New England, which has about 7.1 million retail customers, encompassing not just residential customers but also commercial and industrial.
5. A megawatt-hour (MWh) of electricity can serve about 860 homes for one hour in New England, on average.

Outage Scenarios

(Modeled on Ref and Max Cases; Assumed More Dual-Fuel Tank Fills)



		INPUTS					TOTAL WINTER IMPACT									
							OP 4 Actions		Depletion of 10-Minute Reserves ¹		OP 7 Action: Load Shedding					
							All OP 4 Actions	Actions 6-11								
		Retirements (MW)	LNG Cap (Bcf/Day)	Dual-Fuel (Oil Tank Fills) ²	Imports (MW)	Renewables (MW) ³	Hours	Hours	Avg. Hourly Power Deficit (MW) ⁴	Hours	Avg. Hourly Power Deficit (MW) ⁴	Load at Risk (MWh) ⁵	Hours	Avg. Hourly Power Deficit (MW) ⁴	Unserviced Load (MWh) ⁵	Days with Load Shedding
16	Distrigas LNG Outage: Ref ⁶	-1,500	1.00	3	2,500	6,600	276	114	440	87	961	83,628	24	854	20,496	7
17	Distrigas LNG Outage: Max ⁶	-5,400	1.00	3	3,500	9,500	346	181	442	142	971	137,814	49	1,016	49,805	11
18	Canaport LNG Outage: Ref ⁷	-1,500	0.65	3	2,500	6,600	270	129	421	90	944	84,973	27	816	22,026	9
19	Canaport LNG Outage: Max ⁷	-5,400	0.65	3	3,500	9,500	354	187	424	134	998	133,779	46	844	38,819	11
20	Millstone Nuclear Outage: Ref ⁸	-1,500	1.00	3	2,500	6,600	349	166	433	124	1,015	125,852	47	874	41,080	10
21	Millstone Nuclear Outage: Max ⁸	-5,400	1.00	3	3,500	9,500	389	243	450	193	1,012	195,358	70	1,147	80,312	12
22	Compressor Outage: Ref ⁹	-1,500	1.50	3	2,500	6,600	458	290	468	252	1,231	310,163	138	1,411	194,705	17
23	Compressor Outage: Max ⁹	-5,400	1.50	3	3,500	9,500	510	340	448	273	1,107	302,258	121	1,236	149,574	19
6	➔ Reference Case (Ref)	-1,500	1.00	2	2,500	6,600	165	76	419	53	980	51,963	14	743	10,397	6



Six Major Conclusions

The study results suggest the following major conclusions:

1. **Outages:** The region is vulnerable to the season-long outage of any of several major energy facilities
2. **Key dependencies:** Reliability is heavily dependent on LNG and electricity imports; more dual-fuel capability is also a key reliability factor
3. **Logistics:** Timely availability of fuel is critical, highlighting the importance of fuel-delivery logistics
4. **Risk:** All but four of 23 scenarios result in load shedding, indicating a trend towards increased fuel-security risk
5. **Renewables:** More renewables can help lessen fuel-security risk, but are likely to drive oil-and coal-fired generator retirements which, in turn, require more LNG
6. **Positive Outcomes:** Higher levels of LNG, imports, and renewables can minimize system stress and maintain reliability; delivery assurances and transmission expansion would be needed

Next Steps

- The ISO released this fuel-security report January 17, 2018 and will continue to discuss its results with stakeholders
- A key question to be addressed will be the level of fuel-security risk that the ISO, the region, and its policymakers and regulators are willing to tolerate
- As the system operator responsible for system reliability, the ISO must independently assess the level of risk to reliable operation
- Discussions with stakeholders on potential solutions to address fuel-security risks are targeted to begin later in 2018



Questions



Acronyms Used in this Presentation

- Bcf = billion cubic feet
- Bcf/d = billion cubic feet per day
- EE = Energy Efficiency (passive demand response)
- ICF = ICF International, Inc.
- ISO = ISO New England Inc.
- LDC = Local Distribution Company
- LNG = liquefied natural gas
- MW = megawatt or megawatts
- MWh = megawatt-hours
- PV = photovoltaics
- RC = NEPOOL Reliability Committee