



PERMIT

Permittee: Town of Sprague
1 Main Street
P.O. Box 677
Baltic, CT 06330

Permit No: DS-202111518

Town: Sprague

Project: Harrington Apartments Dam Removal (DEEP ID #13306; Hazard Class B, Significant Hazard)

Waters: Beaver Brook

Pursuant to Connecticut General Statutes Section 22a-403, the Commissioner of Energy and Environmental Protection (“Commissioner”) hereby grants a permit to the Town of Sprague (“the Permittee”) to conduct regulated activities associated with the Harrington Apartments Dam modifications. The purpose of said activities is to remove an existing dam.

AUTHORIZED ACTIVITY

Specifically, the permittee is authorized to do the following: remove the existing spillway and left training wall, partially remove and regrade the left earthen embankment, excavate sediment within the channel and redistribute it in the upland area.

The proposed activities will impact 4,850 square feet of wetlands and 16,547 square feet of watercourse associated with the Beaver Brook.

All activities shall be conducted in accordance with plans entitled: “Harrington Apartments Dam Removal”, prepared by Elsa E. Loehmann, P.E. of Fuss & O’Neill, signed and sealed in December 2021, and submitted as a part of the application.

This authorization constitutes the licenses and approvals required by Section 22a-403 of the Connecticut General Statutes. This authorization is subject to and does not derogate any present or future property rights or other rights or powers of the State of Connecticut, conveys no property rights in real estate or material nor any exclusive privileges, and is further subject to any and all public and private rights and to any federal, state, or local laws or regulations pertinent to the property or activity affected thereby.

The permittee's failure to comply with the terms and conditions of this permit shall subject the permittee, including the permittee's agents or contractor(s) to enforcement actions and penalties as provided by law.

This authorization is subject to the following conditions:

CONDITIONS:

1. **Expiration.** This permit shall expire three years following the date of issue unless this permit is specifically renewed.
2. **Construction Commencement and Completion.** If construction of any structures or facilities authorized herein is not completed within three years of issuance of this permit or within such other time as may be provided by this permit, or if any activity authorized herein is not commenced within three years of issuance of this permit or within such other time as may be provided by this permit, this permit shall expire three years after issuance or at the end of such time as may be authorized by the Commissioner.
3. **Notification of Project Initiation.** The permittee shall notify the Commissioner in writing no less than seven (7) days prior to commencement of permitted activities and no less than seven (7) days following completion of permitted activities.
4. **De minimis Alteration.** The permittee may not make any alterations, except de minimis alterations, to any structure, facility, or activity authorized by this permit. A de minimis alteration means a change in the design, construction or operation authorized under this permit that does not increase environmental impacts or substantively alter the construction of the project as authorized. If during the process of construction, unforeseen conditions are found on the site and the permittee and their engineer determine that it would be appropriate to modify the design, then the permittee shall notify DEEP within 24 hours of any potential design changes. DEEP shall determine if the design modifications will be an activity that can be categorized as a de minimis activity when compared to the permitted design. No work shall take place which was not included as part of the permitted design until DEEP responds to this determination request.
5. **Maintenance of Structures.** All structures, facilities, or activities constructed, maintained, or conducted pursuant hereto shall be consistent with the terms and conditions of this permit, and any structure, facility or activity not specifically authorized by this permit, or exempted pursuant to Section 22a-377 of the Connecticut General Statutes or Section 22a-377(b)-1 of the Regulations of Connecticut State Agencies, or otherwise exempt pursuant to other Connecticut General Statutes, shall constitute a violation hereof which may result in modification, revocation or suspension of this permit or in the institution of other legal proceedings to enforce its terms and conditions.

6. **Accuracy of Documentation.** In issuing this permit, the Commissioner has relied on information provided by the permittee. If such information was false, incomplete, or misleading, this permit may be modified, suspended or revoked and the permittee may be subject to any other remedies or penalties provided by law.
7. **Best Management Practices & Notification of Adverse Impact.** The permittee shall utilize engineered erosion and sediment controls to prevent pollution of wetlands and watercourses in accordance with Best Management Practices. Best Management Practices include, but are not limited to, the Connecticut Guidelines for Soil Erosion and Sediment Control as revised, the Connecticut Stormwater Quality Manual as revised, the Department of Transportation's ConnDOT Drainage Manual as revised, and the Department of Transportation Standard Specifications as revised.

The permittee shall deploy controls prior to the commencement of construction, and regularly inspect and maintain controls as needed for effectiveness. Said controls shall be inspected by the permittee for deficiencies at least once per week and immediately after each rainfall and at least daily during prolonged rainfall. The permittee shall correct any such deficiencies within forty eight (48) hours of said deficiencies being found.

The permittee shall immediately inform the Commissioner of any adverse impact or hazard to the environment which occurs or is likely to occur as the direct result of the construction, maintenance, or conduct of structures, facilities, or activities authorized herein.

8. Reporting of Potential Violations.

- a. In the event that a potentially adverse impact or hazard to environment is observed, the permittee shall take the following action(s) within 24 hours of its initial observation:
 - i. The site owner/operator and DEEP Dam Safety shall be notified (860-424-3706) and action shall be taken immediately including stopping work to alleviate the cause of the exceedance.
 - ii. If applicable, the DEEP Fisheries and/or DEEP Wildlife Divisions should be notified if sensitive species are known to be present in the project/site area.
 - iii. If a visual plume has been observed, turbidity levels should be tested and recorded at least once every 24 hours until the plume is no longer observed.
- b. No later than forty-eight (48) hours after initially observing a potential violation, the permittee shall follow up with a written report emailed to DEEP.DamSafety@ct.gov. Such email report shall contain the following information:

- i. The provision(s) of this permit that has been violated;
 - ii. The date and time the violation(s) was first observed and by whom;
 - iii. The names of people initially contacted in Section 9a;
 - iv. The cause of the violation(s), if known;
 - v. If a visual plume was observed, provide the turbidity measurements required in Section 8a;
 - vi. If the violation(s) has ceased, the duration of the violation(s) and the exact date(s) and times(s) it was corrected;
 - vii. If the violation(s) has not ceased, the anticipated date when it will be corrected;
 - viii. Steps taken and steps planned to prevent a reoccurrence of the violation(s) and the date(s) such steps were implemented or will be implemented; and
 - ix. The best telephone number where DEEP can reach the engineering consultant in a timely manner.
- 9. Material Storage in the Floodplain.** The storage of any materials at the site which are buoyant, hazardous, flammable, explosive, soluble, expansive, radioactive, or which could in the event of a flood be injurious to human, animal or plant life, below the elevation of the five-hundred (500) year flood is prohibited. Any other material or equipment stored at the site below said elevation by the permittee or the permittee's contractor must be firmly anchored, restrained or enclosed to prevent flotation. The quantity of fuel stored below such elevation for equipment used at the site shall not exceed the quantity of fuel that is expected to be used by such equipment in one day.
- 10. Permit Transfer.** This permit is not transferable without the prior written consent of the Commissioner.
- 11. Contractor Notification.** The permittee shall give a copy of this permit to the contractor(s) who will be carrying out the activities authorized herein prior to the start of construction and shall receive a written receipt for such copy, signed and dated by such contractor(s). The permittee's contractor(s) shall conduct all operations at the site in full compliance with this permit and, to the extent provided by law, may be held liable for any violation of the terms and conditions of this permit.
- 12. Certification of Documents.** Any document, including but not limited to any notice, which is required to be submitted to the Commissioner under this permit shall be signed by the permittee or a responsible corporate officer of the permittee, a general partner of the permittee, and by the individual or individuals responsible for actually preparing such document, each of whom shall certify in writing as follows:

“I have personally examined and am familiar with the information submitted in this document and all attachments thereto and I certify that based on reasonable investigation, including my inquiry of the individuals responsible for obtaining the information, the submitted information is true, accurate and complete to the best of my knowledge and

belief. I understand that a false statement in the submitted information may be punishable as a criminal offense in accordance with Section 22a-6 of the General Statutes, pursuant to Section 53a-157b and in accordance with any other applicable statute.”

- 13. Submission of Documents.** Any document or notice required to be submitted to the Commissioner under this permit shall, unless otherwise specified in writing by the Commissioner, be directed to: DEEP.DamSafety@ct.gov

The date of submission to the Commissioner of any document required by this permit shall be the date such document is received by the Commissioner. The date of any notice by the Commissioner under this permit, including but not limited to notice of approval or disapproval on any document or other action, shall be the date such notice is personally delivered or the date three days after it is mailed by the Commissioner, whichever is earlier. Except as otherwise specified in this permit, the word "day" means any calendar day. Any document or action which is required by this permit to be submitted or performed by a date which falls on a Saturday, Sunday or legal holiday shall be submitted or performed by the next business day thereafter.

- 14. Rights.** This permit is subject to and does not derogate any rights or powers of the State of Connecticut, conveys no property rights or exclusive privileges, and is subject to all public and private rights and to all applicable federal, state, and local law. In constructing or maintaining any structure or facility or conducting any activity authorized herein, the permittee may not cause pollution, impairment, or destruction of the air, water, or other natural resources of this State. The issuance of this permit shall not create any presumption that this permit should be renewed.

15. Dam Safety Conditions.

- a. This permit and a copy of the approved plans and specifications shall be kept at the project site and made available to the Commissioner at any time during the construction of permitted activities.
- b. Permitted activities shall be performed under the supervision of an engineer who is licensed to practice in the State of Connecticut and who is familiar with dam construction. Said engineer shall, upon completion of the permitted activities, certify to the Commissioner in writing that the permitted activities have been completed according to the approved plans and specifications.
- c. Within thirty (30) days of completion of the permitted activities, permittee shall submit to the Commissioner record drawings depicting the dam construction as completed, including any deviations from the approved plans and specifications. Said drawings shall be prepared and sealed by the engineer who oversaw the construction. In addition, the permittee shall arrange for submission of an electronic copy of the final record drawings in Adobe Acrobat “pdf” format.

- d. Nothing in this permit and no order, approval or advice of the Commissioner, shall relieve any owner or operator of this dam from his legal duties, obligations and liabilities resulting from such ownership or operation. No action for damages sustained through the partial or total failure of any structure or its maintenance shall be brought or maintained against the state, the Commissioner of Energy and Environmental Protection, or his employees or agents.
- e. The Sequence of Construction and Water Handling Plan provided in the application shall be reviewed by the contractor removing the dam. If the plan is revised or updated, a copy of the revised plan must be submitted to the Dam Safety Program at its email address: DEEP.DamSafety@ct.gov before beginning dam removal or within 48 hours of its revision after the work has started.
- f. The flood contingency plan submitted with the application as Attachment I shall be reviewed by the contractor removing the dam and if any revisions are made to the plan, a copy of the revised plans must be submitted to the Dam Safety Program at DEEP.DamSafety@ct.gov within 48 hours.

16. Special Conditions.

DEEP Fisheries Division Coordination. The permittee must contact Bruce Williams, (860) 447-4317 or Bruce.Williams@ct.gov, of the DEEP Fisheries Division a minimum of ten days prior to commencement of the stone steps for input and possible oversight.

Time-of-Year Restrictions. Unconfined in-water excavation, dredging, filling or removal of debris or other material is prohibited between July 1st and September 30th, inclusive, of any year in order to protect fisheries resources in the area unless otherwise authorized in writing by the Commissioner.

Management of Materials. Any dredged/excavated sediment removed from the site shall be managed in accordance with all federal, state, and local requirements, including Chapter 446K Water Pollution Control, Chapter 445 Hazardous Waste, and Chapter 446d Solid Waste of the Connecticut General Statutes.

Placement of Dredged Material. The Permittee shall ensure that dredged material placed on site is placed according to the following:

- a. The dredged material shall not be placed below the water table;
- b. The upland placement of the dredged material shall not exceed four (4) feet above the pre-existing elevation; and
- c. The dredged material shall be covered by one foot of material consisting of clean fill provided that the concentrations in the cover material are less than the direct exposure criteria outlined in the Remediation Standard Regulations.

Land Record Filing. The Permittee shall file an affidavit of facts on the land records of the municipality in which the subject property is located not later than ninety (90) days after the completion of the project. Such affidavit of facts is intended to minimize future disturbance or relocation of the placed material and shall include a figure documenting the location and dimensions of the upland dredge material placement.

Issued by the Commissioner of Energy and Environmental Protection on:

Date

Graham J. Stevens
Bureau Chief
Water Protection and Land Reuse