

**National Pollutant Discharge Elimination System Permit
issued to**

Permittee:

Pfizer Inc
445 Eastern Point Road
Groton, CT 06340

Permit ID: CT0000957

Receiving Water Body: Thames River

Receiving Water Body ID: CT-E1_014-SB

Location Address:

Pfizer Inc
445 Eastern Point Road
Groton, CT 06340

Issuance Date: Date of Signature

Effective Date: 1st of the month after

Issuance Date

Permit Expires: 5 years from effective date

SECTION 1: GENERAL PROVISIONS

- 1.1 This permit is reissued in accordance with Section 22a-430 of Chapter 446k, Connecticut General Statutes (“Conn. Gen. Stat.”), and Regulations of Connecticut State Agencies (“Regs. Conn. State Agencies”) adopted thereunder, as amended, and Section 402(b) of the Clean Water Act (“CWA”), as amended, 33 USC 1251, *et. seq.*, and pursuant to an approval dated September 26, 1973, by the Administrator of the United States Environmental Protection Agency for the State of Connecticut to administer a National Pollutant Discharge Elimination System (“NPDES”) permit program.
- 1.2 **Pfizer Inc** (“Permittee”) shall comply with all conditions of this permit including the following sections of the Regs. Conn. State Agencies which have been adopted pursuant to Section 22a-430 of the Conn. Gen. Stat. and are hereby incorporated into this permit. Your attention is especially drawn to the notification requirements of subsections (i)(2), (i)(3), (j)(1), (j)(6), (j)(8), (j)(9)(C), (j)(10)(C), (j)(11)(C), (D), (E), and (F), (k)(3) and (4) and (l)(2) of Section 22a-430-3.

Section 22a-430-3: General Conditions

- (a) Definitions
- (b) General
- (c) Inspection and Entry
- (d) Effect of a Permit
- (e) Duty to Comply
- (f) Proper Operation and Maintenance
- (g) Sludge Disposal
- (h) Duty to Mitigate
- (i) Facility Modifications; Notification
- (j) Monitoring, Records and Reporting Requirements
- (k) Bypass
- (m) Effluent Limitation Violations (Upsets)
- (n) Enforcement
- (o) Resource Conservation
- (p) Spill Prevention and Control
- (q) Instrumentation, Alarms, Flow Recorders
- (r) Equalization

Section 22a-430-4: Procedures and Criteria

- (a) Duty to Apply
- (b) Duty to Reapply
- (c) Application Requirements
- (d) Preliminary Review
- (e) Tentative Determination
- (f) Draft Permits, Fact Sheets
- (g) Public Notice, Notice of Hearing
- (h) Public Comments
- (i) Final Determination
- (j) Public Hearings
- (k) Submission of Plans and Specifications, Approval
- (l) Establishing Effluent Limitations and Conditions
- (m) Case by Case Determinations
- (n) Permit Issuance or Renewal
- (o) Permit Transfer
- (p) Permit Revocation, Denial or Modification
- (q) Variances
- (s) Treatment Requirements

1.3 Violations of any of the terms, conditions, or limitations contained in this permit may subject the Permittee to enforcement action including, but not limited to, seeking penalties, injunctions and/or forfeitures pursuant to applicable sections of the Conn. Gen. Stat. and Regs. Conn. State Agencies.

1.4 Any false statement in any information submitted pursuant to this permit may be punishable as a criminal offense under Section 22a-438 or 22a-131a of the Conn. Gen. Stat. or in accordance with Section 22a-6, under Section 53a-157b of the Conn. Gen. Stat.

1.5 The authorization to discharge under this permit may not be transferred without prior written approval of the Commissioner of Energy and Environmental Protection (“Commissioner”). To request such approval, the Permittee and proposed transferee shall register such proposed transfer with the Commissioner, at least thirty (30) days prior to the transferee becoming legally responsible for creating or maintaining any discharge which is the subject of the permit transfer. Failure, by the transferee, to obtain the Commissioner's approval prior to commencing such discharge(s) may subject the transferee to enforcement action for discharging without a permit pursuant to applicable sections of the Conn. Gen. Stat. and Regs. Conn. State Agencies.

1.6 No provision of this permit and no action or inaction by the Commissioner shall be construed to constitute an assurance by the Commissioner that the actions taken by the Permittee pursuant to this permit will result in compliance or prevent or abate pollution.

1.7 Nothing in this permit shall relieve the Permittee of other obligations under applicable federal, state and local law.

1.8 An annual fee shall be paid for each year this permit is in effect as set forth in Section 22a-430-7 of the Regs. Conn. State Agencies.

1.9 The Permittee shall operate and maintain its collection and treatment system in accordance with its Operation and Maintenance Plan and with any approvals issued in accordance with Regs. Conn. State Agencies Section 22a-430-3(i)(3).

1.10 The Permittee shall implement its Spill Prevention and Control Plan in accordance with Regs. Conn. State Agencies Section 22a-430-3(p) and 22a-430-4(c)(10). The plan shall include practices, procedures and facilities designed to prevent, minimize and control spills, leaks or such other unplanned releases of all toxic or hazardous substances and any other substances to prevent pollution of the waters of the state. Such requirements shall, unless otherwise allowed by the Commissioner, apply to all facilities used for storing, handling, transferring, loading or unloading such substances, including manufacturing areas. The Permittee shall revise and maintain the Spill Prevention and Control Plan upon the Commissioner's request or to

address equipment or operational changes.

SECTION 2: DEFINITIONS

2.1 The definitions of the terms used in this permit shall be the same as the definitions contained in Section 22a-423 of the Conn. Gen. Stat. and Section 22a-430-3(a) and 22a-430-6 of the Regs. Conn. State Agencies.

2.2 In addition to the above, the following definitions shall apply to this permit:

“40 CFR” means Title 40 of the Code of Federal Regulations.

“Annually” when used as a sampling frequency in Section 5 of this permit, means that sampling is required in the month of August.

“Average Monthly Limit” means the maximum allowable “Average Monthly Concentration” as defined in Section 22a-430-3(a) of the Regs. Conn. State Agencies when expressed as a concentration (e.g., mg/l). Otherwise, it means “Average Monthly Discharge Limitation” as defined in Section 22a-430-3(a) of the Regs. Conn. State Agencies.

Connecticut Water Quality Standards means the regulations adopted under Regs. Conn. State Agencies Sections 22a-426-1 through 22a-426-9, as amended.

“Daily Concentration” means the concentration of a substance as measured in a daily composite sample, or the arithmetic average of all grab sample results defining a grab sample average.

“Daily Quantity” means the quantity of waste discharged during an operating day.

“DMR” means Discharge Monitoring Report.

“IC” means “Inhibition Concentration”.

“IC₂₅” means a point estimate of the toxicant concentration that would cause a twenty-five (25) percent reduction in a non-lethal biological measurement of the test organism, such as reproduction or growth.

“Instantaneous Limit” means the highest allowable concentration of a substance as measured by a grab sample, or the highest allowable measurement of a parameter as obtained through instantaneous monitoring.

“In-stream Waste Concentration” (IWC) means the concentration (as a percent) of the effluent in the receiving water after mixing has occurred in the allocated zone of influence. It is the inverse of the dilution factor.

“LC” means Lethal Concentration

“LC₅₀” means the concentration lethal to fifty (50) percent of the test organisms during a specific period.

“Lowest Observed Effect Concentration” (LOEC) means the lowest concentration of an effluent or toxicant to which organisms are exposed in a life cycle or partial life-cycle test, which causes adverse effects on the test organisms.

“Maximum Daily Limit” means the maximum allowable “Daily Concentration” (defined above) when expressed as a concentration (e.g., mg/l). Otherwise, it means the maximum allowable “Daily Quantity” as defined above, unless it is expressed as a flow quantity. If expressed as a flow quantity, it means “Maximum Daily Flow” as defined in Section 22a-430-3(a) of the Regs. Conn. State Agencies.

“No Observed Effect Concentration” (NOEC) means the highest concentration of an effluent or toxicant to which organisms are exposed in a life cycle or partial life-cycle test, that causes no observable adverse effects on the test organisms.

“Quarterly”, when used as a sampling frequency in this permit, means that sampling is required in the months of February, May, August, and November.

“Reporting Frequency” means the frequency at which monitoring results must be provided.

“Semi-Annually” when used as a sampling frequency in this permit, means that sampling is required in the months of February and August.

SECTION 3: COMMISSIONER'S DECISION

- 3.1 The Commissioner has issued a final determination and found that continuance of the existing discharge will not cause pollution of the waters of the state. The Commissioner's decision is based on Application No. 201814996 for permit reissuance received on November 20, 2018, and the administrative record established in the processing of that application.
- 3.2 Upon the effective date of this permit and continuing until this permit expires or is modified or revoked, the Commissioner hereby authorizes the Permittee to discharge in accordance with the terms and conditions of this permit, the information provided in Application No. 201814996, received by the Commissioner on November 20, 2018, and all modifications and approvals issued by the Commissioner or the Commissioner's authorized agent, for the discharge and/or activities authorized by, or associated with this Permit.
- 3.3 The Commissioner reserves the right to make appropriate revisions to the permit in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the Federal Clean Water Act or the Conn. Gen. Stat. or regulations adopted thereunder, as amended. The permit as modified or renewed under this paragraph may also contain any other requirements of the Federal Clean Water Act or the Conn. Gen. Stat. or regulations adopted thereunder which are then applicable.
- 3.4 This permit includes a determination regarding Section 316(a) of the Federal Water Pollution Control Act 33 U.S.C. § 1326(a) regarding the thermal component of the discharge, and compliance with this permit is sufficient to assure the protection and propagation of a balanced indigenous population of shellfish, fish, and wildlife in and on the receiving waters.

SECTION 4: GENERAL EFFLUENT LIMITATIONS

- 4.1 The Permittee shall assure that the surface water affected by the subject discharge shall conform to the *Connecticut Water Quality Standards*.
- 4.2 No discharge shall contain, or cause in the receiving stream, a visible oil sheen or floating solids, or cause visible discoloration or foaming in the receiving stream.
- 4.3 No discharge shall cause acute or chronic toxicity in the receiving water body beyond any zone of influence specifically allocated to that discharge in this permit.
- 4.4 The temperature of any discharge shall not increase the temperature of the receiving stream above 83 °F, or in any case, raise the temperature of the receiving stream by more than 4 °F beyond any approved thermal zone of influence. The incremental temperature increase in coastal and marine waters during the period including July, August, and September is limited to 1.5 °F beyond any approved thermal zone of influence.

SECTION 5: SPECIFIC EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

- 5.1 The discharge is restricted by and shall be monitored in accordance with the following tables in this section. The wastewater discharge shall not exceed the effluent limitations in these tables and shall otherwise conform to the specific terms and conditions listed in the tables. The Permittee shall comply with the "Footnotes" and "Remarks" noted in the tables that follow. Such footnotes and remarks are enforceable like any other term or condition of this permit.
- 5.2 The wastewaters authorized/approved by this permit shall be collected, treated, and discharged in accordance with this permit and with any approvals issued by the Commissioner or his/her authorized agent for the discharges and activities authorized by or associated with this permit. Any wastewater discharges not expressly identified in these tables or otherwise approved to be discharged by this permit shall not be authorized by this permit.
- 5.3 All samples shall be comprised of only the wastewater described in these tables. Samples shall be collected prior to combination with receiving waters or wastewater of any other type, and after all approved treatment units, if applicable. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. Collection of permit-required effluent samples in any location other than the authorized location noted in this permit shall be a violation of this permit.
- 5.4 In cases where limits and sample type are specified but sampling is not required by this permit, the limits specified shall apply to all samples which may be collected and analyzed by the Department of Energy and Environmental Protection ("DEEP") personnel, the Permittee, or other parties.

Table A

Discharge Serial Number: DSN 008-1				Monitoring Location: 1 (EXTERNAL OUTFALL)													
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>																	
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin																	
Discharge is to: Thames River		Zone of Influence: 1,229,167 gallons per hour			Instream Waste Concentration: 1.67 %			Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)									
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			MINIMUM LEVEL ²							
			Average Monthly Limit	Maximum Daily Limit	Sample/Reporting Frequency ¹	Sample Type or Measurement to be reported	Instantaneous Limit or Required Range	Sample/Reporting Frequency	Sample Type or Measurement to be Reported								
Bis(2-ethylhexyl) phthalate	39100	µg/L	2.2	3.2	Monthly	Daily Composite	4.8	NR	Grab	2.2							
Bis(2-ethylhexyl) phthalate	39100	g/day	4.2	6.1	Monthly	Calculation	NA	NR	NA								
Biochemical Oxygen Demand, 5-day (BOD ₅)	85002	mg/L	---	---	Monthly	Daily Composite	NA	NR	NA								
Chlorine, Total Residual	50060	µg/L	---	---	Quarterly	Grab Sample Average	NA	NR	NA	20							
Chromium, Total	01034	µg/L	---	---	Quarterly	Daily Composite	NA	NR	NA	5							
Copper, Total	01042	µg/L	133	288	Quarterly	Daily Composite	NA	NR	NA	3							
Copper, Total	01042	g/day	251	545	Quarterly	Calculation	NA	NR	NA								
Fecal coliform ³	74055	cfus/100 ml	NA	NA	NR	NA	---	Semi-Annually	Grab								
Flow Rate, Average Daily ⁴	00056	gpd	500,000	NA	Daily	Total Daily Flow	NA	NR	NA								
Flow, Maximum Daily ⁴	50047	gpd	NA	750,000	Daily	Total Daily Flow	NA	NR	NA								
Iron, Total	01045	mg/L	3.0	5.0	Quarterly	Daily Composite	7.5	NR	Grab	0.1							
Iron, Total	01045	kg/day	5.6	9.4	Quarterly	Calculation	NA	NR	NA								
Lead, Total	01051	µg/L	---	---	Quarterly	Daily Composite	NA	NR	NA	1							
Nickel, Total	01067	µg/L	51.4	158	Quarterly	Daily Composite	NA	NR	NA	5							
Nickel, Total	01067	g/day	97	299	Quarterly	Calculation	NA	NR	NA								
Nitrogen, Ammonia (total as N)	00610	mg/L	---	---	Monthly	Daily Composite	NA	NR	NA								
Nitrogen, Kjeldahl (total as N)	00625	mg/L	---	---	Monthly	Daily Composite	NA	NR	NA								
Nitrogen, Nitrate (total as N)	00620	mg/L	---	---	Monthly	Daily Composite	NA	NR	NA								
Nitrogen, Nitrite (total as N)	00615	mg/L	---	---	Monthly	Daily Composite	NA	NR	NA								
Nitrogen, Total (as N)	00600	lbs/day	---	---	Monthly	Calculation ⁵	NA	NR	NA								
Nitrogen, Total (Annual Loading)	51084	lbs/day	331	---	Annually ⁵	Calculation ⁵	NA	NR	NA								
Oil & Grease, Total	00556	mg/L	---	5.0	Quarterly	Grab Sample Average	7.5	NR	Grab								

Table A

Discharge Serial Number: DSN 008-1				Monitoring Location: 1 (EXTERNAL OUTFALL)							
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>											
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin											
Discharge is to: Thames River		Zone of Influence: 1,229,167 gallons per hour			Instream Waste Concentration: 1.67 %		Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)				
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING				
			Average Monthly Limit	Maximum Daily Limit	Sample/Reporting Frequency ¹	Sample Type or Measurement to be reported	Instantaneous Limit or Required Range	Sample/Reporting Frequency	Sample Type or Measurement to be Reported		
pH, Minimum ⁴	61942	SU	NA	NA	NR	NA	6.8	Continuous	Instantaneous		
pH, Maximum ⁴	61941	SU	NA	NA	NR	NA	8.5	Continuous	Instantaneous		
Total Suspended Solids	00530	mg/L	20.0	30.0	Monthly	Daily Composite	45.0	NR	Grab		
Total Suspended Solids	00530	kg/day	37.8	56.7	Monthly	Calculation	NA	NR	NA		
Temperature, Maximum	00011	°F	NA	NA	NR	NA	90.0	Continuous	Instantaneous		
Temperature, Difference (Sample & Upstream)	00018	°F	NA	32.1	Daily	Calculation ⁶	NA	NR	NA		
Waste Heat Rejection Rate	00179	MBtus/day	NA	---	Daily	Calculation ⁷	NA	NR	NA		
Zinc, Total	01092	µg/L	---	---	Quarterly	Daily Composite	NA	NR	NA		
20											

TABLE FOOTNOTES AND REMARKS

Footnotes:

¹ The first entry in this column is the “Sample Frequency.” If a “Reporting Frequency” does not follow this entry, then the “Reporting Frequency” is monthly.

² Refer to Section 6.3 of this permit. The minimum levels (MLs) identified in this table represent the highest acceptable MLs that shall be achieved by the Permittee’s analytical methods. Actual MLs reported by the laboratory must be reported as a comment on the DMR. Detected concentrations less than the laboratory ML shall be reported on the DMR in accordance with Section 6.5.

³ Monitoring for fecal coliform shall be reported as follows: If less than five (5) samples are collected in a month, the maximum value in that sample set shall be reported on the DMR. If five (5) or more samples are collected in a month, the results of the geometric mean of those samples shall be reported on the DMR for that month.

⁴ For this parameter, the Permittee shall maintain at the facility a record of the Total Daily Flow and pH range for each operating day. The Permittee shall report on its DMR the “Average Daily Flow” and the “Maximum Daily Flow” and pH for each month.

⁵ Total Nitrogen concentration means the sum of the concentrations of: Ammonia Nitrogen + Organic Nitrogen + Nitrate Nitrogen + Nitrite Nitrogen. Daily Total Nitrogen means the Total Nitrogen Concentration multiplied by the daily flow volume and converted to lbs/day. The average monthly Total Nitrogen shall be reported as the sum of the Daily Total Nitrogen divided by the number of nitrogen sampling days during the month and rounded to the nearest whole number. Total Nitrogen (Annual Loading) shall be reported as the sum of the average monthly Total Nitrogen from January through December divided by 12 and rounded to the nearest whole number. Total Nitrogen (Annual Loading) shall be reported on the December DMR.

⁶ Temperature Difference (Sample & Upstream) is calculated as follows: Effluent Temperature (Maximum Daily) – Water Temperature @ NOAA Station 8461490 (Maximum Daily). The Permittee shall report the maximum value determined in a month on the DMR.

⁷ Waste Heat Rejection Rate is calculated as follows and shall be reported to 1 MBtu/day:

$$\text{Waste Heat Rejection Rate} \left(\frac{\text{BTU} \text{s}}{\text{day}} \right) = 1.0 \left(\frac{\text{BTU} \text{s}}{\text{lb} \text{ °F}} \right) * \text{Flow} \left(\frac{\text{gal}}{\text{day}} \right) * 8.34 \left(\frac{\text{lbs}}{\text{gal}} \right) * \Delta T \text{ (°F)}; \Delta T = \text{Temperature Difference (Sample & Upstream)}$$

Table A

Discharge Serial Number: DSN 008-1				Monitoring Location: 1 (EXTERNAL OUTFALL)									
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>													
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin													
Discharge is to: Thames River		Zone of Influence: 1,229,167 gallons per hour			Instream Waste Concentration: 1.67 %		Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)						
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING		MINIMUM LEVEL ²				
			Average Monthly Limit	Maximum Daily Limit	Sample/Reporting Frequency ¹	Sample Type or Measurement to be reported	Instantaneous Limit or Required Range	Sample/Reporting Frequency					
Remarks:													
<ol style="list-style-type: none"> Abbreviations used for units are as follows: °F means degrees Fahrenheit; cfus/100ml means colony forming units per 100 milliliters; gpd means gallons per day; g/day means grams per day; g/L means grams per liter; lbs/day means pounds per day; MBtus/day means million British thermal units per day; mg/L means milligrams per liter; lbs/day means pounds per day; SU means Standard Units; µg/L means micrograms per liter; µMho/s means micromhos per second. Other abbreviations are as follows: NA means Not Applicable; NR means Not Reportable (unless sampling is conducted relative to Section 5.4 of this permit). If “---” is noted in the limits column in the table, this means that a limit is not specified but a value must be reported on the DMR. In calculating average concentrations, use zeros for values reported as less than the ML. “Continuous”, used in this table as a “Sample” or “Sample Type”, means monitoring that produces one or more data points in fifteen minutes or less. Supplemental data shall be provided, at a minimum, for those monitoring parameters identified on Attachment A of this permit and such data shall be submitted consistent with Section 8.1 of this permit. The supplemental data can be provided in any acceptable format as long as it contains the information identified on Attachment A. 													

Table B – Acute Toxicity Monitoring

Discharge Serial Number: DSN 008-AT								Monitoring Location Codes: Y – Acute toxicity effluent results O – Acute toxicity chemical analyses U – Salinity adjusted effluent chemical analyses							
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>															
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin															
Discharge is to: Thames River		Zone of Influence: 1,229,167 gallons per hour				Instream Waste Concentration: 1.67 %		Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)							
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			Min- imum Level⁵	Mon- itoring Loca- tion				
			Average Monthly Limit	Minimum Daily Limit or Maximum Daily Limit ¹	Sample/ Reporting Frequency ^{2,3}	Sample Type or Measurement to be Reported ⁴	Instantaneous Limit or Required Range	Sample/ Reporting Frequency	Sample Type or Measurement to be Reported						
Whole Effluent Toxicity ("WET")															
Acute Aquatic Toxicity ⁶ <i>Americamysis bahia</i> , LC ₅₀	TAA3E	%	NA	≥100	Semi-Annually ⁷	Daily Composite	≥33	NR	Grab		Y				
Acute Aquatic Toxicity ⁶ <i>Cyprinodon variegatus</i> , LC ₅₀	TAA6A	%	NA	≥100	Semi-Annually ⁷	Daily Composite	≥33	NR	Grab		Y				
Chemical Analyses Required with Whole Effluent Toxicity Monitoring – See Sections 7.1.6 and 7.2.7. for Acute and Chronic Testing⁸															
Date of WET Chemistry Sample Collection ⁹	51883	YYYYMMDD	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		Y				
Alkalinity	00410	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U				
Bis(2-ethylhexyl) phthalate	39100	µg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA	2.2	O, U				
Biochemical Oxygen Demand, 5-day (BOD ₅)	85002	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U				
Chlorine, Total Residual	50060	µg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA	20	O, U				
Chromium, Total	01034	µg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA	5	O, U				
Copper, Total	01042	µg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA	3	O, U				
Flow, Day of Sampling	74076	gpd	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		Y				
Hardness, Total	00900	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U				
Iron, Total	01045	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA	0.1	O, U				
Lead, Total	01051	µg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA	1	O, U				
Nickel, Total	01067	µg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA	5	O, U				
Nitrogen, Ammonia (total as N)	00610	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U				
Nitrogen, Kjeldahl (total as N)	00625	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U				
Nitrogen, Nitrate (total as N)	00620	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U				
Nitrogen, Nitrite (total as N)	00615	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U				

Table B – Acute Toxicity Monitoring

Discharge Serial Number: DSN 008-AT								Monitoring Location Codes: Y – Acute toxicity effluent results O – Acute toxicity chemical analyses U – Salinity adjusted effluent chemical analyses					
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>													
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin													
Discharge is to: Thames River		Zone of Influence: 1,229,167 gallons per hour			Instream Waste Concentration: 1.67 %		Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)						
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			Min- imum Level ⁵	Mon- itoring Loca- tion		
			Average Monthly Limit	Minimum Daily Limit or Maximum Daily Limit ¹	Sample/ Reporting Frequency ^{2, 3}	Sample Type or Measurement to be Reported ⁴	Instantaneous Limit or Required Range	Sample/ Reporting Frequency	Sample Type or Measurement to be Reported				
Nitrogen, Total (as N) ¹⁰	00600	mg/L	NA	---	Semi-Annually ⁷	Calculation	NA	NR	NA		O, U		
Oil & Grease, Total	00556	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U		
pH, Day of Sampling	00400	SU	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U		
Salinity	00480	g/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U		
Specific Conductance	00095	µMho/cm	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U		
Temperature	00011	°F	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U		
Total Suspended Solids	00530	mg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA		O, U		
Zinc, Total	01092	µg/L	NA	---	Semi-Annually ⁷	Daily Composite	NA	NR	NA	20	O, U		

Table B – Acute Toxicity Monitoring

Discharge Serial Number: DSN 008-AT							Monitoring Location Codes: Y – Acute toxicity effluent results O – Acute toxicity chemical analyses U – Salinity adjusted effluent chemical analyses							
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>														
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin														
Discharge is to: Thames River		Zone of Influence: 1,229,167 gallons per hour			Instream Waste Concentration: 1.67 %		Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)							
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING		Min- imum Level ⁵	Mon- itoring Loca- tion				
			Average Monthly Limit	Minimum Daily Limit or Maximum Daily Limit ¹	Sample/ Reporting Frequency ^{2,3}	Sample Type or Measurement to be Reported ⁴	Instantaneous Limit or Required Range	Sample/ Reporting Frequency	Sample Type or Measurement to be Reported					
TABLE FOOTNOTES AND REMARKS														
Footnotes:														
1 WET limits are expressed as a minimum daily limit, meaning the minimum allowable daily discharge over the course of the 24-hour sampling period. Chemical results analyzed in conjunction with WET tests shall be reported as the max value collected during the 24-hour sampling period.														
2 The first entry in this column is the “Sample Frequency”. If a “Reporting Frequency” does not follow this entry and the “Sample Frequency” is more frequent than monthly, then the “Reporting Frequency” is monthly. If the “Sample Frequency” is specified as monthly, or less frequent, then the “Reporting Frequency” is the same as the “Sample Frequency.”														
3 If more than one toxicity sample is collected during a single month, report subsequent WET and chemistry results as an attachment to the DMR in accordance with Section 8.2 of this permit.														
4 Daily composite samples shall be collected for acute toxicity tests consistent with the methodology outlined in Section 7.1 of this permit.														
5 “Minimum Level” refers to Section 6.3 of this permit.														
6 Acute toxicity testing shall be conducted in accordance with Section 7.1 of this permit. The LC ₅₀ results (in %) for the acute toxicity testing shall be reported on the DMR. The Aquatic Toxicity Monitoring Report (ATMR) shall be completed for each toxicity testing event and submitted in accordance with Section 8.2 of this permit.														
7 Semi-Annually in the context of acute toxicity testing means that sampling is required in the months of May and November.														
8 Chemical analyses shall be conducted on samples used in the acute toxicity tests. These analyses shall be conducted on all samples used in the acute toxicity test and reported under Monitoring Locations O and U. Results shall also be included on the ATMR and submitted in accordance with Section 8.2 of this permit.														
9 The Permittee shall report the date of sample collection for the acute toxicity test and associated chemistry data in the format: year month day (YYYYMMDD).														
10 Total Nitrogen means the sum of the concentrations of: Ammonia Nitrogen + Organic Nitrogen + Nitrate Nitrogen + Nitrite Nitrogen.														
Remarks:														
1. Abbreviations used for units are as follows: °F means degrees Fahrenheit; cfus/100ml means colony forming units per 100 milliliters; gpd means gallons per day; g/day means grams per day; g/L means grams per liter; lbs/day means pounds per day; MBtus/day means million British thermal units per day; mg/L means milligrams per liter; lbs/day means pounds per day; SU means Standard Units; µg/L means micrograms per liter; µMho/cm means micromhos per centimeter. Other abbreviations are as follows: NA means Not Applicable; NR means Not Reportable (unless sampling is conducted relative to Section 5.4 of this permit).														
2. If “---” is noted in the limits column in the table, this means that a limit is not specified but a value must be reported on the DMR.														
3. Analyses that indicate that a parameter was not detected or that was detected less than the noted ML shall be reported in accordance with Section 6.5.														

Table C – Chronic Toxicity Monitoring

Discharge Serial Number: DSN 008-CT										Monitoring Location Codes: Y – Chronic toxicity effluent results O – Day 1 chronic toxicity chemical analyses P – Day 3 chronic toxicity chemical analyses Q – Day 5 chronic toxicity chemical analyses R – Day 1 upstream monitoring S – Day 3 upstream monitoring T – Day 5 upstream monitoring U – Day 1 salinity adjusted effluent chemical analyses V – Day 3 salinity adjusted effluent chemical analyses W – Day 5 salinity adjusted effluent chemical analyses			
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>													
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin													
Discharge is to: Thames River	Zone of Influence: 1,229,167 gallons per hour				Instream Waste Concentration:			Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)					
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			MINIMUM LEVEL ⁵	MONITORING LOCATION		
Whole Effluent Toxicity (“WET”)													
Chronic Aquatic Toxicity (Survival) ⁶ <i>Americanopsis bahia</i> , C-NOEC	TOP3E	%	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		Y		
Chronic Aquatic Toxicity (Growth) ⁶ <i>Americanopsis bahia</i> , C-NOEC	TPP3E	%	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		Y		
Chronic Aquatic Toxicity (Reproduction) ⁶ <i>Americanopsis bahia</i> , C-NOEC	TVP3E	%	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		Y		
Chronic Aquatic Toxicity (Survival) ⁶ <i>Cyprinodon variegatus</i> , C-NOEC	TOP6A	%	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		Y		
Chronic Aquatic Toxicity (Growth) ⁶ <i>Cyprinodon variegatus</i> , C-NOEC	TPP6A	%	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		Y		
Chemical Analyses Required with Whole Effluent Toxicity Monitoring – See Sections 7.1.6 and 7.2.7. for Acute and Chronic Testing⁷													
Date of WET Chemistry Sample Collection ⁸	51883	YYYYMMDD	NA	---	Semi-Annually	Calculated	NA	NR	NA		O, P, Q; R, S, T; U, V, W		
Alkalinity	00410	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W		

Table C – Chronic Toxicity Monitoring

Discharge Serial Number: DSN 008-CT									Monitoring Location Codes: Y – Chronic toxicity effluent results O – Day 1 chronic toxicity chemical analyses P – Day 3 chronic toxicity chemical analyses Q – Day 5 chronic toxicity chemical analyses R – Day 1 upstream monitoring S – Day 3 upstream monitoring T – Day 5 upstream monitoring U – Day 1 salinity adjusted effluent chemical analyses V – Day 3 salinity adjusted effluent chemical analyses W – Day 5 salinity adjusted effluent chemical analyses					
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>														
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin														
Discharge is to: Thames River	Zone of Influence: 1,229,167 gallons per hour			Instream Waste Concentration: 1.67 %			Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)							
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			MINIMUM LEVEL⁵	MONITORING LOCATION			
			Average Monthly Limit	Minimum Daily Limit or Maximum Daily Limit ¹	Sample/Reporting Frequency ^{2, 3}	Sample Type or Measurement to be Reported ⁴	Instantaneous Limit or Required Range	Sample/Reporting Frequency	Sample Type or Measurement to be Reported					
Bis(2-ethylhexyl) phthalate	39100	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	2.2	O, P, Q; R, S, T; U, V, W			
Biochemical Oxygen Demand, 5-day (BOD ₅)	85002	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W			
Chlorine, Total Residual	50060	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	20	O, P, Q; R, S, T; U, V, W			
Chromium, Total	01034	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	5	O, P, Q; R, S, T; U, V, W			
Chromium, Dissolved	01030	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	5	O, P, Q; R, S, T; U, V, W			
Copper, Total	01042	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	3	O, P, Q; R, S, T; U, V, W			
Copper, Dissolved	01040	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	3	O, P, Q; R, S, T; U, V, W			

Table C – Chronic Toxicity Monitoring

Discharge Serial Number: DSN 008-CT									Monitoring Location Codes: Y – Chronic toxicity effluent results O – Day 1 chronic toxicity chemical analyses P – Day 3 chronic toxicity chemical analyses Q – Day 5 chronic toxicity chemical analyses R – Day 1 upstream monitoring S – Day 3 upstream monitoring T – Day 5 upstream monitoring U – Day 1 salinity adjusted effluent chemical analyses V – Day 3 salinity adjusted effluent chemical analyses W – Day 5 salinity adjusted effluent chemical analyses					
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>														
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin														
Discharge is to: Thames River	Zone of Influence: 1,229,167 gallons per hour			Instream Waste Concentration: 1.67 %			Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)							
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			MINIMUM LEVEL⁵	MONITORING LOCATION			
			Average Monthly Limit	Minimum Daily Limit or Maximum Daily Limit ¹	Sample/Reporting Frequency ^{2, 3}	Sample Type or Measurement to be Reported ⁴	Instantaneous Limit or Required Range	Sample/Reporting Frequency	Sample Type or Measurement to be Reported					
Flow, Day of Sampling	74076	gpd	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W			
Hardness, Total	00900	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W			
Iron, Total	01045	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	0.1	O, P, Q; R, S, T; U, V, W			
Iron, Dissolved	01046	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	0.1	O, P, Q; R, S, T; U, V, W			
Lead, Total	01051	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	1	O, P, Q; R, S, T; U, V, W			
Lead, Dissolved	01049	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	1	O, P, Q; R, S, T; U, V, W			
Nickel, Total	01067	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	5	O, P, Q; R, S, T; U, V, W			

Table C – Chronic Toxicity Monitoring

<p>Discharge Serial Number: DSN 008-CT</p> <p>Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i></p>											<p>Monitoring Location Codes:</p> <p>Y – Chronic toxicity effluent results O – Day 1 chronic toxicity chemical analyses P – Day 3 chronic toxicity chemical analyses Q – Day 5 chronic toxicity chemical analyses R – Day 1 upstream monitoring S – Day 3 upstream monitoring T – Day 5 upstream monitoring U – Day 1 salinity adjusted effluent chemical analyses V – Day 3 salinity adjusted effluent chemical analyses W – Day 5 salinity adjusted effluent chemical analyses</p>	
<p>Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin</p>												
Discharge is to: Thames River	Zone of Influence: 1,229,167 gallons per hour			Instream Waste Concentration: 1.67 %			Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)					
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			MINIMUM LEVEL⁵	MONITORING LOCATION	
			Average Monthly Limit	Minimum Daily Limit or Maximum Daily Limit ¹	Sample/Reporting Frequency ^{2, 3}	Sample Type or Measurement to be Reported ⁴	Instantaneous Limit or Required Range	Sample/Reporting Frequency	Sample Type or Measurement to be Reported			
Nickel, Dissolved	01065	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	5	O, P, Q; R, S, T; U, V, W	
Nitrogen, Ammonia (total as N)	00610	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W	
Nitrogen, Kjeldahl (total as N)	00625	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W	
Nitrogen, Nitrate (total as N)	00620	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W	
Nitrogen, Nitrite (total as N)	00615	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W	
Nitrogen, Total (as N) ⁹	00600	mg/L	NA	---	Semi-Annually	Calculation	NA	NR	NA		O, P, Q; R, S, T; U, V, W	
Oil & Grease, Total	00556	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W	

Table C – Chronic Toxicity Monitoring

Discharge Serial Number: DSN 008-CT									Monitoring Location Codes: Y – Chronic toxicity effluent results O – Day 1 chronic toxicity chemical analyses P – Day 3 chronic toxicity chemical analyses Q – Day 5 chronic toxicity chemical analyses R – Day 1 upstream monitoring S – Day 3 upstream monitoring T – Day 5 upstream monitoring U – Day 1 salinity adjusted effluent chemical analyses V – Day 3 salinity adjusted effluent chemical analyses W – Day 5 salinity adjusted effluent chemical analyses					
Wastewater Description: <i>Air compressor/air dryer condensate; Air conditioning condensate; Backflow preventer & fire protection test water; Bleed off or draining of boiler & minor leaks from a boiler; Boiler blowdown; Boiler lab testing wastewater; Boiler washdown; Building maintenance wastewater; Chilled water; Cleaning of chilled water strainers & filters; Condensate polisher resin regeneration wastewater; Cooling tower blowdown/draining; Deaerator and vent stack condensate; Dewatering wastewater; Eyewash stations and miscellaneous plant sinks; Floor drain wastewater; Hydrostatic test water; Non-contact cooling water; Primary neutralization system draining; Pump seal water; Raw water tank overflow; Reverse osmosis non-permeate; Sand filter backwash; Spill containment area stormwater; Steam cleaning and power wash wastewater; Steam condensate; Stormwater; Wastewater drained from solids filter system; Water softener regeneration wastewater; West Basin cooling system strainer cleaning wastewater</i>														
Monitoring Location Description: Basin instrument trailer on the west side of the effluent basin														
Discharge is to: Thames River	Zone of Influence: 1,229,167 gallons per hour			Instream Waste Concentration: 1.67 %			Outfall Location: Latitude (41.33056°) and Longitude (-72.07889°)							
PARAMETER	NET DMR CODE	UNITS	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			MINIMUM LEVEL ⁵	MONITORING LOCATION			
			Average Monthly Limit	Minimum Daily Limit or Maximum Daily Limit ¹	Sample/Reporting Frequency ^{2, 3}	Sample Type or Measurement to be Reported ⁴	Instantaneous Limit or Required Range	Sample/Reporting Frequency	Sample Type or Measurement to be Reported					
pH, Day of Sampling	00400	SU	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W			
Salinity	00480	g/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W			
Specific Conductance	00095	µMho/cm	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W			
Temperature	00011	°F	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W			
Total Suspended Solids	00530	mg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA		O, P, Q; R, S, T; U, V, W			
Zinc, Total	01092	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	20	O, P, Q; R, S, T; U, V, W			
Zinc, Dissolved	01090	µg/L	NA	---	Semi-Annually	Daily Composite	NA	NR	NA	20	O, P, Q; R, S, T; U, V, W			

TABLE FOOTNOTES AND REMARKS

Footnotes:

- ¹ WET limits are expressed as a minimum daily limit, meaning the minimum allowable daily discharge over the course of the 24-hour sampling period. Chemical results analyzed in conjunction with WET tests shall be reported as the max value collected during the 24-hour sampling period.
- ² The first entry in this column is the “Sample Frequency”. If a “Reporting Frequency” does not follow this entry and the “Sample Frequency” is more frequent than monthly, then the “Reporting Frequency” is monthly. If the “Sample Frequency” is specified as monthly, or less frequent, then the “Reporting Frequency” is the same as the “Sample Frequency.”
- ³ If more than one toxicity sample is collected during a single month, report subsequent WET and chemistry results in accordance with Sections 8.2 and 9.4 of this permit.
- ⁴ Daily composite samples shall be collected for aquatic toxicity tests consistent with the methodology outlined in Section 7.2 of this permit.
- ⁵ “Minimum Level” refers to Section 6.3 of this permit.
- ⁶ Chronic toxicity testing shall be conducted in accordance with Section 7.2 of this permit. The C-NOEC (Chronic-No Observed Effect Concentration) results (in %) for the conditions noted in this table shall be reported on the DMR. The ATMR shall be completed for each chronic toxicity testing event and submitted in accordance with Section 8.2 of this permit.
- ⁷ Chemical analyses shall be conducted on all samples used in the chronic toxicity tests. These analyses shall be conducted on an undiluted aliquot of each effluent sample and each sample of upstream receiving water used in the chronic toxicity test. Results for effluent sampling from day 1, day 3, and day 5 of the chronic toxicity test shall be reported under Monitoring Location O, P, and Q, respectively. Receiving water (upstream) results from day 1, day 3, and day 5 of sampling shall be reported under Monitoring Location R, S, and T, respectively. Results for salinity adjusted effluent sampling from day 1, day 3, and day 5 of the chronic toxicity test shall be reported under Monitoring Location U, V, and W, respectively. Results shall also be included on the ATMR and submitted in accordance with Section 8.2 of this permit.
- ⁸ The Permittee shall report the dates of sample collection for each day of chronic toxicity test chemistry sampling (days 1, 3, and 5) in the format: year month day (YYYYMMDD).
- ⁹ Total Nitrogen means the sum of the concentrations of: Ammonia Nitrogen + Organic Nitrogen + Nitrate Nitrogen + Nitrite Nitrogen.

Remarks:

1. Abbreviations used for units are as follows: °F means degrees Fahrenheit; cfus/100ml means colony forming units per 100 milliliters; gpd means gallons per day; g/day means grams per day; g/L means grams per liter; lbs/day means pounds per day; MBtus/day means million British thermal units per day; mg/L means milligrams per liter; lbs/day means pounds per day; SU means Standard Units; µg/L means micrograms per liter; µMho/cm means micromhos per centimeter. Other abbreviations are as follows: NA means Not Applicable; NR means Not Reportable (unless sampling is conducted relative to Section 5.4 of this permit).
2. If “---” is noted in the limits column in the table, this means that a limit is not specified but a value must be reported on the DMR.
3. Analyses that indicate that a parameter was not detected or that was detected less than the noted ML shall be reported in accordance with Section 6.5.

SECTION 6: SAMPLE COLLECTION, HANDLING AND ANALYTICAL TECHNIQUES

- 6.1 All samples shall be collected, handled, and analyzed in accordance with the methods approved under 40 CFR 136, unless another method is required under 40 CFR subchapter N or unless an alternative method has been approved in writing pursuant to 40 CFR 136.5. To determine compliance with limits and conditions established in this permit, monitoring must be performed using sufficiently-sensitive methods approved pursuant to 40 CFR 136 for the analysis of pollutants having approved methods under that part, unless a method is required under 40 CFR subchapter N or unless an alternative method has been approved in writing pursuant to 40 CFR 136.5.
- 6.2 All metals analyses identified in this permit shall refer to analyses for Total Recoverable Metal as defined in 40 CFR 136, unless otherwise specified.
- 6.3 The term Minimum Level (“ML”) refers to either the sample concentration equivalent to the lowest calibration point in a method or a multiple of the method detection limit (“MDL”). MLs may be obtained in several ways: They may be published in a method; they may be sample concentrations equivalent to the lowest acceptable calibration point used by the laboratory; or they may be calculated by multiplying the MDL in a method, or the MDL determined by a lab, by a factor of 3. The MLs specified in Section 5 Tables A - C. represent the minimum concentrations at which quantification must be achieved and verified during the chemical analyses for the parameters identified in Section 5 Tables A - C Analyses for these parameters must include check standards within ten percent of the specified ML or calibration points equal to or less than the specified ML.
- 6.4 The value of each parameter for which monitoring is required under this permit shall be reported to the maximum level of accuracy and precision possible, consistent with the requirements of this Section of the permit.
- 6.5 Analyses for which quantification was verified to be below a ML, including non-detect, shall be reported as zero on the DMR for purposes of determining compliance with effluent limitations or conditions specified in this permit. The Permittee shall attach documentation demonstrating the ML of the analysis as an attachment to the DMR and identify the ML as a comment on the DMR.
- 6.6 It is a violation of this permit for a Permittee or his/her designated agent, to manipulate test samples in any manner, to delay sample shipment, or to terminate or to cause to terminate a toxicity test. Once initiated, all toxicity tests must be completed.
- 6.7 Analyses required under this permit shall be performed in accordance with Conn. Gen. Stat. Section 19a-29a. An “environmental laboratory”, as that term is defined in the referenced section, that is performing analyses required by this permit, shall be registered and have certification acceptable to the Commissioner, as such registration and certification is necessary.

SECTION 7: AQUATIC TOXICITY TESTING

- 7.1 **ACUTE TESTING REQUIREMENTS** The Permittee shall conduct acute aquatic toxicity for DSN 008-AT as follows:
 - 7.1.1 **TEST METHOD:** Acute aquatic toxicity shall be performed as prescribed in the reference document *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (EPA-821-R-02-012), or the most current version, with any exceptions or clarifications noted below.
 - 7.1.2 **SAMPLE COLLECTION AND HANDLING:**
 - 7.1.2.1 Composite samples shall be chilled as they are collected. Grab samples shall be chilled immediately following collection. Samples shall be held at 0-6 °C until aquatic toxicity testing is initiated.

7.1.2.2 Effluent samples shall not be dechlorinated, filtered, or modified in any way prior to testing for acute aquatic toxicity unless specifically approved in writing by the Commissioner for monitoring at this facility.

7.1.2.3 Tests for acute aquatic toxicity shall be initiated within 36 hours of sample collection.

7.1.3 **TEST SPECIES AND TEST DURATION:** Monitoring for aquatic toxicity to determine compliance with the acute toxicity limits in this permit shall be conducted as follows:

7.1.3.1 For 48-hours utilizing neonatal *Mysidopsis bahia* (1-5 days old with no more than 24-hours range in age).

7.1.3.2 For 48-hours utilizing larval *Cyprinodon variegatus* (1-14 days old with no more than 24-hours range in age).

7.1.4 **ACUTE ENDPOINT:** Survival at 48-hours measured by LC₅₀.

7.1.5 **TEST CONDITIONS:**

7.1.5.1 Tests for acute aquatic toxicity shall be conducted as prescribed for static non-renewal tests.

7.1.5.2 Definitive (multi-concentration) testing, with LC₅₀ as the endpoint, shall be conducted to determine compliance with limits on acute aquatic toxicity and monitoring conditions and shall incorporate, at a minimum, the following effluent concentrations: 100%, 75%, 50%, 25%, 12.5% and 6.25%.

7.1.5.3 Aquatic toxicity tests with saltwater organisms shall be conducted at a salinity of 28 parts per thousand (\pm 2 parts per thousand).

7.1.5.3.1 Synthetic seawater for use as dilution water or controls shall be prepared with deionized water and artificial sea salts as described in EPA-821-R-02-012.

7.1.5.3.2 If the salinity of the source water is more than 5 parts per thousand higher or lower than the culture water used for rearing the organisms, a second set of controls matching the salinity of the culture water shall be added to the test series. Test validity shall be determined using the controls adjusted to match the source water salinity.

7.1.5.3.3 Salinity adjustment that may be required in tests with saltwater organisms shall utilize the minimum amount of synthetic hypersaline brine (not to exceed 100 parts per thousand) or dilute (2 parts per thousand) synthetic seawater necessary to achieve the required salinity.

7.1.5.3.4 The actual effluent concentrations in definitive tests with saltwater organisms shall be used in calculating test results.

7.1.5.4 All effluent concentrations and the control(s) used in the test shall have the same salinity. If the effluent requires salinity adjustment to a standard salinity, this shall be accomplished by adding a minimum amount of commercial sea salts as described in EPA-821-R-02-012.

7.1.5.5 Organisms shall not be fed during the tests.

7.1.5.6 Sodium lauryl sulfate or sodium dodecyl sulfate shall be used as the reference toxicant.

7.1.5.7 Dissolved oxygen, pH, and temperature shall be measured in the control and in all test concentrations at the beginning of the test, daily thereafter, and at test termination.

7.1.5.8 Specific conductance, pH, salinity, alkalinity, hardness, and total residual chlorine shall be measured in the undiluted effluent sample and in the dilution (control) water at the beginning of the test and at test termination. If total residual chlorine is not detected at test initiation, it does not need to be measured at test termination.

7.1.6 **CHEMICAL ANALYSIS:** All effluent samples used in the acute toxicity test, including salinity adjusted effluent samples, if salinity adjustment is required, shall at a minimum, be analyzed and results reported in accordance with the provisions listed in Section 5 Table B and Section 6.1 for the parameters identified on Section 5 Table B of the permit.

7.1.7 **TEST ACCEPTABILITY CRITERIA:** For the test results to be acceptable, control survival must equal or exceed 90%. If the laboratory control fails to meet test acceptability criteria for either of the test organisms at the end of the respective test period, then the test is considered invalid and the test must be repeated with a newly collected sample in accordance with Section 9.4.

7.1.8 **TEST COMPLIANCE:** Compliance with limits on Acute Toxicity shall be determined as follows: For limits expressed as a minimum LC₅₀ value, compliance shall be demonstrated when the results of a valid definitive acute aquatic toxicity test indicates that the LC₅₀ value for the test is greater than the acute toxicity limit.

7.2 **CHRONIC TESTING REQUIREMENTS.** The Permittee shall conduct chronic toxicity testing for DSN 008-CT as follows:

7.2.1 **TEST METHOD:** Chronic aquatic toxicity testing shall be performed as prescribed in the reference document *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, EPA-821-R-02-014, or the most current version, with the following exceptions or clarifications noted below.

7.2.2 **SAMPLE COLLECTION AND HANDLING:**

7.2.2.1 Composite samples shall be chilled as they are being collected. Samples shall be held at 0-6 °C until aquatic toxicity testing is initiated.

7.2.2.2 Effluent samples shall not be dechlorinated, filtered, or modified in any way prior to testing for aquatic toxicity unless specifically approved in writing by the Commissioner for monitoring at this facility.

7.2.2.3 Tests for aquatic toxicity shall be initiated within 36 hours of sample collection.

7.2.3 **TEST SPECIES AND TEST DURATION:** Monitoring for aquatic toxicity to determine compliance with the chronic toxicity limits/conditions in the permit shall be conducted as follows:

7.2.3.1 For seven days utilizing juvenile *Americamysis bahia* (7 days old with no more than 24 hours range in age).

7.2.3.2 For seven days utilizing larval *Cyprinodon variegatus* (less than 24 hours old with no more than 24 hours range in age).

7.2.4 **CHRONIC ENDPOINTS:**

7.2.4.1 *Americamysis bahia*: Survival, Growth, and Fecundity

7.2.4.2 *Cyprinodon variegatus*: Survival and Growth

7.2.5 **DILUTION WATER:** Thames River water shall be collected upstream of the area influenced by the discharge and shall be used as site control water (0% effluent) and dilution water in the toxicity tests. The Permittee shall document the dilution water sampling location by providing coordinates and/or a map of the location.

7.2.6 TEST CONDITIONS:

- 7.2.6.1 Testing for aquatic toxicity shall be conducted as prescribed in the reference document for static daily renewal tests.
- 7.2.6.2 Daily composite samples of the discharge and grab samples of the Thame River for use as site water and dilution water shall be collected on: Day 1 of the test (for test initiation and renewal on Day 2 of the test); Day 3 of the test (for test solution renewal on Day 3 and Day 4 of the test); and on Day 5 of the test, (for test solution renewal on Day 5, Day 6, and Day 7 of the test). Samples shall not be dechlorinated, pH or hardness adjusted, or chemically altered in any way.
- 7.2.6.3 Test concentrations shall be comprised of a minimum of five dilutions (100%, 50%, 25%, 12.5%, 6.25%, and 1.67% effluent), laboratory control water, and site dilution water.
- 7.2.6.4 Dissolved oxygen, pH, salinity, and temperature shall be measured in each sample of effluent and the Thame River water sample prior to and immediately following renewal of the test solutions.
- 7.2.6.5 Synthetic seawater prepared with deionized water and artificial salts adjusted to a salinity of 28 parts per thousand (± 2 parts per thousand) as described in *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms* (EPA-821-R-02-014) shall be used as laboratory control water.

7.2.7 **CHEMICAL ANALYSIS:** Chemical analysis for the parameters identified in Section 5 Table C of the permit shall be conducted on an undiluted aliquot of each effluent sample, an undiluted aliquot of each salinity adjusted effluent sample, if salinity adjustment is required, and each sample of upstream Thames River used in the test. The chemical analysis shall be analyzed, and results reported in accordance with the provisions listed in Section 5 Table C and Section 6.1 of the permit.

7.2.8 **TEST ACCEPTABILITY CRITERIA:** If the laboratory control fails to meet test acceptability criteria specified in the reference document for either of the test organisms at the end of the respective test period, then the test is considered invalid and the test must be repeated.

7.2.9 **REPORTING:** A report detailing the results of the chronic toxicity monitoring shall be documented on an ATMR and submitted to the Commissioner by the last day of the month following the month in which samples are collected in accordance with Section 8.2 of this permit. The report shall include the items identified in Section 8.2 of this permit. Endpoints to be reported are: 48-hour LC₅₀ (survival), 7-day LC₅₀ (survival), 7-day C-NOEC (survival), 7-day C-LOEC (survival), 7-day C-NOEC (growth), 7-day C-LOEC (growth), 7-day C-NOEC (fecundity), 7-day C-LOEC (fecundity), 7-day IC₂₅ (growth and fecundity).

SECTION 8: REPORTING REQUIREMENTS

8.1 The results of chemical analyses and any aquatic toxicity test required by this permit shall be submitted electronically using NetDMR. Monitoring results shall be reported at the monitoring frequency specified in this permit. Any monitoring required more frequently than monthly shall be reported on an attachment to the DMR, and any additional monitoring conducted in accordance with 40 CFR 136, or another method required for an industry-specific waste stream under 40 CFR subchapter N, or other methods approved by the Commissioner, shall also be included on the DMR, or as an attachment, if necessary, and the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Commissioner in the permit. All aquatic toxicity reports shall also be included as an attachment to the DMR. A report shall also be included with the DMR which includes a detailed explanation of any violations of the limitations specified. DMRs, attachments, and reports, shall continue to be submitted electronically in accordance with Section 8.4 below. However, if the DMRs,

attachments, and reports are required to be submitted in hard copy form, they shall be received at this address by the last day of the month following the month in which samples are collected:

Bureau of Materials Management and Compliance Assurance
Water Permitting and Enforcement Division (Attn: DMR Processing)
Connecticut Department of Energy and Environmental Protection
79 Elm Street
Hartford, CT 06106-5127

- 8.2 The ATMR associated with aquatic toxicity monitoring shall include all applicable items identified in Section 12 of EPA-821-R-02-012 and in Section 10 of EPA-821-R-02-013 (Freshwater) or EPA-821-R-02-014 (Saltwater), including complete and accurate aquatic toxicity test data, including percent survival of test organisms in each replicate test chamber, LC₅₀ values and 95% confidence intervals for definitive test protocols, and all supporting chemical/physical measurements performed in association with any aquatic toxicity test, including measured daily flow and hours of operation for the 30 consecutive operating days prior to sample collection. The ATMR shall be submitted electronically as an attachment to the DMR and via email to: DEEP.IndustrialWETReports@ct.gov. The ATMR required by Sections 5 and 7 shall be received at this address by the last day of the month following the month in which the samples are collected.
- 8.3 If this permit requires monitoring of a discharge on a calendar basis (e.g., monthly, quarterly, etc.), but a discharge has not occurred within the frequency of sampling specified in the permit, the Permittee must submit the DMR and ATMR, as scheduled, indicating no discharge has occurred using NODI code "C". For those permittees whose required monitoring is discharge dependent (e.g., per batch), the minimum reporting frequency is monthly. Therefore, if there is no discharge during a calendar month for a batch discharge, a DMR must be submitted indicating such by the end of the following month.
- 8.4 NetDMR Reporting Requirements:

The Permittee shall report electronically using NetDMR, a web-based tool that allows permittees to electronically submit DMRs and other required reports through a secure internet connection. The Permittee and/or the signatory authority shall electronically submit DMRs required under this permit to the Commissioner using NetDMR in satisfaction of the DMR submission requirements of Sections 5, 6, 8, and 9 of this permit. All sampling and monitoring records required under the permit, including any monitoring conducted more frequently than monthly or any additional monitoring conducted in accordance with 40 CFR 136, shall be submitted to the Commissioner as an electronic attachment to the DMR in NetDMR. The Permittee shall also electronically file any written report of noncompliance described in Section 9 of this permit as an attachment in NetDMR. DMRs shall be submitted electronically to the Commissioner no later than the last day of the month following the completed reporting period. NetDMR is accessed from: <http://www.epa.gov/netdmr>.

SECTION 9: RECORDING AND REPORTING OF VIOLATIONS, ADDITIONAL TESTING REQUIREMENTS

9.1 *Noncompliance Notifications:*

9.1.1 In accordance with Section 22a-430-3(j)(8), 22a-430-3(j)(11)(D), 22a-430-3(k)(4), and 22a-430-3(i)(3) of the RSCA, the Permittee shall notify the Commissioner of the following actual or anticipated noncompliance with the terms or conditions of this permit within two hours of becoming aware of the circumstances. All other actual or anticipated violations of the permit shall be reported to the Commissioner within 24 hours of becoming aware of the circumstances:

- 9.1.1.1 A noncompliance that is greater than two times an effluent limitation;
- 9.1.1.2 A noncompliance of any minimum or maximum daily limitation or excursion beyond a minimum or maximum daily range;
- 9.1.1.3 Any condition that may endanger human health or the environment, including but not limited to noncompliance with whole effluent toxicity WET limitations;
- 9.1.1.4 Any condition that may endanger the operation of a POTW, including sludge handling and disposal;
- 9.1.1.5 A failure or malfunction of monitoring equipment used to comply with the monitoring requirements of this permit;
- 9.1.1.6 Any actual or potential bypass of the Permittee's collection system or treatment facilities; or
- 9.1.1.7 Expansions or significant alterations of any wastewater collection, treatment facility, or its method of operation for the purpose of correcting or avoiding a permit violation.

9.1.2 Notifications shall be submitted via the Commissioner's online Noncompliance Notification Form: <https://portal.ct.gov/deep/water-regulating-and-discharges/industrial-wastewater/compliance-assistance/notification-requirements>.

9.1.3 Within five days of any notification of noncompliance in accordance with Sections 9.1.1.1 through 9.1.1.6 of this permit, the Permittee shall submit a follow-up report using the Commissioner's online Noncompliance Follow-up Report Form: <https://portal.ct.gov/deep/water-regulating-and-discharges/industrial-wastewater/compliance-assistance/notification-requirements>.

The follow-up report shall contain, at a minimum, the following information: (i) A description of the noncompliance and its cause; (ii) the period of noncompliance, including exact dates and times; (iii) if the noncompliance has not been corrected, the anticipated time it is expected to continue; and (iv) steps taken or planned to correct the noncompliance and reduce, eliminate and prevent recurrence of the noncompliance.

9.1.4 Within 30 days of any notification of facility modifications reported in accordance with Section 9.1.1.7 of this permit, the Permittee shall submit a written follow-up report by submitting a "Facility and Wastewater Treatment System Modification Request for Determination" for the review and approval of the Commissioner. The report shall fully describe the changes made to the facility and reasons therefor.

9.1.5 Notification of an actual or anticipated noncompliance or facility modification does not stay any term or condition of this permit.

9.2 In accordance with Section 22a-430-3(j)(11)(E) of the RSCA, the Permittee shall notify the Commissioner

within 72 hours and in writing within 30 days when he or she knows or has reason to believe that the concentration in the discharge of any substance listed in the application, or any toxic substance as listed in Appendix B or D of RSCA Section 22a-430-4, has exceeded or will exceed the highest of the following levels: (1) One hundred micrograms per liter; (2) Two hundred micrograms per liter for acrolein and acrylonitrile, five hundred micrograms per liter for 2,4-dinitrophenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter for antimony; (3) An alternative level specified by the Commissioner, provided such level shall not exceed the level which can be achieved by the Permittee's treatment system; or (4) A level two times the level specified in the Permittee's application.

72 hour initial notifications shall be submitted via the Commissioner's online Noncompliance Notification Form. 30 day follow-up reports shall be submitted via the Commissioner's online Noncompliance Follow-up Report Form. The Forms are available at the Commissioner's website, here: <https://portal.ct.gov/deep/water-regulating-and-discharges/industrial-wastewater/compliance-assistance/notification-requirements>.

- 9.3 In addition to any other written reporting requirements, the Permittee shall report any instances of noncompliance with this permit with its DMR. Such reporting shall be due no later than the last day of the month following the reporting period in which the noncompliant event occurred. The information provided in the DMR shall include, at a minimum: the type of violation, the duration of the violation, the cause of the violation, and any corrective action(s) or preventative measure(s) taken to address the violation.
- 9.4 If any sample analysis indicates that an aquatic toxicity effluent limitation in Section 5 of this permit has been exceeded, or that the test was invalid, another sample of the effluent shall be collected and tested for aquatic toxicity and associated chemical parameters, as described above in Sections 5 and 7. The exceedance or invalid test shall be reported to Commissioner in accordance with Section 9.1. The results shall be submitted to the Commissioner within 30 days of the exceedance or invalid test. The results and the associated ATMR shall be reported in accordance with Sections 5 and 8.2 of the permit. Results of all tests, whether valid or invalid, shall be reported. If more than one toxicity sample is collected during a single month, report subsequent WET and chemistry results as an attachment to the month's DMR.
- 9.5 If any two consecutive test results or any three test results in a twelve-month period indicate that an aquatic toxicity limit has been exceeded, the Permittee shall immediately take all reasonable steps to eliminate toxicity wherever possible and shall also submit a report, for the review and written approval of the Commissioner, which describes in detail the steps taken or that shall be taken to eliminate the toxic impacts of the discharge on the receiving water and it shall also include a proposed schedule for implementation. Such report shall be submitted in accordance with the timeframe set forth in Section 22a-430-3(j)(10)(C) of the Regs. Conn. State Agencies. The Permittee shall implement all actions in accordance with the approved report and schedule.

This permit is hereby issued on

JENNIFER PERRY, P.E.
Bureau Chief

JP/ JG

ATTACHMENT A

Supplemental Monitoring Data: DSN 008-1

Month: _____

Day	FLOW	pH (min)	pH (max)	MAX DAILY TEMP	NOAA STATION 8461490 TEMP	TEMP DIFFERENCE	HEAT LOAD
	Gpd	SU	SU	°F	°F	°F	Btus/day
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							