

## NPDES PERMIT

### Issued to

**Permittee:**

Town of Beacon Falls  
10 Maple Avenue  
Beacon Falls, CT 06403

**Facility Address:**

Town of Beacon Falls POTW  
411 Lopus Road  
Beacon Falls, CT 06403

**Permit ID:** CT0101061

**Design Flow Rate:** 0.71 MGD

**Effective Date:** **DRAFT**

**Receiving Waters:** Naugatuck River

**Permit Expires:**

### SECTION 1: GENERAL PROVISIONS

(A) This permit is reissued by the Connecticut Department of Energy and Environmental Protection ("Department") in accordance with Section 22a-430 in Chapter 446k of the Connecticut General Statutes ("CGS") and the Regulations of Connecticut State Agencies ("RCSA") adopted thereunder, as amended, and Section 402(b) of the Clean Water Act, as amended, 33 U.S.C. 1251, *et. seq.*, and pursuant to an approval dated September 26, 1973, by the Administrator of the United States Environmental Protection Agency for the State of Connecticut (the "State") to administer a National Pollutant Discharge Elimination System ("NPDES") permit program.

(B) The **Town of Beacon Falls** (the "Permittee") shall comply with all conditions of this permit including the following sections of the RCSA which have been adopted pursuant to Section 22a-430 of the CGS and are hereby incorporated into this permit. **Your attention is especially drawn to the notification requirements of subsections (i)(2), (i)(3), (j)(1), (j)(6), (j)(8), (j)(9)(C), (j)(10)(C), (j)(11)(C), (D), (E), and (F), (k)(3), (k)(4), and (l)(2) of Section 22a-430-3.** To the extent this permit imposes conditions more stringent than those found in the regulations, this permit shall apply.

#### Section 22a-430-3 General Conditions

- (a) Definitions
- (b) General
- (c) Inspection and Entry
- (d) Effect of a Permit
- (e) Duty to Comply
- (f) Proper Operation and Maintenance
- (g) Sludge Disposal
- (h) Duty to Mitigate
- (i) Facility Modifications; Notification
- (j) Monitoring, Records and Reporting Requirements
- (k) Bypass
- (l) Conditions Applicable to POTWs
- (m) Effluent Limitation Violations

- (n) Enforcement
- (o) Resource Conservation
- (p) Spill Prevention and Control
- (q) Instrumentation, Alarms, Flow Recorders
- (r) Equalization

#### **Section 22a-430-4 Procedures and Criteria**

- (a) Duty to Apply
- (b) Duty to Reapply
- (c) Application Requirements
- (d) Preliminary Review
- (e) Tentative Determination
- (f) Draft Permits, Fact Sheets
- (g) Public Notice, Notice of Hearing
- (h) Public Comments
- (i) Final Determination
- (j) Public Hearings
- (k) Submission of Plans and Specifications. Approval.
- (l) Establishing Effluent Limitations and Conditions
- (m) Case-by-Case Determinations
- (n) Permit Issuance or Renewal
- (o) Permit or Application Transfer
- (p) Permit Revocation, Denial or Modification
- (q) Variances
- (r) Secondary Treatment Requirements
- (s) Treatment Requirements
- (t) Discharges to POTWs – Prohibitions

- (C) Violations of any of the terms, conditions, or limitations contained in this permit may subject the Permittee to enforcement action including, but not limited to, seeking penalties, injunctions, and/or forfeitures pursuant to applicable sections of the CGS and RCSA.
- (D) Any false statement in any information submitted pursuant to this permit may be punishable as a criminal offense under Section 22a-438 or 22a-131a of the CGS or, in accordance with Section 22a-6(a)(8), under Section 53a-157b of the CGS.
- (E) No provision of this permit and no action or inaction by the Commissioner of Energy and Environmental Protection (the "Commissioner") shall be construed to constitute an assurance by the Commissioner that the actions taken by the Permittee pursuant to this permit will result in compliance or prevent or abate pollution.
- (F) Nothing in this permit shall relieve the Permittee of other obligations under applicable federal, state, and local law.
- (G) This permit becomes effective on the 1<sup>st</sup> day of the next month following the date of signature by the Commissioner or their designee.
- (H) An annual fee shall be paid for each year this permit is in effect as set forth in Section 22a-430-7 of the RCSA. As of October 1, 2009, in accordance with Section 22a-6f of the CGS, the annual fee is \$1,722.50.

#### **SECTION 2: DEFINITIONS**

- (A) The definitions of the terms used in this permit shall be the same as the definitions contained in Sections 22a-423 and 22a-424a of the CGS and Sections 22a-430-3(a) and 22a-430-6(b) of the RCSA, except for "Composite" and "No Observable Acute Effect Level (NOAEL)", which are redefined below.
- (B) In addition to the above, the following definitions shall apply to this permit:

"-----" in a "Limit" column on any monitoring table in Attachment 1 means that a limit is not specified but a value must be reported on the DMR, MOR, and/or the ATMR.

**"Annually"** in the context of any sampling frequency, shall mean the sample must be collected in the month of July, August, and September.

**"ATMR"** means Aquatic Toxicity Monitoring Report.

**"Average Monthly Limit"** means the maximum allowable "Average Monthly Concentration" as defined in Section 22a-430-3(a) of the RCSA when expressed as a concentration (e.g., mg/L); otherwise, it means "Average Monthly Discharge Limitation" as defined in Section 22a-430-3(a) of the RCSA.

**"Biweekly"** in the context of any sampling frequency, shall mean once every two weeks.

**"Composite"** means a sample consisting of a minimum of eight aliquot samples collected at equal intervals of no less than 30 minutes and no more than 60 minutes and combined proportionally to flow over the sampling period provided that during the sampling period the peak hourly flow is experienced.

**"Connecticut Water Quality Standards"** means the regulations adopted under Sections 22a-426-1 through 22a-426-9 of the RCSA, as amended.

**"Critical Test Concentration"** or **"CTC"** means the specified effluent dilution at which the Permittee is to conduct a single-concentration Aquatic Toxicity Test.

**"Daily Composite"** means a composite sample taken over a full operating day consisting of grab samples collected at equal intervals of no more than sixty (60) minutes and combined proportionally to flow; or a composite sample continuously collected over a full operating day proportionally to flow.

**"Daily Concentration"** means the concentration of a substance as measured in a daily composite sample, or arithmetic average of all grab sample results defining a grab sample average.

**"Daily Quantity"** means the quantity of waste discharged during an operating day.

**"DMR"** means Discharge Monitoring Report.

**"Geometric Mean"** is the  $n^{\text{th}}$  root of the product of  $n$  observations.

**"Instantaneous Limit"** means the highest allowable concentration of a substance as measured by a grab sample, or the highest allowable measurement of a parameter as obtained through instantaneous monitoring.

**"In-stream Waste Concentration"** or **"IWC"** means the concentration of a discharge in the receiving water (as a percentage) after mixing has occurred in the allocated Zone of Influence.

**"Maximum Daily Limit"** means the maximum allowable "Daily Concentration" (defined above) when expressed as a concentration (e.g., mg/L), otherwise, it means the maximum allowable "Daily Quantity" as defined above, unless it is expressed as a flow quantity. If expressed as a flow quantity, it means "Maximum Daily Flow" as defined in Section 22a-430-3(a) of the RCSA.

**"MGD"** means million gallons per day.

**"MOR"** means Monthly Operating Report.

**"NA"** as a Monitoring Table abbreviation means "not applicable".

**"NAR"** means Nutrient Analysis Report submitted pursuant to the General Permit for Nitrogen Discharges.

"NR" as a Monitoring Table abbreviation means "not required".

**"No Observable Acute Effect Level" or "NOAEL"** means any concentration equal to or less than the critical test concentration in a single concentration (pass/fail) toxicity test, conducted pursuant to Section 22a-430-3(j)(7)(A)(i) of the RCSA, demonstrating 90% or greater survival of test organisms in 100% undiluted effluent at a CTC of 100%.

**"Permitted Sewage Bypass"** means any bypass meeting the requirements of Section 22a-430-3(k)(1) of the RCSA, and if applicable, any discharge from a permitted combined sewer overflow outfall in response to wet weather conditions (i.e., rainfall or snowmelt) when the total available transportation, treatment, and storage capabilities are exceeded, as well as any bypass of secondary treatment resulting from wet weather flows collected by a combined sewer system.

**"Quarterly"** in the context of any sampling frequency, shall mean sampling is required in the months of January, April, July, and October.

**"Range During Sampling" or ("RDS")** as a sample type, means the maximum and minimum of all values recorded resulting from analyzing each individual aliquot of 1) a Composite Sample; or 2) a Grab Sample Average. For those permittees with continuously monitoring and recording dissolved oxygen, pH, or ultraviolet light meters, RDS means the maximum and minimum readings recorded with the continuous monitoring device during the Composite or Grab Sample Average sample collection.

**"Semiannually"** in the context of any sampling frequency, shall mean sampling is required in the months of January and July.

"**µg/L**" means micrograms per liter.

**"Workday"** in the context of a sampling frequency, means Monday through Friday excluding holidays.

**"Zone of Influence"** means the spatial area or volume of receiving water flow within which some degradation of water quality or use impairment is anticipated to occur as a result of a discharge.

### **SECTION 3: COMMISSIONER'S DECISION**

- (A)** The Commissioner has issued a final decision and found that continuance of the existing system to treat the discharge would protect the waters of the State from pollution. The Commissioner's decision is based on Application No. 202112159 for permit reissuance received on December 21, 2021 and the administrative record established in the processing of that application.
- (B)** The Commissioner hereby authorizes the Permittee to discharge in accordance with the provisions of this permit, the above referenced application, and all approvals issued by the Commissioner or their authorized agent for the discharges and/or activities authorized by or associated with this permit.
- (C)** The Commissioner reserves the right to make appropriate revisions to the permit, if required after Public Notice, in order to establish any appropriate effluent limitations, schedules of compliance, or other provisions which may be authorized under the Federal Clean Water Act or the CGS or the regulations adopted thereunder, as amended. The permit as reissued under this paragraph may also contain any other requirements of the Federal Clean Water Act or CGS or regulations adopted thereunder which are then applicable.

### **SECTION 4: GENERAL LIMITATIONS AND CONDITIONS**

- (A)** The Permittee shall not accept any new sources of non-domestic sewage conveyed to its publicly owned treatment works (POTW) through its sanitary sewerage system or by any means other than its sanitary sewerage system unless the generator of such wastewater: (a) is authorized by a permit issued by the Commissioner under Section 22a-430 of the CGS (individual permit); (b) is authorized under Section 22a-430b

of the CGS (general permit); or (c) has been issued an emergency or temporary authorization by the Commissioner under Section 22a-6k of the CGS. All such non-domestic sewage shall be processed by the POTW via receiving facilities at a location and in a manner prescribed by the Permittee which are designed to contain and control any unplanned releases.

- (B)** No new discharge of domestic sewage from a single source to the POTW in excess of 35,500 gallons per day shall be allowed by the Permittee until the Permittee has notified the Department via email to [DEEP.MunicipalNPDES@ct.gov](mailto:DEEP.MunicipalNPDES@ct.gov) of said new discharge.
- (C)** Outside of the Zone of Influence specifically assigned to this discharge, the discharge shall not cause or contain:
  - (1)** sludge deposits, solid refuse, floating solids, oils and grease, or scum, except as may result from a discharge from a wastewater treatment facility providing appropriate treatment and none exceeding levels necessary to protect and maintain all designated uses assigned to the classification of the receiving waters pursuant to the Connecticut Water Quality Standards;
  - (2)** color resulting in obvious discoloration of the surface water;
  - (3)** suspended and settleable solids in concentrations or combinations which would impair the designated uses, be aesthetically objectionable, significantly alter the physical or chemical composition of bottom sediments, and/or adversely impact organisms living in or on the bottom sediment;
  - (4)** silt or sand deposits other than of natural origin;
  - (5)** turbidity other than that of natural origin except as may result from a discharge from a wastewater treatment facility providing appropriate treatment, provided all reasonable controls are used to control turbidity and none exceeding levels necessary to protect and maintain all designated uses; or
  - (6)** odor that would impair the designated uses.
- (D)** No discharge from the permitted facility shall cause acute toxicity or chronic toxicity in the receiving water body outside of any Zone of Influence specifically allocated to that discharge in this permit.
- (E)** Any new or increased amount of sanitary sewage discharge to the sewer system is prohibited where it will cause a dry weather overflow or exacerbate an existing dry weather overflow.
- (F)** Sludge Conditions
  - (1)** The Permittee shall comply with all existing federal and state laws and regulations that apply to sewage sludge use and disposal practices, including but not limited to Part 503 of Title 40 of the Code of Federal Regulations (40 CFR 503).
  - (2)** If an applicable management practice or numerical limitation for pollutants in sewage sludge more stringent than existing federal and state regulations is promulgated under Section 405(d) of the Clean Water Act (CWA), this permit shall be modified or revoked and reissued to conform to the promulgated regulations.
  - (3)** The Permittee shall give prior notice to the Commissioner of any planned changes to its sludge use or disposal practice. A change in the Permittee's sludge use or disposal practice may be a cause for modification of the permit.
  - (4)** Testing for inorganic pollutants shall follow "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods", EPA Publication SW-846 as updated and/or revised.
- (G)** Proper Operation & Maintenance
  - (1)** The Permittee shall comply with Sections 22a-416-1 through 22a-416-10 of the RCSA concerning

operator certification.

- (2) **Within fourteen (14) days** after a chief operator, shift operator, or process control operator begins or terminates employment in such capacity at a wastewater treatment facility, the Permittee shall notify the Department of that fact via email to Craig Motasky, Operator Certification Coordinator, at [craig.motasky@ct.gov](mailto:craig.motasky@ct.gov). Direct responsible charge experience shall not start to accumulate for such chief operator, shift operator, or process control operator until the date the Department receives such notification from the Permittee.
- (3) The Permittee shall maintain a system of user charges or dedicated taxes or other fees sufficient to properly operate and maintain the POTW (including the collection system) and replace critical components.
- (4) The Permittee shall maintain a sewer use ordinance that is consistent with the "Model Sewer Ordinance for Connecticut Municipalities" prepared by the Department and dated March 1982, as amended. The Commissioner alone may authorize certain discharges which may not conform to the Model Sewer Ordinance.
- (5) The Permittee shall operate and maintain all processes as installed in accordance with the approved plans and specifications and as outlined in the associated operation and maintenance manual. This includes but is not limited to all preliminary treatment processes, primary treatment processes, recycle pumping processes, anaerobic treatment processes, anoxic treatment processes, aerobic treatment processes, flocculation processes, effluent filtration processes or any other processes necessary for the optimal removal of pollutants. The Permittee shall not bypass or fail to operate any of the aforementioned processes without the written approval of the Commissioner.
- (6) The Permittee shall maintain an alternate power source adequate to provide full operation of all pump stations in the sewerage collection system and to provide a minimum of primary treatment and disinfection at the water pollution control facility to ensure that no discharge of untreated wastewater will occur during a failure of a primary power source.
- (7) **No later than July 31<sup>st</sup> of each calendar year**, the main flow meter shall be calibrated by an independent contractor in accordance with the manufacturer's specifications. The actual record of the calibration shall be retained on-site and upon request, the Permittee shall submit to the Commissioner a copy of that record.
- (8) Without prior written approval from the Commissioner, the Permittee shall not introduce any chemicals, virgin or otherwise, to the treatment process that were not identified in the permit application referenced in Section 3(A) of this permit, nor in any plans and specifications approved by the Department in accordance with Section 22a-430-3(i) of the RCSA.
- (9) **Within 540 days of the effective date of this permit**, the Permittee shall submit an updated Sewer Service Area (SSA) Map to the Department via email to [DEEP.MunicipalNPDES@ct.gov](mailto:DEEP.MunicipalNPDES@ct.gov). The SSA shall at a minimum clearly identify and delineate the following information as applicable:
  - (a) areas currently connected to sanitary sewers;
  - (b) areas considered for future sanitary sewer service; and
  - (c) areas where sanitary sewer service will not be provided.
- (10) **No later than February 15<sup>th</sup> of each calendar year**, the Permittee shall submit to the Department via email to [DEEP.MunicipalNPDES@ct.gov](mailto:DEEP.MunicipalNPDES@ct.gov), an updated listing of all wastewater treatment plant and collection system improvements (**outside of routine maintenance**) and all sewer extensions performed during the most recent calendar year. At a minimum the following information must be included in the submission:
  - (a) the street name or nearest identifiable location to where the project was performed;
  - (b) the total linear feet of pipe replaced or repaired;

- (c) the number of manholes repaired or replaced;
- (d) a description of work performed at pump stations;
- (e) a description of work performed at the treatment plant; and
- (f) a project listing with proposed collection system and plant improvements for the following calendar year.

- (11) **Within one (1) year** from the date when the arithmetic mean of the average daily flow from the POTW exceeds 90% of the design flow rate over the previous 180 days, the Permittee shall develop and submit a report to [DEEP.MunicipalNPDES@ct.gov](mailto:DEEP.MunicipalNPDES@ct.gov) for the review and approval of the Commissioner describing a plan to accommodate future increases in flow to the plant. This plan shall include a schedule for completing any recommended studies, rehabilitations, and/or improvements and a plan for financing them.
- (12) **Within one (1) year** from the date when the arithmetic mean of the average daily BOD5 or TSS load into the POTW exceeds 90% of the design load rate over the previous 180 days, the Permittee shall develop and submit a report to [DEEP.MunicipalNPDES@ct.gov](mailto:DEEP.MunicipalNPDES@ct.gov) for the review and approval of the Commissioner describing a plan to accommodate future increases in load to the plant. This plan shall include a schedule for completing any recommended studies, rehabilitations, and/or improvements and a plan for financing them.

## **SECTION 5: SPECIFIC LIMITATIONS, MONITORING REQUIREMENTS, and CONDITIONS**

- (A) The discharge(s) shall not exceed and shall otherwise conform to the specific limitations, terms, and conditions listed in this permit. The discharge is restricted by and shall be monitored in accordance with Tables A through G incorporated in this permit as Attachment 1.
- (B) The Permittee shall provide monitoring data of the performance of the treatment process in accordance with the Monthly Operating Report (MOR) form incorporated in this permit as Attachment 2.
- (C) The average monthly concentrations of 5-day Biochemical Oxygen Demand (BOD<sub>5</sub>) and Total Suspended Solids (TSS) in the Permittee's effluent shall not exceed 15% of the respective average monthly concentrations of BOD<sub>5</sub> and TSS in the influent.
- (D) The temperature of any discharge shall not increase the temperature of the receiving stream above 85°F, or, in any case, raise the normal temperature of the receiving stream more than 4°F beyond the permitted Zone of Influence.

## **SECTION 6: SAMPLE COLLECTION, HANDLING and ANALYTICAL TECHNIQUES**

- (A) Chemical Analyses
  - (1) All samples collected to determine compliance with effluent limitations and conditions established in this permit shall be handled and analyzed in accordance with methods approved under 40 CFR 136 unless an alternative method has been approved in writing pursuant to 40 CFR 136.4 or as provided in Section 22a-430-3(j)(7) of the RCSA. Monitoring parameters which do not have approved methods of analysis defined in 40 CFR 136 or the RCSA shall be sampled and analyzed in accordance with methods specified in this permit.
  - (2) All metals analyses identified in this permit shall refer to analyses for Total Recoverable Metal as defined in 40 CFR 136, unless otherwise specified.
  - (3) Grab samples shall be taken during the period of the day when the peak hourly flow is normally experienced.
  - (4) Samples collected for bacteriological examination shall be collected between the hours of 11 a.m. and 3

p.m. or at the time of day when the peak hourly flow is normally experienced.

(5) The Minimum Levels specified below represent the concentrations at which quantification must be achieved and verified during the chemical analyses for the parameters identified in Attachment 1, Tables A through E. Analyses for these parameters must include check standards within ten percent of the specified Minimum Level or calibration points equal to or less than the specified Minimum Level.

<u>Parameter</u>	<u>Minimum Level</u>
Aluminum, Total	50 µg/L
Antimony, Total	10 µg/L
<b>Arsenic, Total</b>	<b>**0.5 µg/L</b>
Beryllium, Total	1 µg/L
Cadmium, Total	0.5 µg/L
Chlorine, Total Residual	50 µg/L
Chromium, Total	5 µg/L
Chromium, Total Hexavalent	10 µg/L
Copper, Total	5 µg/L
Cyanide, Total	10 µg/L
Iron, Total	40 µg/L
Lead, Total	5 µg/L
Mercury, Total	0.2 µg/L
<b>Mercury, Total</b>	<b>***0.05 µg/L</b>
Nickel, Total	5 µg/L
Phosphorus, Total	0.10 mg/L
Selenium, Total	5 µg/L
Silver, Total	2 µg/L
Thallium, Total	5 µg/L
Zinc, Total	20 µg/L

(a) *\*\*Please note the change in the Arsenic Minimum Level, from 5 µg/L down to 0.5 µg/L. This lower ML should be achievable using the existing approved 40 CFR 136 methods.*

(b) **\*\*\*No later than 365 days after the effective date of this permit**, the Permittee shall comply with a Mercury Minimum Level of 0.05 µg/L, which is achievable using EPA Methods 245.7 and 1631E. Until such time, the Permittee shall comply with a Mercury Minimum Level of 0.2 µg/L.

(6) The value of each parameter for which monitoring is required under this permit shall be reported to the maximum level of accuracy and precision possible, consistent with the requirements of this Section of the permit.

(7) Effluent analyses for which quantification was verified to be at or below a minimum level specified in this Section and which indicate that a parameter was not detected shall be reported as "less than x" where x is the numerical value equivalent to the analytical method detection limit for that analysis.

(8) Results of effluent analyses which indicate that a parameter was not present at a concentration greater than or equal to the Minimum Level specified for that analysis shall be considered equivalent to zero (0.0) for purposes of determining compliance with effluent limitations or conditions specified in this permit.

(9) It is a violation of this permit for a Permittee or their designated agent to manipulate test samples in any manner, to delay sample shipment, or to terminate or to cause to terminate a toxicity test. Once initiated, all toxicity tests must be completed.

**(B) Acute Aquatic Toxicity Testing**

(1) Samples for monitoring of Acute Aquatic Toxicity shall be collected and handled as prescribed in

"Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA-821-R-02-012).

- (a) Composite samples shall be chilled as they are collected. Grab samples shall be chilled immediately following collection. Unless samples are hand delivered to the testing laboratory for use on the day of collection, they shall be held at 0–6°C until Acute Aquatic Toxicity testing is initiated to inhibit microbial degradation, chemical transformations, and loss of highly volatile toxic substances. Samples shipped to the testing laboratory should be placed in a shipping container with sufficient ice to ensure that ice will still be present when the samples arrive at the laboratory and are unpacked.
- (b) Effluent samples shall not be dechlorinated, filtered, or modified in any way prior to testing for Acute Aquatic Toxicity unless specifically approved in writing by the Commissioner for monitoring at this facility. Facilities with effluent dechlorination and/or filtration designed as part of the treatment process are not required to obtain approval from the Commissioner.
- (c) Samples shall be taken at the final effluent for Acute Aquatic Toxicity unless otherwise approved in writing by the Commissioner for monitoring at this facility.
- (d) Chemical analyses of the parameters identified in Attachment 1, Table C, shall be conducted on an aliquot of the same sample tested for Acute Aquatic Toxicity.
  - (i) At a minimum, pH, specific conductance, total alkalinity, total hardness, and total residual chlorine shall be measured in the effluent sample and, during Acute Aquatic Toxicity tests, in the highest concentration of the test and in the dilution (control) water at the beginning of the test and at test termination. If total residual chlorine is not detected at test initiation, it does not need to be measured at test termination. Dissolved oxygen, pH, and temperature shall be measured in the control and all test concentrations at the beginning of the test, daily thereafter, and at test termination.
- (e) Tests for Acute Aquatic Toxicity shall be initiated within 36 hours of sample collection.

(2) Monitoring for Acute Aquatic Toxicity to determine compliance with the permit condition on Acute Aquatic Toxicity (invertebrate) shall be conducted for 48 hours utilizing neonatal (less than 24 hours old) *Daphnia pulex*.

(3) Monitoring for Acute Aquatic Toxicity to determine compliance with the permit condition on Acute Aquatic Toxicity (vertebrate) shall be conducted for 48 hours utilizing larval (1 to 14-day old with no more than 24 hours range in age) *Pimephales promelas*.

(4) Tests for Acute Aquatic Toxicity shall be conducted as prescribed for static non-renewal acute tests in "Methods for Measuring the Acute Aquatic Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms" (EPA-821-R-02-012), except as specified below.

- (a) For Acute Aquatic Toxicity limits, and for monitoring only conditions, expressed as a NOAEL value, Pass/Fail (single concentration) tests shall be conducted at a specified Critical Test Concentration (CTC) equal to the Aquatic Toxicity limit, (100% in the case of monitoring only conditions), as prescribed in Section 22a-430-3(j)(7)(A)(i) of the RCSA.
- (b) Organisms shall not be fed during the tests.
- (c) Synthetic freshwater prepared with deionized water adjusted to a hardness of  $50\pm5$  mg/L as  $\text{CaCO}_3$  shall be used as dilution water in the tests.
- (d) Copper nitrate shall be used as the reference toxicant.

(5) For monitoring only conditions, toxicity shall be demonstrated when the results of a valid pass/fail Acute Aquatic Toxicity test indicates less than 90% survival in the effluent at the CTC (100%).

(C) Chronic Aquatic Toxicity Test for Freshwater Discharges

(1) Chronic Aquatic Toxicity testing of the discharge shall be conducted annually during July, August, or September of each year.

(2) Chronic Aquatic Toxicity testing shall be performed on the discharge in accordance with the test methodology established in "Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms" (EPA-821-R-02-013) as referenced in 40 CFR 136 for *Pimephales promelas* larval survival and growth and *Ceriodaphnia dubia* survival and reproduction.

(a) Chronic Aquatic Toxicity tests shall utilize a minimum of five effluent dilutions prepared using a dilution factor of 0.5 (100% effluent, 50% effluent, 25% effluent, 12.5% effluent, 6.25% effluent).

(b) Naugatuck River water collected immediately upstream of the area influenced by the discharge shall be used as control (0% effluent) and dilution water in the toxicity tests.

(c) A laboratory water control consisting of synthetic freshwater prepared in accordance with EPA-821-R-02-013 at a hardness of 50±5 mg/l shall be used as an additional control (0% effluent) in the toxicity tests.

(d) Daily composite samples of the discharge (final effluent following disinfection) and grab samples of the Naugatuck River for use as site water control and dilution water shall be collected on day 0 for test solution renewal on day 1 and day 2 of the test; day 2, for test solution renewal on day 3 and day 4 of the test; and day 4, for test solution renewal for the remainder of the test. Samples shall not be pH or hardness adjusted, or chemically altered in any way.

(3) All samples of the discharge and Naugatuck River water used in the Chronic Aquatic Toxicity test shall, at a minimum, be analyzed and results reported in accordance with the provisions listed in Section 6(A) of this permit for the parameters listed in Attachment 1, Table D included herein, except for organism testing, which is specified in paragraph C(2) above.

(4) As part of each chronic toxicity test's daily renewal procedure, dissolved organic carbon, pH, and hardness must be measured in the effluent and receiving waters at the beginning and end of each 24-hour period.

## SECTION 7: DATA RECORDING AND REPORTING REQUIREMENTS

(A) The results of the process monitoring required in Section 5 of this permit shall be entered on the Monthly Operating Report (MOR) form, included herein as Attachment 2, and submitted to the Department via email to [DEEP.WPCF@ct.gov](mailto:DEEP.WPCF@ct.gov), or in another format approved by the Commissioner, **by the 15<sup>th</sup> day of the month** following the month in which the data and samples were collected. The subject line of the email shall include the name of the facility and the keyword "MOR" to ensure proper routing. The MOR report shall also be accompanied by a detailed explanation of any violations of the limitations specified in this permit.

(B) Complete and accurate test data, including percent survival of test organisms in each replicate test chamber, LC<sub>50</sub> values and 95% confidence intervals for definitive test protocols, and all supporting chemical/physical measurements performed in association with any aquatic toxicity test as outlined in Section 6(B) shall be entered on the Aquatic Toxicity Monitoring Report (ATMR) forms and submitted to the Department via email to [DEEP.WPCF@ct.gov](mailto:DEEP.WPCF@ct.gov), or in another format approved by the Commissioner, **by the 15<sup>th</sup> day of the month** following the month in which the samples were collected. The subject line of the email shall include the name of the facility and the keyword "ATMR" to ensure proper routing.

(C) A complete and thorough report of the results of the chronic toxicity monitoring outlined in Section 6(C) shall be prepared as outlined in Section 10 of EPA-821-R-02-013 and submitted to the Department via email to

[DEEP.WPCF@ct.gov](mailto:DEEP.WPCF@ct.gov), or in another format approved by the Commissioner, **no later than December 31<sup>st</sup> of each calendar year**. The subject line of the email shall include the name of the facility and the keyword "Chronic" to ensure proper routing.

(D) The Permittee shall continue to report the results of chemical analyses and aquatic toxicity tests required by Sections 5 and 6 above and detailed in Attachment 1 below via electronic submission of Discharge Monitoring Reports (DMRs) to the Department using the NetDMR system. Monitoring results shall be reported at the monitoring frequencies specified in this permit. Any parameters for which monitoring is required more frequently than monthly shall be reported on an attachment to the DMR, and any additional monitoring conducted in accordance with 40 CFR 136 or other methods approved by the Commissioner, shall also be included on the DMR, or as an attachment, if necessary, and the results of such monitoring shall be included in the calculation and reporting of the data submitted in the DMR. Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Commissioner in the permit. All aquatic toxicity reports shall also be included as an attachment to the DMR. A report shall also be included with the DMR which includes a detailed explanation of any violations of the limitations specified. DMRs shall be submitted via NetDMR monthly, **no later than the 15<sup>th</sup> day of the month** following the month in which the samples were collected.

(E) For composite samples not collected by automatic samplers, the instantaneous flow and the time of each aliquot sample collection shall be recorded and maintained at the POTW.

## **SECTION 8: RECORDING AND REPORTING OF VIOLATIONS, BYPASSES, MECHANICAL FAILURES, AND MONITORING EQUIPMENT FAILURES**

(A) Initial Emergency Response Notification

(1) For any sewage spill or permitted sewage bypass that reaches a water body, wetland, or catch basin **or** exceeds one hundred (100) gallons in volume over a 24-hour period, the reporting requirements of Section 22a-450 of the CGS shall apply. **Within one (1) hour** of becoming aware of any such spill or bypass, the Permittee shall notify the DEEP Emergency Response Unit via telephone at (860) 424-3338. The Permittee shall record the time the call was made, the name of the DEEP staff spoken with, and the case number.

(2) For any sewage spill or permitted sewage bypass that reaches a water body **or** may come in contact with the general public, the reporting requirements of Section 22a-424a(c)(3) of the CGS shall apply. **Within two (2) hours** of becoming aware of any such spill or bypass, the Permittee shall notify the chief elected official (CEO) and the local public health official in the municipality where the spill occurred and the CEO and local public health official of any municipality that may be potentially impacted downstream.

(B) Required Electronic Reporting to DEEP

(1) In accordance with Section 22a-424a(d) of the CGS, any report required pursuant to Section 22a-430-3 of the RCSA shall be submitted electronically. The Department maintains an electronic sewage bypass and permit noncompliance reporting system located at <https://deepct.qscend.com/qalert/>. The Permittee shall submit an **initial incident report** to the Commissioner through the Department's electronic sewage bypass and permit noncompliance reporting system or in another format approved by the Commissioner, **within two (2) hours** of becoming aware of any of the following circumstances:

(a) All instances of bypass, including bypass of the entire treatment plant or any portion thereof, permitted sewage bypasses such as those performed during required maintenance, and bypass of any component of the sewage collection system including any discharge through combined sewer overflow, in accordance with Section 22a-424a(c)(2) of the CGS and Section 22a-430-3(k) of the RCSA;

(b) Any actual or anticipated noncompliance with a minimum or maximum daily limit or any actual or anticipated noncompliance that is greater than two times any permit limit, in accordance with Section 22a-430-3(j)(11)(D) of the RCSA;

- (c) Any condition that may endanger human health or the environment, including but not limited to noncompliance with aquatic toxicity effluent limitations, or any condition that may endanger the operation of the POTW, including sludge handling and disposal, in accordance with Section 22a-430-3(j)(11)(D) of the RCSA;
- (d) In the event of a monitoring equipment malfunction or failure including, but not limited to, loss of refrigeration for an auto-sampler or lab refrigerator or loss of flow proportion sampling ability, in accordance with Section 22a-430-3(j)(8) of the RCSA; and
- (e) In the event of failure of any major component of the treatment facility which the Permittee may have reason to believe would result in an effluent violation, in accordance with Sections 22a-430-3(i)(3), (j), and (k) of the RCSA.

(2) A **final incident report** shall be submitted to the Commissioner through the electronic reporting system **within five (5) days** of submission of the initial incident report for any of the scenarios described under paragraph (B)(1) above.

(3) If the electronic reporting system is not functioning or there is an emergency at the facility that impedes electronic reporting (no electricity, flooding, etc.) and a call to the DEEP Emergency Response Unit has not already been made, then the Permittee shall call DEEP's Emergency Response Unit at (860) 424-3338 to provide the bypass information and describe the issue(s) the facility is having with reporting. The Permittee shall record the time the call was made, the name of the DEEP staff spoken with, and the case number. Once the event impeding electronic reporting has cleared, the operator is required to submit the event electronically.

(C) Failed/Invalid Aquatic Toxicity Tests

- (1) If any Aquatic Toxicity sample analysis indicates toxicity, or that the test was invalid, an additional sample of the effluent shall be collected and tested for Aquatic Toxicity and associated chemical parameters as described above in Sections 5 and 6, and the results shall be reported to the Department via the ATMR form in accordance with Section 7(B) **within thirty (30) days** of the previous test. These test results shall also be reported on DMR report in accordance with Section 7(A). The results of all toxicity tests and associated chemical parameters, valid and invalid, shall be reported.
- (2) If any two consecutive Acute Aquatic Toxicity test results or any three Acute Aquatic Toxicity test results within a twelve month period indicate toxicity, the Permittee shall immediately take all reasonable steps to eliminate toxicity wherever possible and in accordance with Section 22a-430-3(j)(10)(c) of the RCSA, **within thirty (30) days**, shall submit a report to [DEEP.WPCF@ct.gov](mailto:DEEP.WPCF@ct.gov) for the review and approval of the Commissioner describing proposed steps to eliminate the toxic impact of the discharge on the receiving water body. Such a report shall include a proposed time schedule to accomplish toxicity reduction and the Permittee shall comply with any schedule approved by the Commissioner.

This permit is hereby issued on

Brian P. Thompson  
Acting Bureau Chief  
Bureau of Water Protection and Land Reuse

**ATTACHMENT 1**

**Tables A through G**

**DRAFT**

## TABLE A – EFFLUENT MONITORING

Discharge Serial Number (DSN): 001-1				Monitoring Location: 1											
Wastewater Description: Sanitary Sewage															
Monitoring Location Description: Final Effluent															
Allocated Zone of Influence (ZOI): 615,347 gph = 22.85 cfs				In-stream Waste Concentration (IWC): 4.59%											
PARAMETER	UNIT	FLOW/TIME BASED MONITORING				INSTANTANEOUS MONITORING			REPORTING FORM	Minimum Level Analysis (See Section 6)					
		Average Monthly Limit	Maximum Daily Limit	Sample Freq.	Sample Type	Instantaneous Limit or Required Range <sup>1</sup>	Sample Freq.	Sample Type							
Alkalinity, Total	mg/L	NA	NA	NR	NA	-----	Monthly	Grab	MOR						
Biochemical Oxygen Demand, 5-day (BOD <sub>5</sub> ) <sup>2</sup>	mg/L	30	50	Weekly	Daily Composite	NA	NR	NA	DMR/MOR						
Carbonaceous Biochemical Oxygen Demand, 5-day (CBOD <sub>5</sub> ) <sup>3</sup>	mg/L	NA	-----	Monthly	Daily Composite	NA	NR	NA	DMR/MOR						
Oxygen, Dissolved	mg/L	NA	NA	NR	NA	-----	Workday	Grab	MOR						
Escherichia coli <sup>4</sup> May 1 <sup>st</sup> – September 30 <sup>th</sup>	Colonies/100 ml	NA	NA	NR	NA	410	Weekly	Grab	DMR/MOR						
Flow <sup>5</sup>	MGD	-----	-----	Daily	Continuous (Metered)	NA	NR	NA	DMR/MOR						
Nitrogen, Ammonia (total as N)	mg/L	NA	-----	Monthly	Daily Composite	NA	NR	NA	DMR/MOR						
Nitrogen, Nitrate (total as N)	mg/L	-----	-----	Monthly	Daily Composite	NA	NR	NA	MOR						
Nitrogen, Nitrite (total as N)	mg/L	-----	-----	Monthly	Daily Composite	NA	NR	NA	MOR						
Nitrogen, Total Kjeldahl	mg/L	-----	-----	Monthly	Daily Composite	NA	NR	NA	MOR						
Nitrogen, Total	mg/L	-----	-----	Monthly	Daily Composite	NA	NR	NA	DMR/MOR						
Nitrogen, Total <sup>6</sup>	lbs/day	-----	-----	Monthly	Daily Composite	NA	NR	NA	DMR/MOR						
pH	S.U.	NA	NA	NR	NA	6.0 – 9.0	Workday	Grab	DMR/MOR						
Phosphate, Ortho April 1 <sup>st</sup> – October 31 <sup>st</sup> November 1 <sup>st</sup> – March 31 <sup>st</sup>	mg/L	----- NA	----- -----	Weekly Monthly	Daily Composite	NA	NR	NA	MOR						

Phosphorus, Total April 1 <sup>st</sup> – October 31 <sup>st</sup> November 1 <sup>st</sup> – March 31 <sup>st</sup>	mg/L	1.55 NA	3.11 -----	Weekly Monthly	Daily Composite	NA	NR	NA	DMR/MOR	*
Phosphorus, Total <sup>7</sup> April 1 <sup>st</sup> – October 31 <sup>st</sup>	lbs/day	-----	-----	Weekly	Daily Composite	NA	NA	NA	DMR/MOR	
Phosphorus, Total (Average Seasonal Load Cap, April 1 <sup>st</sup> – October 31 <sup>st</sup> season) <sup>6, 7</sup>	lbs/day	2.67		End of October	Calculated	NA	NA	NA	DMR/MOR	
Solids, Settleable	ml/l	NA	NA	NR	NA	-----	Workday	Grab	MOR	
Solids, Total Suspended (TSS) <sup>2</sup>	mg/L	30	50	Weekly	Daily Composite	NA	NA	NA	DMR/MOR	
Temperature	°F	NA	NA	NR	NA	-----	Workday	Grab	MOR	
Turbidity	NTU	NA	NA	NR	NA	-----	Workday	Grab	MOR	
UV Intensity <sup>8</sup> May 1 <sup>st</sup> – September 30 <sup>th</sup>	mW/cm <sup>2</sup>	NA	NA	NR	NA	≥6.10	4/Workday	Grab	DMR/MOR	
UV Transmittance <sup>8</sup> May 1 <sup>st</sup> – September 30 <sup>th</sup>	%	NA	NA	NR	NA	-----	Lowest workday reading	Grab	MOR	

**TABLE A – CONDITIONS**

**Footnotes:**

- <sup>1</sup> The instantaneous limits in this column are maximum limits except for UV Intensity, which is a minimum limit.
- <sup>2</sup> The average weekly discharge limitation for BOD<sub>5</sub> and TSS shall be 1.5 times the Average Monthly Limit listed above.
- <sup>3</sup> CBOD<sub>5</sub> testing shall be performed on the same final effluent sample collected for one of the BOD<sub>5</sub> tests.
- <sup>4</sup> The geometric mean of the Escherichia coli bacteria values for the effluent samples collected in a period of a calendar month shall not exceed 126 per 100 milliliters.
- <sup>5</sup> The Permittee shall report on the MOR the minimum instantaneous, maximum instantaneous, and total flow for each day of discharge, as well as the average daily flow for each sampling month. The Permittee shall report on the DMR the average daily flow and maximum daily flow for each sampling month.
- <sup>6</sup> For load reporting in lbs/day, the mg/L concentration values from each sample should be converted using the following equation:  

$$\text{Load (lbs/day)} = \text{Concentration (mg/l)} \times 8.34 \times \text{Total Flow on Day of Sampling (MGD)}$$
- <sup>7</sup> Compliance with the Average Seasonal Load Cap for total phosphorus of 2.67 lbs/day is determined as follows: Calculate the Average Seasonal Load by adding together all Total Phosphorus sample results in lbs/day from the April 1<sup>st</sup> through October 31<sup>st</sup> season and dividing by the total number of samples in that season. This calculated seasonal average shall be reported on the October MOR and DMR.
- <sup>8</sup> Ultraviolet disinfection shall be utilized from May 1<sup>st</sup> through September 30<sup>th</sup>. If continuous monitoring is indicated as the sample type, the Permittee shall report the lowest reading for each day of operation.

## TABLE B – BOD<sub>5</sub> & TSS % - REMOVAL EFFICIENCY MONITORING

Discharge Serial Number (DSN): 001-1	Monitoring Location: K									
Wastewater Description: Sanitary Sewage										
Monitoring Location Description: Final Effluent										
Allocated Zone of Influence (ZOI): 615,347 gph = 22.85 cfs	In-stream Waste Concentration (IWC): 4.59 %									
PARAMETER	UNIT	FLOW/TIME BASED MONITORING			REPORT FORM(S)					
		Average Monthly Minimum Limit	Reporting Freq.	Sample Type						
Biochemical Oxygen Demand, 5-day (BOD <sub>5</sub> ) Percent Removal <sup>1</sup>	% (of Influent)	85	Monthly	Calculated <sup>2</sup>	DMR	Average % Removal				
Solids, Total Suspended (TSS) Percent Removal <sup>1</sup>	% (of Influent)	85	Monthly	Calculated <sup>2</sup>	DMR	Average % Removal				
<b>TABLE B – CONDITIONS</b>										
<b>Footnotes:</b>										
1 The average monthly concentrations of BOD <sub>5</sub> and TSS in the POTW's final effluent shall not exceed 15% of the average monthly concentrations of BOD <sub>5</sub> and TSS in the influent.										
2 Calculated based on the average monthly concentrations of samples collected and analyzed in accordance with Tables A and E:										
$\text{Removal efficiency (\%)} = \frac{(\text{Inf. BOD or TSS}) - (\text{Eff. BOD or TSS})}{\text{Inf. BOD or TSS}} \times 100$										

## TABLE C – ACUTE TOXICITY MONITORING

Discharge Serial Number (DSN): 001-1			Monitoring Location: T							
<b>Wastewater Description:</b> Final Effluent										
<b>Monitoring Location Description:</b> Final Effluent										
<b>Allocated Zone of Influence (ZOI):</b> 615,347 gph = 22.85 cfs				<b>In-stream Waste Concentration (IWC):</b> 4.59 %						
PARAMETER	UNIT	DAILY LIMIT	Sampling Frequency <sup>1</sup>	Sample Type	REPORTING FORM <sup>2</sup>	Minimum Level Analysis See Section 6				
NOAEL Static 48Hr Acute <i>D. pulex</i> <sup>3</sup>	% survival	-----	Quarterly	Daily Composite	ATMR/DMR					
NOAEL Static 48Hr Acute <i>P. promelas</i> <sup>3</sup>	% survival	-----	Quarterly	Daily Composite	ATMR/DMR					
Date of Sample Collection	YYYYMMDD	-----	Quarterly	Recorded	ATMR/DMR					
Flow, Total (on Date of Sample Collection)	MGD	-----	Quarterly	Continuous (Metered)	ATMR/DMR					
Aluminum, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Antimony, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Alkalinity, Total	mg/L	-----	Quarterly	Daily Composite	ATMR/DMR					
Arsenic, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Beryllium, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Biochemical Oxygen Demand, 5-day (BOD <sub>5</sub> )	mg/L	-----	Quarterly	Daily Composite	ATMR/DMR/ MOR					
Cadmium, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Chlorine, Total Residual	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Chromium, Hexavalent	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Chromium, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Copper, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Cyanide, Amenable	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR					
Cyanide, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Hardness, Total	mg/L	-----	Quarterly	Daily Composite	ATMR/DMR					
Iron, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Lead, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Mercury, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Nickel, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				
Nitrogen, Ammonia (total as N)	mg/L	-----	Quarterly	Daily Composite	ATMR/DMR/ MOR					
Nitrogen, Nitrate, (total as N)	mg/L	-----	Quarterly	Daily Composite	ATMR/DMR/ MOR					
Nitrogen, Nitrite, (total as N)	mg/L	-----	Quarterly	Daily Composite	ATMR/DMR/ MOR					
pH	S.U.	-----	Quarterly	Daily Composite	ATMR/DMR					
Phenols, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR					
Phosphorus, Total	mg/L	-----	Quarterly	Daily Composite	ATMR/DMR/ MOR	*				
Selenium, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*				

Silver, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*
Specific Conductance	µMhos/cm	-----	Quarterly	Daily Composite	ATMR/DMR	
Suspended Solids, Total	mg/L	-----	Quarterly	Daily Composite	ATMR/DMR/ MOR	
Thallium, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*
Zinc, Total	µg/L	-----	Quarterly	Daily Composite	ATMR/DMR	*

### TABLE C - CONDITIONS

#### Footnotes:

- <sup>1</sup> Sampling shall be completed in the months of January, April, July, and October. If more than one toxicity sample is collected during a single month (i.e. due to a re-test following a failed or invalid test), report subsequent toxicity and chemistry results on the subsequent month's DMR.
- <sup>2</sup> Results for parameters in this table for which MOR reporting is indicated shall be entered on the MOR and included in the calculations of average monthly concentrations in the effluent.
- <sup>3</sup> The results of the Toxicity Tests are recorded in % survival. The Permittee shall report % survival on the DMR and ATMR based on criteria in Section 6(B) of this permit.

**TABLE D – CHRONIC TOXICITY MONITORING**

<b>Discharge Serial Number (DSN):</b> 001-CT				<b>Monitoring Locations:</b> O = Day 1 Chronic Toxicity Chemical Analyses P = Day 3 Chronic Toxicity Chemical Analyses Q = Day 5 Chronic Toxicity Chemical Analyses R = Day 1 Upstream Monitoring S = Day 3 Upstream Monitoring T = Day 5 Upstream Monitoring Y = Chronic Toxicity Test Results			
<b>Wastewater Description:</b> Final Effluent							
<b>Monitoring Location Description:</b> Final Effluent							
<b>Allocated Zone of Influence (ZOI):</b> 615,347 gph				<b>In-stream Waste Concentration (IWC):</b> 4.59 %			
PARAMETER	UNIT	DAILY LIMIT	Sampling Frequency <sup>1</sup>	Sample Type	REPORTING FORM <sup>2,3</sup>	Minimum Level Analysis See Section 6	Monitoring Locations
Chronic Aquatic Toxicity (Survival) Ceriodaphnia dubia, C-NOEC <sup>3</sup>	%	-----	Annually	Daily Composite	DMR/Chronic Report		Y
Chronic Aquatic Toxicity (Reproduction) Ceriodaphnia dubia, C-NOEC <sup>3</sup>	%	-----	Annually	Daily Composite	DMR/Chronic Report		Y
Chronic Aquatic Toxicity (Survival) Pimephales promelas, C-NOEC <sup>3</sup>	%	-----	Annually	Daily Composite	DMR/Chronic Report		Y
Chronic Aquatic Toxicity (Growth) Pimephales promelas, C-NOEC <sup>3</sup>	%	-----	Annually	Daily Composite	DMR/Chronic Report		Y
Date of Sample Collection	YYYYMMDD	-----	Annually	Recorded	DMR/Chronic Report		O, P, Q; R, S, T
Flow, Total (on Date of Sample Collection)	MGD	-----	Annually	Continuous (Metered)	DMR/Chronic Report		O, P, Q; R, S, T
Aluminum, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Antimony, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Alkalinity, Total	mg/L	-----	Annually	Daily Composite	DMR/Chronic Report		O, P, Q; R, S, T
Arsenic, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Beryllium, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Biochemical Oxygen Demand, 5-day (BOD <sub>5</sub> )	mg/L	-----	Annually	Daily Composite	DMR/MOR/Chronic Report		O, P, Q; R, S, T
Cadmium, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Carbon, Dissolved Organic	mg/L	-----	Annually	Daily Composite	DMR/Chronic Report		O, P, Q; R, S, T

Chlorine, Total Residual	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Chromium, Hexavalent	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Chromium, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Copper, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Cyanide, Amenable	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report		O, P, Q; R, S, T
Cyanide, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Hardness, Total	mg/L	-----	Annually	Daily Composite	DMR/Chronic Report		O, P, Q; R, S, T
Iron, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Lead, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Mercury, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Nickel, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Nitrogen, Ammonia (total as N)	mg/L	-----	Annually	Daily Composite	DMR/MOR/Chronic Report		O, P, Q; R, S, T
Nitrogen, Nitrate, (total as N)	mg/L	-----	Annually	Daily Composite	DMR/MOR/Chronic Report		O, P, Q; R, S, T
Nitrogen, Nitrite, (total as N)	mg/L	-----	Annually	Daily Composite	DMR/MOR/Chronic Report		O, P, Q; R, S, T
pH	S.U.	-----	Annually	Daily Composite	DMR/Chronic Report		O, P, Q; R, S, T
Phenols, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report		O, P, Q; R, S, T
Phosphorus, Total	mg/L	-----	Annually	Daily Composite	DMR/MOR/Chronic Report	*	O, P, Q; R, S, T
Selenium, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Silver, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
Specific Conductance	µMhos/cm	-----	Annually	Daily Composite	DMR/Chronic Report		O, P, Q; R, S, T
Suspended Solids, Total	mg/L	-----	Annually	Daily Composite	DMR/MOR/Chronic Report		O, P, Q; R, S, T
Thallium, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T

Zinc, Total	µg/L	-----	Annually	Daily Composite	DMR/Chronic Report	*	O, P, Q; R, S, T
<b>TABLE D – CONDITIONS</b>							

**Footnotes:**

- <sup>1</sup> Sampling shall be completed during July, August, or September.
- <sup>2</sup> Results for parameters in this table for which MOR reporting is indicated shall be entered on the MOR and included in the calculations of average monthly concentrations in the effluent.
- <sup>3</sup> Chronic toxicity testing shall be conducted in accordance with Section 6(C) of this permit. The C-NOEC (Chronic-No Observed Effect Concentration) results (in %) for the conditions noted in this table shall be reported on the DMR. A complete and thorough report of the results of the chronic toxicity monitoring shall be prepared for each chronic toxicity testing event and submitted consistent with Section 7(C) of this permit.

**TABLE E – INFLUENT MONITORING**

Discharge Serial Number: 001-1			Monitoring Location: G									
<b>Wastewater Description:</b> Raw Sewage Influent												
<b>Monitoring Location Description:</b> Influent												
PARAMETER	UNIT	FLOW/TIME BASED MONITORING		INSTANTANEOUS MONITORING		REPORTING FORM	DMR REPORTING FORMAT					
		Sample Frequency	Sample Type	Sample Frequency	Sample Type							
Biochemical Oxygen Demand, 5-day (BOD <sub>5</sub> )	mg/L	Weekly	Daily Composite	NA	NA	DMR/MOR	Monthly average					
Nitrogen, Ammonia (total as N)	mg/L	Monthly	Daily Composite	NA	NA	MOR	NA					
Nitrogen, Nitrate (total as N)	mg/L	Monthly	Daily Composite	NA	NA	MOR	NA					
Nitrogen, Nitrite (total as N)	mg/L	Monthly	Daily Composite	NA	NA	MOR	NA					
Nitrogen, Total Kjeldahl	mg/L	Monthly	Daily Composite	NA	NA	MOR	NA					
Nitrogen, Total	mg/L	Monthly	Daily Composite	NA	NA	MOR	NA					
Phosphate, Ortho	mg/L	Monthly	Daily Composite	NA	NA	MOR	NA					
Phosphorus, Total	mg/L	Monthly	Daily Composite	NA	NA	MOR	NA					
pH	S.U.	NA	NA	Workday	Grab	MOR	NA					
Solids, Total Suspended (TSS)	mg/L	Weekly	Daily Composite	NA	NA	DMR/MOR	Monthly average					
Temperature	°F	NA	NA	Workday	Grab	MOR	NA					

## TABLE F – PRIMARY EFFLUENT MONITORING

Discharge Serial Number: 001-1			Monitoring Location: F									
Wastewater Description: Primary Effluent												
Monitoring Location Description: Primary Sedimentation Basin Effluent												
PARAMETER	UNIT	REPORTING FORMAT	TIME/FLOW BASED MONITORING		INSTANTANEOUS MONITORING		REPORTING FORM					
			Sample Frequency	Sample Type	Sample Frequency	Sample Type						
Alkalinity, Total	mg/L	NA	NA	NA	Monthly	Grab	MOR					
Biochemical Oxygen Demand, 5-day (BOD <sub>5</sub> )	mg/L	Monthly average	Monthly	Composite	NA	NA	MOR					
Nitrogen, Ammonia (total as N)	mg/L	NA	Monthly	Composite	NA	NA	MOR					
Nitrogen, Nitrate (total as N)	mg/L	NA	Monthly	Composite	NA	NA	MOR					
Nitrogen, Nitrite (total as N)	mg/L	NA	Monthly	Composite	NA	NA	MOR					
Nitrogen, Total Kjeldahl	mg/L	NA	Monthly	Composite	NA	NA	MOR					
Nitrogen, Total	mg/L	NA	Monthly	Composite	NA	NA	MOR					
Phosphate, Ortho	mg/L	NA	Monthly	Composite	NA	NA	MOR					
Phosphorus, Total	mg/L	NA	Monthly	Composite	NA	NA	MOR					
pH	S.U.	NA	NA	NA	Monthly	Grab	MOR					
Solids, Total Suspended (TSS)	mg/L	Monthly average	Monthly	Composite	NA	NA	MOR					

## TABLE G – AERATION BASIN MONITORING

Discharge Serial Number: 001-1		Monitoring Location: N							
Wastewater Description: Aeration Unit									
Monitoring Location Description: Each Aeration Unit									
PARAMETER	UNIT	INSTANTANEOUS MONITORING		REPORTING FORM	REPORTING FORMAT				
		Sample Frequency	Sample Type						
Oxygen, Dissolved	mg/L	4/Workday	Grab	MOR	High & Low for each workday				
Sludge Volume Index	mL/g	Workday	Grab	MOR	Workday				
Mixed Liquor Suspended Solids	mg/L	Workday	Grab	MOR	Workday				

## TABLE G – SLUDGE MONITORING

Discharge Serial Number: 001-1		Monitoring Location: SL					
Wastewater Description: Liquid Sludge							
Monitoring Location Description: At Sludge Draw-off							
PARAMETER	UNIT	INSTANTANEOUS MONITORING		REPORTING FORM			
		Sample Frequency	Sample Type				
Arsenic, Total	mg/kg	Semi-annually	Grab	DMR			
Beryllium, Total	mg/kg	Semi-annually	Grab	DMR			
Cadmium, Total	mg/kg	Semi-annually	Grab	DMR			
Chromium, Total	mg/kg	Semi-annually	Grab	DMR			
Copper, Total	mg/kg	Semi-annually	Grab	DMR			
Lead, Total	mg/kg	Semi-annually	Grab	DMR			
Mercury, Total	mg/kg	Semi-annually	Grab	DMR			
Nickel, Total	mg/kg	Semi-annually	Grab	DMR			
Polychlorinated Biphenyls	mg/kg	Semi-annually	Grab	DMR			
Solids, Fixed	%	Semi-annually	Grab	DMR			
Solids, Total	%	Semi-annually	Grab	DMR			
Solids, Volatile	%	Semi-annually	Grab	DMR			
Zinc, Total	mg/kg	Semi-annually	Grab	DMR			
Testing for inorganic pollutants shall follow "Test Methods for Evaluating Solid Waste, Physical/Chemical Methods", EPA Publication SW-846 as updated and/or revised.							

**ATTACHMENT 2**

**MONTHLY OPERATING REPORT (MOR) FORM**