

Connecticut DEEP Public Record - Summary Information
Underground Storage Tanks (USTs)

General Information

Public Record Reporting Period: 2024

Total Number Of UST Facilities: 1835
Total Number Of USTs: 5034

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 863
Inspection Period Dates: 10-1-23 To: 9-30-24
Percent Compliance (Combined Measure): 89%

[NOTE: TANK, FACILITY, AND ON-SITE INSPECTION INFORMATION IS BASED ON INSPECTIONS OF UST FACILITIES REGULATED UNDER SECTION 22a-449(d)-101 THROUGH 113 ONLY; HEATING OIL USTs ARE NOT INCLUDED. ON-SITE INSPECTIONS MEASURE COMPLIANCE WITH STATE OF CONNECTICUT AND U.S. EPA REGULATIONS AND LAWS GOVERNING THE PREVENTION AND DETECTION OF PETROLEUM RELEASES OR DISCHARGES.]

Summary Information For Releases

Number Of Confirmed UST Releases: 54
Release Reporting Period Dates: October 1, 2023 To: September 30, 2024

Summary Information For Release Sources And Causes

SOURCE			CAUSE													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	4	7					2	50	2	50						
Piping	2	4													2	100
Dispenser	4	7													4	100
STP*																
Delivery Problem	1	2			1	10										
Other																
Unknown**	43	80													43	100
Totals	54	100	0		1	2	2	4	2	4	0	0	0	0	49	91

= number of release per source and/or cause, source % = percent of total number of releases, cause % = percent of total number of releases per source

*STP means Submersible Turbine Pump

**Unknown indicates releases where the exact source was not able to be determined (i.e. historic releases)

[NOTE: RELEASE, SOURCE AND CAUSE INFORMATION IS BASED ON REPORTED RELEASES AT UST FACILITIES REGULATED UNDER SECTION 22a-449(d)-101 THROUGH 113. SOURCE AND CAUSE DATA WERE COMPILED FROM DATA RECEIVED DURING THE INVESTIGATION AND REMEDIATION OF UST SYSTEM RELEASES AND RECORDED IN THE DEEP'S CASE MANAGEMENT SYSTEM.]

To obtain site-specific UST information on compliance and releases or information on this page, please contact the Licensing and Enforcement Unit at (860) 424-3374 or e-mail DEEP.USTenforcement@ct.gov or write to:

Department of Energy and Environmental Protection
Bureau of Materials Management and Compliance Assurance
Licensing and Enforcement Unit
79 Elm Street
Hartford, CT 06106-5127

Last Updated 12/17/2024