

Connecticut DEEP Public Record - Summary Information Underground Storage Tanks (USTs)

General Information

Public Record Reporting Period: 2025

Total Number Of UST Facilities: 1820

Total Number Of USTs: 4995

Summary Information For On-Site Inspections

Number Of UST Facilities Inspected: 875

Inspection Period Dates: 10-1-24 To: 9-30-25

Percent Compliance (Combined Measure): 95%

[NOTE: TANK, FACILITY, AND ON-SITE INSPECTION INFORMATION IS BASED ON INSPECTIONS OF UST FACILITIES REGULATED UNDER [SECTION 22a-449\(d\)-101 THROUGH 114 ONLY OF THE REGULATIONS OF CONNECTICUT STATE AGENCIES \("RCSA"\)](#); HEATING OIL USTs ARE NOT INCLUDED. ON-SITE INSPECTIONS MEASURE COMPLIANCE WITH STATE OF CONNECTICUT AND U.S. EPA REGULATIONS AND LAWS GOVERNING THE PREVENTION AND DETECTION OF PETROLEUM RELEASES OR DISCHARGES.]

Summary Information For Releases

Number Of Confirmed UST Releases: 52

Release Reporting Period Dates: October 1, 2024 To: September 30, 2025

Summary Information For Release Sources And Causes

SOURCE			CAUSE													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
#	%	#	%	#	%	#	%	#	%	#	%	#	%	#	%	
Tank	8	15	1	13			1	13	2	25					4	50
Piping	2	4					1	50							1	50
Dispenser	6	12	1	16			2	33							3	50
STP*																
Delivery Problem	3	6			2	67									1	33
Other	1	2					1	100								
Unknown**	32	62													32	100
Totals	52	100	2	4	2	4	5	10	2	4	0	0	0	0	41	79

= number of releases per source and/or cause, source % = percent of total number of releases, cause % = percent of total number of releases per source

*STP means Submersible Turbine Pump

**Unknown indicates releases where the exact source was not able to be determined (i.e. historic releases)

[NOTE: RELEASE, SOURCE AND CAUSE INFORMATION IS BASED ON REPORTED RELEASES AT UST FACILITIES REGULATED UNDER [RCSA SECTION 22a-449\(d\)-101 THROUGH 114](#). SOURCE AND CAUSE DATA WERE COMPILED FROM DATA RECEIVED DURING THE INVESTIGATION AND REMEDIATION OF UST SYSTEM RELEASES AND RECORDED IN THE DEEP'S CASE MANAGEMENT SYSTEM.]

To obtain site-specific UST information on compliance and releases or information on this page, please contact the Licensing and Enforcement Unit at (860) 424-3374, by e-mail to DEEP.USTenforcement@ct.gov or write to:

Department of Energy and Environmental Protection
Bureau of Materials Management and Compliance Assurance
Emergency Response and Spill Prevention Division
Licensing and Enforcement Unit
79 Elm Street
Hartford, CT 06106-5127

Last Updated 12/19/2025