

**General Pretreatment Permit for Non-Significant Industrial User Discharges to
Publicly Owned Treatment Works**

Appendix F

Vehicle Maintenance Wastewater Treatment System Inspection & Clean Out Log

Purpose: The following is the inspection and clean out log

Date	Inspector			Separator Measurements			Separator Maintenance		
	Name	Title	Signature	Sand ¹ [inches]	Oil & Grease ¹ [inches]	Working Depth ² [inches]	Clean-out ¹ Date	Clean-out ¹ Contractor	Other
/ /							/ /		
/ /							/ /		
/ /							/ /		
/ /							/ /		
/ /							/ /		
/ /							/ /		
/ /							/ /		
/ /							/ /		
/ /							/ /		

1 The separator shall be completely cleaned by a certified waste transporter as often as necessary to assure that the separator continues to operate effectively and efficiently. The quantity of oil, grease and grit located within the separator at any time shall not exceed twenty percent of the distance between the separator base and static liquid level.

2 The working depth is the distance between the separator base and static liquid level.