

- Revised Total Coliform Rule - Level 2 Assessor Training

Overview of Level 2 Assessment Form



Vicky Carrier, P.E., Sanitary Engineer 3

John Czaja, Sanitary Engineer 3

William Sullivan, Sanitary Engineer 3

Steve Wallett, Environmental Sanitarian

CT DPH – Drinking Water Section

Agenda

- System Information
- General Questions
- Operational Changes
- Sampling Site
- Sampling Protocol
- Sources
- Treatment Facility
- Storage Facilities
- Distribution



System Information



STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

Revised Total Coliform Rule Level 2 Assessment Form

PWS ID#: CT	PWS Name:	Town:
System Type: CWS <input type="radio"/> NTNC <input type="radio"/> TNC <input type="radio"/>	Date Assessment Form Completed: <i>This form must be completed and returned no later than 30 days after the Assessment Trigger Date.</i>	
Assessment Trigger Date:		
Assessment Trigger:	<input type="checkbox"/> <i>E. coli</i> MCL violation <input type="checkbox"/> Second Level 1 Assessment in a rolling 12-month period <input type="checkbox"/> Voluntary Level 2 Assessment	
Instructions: <i>Review and evaluate all of the elements for possible sanitary defects. Indicate Yes or No if any sanitary defects are identified or N/A if the element is not applicable to the water system. All sections of this form must be completed. If a potential sanitary defect is identified, provide a description of the defect along with the actions taken or proposed to correct the defect. Indicate the date that the corrective action was completed or the proposed corrective action date if not yet corrected. Use the space provided following each section to provide more detail if needed. Please attach additional pages and include any supporting documentation where necessary.</i>		

General Questions

1	General Questions	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/Proposed
1.1	Are there any unresolved significant deficiencies from the last CT DPH Sanitary Survey?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
1.2	Are there any unresolved sanitary defects identified in prior Level 1 or 2 Assessments?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
1.3	Have there been any community illnesses suspected of being waterborne? (e.g., Do community public health officials indicate that an outbreak has occurred?)	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
1.4	Have there been any visible or physical indicators of unsanitary conditions?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
1.5	Have there been any signs of vandalism or forced entry to water system components or facilities?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
1.6	Have there been any other water quality issues within distribution or plumbing systems (color, turbidity, taste, and odor)?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
1.7	Have there been any fire-fighting events, flushing activities, water main breaks or service line breaks which may have contributed to the bacteriological contamination?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		



General Questions

1.1- Are there any unresolved significant deficiencies from the last CT DPH Sanitary Survey?

1.2- Have all sanitary defects identified in any prior Level 1 or 2 Assessments been corrected?

STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

Jewel Mullon, M.D., M.P.H., M.P.A.
Commissioner

Dannel P. Malley
Governor
Nancy Wyman
Lt. Governor

November 30, 2015

Mr. Jack R. Braverman
Lynnwood Place LLC
C/O Braverman Group
P.O. Box 431
Westport, CT 06881-0431

PUBLIC WATER SYSTEM: Rocky Glen Mill
75 Glen Road, Newton

CLASSIFICATION TYPE: Non-Transient Non-C
PWSID: CT0979113

SUBJECT: SANITARY SURVEY REPORT

Dear Mr. Braverman:

I performed a sanitary survey of the public water system with Will Freeborn of Foley's Pump Service. This is B102(a)(7)(E) of the Regulations of Connecticut State review of the water source, treatment, distribution system controls, monitoring and reporting data, system manager the Department of Public Health (DPH) requirements.

Sanitary Survey Report Response Requirements:

No later than December 30, 2015 (per RCSA written plan to correct all significant deficiencies I written response must also address all minor information, and as needed, address any recommen

A response to Significant Deficiencies (Broken w was due no later than March 30 2016 (per RCS however Mr. Braverman emailed photos of the November 23, 2015 for work completed the previo

Attached is a Sanitary Survey Response Form that you and accurate response to this department. Please rems completion of all corrective actions. If no written resg minor deficiencies, and additional information requir may be initiated.

Phone: (860) 509-7333 • Fax: (860) 410 Capitol Avenue, MS#01 Hartford, Connecticut www.ct.gov
Affirmative Action/Equal

Sanitary Survey Report
CT0979113
November 30, 2015
Page 2

SYSTEM DESCRIPTION:

This water system is served by two drilled wells. Well#1 is located near a propane tank and a restaurant entrance, fairly close to the curb. Well#2 is located in the same general area further up in a lawn area. The septic is reportedly located under the parking lot, adjacent to the river. The well discharge lines appear to combine outside the building before they enter two 500-gallon poly atmospheric tanks that are manifolded together. A continuous chlorinator (paced to flow) injects chlorine prior to the two tanks and then to single transfer pump to pressurized storage (several larger pressure tanks and a bank of Well-X-Trol tanks). The building is a large brick structure housing many offices and a restaurant. Chlorine residuals were about 1.8 mg/L for readings taken thus far in November.

SURVEY FINDINGS:

A) **Significant Deficiencies**

Section 19-13-B102(a)(104) of the RCSA defines a significant deficiency as any situation, practice, or condition in a public water system with respect to design, operation, maintenance, or administration that the department determines to be causing, or has the potential for causing, risks to health or safety of the public served by the system. Please note that all significant deficiencies must be corrected or the system must be in compliance with a department-approved corrective action plan within 120 days of the date of this report in accordance with B102(a)(14)(A)(v) of the RCSA.

Significant Deficiencies	Observed Condition and Corrective Action Options
1. Equipment, piping or appurtenances, including well caps, are not joined watertight to the well casing (S006)	Observed Condition: Well #1 had ✓ a broken/cracked cap. Corrective Action Options: The well cap was replaced on November 20, 2015 - see photo at end of report.
2. The wellhead is susceptible to vehicle traffic and is not adequately protected from physical damage with bollards or other protective measures. (S015)	Observed Condition: Well #1 was in a location where it may be severely damaged by vehicle traffic, snow plowing or other vehicle activities. Corrective Action Options: Bollards were installed on November 20, 2015 - see photo at the end of the report.

B) **Minor Deficiencies**

Minor deficiencies are defined as all other violations of the RCSA that have not been designated as significant.

Minor Deficiencies	Observed Condition and Corrective Action Options
1. A tap shall be provided to sample water directly from each individual source of supply. The sample tap shall be located	Observed Condition: Only one sampling tap could be located therefore it appears that the two well discharge lines combine outside the building.

STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

Revised Total Coliform Rule Level 1 Assessment Form

PWS ID#: CT PWS Name: Town:

System Type: CWS NTNC TNCC Date Assessment Form Completed: This form must be completed and returned no later than 30 days after the Assessment Trigger Date.

Assessment Trigger Date: For a system collecting at least 40 samples per month, more than 5.0% of samples collected are TC+
 For a system collecting fewer than 40 samples per month, two or more samples are TC+
 The PWS fails to take every required repeat sample after any single routine TC+

NOTE: If this is the second Level 1 treatment technique trigger within the past 12-month rolling period, the system is required to perform a Level 2 Assessment.

Instructions: Review and evaluate all of the elements for possible sanitary defects. Indicate Yes or No if any sanitary defects are identified or N/A if the element is not applicable to the water system. All sections of this form must be completed. If a sanitary defect is identified, provide a description of the defect along with the actions taken or proposed to correct the defect. Indicate the date that the corrective action was completed or the proposed corrective action date if not yet corrected. If additional space is needed, please attach additional pages and include any supporting documentation.

1 General Questions	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/Proposed
1.1 Have there been any visible or physical indicators of unsanitary conditions?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
1.2 Have there been any signs of vandalism or forced entry?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
1.3 Have there been any other water quality issues within the distribution or plumbing systems (i.e. color, turbidity, taste, and odor)?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
2 Operational Changes	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/Proposed
2.1 Has there been any other source of supply used or placed into operation that is not normally used?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
2.2 Have there been any general repairs, operational changes or maintenance activities on the water system?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
2.3 Was there a failure to follow adequate disinfection practices following any repairs or maintenance activities on the system?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		

Rev 03/2016 Page 1 of 6 RTCR Level1 Assessment Form

General Questions

1.3- Have there been any community illnesses suspected of being waterborne (e.g., Does the community public health official indicate that an outbreak has occurred)?

1.4- Have there been any visible or physical indicators of unsanitary conditions?



General Questions

1.5- Have there been any signs of vandalism or forced entry to water system components or facilities?



1.6- Have there been any other water quality issues within distribution or plumbing systems (color, turbidity, taste, and odor)?



General Questions

1.7- Has there been a fire fighting events, flushing activities, water main breaks, etc.?



Operational Changes

PWS ID#: CT		PWS Name:		Town:	
2	Operational Changes	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/Proposed	
2.1	Has there been any other source of supply used or placed into operation that is not normally used?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A			
2.2	Have there been any general repairs, operational changes or maintenance activities on the water system?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A			
2.3	Was there a failure to follow adequate disinfection practices following any repairs or maintenance activities on the system?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A			
2.4	If this is a seasonal system, were there any problems during the most recent start-up procedure?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A			

Operational Changes

2.1- Have there been any wells or other sources used or placed into operation which is not normally used?



Operational Changes

2.2- Have there been any general repairs, operational changes or maintenance activities on the water system?



Operational Changes

2.3- Was there a failure to follow adequate disinfection practices following any repairs or maintenance activities on the system

DEPARTMENT OF PUBLIC HEALTH
Drinking Water Section

Disinfection of a Well Water Supply

Introduction
All new or repaired wells should be disinfected prior to use of the water system. A water system should also be disinfected following plumbing repairs or modifications, as internal piping may have been exposed to contamination.

In case of a new well, it is helpful that there be coordination between the well driller and pump installer and the contractor/plumber if applicable. In this way, the disinfection can be combined with pressure and leakage tests of the entire water system, and the required bacteriological test for assuring safety of the drinking water supply can be performed at the same time. The chance of contamination is less likely to occur if there is no long delay between the time the well is drilled and the time the pump/installer completes the connection from the well to the house plumbing along with the disinfection treatment.

Prior to disinfection, it is expected that the entire well and piping system has been running clear and clean - purged of any sediment, foreign matter, or other materials (due to incomplete development, unsanitary construction, or long idleness of the well). These substances react with the chlorine and decrease its effectiveness in destroying harmful bacteria and organic materials.

Application

1. Prepare a chlorine solution by mixing the required amount of chlorine to about 10 gallons of water. For effective disinfection, a minimum of 50 parts per million (ppm) chlorine dosage is needed. See Tables 1 and 2 and "Examples" for exact amount of chlorine compound needed to produce the required 50 ppm dosage. Note: For a typical 8" well of about 100'-100' depth, use approximately one (1) 70% available chlorine granules (HTH) or 1.0 quart of unscented household 8.25% bleach (Clorox or equivalent).
2. Pour the 10 gallons solution down the well casing.
3. Open each faucet and tap individually in the plumbing system until the chlorine odor is noticed, then close the taps. During this time, it is important that all parts of the water systems come in contact with this chlorinated water. This includes, but is not limited to: hot water heaters, washing machines, dishwashers, tubs, shower heads, and hydrants and finally urinals and water closets. This should be repeated on all outbuildings connected to the water system. If there are large non-pressure or pressure storage tanks (such as used in community well supply) on the water system, they should be temporarily water-tight to assure that all water contact surfaces

1 | Page Disinfection of a Well Water Supply

are chlorinated adequately. All piping should be inspected for dead ends. All dead-end piping should be removed, looped or valved off. This allows for both the flushing of stagnant water and the chlorine solution to be introduced. Dead-end piping can harbor bacteria. Chlorine will also not enter the piping, unless water flows through it.

4. With the use of a food grade hose connected to a nearby sill cock, recirculate some of the chlorinated water back down and along the interior of the well casing to dilute the initial concentrated solution. (The initial chlorine solution may affect the integrity of the concrete grout, such as between the tile sections of a dug well).
5. Install or replace the watertight well cap on the well casing so that the system cannot be subsequently contaminated. If the existing well is located in a well pit, this is an opportunity to bring the well into compliance with Public Health Code 19-13-851. Please refer to the Well Casing Extension Guidance Document on our website for more information.
6. Allow the chlorinated water to stand idle in the well and piping system for at least three hours. It is preferable to allow the solution to remain in the system overnight.
7. With the well pumping, flush the chlorinated water from the system through the stagnant end and taps. An outside sill cock may be used to flush the water to waste; however care should be taken to avoid contact of chlorinated water with the grass, shrubbery, streams, brooks, etc. (in a small well supply, it may take a few days to remove all of the chlorine from the system). **DO NOT OVER-TAX A LOW-YIELDING WELL.**

Drilled vs. Dug Wells:
Most homeowner wells are either drilled or hand dug. In the case of a drilled well, the steel casing should extend a minimum of six inches above the established grade. It should also be outfitted with a certified watertight well cap with screened vent, as is specified in PHC 19-13-851 (g)(5). The following web site lists all approved watertight well caps in the State of Connecticut:
<http://www.waterresources.com/ct/water/wellcaps.htm> An existing well pit should be eliminated and the well casing raised to a minimum of six inches above established grade. The above listed Well Casing Extension Guidance Document should be referred to for specifications.

Dug wells are generally "high risk" because they are typically not constructed watertight, allowing the entrance of surface water, insects and rodents. Dug wells must be inspected and repaired prior to disinfection. They should be tightly sealed after chlorination. Serious consideration should be given to connecting to a public water supply, if available. If this is not possible, a properly constructed drilled well should be considered.

Bacteriological Test:
Before the required water sample is taken, it is very important that there be no trace of chlorine left in the water supply. A desirable and precise method to determine the complete absence of chlorine in the water is to use a chlorine residual test kit.

Once the chlorine is absent from the water system, a sample is collected in a sterile bottle furnished by, and to be analyzed at, a state-approved laboratory. The collection of the sample should be done with

2 | Page Disinfection of a Well Water Supply

cars, following the instructions of the laboratory. The sample should be collected from a tap that is representative of water in the distribution system. It is recommended to have either a certified operator or a laboratory technician collect the sample. The effectiveness of the disinfection and safety of the water supply for drinking purposes is shown if the test report results an absence of coliform bacteria. Note: If the test is found positive for coliform bacteria, a re-sample should be taken to confirm the first test. Occasional positive tests result from improper sampling technique or other chance contamination. If the re-sample test is again unsatisfactory, the disinfecting and sampling should be repeated.

TABLE 1
VOLUME OF WATER PER FOOT OF PIPE

Pipe Diameter	Gal./ft. Of Pipe	Pipe Diameter	Gal./ft. Of Pipe
2 1/2"	0.254	24"	23.4
4"	0.972	30"	36.6
6"	1.47	36"	52.6
8"	2.61	42"	71.6
10"	4.08	48"	93.6
12"	5.66	54"	119.0
16"	10.45	60"	146.0
18"	13.20	72"	211.0

TABLE 2
TABLE OF DOSAGE OF DISINFECTANT FOR VARIOUS VOLUMES OF WATER APPROXIMATE CHLORINE DOSAGE TO PRODUCE 50 PPM AVAILABLE CHLORINE

Volume of Water (Gallons)	Dry Calcium Hypochlorite HTH, Fenchlorox, or Similar Compound (70% Available Chlorine)	No. Of 5 Gram HTH Tablets (70% of Available Chlorine)	Liquid 8.25% Sodium Hypochlorite Clorox or Similar Household Bleach (8.25 - Available Chlorine)
50	0.5 oz.	3	4.8 fl. oz.
100	1.0 oz.	6	9.6 fl. oz.
150	1.5 oz.	9	14.4 fl. oz.
200	2.0 oz.	12	19.2 fl. oz.
300	3.0 oz.	17	28.8 fl. oz.
500	5.0 oz.	28	48.0 fl. oz.
1,000	10.0 oz.	56	96.0 fl. oz.
2,000	1 lb. 3 oz.		1.5 gallons
3,000	1 lb. 13 oz.		2.25 gallons
4,000	2 lbs. 7 oz.		3 gallons
5,000	3 lbs.		3.75 gallons
10,000	6 lbs.		
25,000	15 lbs.		(1 quart = 32 fl.oz)
50,000	30 lbs.		(1 gallon = 4 quarts)
100,000	60 lbs.		

3 | Page Disinfection of a Well Water Supply

Example A
Given: 6" drilled well, Depth - 500'
Calculations: (from Table 1) - 500 feet x 1.47 gallons per foot = 735 gallons of water to be disinfected
Dosage Required: 50 ppm Chlorine
Use: (from Table 2) - 7.5 oz. of 70% HTH or similar compound; (or) 42 HTH tablets (5 grams each); (or) approximately 2.2 quarts Clorox or similar household bleach.

Example B:
Given: 36" dug well, depth-20'
Calculations: (from Table 1) - 20 feet x 52.6 gallons per foot = 1052 gallons of water to be disinfected.
Dosage Required: 50 ppm chlorine
Use: (from Table 2) - 10 oz. of 70% HTH or similar compound; (or) 56 HTH tablets (5 grams each); (or) approximately 2.2 quarts Clorox or similar household bleach.

Example C:
Given: Community well water supply, with same well as in "Example B" (1052 gallons); and, 1-10,000 gallon non-pressure tank, and, 1-5,000 gallon pressure tank.
Calculations: Total volume to be disinfected = 1052 gallons + 10,000 gallons + 5,000 gallons = 16,052 gallons
Dosage Required: 50 ppm chlorine
Use: (from Table 2) 9 lbs. 10 oz. of 70% HTH or similar compound
NOTE: In a case where such a large concentration of chlorine is required, it is suggested that the dosage applied at the well be staggered

4 | Page Disinfection of a Well Water Supply

Sampling Sites and Protocols

💧 Sections 3 and 4

💧 Sampling Sites and Protocols

3	Sampling Sites	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/Proposed
3.1	Does the area surrounding each sampling tap appear to be unsanitary?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
3.2	Are there sampling taps that are not routinely used or not identified in the system's Sampling Site Plan?	<input type="radio"/> Y <input type="radio"/> N		
4	Sampling Protocol	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/Proposed
4.1	Was the sample taken in an improper sample container?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
4.2	Were there any sampling or handling errors (i.e. human error)?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
4.3	Were any of the sampling locations equipped with an auto sensing, swivel-or single-spout type faucet?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
4.4	Were there any sample holding time or storage temperature exceedances?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
4.5	Did the laboratory report any testing errors?	<input type="radio"/> Y <input type="radio"/> N		

Sampling Sites and Protocols

- 💧 Sections 3 and 4
- 💧 Sampling Sites and Protocols

“This section of the assessment is designed to determine whether water samples could have been contaminated during the sample collection or processing, resulting in total coliform or *E. coli*-positive samples. In that case, the positive results may not indicate a distribution system problem but rather a sampling problem” .

Proposed Revised Total Coliform Rule Assessments and Corrective Actions Guidance Manual (Proposed RTCR A/CA GM).

Sampling Sites and Protocols

- The evaluation of the sample site(s) with the positive sample(s) and the sampling protocol would be performed in a similar manner for systems of all sizes and types. Because the sample site(s) is/are a key indicator of whether the problem is system-wide or localized, the assessment would be similar for both a Level 1 and Level 2 assessment, and would include a field visit to inspect the sample location(s) or a detailed discussion with the sample collector to determine the conditions at the sample site(s).

(Proposed RTCR A/CA GM).

Sampling Sites and Protocols

Some of the common items to evaluate at the sample site(s) include:

- 💧 Cleanliness and suitability of the sample tap and sink
- 💧 Potential for hot water to enter the sample through the tap
- 💧 Conditions that may have changed at the sample site since the last sample collection

Sampling Sites and Protocols

In addition to sample tap contamination, it is possible that elements of the sampling protocol that were not followed closely could result in contamination of the sample. Elements of the sampling protocol may include:

- ☉ Removal of the tap aerator
- ☉ Adequate flushing of the tap prior to sample collection
- ☉ Proper storage and preparation of the sampling container
- ☉ Correct storage, preservation, and handling of sample(s) during transport to the laboratory
- ☉ Compliance with holding time and temperature requirements
- ☉ Finally, this evaluation should include a discussion with the laboratory, either in-house or externally, to determine if all laboratory quality checks were performed with satisfactory results.

Sampling Sites and Protocols

- Three Best Management Practices to minimize water quality problems associated with Sampling Sites and Protocols:



Sampling Sites and Protocols

- 💧 Three Best Management Practices to minimize water quality problems associated with Sampling Sites and Protocols:
- 💧 Follow your DPH approved Sampling Site Plan,

Sampling Sites and Protocols

- 💧 Three Best Management Practices to minimize water quality problems associated with Sampling Sites and Protocols:
- 💧 Follow your DPH approved Sampling Site Plan,
- 💧 Follow the appropriate sampling guidelines

Sampling Sites and Protocols

- 💧 Three Best Management Practices to minimize water quality problems associated with Sampling Sites and Protocols:
- 💧 Follow your DPH approved Sampling Site Plan,
- 💧 Follow the appropriate sampling guidelines,
- 💧 Maintain effective communication with your laboratory, local health personnel, and the DPH DWS

Sampling Sites

Section 3

3 Sampling Sites		See Sampling Site Plan Guidance
3.1	Does the area surrounding each sampling tap appear to be unsanitary?	Determine if the taps used for the compliance monitoring are clean and in sanitary condition. Slop sink taps, taps in dirty condition, etc. may result in bacteriological contaminated samples.
3.2	Are there sampling taps that are not routinely used or not identified in the system's Sampling Site Plan?	Determine that the sampling taps are from locations where water is used on a routine basis and from locations identified in your DPH approved Sampling Site Plan. A tap that is not used on a routine basis may result in bacteriological contaminated samples, and a system is required to collect samples from approved sites.

- (RTCR) - Total coliform samples must be collected at sites which are representative of water quality throughout the distribution system according to a written sample siting plan subject to State review and revision.

Sampling Taps



Sampling Protocol

Section 4

4 Sampling Protocol		In answering the following questions consult with the laboratory that conducted the analysis and/or sample collector(s).
4.1	Was the sample taken in an improper sample container?	Verify that the sample containers were sterile and of the appropriate size or type for bacteriological sampling.
4.2	Were there any sampling or handling errors (i.e. human error)?	Review chain-of-custody records and lab compliance reports to verify that samples containers were properly collected, handled and stored prior to, during or after sampling. This may include the removal of aerator, flushing or other procedure as a specific laboratory may conduct or require.
4.3	Were any of the sampling locations equipped with an auto sensing, swivel-or single-spout type faucet?	Determine if these type faucets were used. These types of faucets should not be used as sampling locations since hot water flows through the faucet or may leak and blend with the cold water, and hot water may contain bacteria.
4.4	Were there any sample holding time or storage temperature exceedances?	Review chain-of-custody records and lab compliance reports to verify that samples did not exceed allowed sample holding times and that the samples were stored properly at all times prior to analysis.
4.5	Did the laboratory report any testing errors?	Review chain-of-custody records and lab compliance reports to verify that samples were analyzed in accordance with applicable methods.
4.6	Was there a failure to follow appropriate collection procedures when samples were collected?	Verify that proper sample collection procedures were followed prior to sample collection. This may include the removal of aerator, flushing or other procedure that a specific laboratory analysis method requires.
4.7	Have there been any special samples taken from a water treatment plant, well, tank or distribution system as part of the investigation that have confirmed the bacteriological contamination?	Review the results of any special samples taken (those not used for compliance) during the investigation and determine if any indicated the presence of bacteria. Detections may help identify where areas where the bacteriological contamination may be coming from. A summary of these special sample test results should be provided as supporting documentation where applicable.

Sampling Protocol

4.1

Laboratory Methods can determine the type of bottle required. Work with lab to verify correct type.

Analysis Report

FOR:

December 26, 2013

Sample Information

Matrix: DRINKING WATER
 Location Code: [REDACTED]
 Rush Request: Standard
 P.O.#:

Custody Information

Collected by: [REDACTED]
 Received by: SW
 Analyzed by: see "By" below

Date Time
 12/20/13 11:45
 12/20/13 13:24

Laboratory Data

SDG ID: GBF91304
 [REDACTED] BF91304

Project ID: [REDACTED]
 Client ID:

Parameter	Result	RL/ PQL	Units	DW MCL	Sec Goal	Date/Time	By	Reference
Escherichia Coli	0	0	MPN/100 mls	0		12/20/13 15:35	CB/KDB	SM 9223B
Total Coliforms	0	0	MPN/100 mls	0		12/20/13 15:35	CB/KDB	9223B
Hardness (CaCO3)	42.4	0.1	mg/L			12/24/13		E200.7
Alkalinity-CaCO3	42	20	mg/L			12/21/13	BS/EG	SM 2320B
Color	< 1	1	Color Units		15	12/20/13 19:00	DH/KDB	SM 2120B
Nitrite as Nitrogen	< 0.01	0.01	mg/L	1		12/20/13 22:49	BS/EG	300.0
Nitrate as Nitrogen	< 0.05	0.05	mg/L	10		12/20/13 22:49	BS/EG	300.0
Odor at Room Temperature	< 1	1	T.O.N.		3	12/20/13 19:00	DH/KDB	SM 2150B
pH	7.50	0.10	pH Units		6.5-8.5	12/21/13 04:43	BS/EG	4500-H B
Turbidity	1.24	0.20	NTU		5	12/20/13 18:33	Z	SM2130B
Iron	2.19	0.005	mg/L		0.3	12/24/13	LK	E200.7
*** Iron exceeds Secondary Goal ***								
Manganese	0.068	0.002	mg/L		0.05	12/24/13	LK	E200.7
*** Manganese exceeds Secondary Goal ***								
Total Metal Digestion	Completed					12/23/13	TH	E200.7

Sampling Protocol

4.2

Laboratory Reports will have information on sampling or testing errors.

Project ID: [REDACTED]

Client ID: [REDACTED]

Parameter	Result	RL/ PQL	Units	DW MCL	Sec Goal	Date/Time	By	Reference
-----------	--------	------------	-------	-----------	-------------	-----------	----	-----------

RL/PQL=Reporting/Practical Quantitation Level ND=Not Detected BRL=Below Reporting Level (less than the reporting level, the lowest amount the laboratory can detect and report.) MCL = Maximum Contaminant Level MCLG = Maximum Contaminant Level Goal

Comments:

Maximum Contaminant Level (Lower of): 40 CFR Part 141; CT Public Health Code 19-13-B102. The highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

Secondary DW Maximum Contaminant Level Goal (MCLG): (Lower of): 40 CFR Part 143; CT Public Health Code 19-13-B102. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are non-enforceable public health goals.

The regulatory hold time for pH is immediately. This pH was performed in the laboratory and may be considered outside of hold-time.

Sampling Protocol

💧 4.3

Review your
Sampling
Site Plan
and verify
appropriate
locations.





Sampling Protocol

4.4

Laboratory Chain of Custody will have information on sample condition at time of receipt.

CHAIN OF CUSTODY RECORD					Cooler: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Temp: <u>8</u> °C Pg. <u>1</u> of <u>1</u>					Contact Options:	
Project: <u>Water Quality</u>					Project P.O.:	
Report to:					Fax: _____	
Invoice to:					Phone: _____	
					Email: _____	
					This section MUST be completed with Bottle Quantities.	
Client Sample - Information - Identification			Analysis Request			
Sampler's Signature: _____ Date: _____			TC DW pH Alkalinity			
Matrix Code: DW=Drinking Water GW=Ground Water SW=Surface Water WW=Waste Water RW=Raw Water SE=Sediment SL=Sludge S=Soil SD=Solid W=Wipe OIL=Oil B=Bulk L=Liquid						
PHOENIX USE ONLY	Customer Sample Identification	Sample Matrix	Date Sampled	Time Sampled	Soil VOC Vials (1 methanol) (1 H ₂ O)	GL-Soil container (1oz)
SAMPLE #					GL-Soil container (1oz)	GL-20 ml VOC Vial (1 As is) (1 PC)
91304	XXXXXXXXXX	DW	12/29/13	12:45	GL Amber 100ml (1 As is) (1 H ₂ O)	PL H ₂ SO ₄ (1 250ml) (1 H ₂ SO ₄)
					PL H ₂ SO ₄ (1 250ml) (1 H ₂ SO ₄)	PL HNO ₃ 250ml
					PL HNO ₃ 250ml	Backlogs Bottle
Refiniquished by: <u>Eric O'Connell</u>	Accepted by: <u>[Signature]</u>	Date: <u>12-20-13</u>	Time: <u>12:45</u>	RI	CT	MA
				<input type="checkbox"/> Direct Exposure (Residential)	<input type="checkbox"/> RCP Cert	<input type="checkbox"/> MCP Certification
				<input type="checkbox"/> GW	<input type="checkbox"/> GW Protection	<input type="checkbox"/> GW-1
				<input type="checkbox"/> Other	<input type="checkbox"/> SW Protection	<input type="checkbox"/> GW-2
					<input type="checkbox"/> GA Mobility	<input type="checkbox"/> GW-3
					<input type="checkbox"/> GB Mobility	<input type="checkbox"/> S-1
					<input type="checkbox"/> Residential DEC	<input type="checkbox"/> S-2
					<input type="checkbox"/> I/C DEC	<input type="checkbox"/> S-3
					<input type="checkbox"/> Other	<input type="checkbox"/> MWRA eSMART
						<input type="checkbox"/> Other
Comments, Special Requirements or Regulations:				Turnaround:	State where samples were collected: <u>CT</u>	
				<input type="checkbox"/> 1 Day*	* SURCHARGE APPLIES	
				<input type="checkbox"/> 2 Days*		
				<input type="checkbox"/> 3 Days*		
				<input type="checkbox"/> Standard		
				<input type="checkbox"/> Other		
				* SURCHARGE APPLIES		

Sampling Protocol

4.7

“For both a Level 1 and Level 2 assessment, the collection of additional samples for total coliforms with potential subsequent E. coli analysis and supporting water quality parameters is encouraged. Systems should keep records of any special purpose samples taken in order to create a baseline for comparison should another assessment be triggered in the future”. (Proposed RTCR A/CA GM)

Sampling Protocol

- The level of effort and resources required to implement the Level 2 assessments will be commensurate with a more comprehensive investigation, a higher level review of available information, and may involve the engagement of additional parties and expertise..... (Proposed RTCR A/CA

GM) •

Sampling Sites and Protocols

....

- Follow your DPH approved Sampling Site Plan,
- Follow the appropriate sampling guidelines,
- Maintain effective communication with your laboratory, local health personnel, and the DPH DWS

5 Distribution



STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH


Revised Total Coliform Rule Level 2 Assessment Form

PWS ID#: CT		PWS Name:		Town:
5	Distribution	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/Proposed
5.1	Have there been any incidents of low or inadequate pressure (<25 psi)?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
5.2	Have there been any distribution plumbing installations, water service line breaks or main breaks?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
5.3	Were there any events that may have caused flows in excess of normal?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
5.4	Have all cross connection violations been corrected?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
5.5	Are there any dead end or low flow sections within the distribution system or plumbing system?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
5.6	Are there any automatically operating air vacuum, air release or combination air release/air vacuum valves having a discharge port connected to drain, not screened or that may have been submerged in water?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
5.7	Were there low disinfection residuals?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		

5.1 Have there been any incidents of low or inadequate pressure (<25 psi)?

- ☉ Determine if there been any inadequate or low pressure events.

Adequate pressure is the first barrier in protection of water system from contamination.



5.2 Have there been any distribution plumbing installations, water service line breaks or main breaks?



- 💧 Review records to determine if there were any breaks or repairs to the system.

A break or installation may cause bacteria to be introduced into a system directly or indirectly. Increased flows or other disturbances to the pipes may release bacteria in sediment or scale within the pipe.


Effective disinfection followed by sampling and testing for bacteria is warranted following these events.

5.3 Was there any events that may have caused flows in excess of normal?



- Review records to determine if there was any event where flows within the system were in excess of normal.

Such events may include flushing, fire event, unauthorized use, operation of a blow off, etc. Increased flows in pipes may disturb bacteria-containing sediment or scale buildup and cause the bacteria to be released into the water.





5.4 Have all cross connection violations been corrected?

- Review sanitary survey reports, cross connection inspection reports and recent work orders to determine if any cross connection violations have been identified and not corrected.

SURVEY YEAR _____ **CROSS CONNECTION SURVEY REPORT FORM** PAGE ____ OF ____
 Community Public Water Systems Serving 1,000 persons or less and Non-Community Public Water Systems

PUBLIC WATER SYSTEM: _____ PUBLIC WATER SYSTEM ID #: _____
 TOWN: _____

You may copy this form if additional consumer premises (more than 4) are to be listed.

A)

Name of Tester(s) / Inspector(s)	Certificate #	Expiration date	I certify that the information in this report is substantially correct (Signature)

B) C) D) E) F)


Consumer Premise	Categories of concern	Date of most recent inspection	Violations		Testing Backflow Prevention Devices				
			Number found	Number uncorrected	Device type ¹	Number of Devices			
						Total	Tested	Failed	Repaired
1					PVB				
					DCVA				
					RPD				
2					PVB				
					DCVA				
					RPD				
3					PVB				
					DCVA				
					RPD				
4					PVB				
					DCVA				
					RPD				

¹ PVB = Pressure Vacuum Breaker, DCVA = Double Check Valve Assembly, RPD = Reduced Pressure Principle Device

B) G)

Consumer Premise (as numbered above)	Status of Uncorrected Violation
1	
2	
3	
4	

5.5 Are there any dead end or low flow sections within the distribution system or plumbing system?



Chronic repeated coliform bacteriological issues have been associated with inadequate disinfection of stagnant water lines.

5.6 Are there any automatically operating air vacuum, air release or combination air release/air vacuum valves having a discharge port connected to drain, not screened or that may have been submerged in water?

- Review records and/or inspect system to determine if there is any air vacuum, air release or combination air release/air vacuum valves.

If present determine that they are not connected to a drain, submerged in water or may become submerged in water. Any valves routinely operated on a pump discharge or elsewhere should be appropriately screened.



5.7 Was there low disinfection residuals?

- Review distribution sample results to determine if chlorine was below normal operating levels or if a detectable free chlorine level (i.e. > 0.05 mg/L) is maintained in the distribution or plumbing system. This would apply only to water systems which provide continuous chlorination treatment.



Sources

PWS ID#: CT		PWS Name:		Town:	
Source of Supply			Source Type:		
6	Source Name:	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/Proposed	
	Source Facility ID:				
6.1	Have there been any recent activities (i.e. septic or sewer releases, construction, waste discharges) in the vicinity of the source?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A			



Signs Of A Failing Septic System

- Sewage/Plumbing Backup into the House
- Sewage Odors in the House
- Slow Draining Sinks and Toilets
- Gurgling Sounds in the Plumbing
- Puddles Forming on the Soil Treatment Area (Drainfield) Surface
- Bad Odors around the Drainfield
- Backflow from the Drainfield into the Septic Tank
- System Alarms Sounding (if present on the system)
- Frozen Pipes or Frozen Soil Treatment Area (Drainfield)
- Algae Blooms or Excessive Plant Growth in Nearby Ponds/Lakes
- High Levels of Nitrates or Coliform Bacteria in Well Water Tests

Sources

6.2	Are there any holes or unprotected openings in the well casing?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
------------	---	---	--	--



Sources

6.3	Does the well casing terminate less than 6 inches below established grade or well pit floor?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
-----	--	---	--	--



Sources

6.4	Does the well casing terminate less than ten feet below the surface or do the casing sections not appear to be joined watertight?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A	
-----	---	---	--

WELL COMPLETION REPORT
ONE-FIVE-11-82

STATE OF CONNECTICUT
 DEPARTMENT OF CONSUMER PROTECTION
 WELL DRILLING BOARD
 105 CAPITOL AVE.
 HARTFORD, CONNECTICUT 06105

1343
 ENTERCO JUN 13 1985

Do NOT fill in
 STATE WELL NO.
 OTHER NO.

OWNER NAME: Paul Connolly ADDRESS: 92 Clinton Hill Road, Shelton, CT

LOCATION OF WELL: Spinaker Hill Road, Shelton, CT Well # 2

PROPOSED USE OF WELL: DOMESTIC BUSINESS FARM DOG TEST WELL
 PUBLIC SUPPLY INDUSTRIAL AIR CONDITIONING OTHER (P-#)

DRILLING EQUIPMENT: ROTARY COMPRESSED AIR PENETRATOR CORE PENETRATOR OTHER (P-#)

CASING DETAILS: LENGTH (feet) 60, DIAMETER (inches) 6, WEIGHT PER FOOT 17, BRASS WELDED, DRIVE SHAFT YES NO, JOINT TIGHTENING YES NO

YIELD TEST: BASED PUMPED COMPRESSED AIR, HOURS, YIELD (GPM)

WATER LEVEL: MEASURE FROM LAND SURFACE - STATIC (Specify feet) _____, DURING YIELD TEST (feet) _____, Depth of Completed Well in feet below land surface: 26.3, LENGTH OPEN TO AIR/ATER (feet) _____

SCREEN DETAILS: SCREEN SIZE, DIAMETER (Inches), # GRAVEL PACKS, Diameter of well including gravel pack (Inches), GRAVEL SIZE (Inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET TO FEET	FORMATION DESCRIPTION	Sketch exact location of this permanent landmark
0 - 26	Haystack / Gravel / Sand	
26 - 29	Claystone / Shale	
29 - 26.3	Claystone	

RECEIVED JUN 13 1985 CHESBROOK HEALTH DISTRICT

IF WELL WAS TESTED AT DIFFERENT DEPTHS DURING DRILLING, SEE BOTTOM

FEET GALLONS PER MINUTE

BY WELL COMPLETER: [Signature] PERMIT NO. 102939 REGISTRATION NO. 126 DATE OF REPORT: [Signature] WELL DRILLER (Signature): [Signature] Sign Drilling Co.

LOCAL DIRECTOR OF HEALTH

Sources

6.5	Is the cover of the dug well watertight and sealed watertight to the casing?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
-----	--	---	--	--



Sources

<p>6.6</p>	<p>Is the well located in a depressed area where water may collect or is subject to flooding, and has any flooding or ponding occurred?</p>	<p> <input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A </p>		
-------------------	---	--	--	--



Sources

6.7	Is the sanitary seal or well cap improperly installed to the casing and electric conduit, or are they in an unsatisfactory condition?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
------------	---	---	--	--




Sources

6.8	Does the well lack a vent?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
-----	----------------------------	---	--	--



Sources

6.9	Is the well vent not shielded or properly screened?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
-----	---	---	--	--




Sources

6.10	Is the well pit currently flooded or is there any indication that water collects in the pit?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
-------------	--	---	--	--



Sources

6.11	Is the well pit drain line directly connected to a septic, sewer or storm drain system?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
------	---	---	--	--



Sources

6.12	Is the source in compliance with separation distance requirements associated with a potential bacterial source?	<input type="radio"/> Y	
		<input type="radio"/> N	
		<input type="radio"/> N/A	





FIGURE #14
WELL LOCATION WITH WITHDRAWAL RATES OF 10 TO 50 GALLONS PER DAY
CONNECTICUT DEPARTMENT OF PUBLIC HEALTH WATER SUPPLIES SECTION
REVISION DATE: SEPTEMBER 1998 | FILE No.: 97502003





FIGURE #14
WELL LOCATION WITH WITHDRAWAL RATES OF 10 TO 50 GALLONS PER DAY
CONNECTICUT DEPARTMENT OF PUBLIC HEALTH WATER SUPPLIES SECTION
REVISION DATE: SEPTEMBER 1998 | FILE No.: 97502003






FIGURE #15
WELL LOCATION WITH WITHDRAWAL RATES OF >50 GALLONS PER DAY
CONNECTICUT DEPARTMENT OF PUBLIC HEALTH WATER SUPPLIES SECTION
REVISION DATE: SEPTEMBER 1998 | FILE No.: 97502003


Sources

6.12	Is the source in compliance with separation distance requirements associated with a potential bacterial source?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
-------------	---	---	--	--



Sources

6.13	Does the spring box have any breaches, holes or unprotected openings?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
------	---	---	--	--



Sources

6.14	Are all spring box hatches appropriately sealed and overflow vents appropriately shielded and screened?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
------	---	---	--	--



Sources

6.14	Are all spring box hatches appropriately sealed and overflow vents appropriately shielded and screened?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A		
------	---	---	--	--



Sources

6.15	Does the source have a history of bacteriological contamination?	<input type="radio"/> Y <input type="radio"/> N <input type="radio"/> N/A	
-------------	--	---	--

Violation Summary Report						
Water System Name: 39 Hop Brook Rd - Apt Complex		Admin Contact: Mrs. Jeanne L. Miller				
Water System Town: Brookfield		Organization: Arc Capital, LLC.				
PWS ID/Type: CT0189971 / C		Title: Owner				
Population: 36		Phone / Ext: 203-942-8343 /				
Food Service Establishment? No		E-Mail: brookfield@hopbrookcrossing.com				
Chief Certified Operator(s): Mr. Andrew Hurlbut, Certified						
Violation Name (Type)	Analyte / Requirement	Compliance Period	Issue Date	Public Notification Required	Water System Facility	Compliance Achieved
CCR	CONSUMER CONFIDENCE RULE	8/10/2013 -	11/13/2013			
CCR REPORT	CONSUMER CONFIDENCE RULE	7/1/2013 -	11/13/2013			
FAILURE TO RESPOND TO SANITARY SURVEY	SANITARY SURVEY	4/25/2015 -	5/18/2015			
MCL (TCR), ACUTE	COLIFORM (TCR)	3/1/2015 - 2/28/2015	3/21/2015	3/4/2015	DISTRIBUTION SYSTEM	3/31/2015
MCL (TCR), MONTHLY	COLIFORM (TCR)	2/1/2016 - 2/29/2016	3/14/2016	4/13/2016	DISTRIBUTION SYSTEM	
MCL (TCR), MONTHLY	COLIFORM (TCR)	1/1/2016 - 1/31/2016	2/17/2016	3/18/2016	DISTRIBUTION SYSTEM	
MCL, AVERAGE	CHLORIDE	10/1/2015 - 12/31/2015	11/19/2015	12/19/2015	ENTRY POINT	
MCL, AVERAGE	CHLORIDE	7/1/2015 - 9/30/2015	11/19/2015	12/2/2015	ENTRY POINT	
MCL, AVERAGE	CHLORIDE	4/1/2015 - 6/30/2015	8/19/2015	9/18/2015	ENTRY POINT	
MCL, AVERAGE	CHLORIDE	1/1/2015 - 3/31/2015	4/17/2015	5/17/2015	ENTRY POINT	
MCL, AVERAGE	CHLORIDE	10/1/2014 - 12/31/2014	12/16/2014	1/15/2015	ENTRY POINT	
MCL, AVERAGE	CHLORIDE	7/1/2014 - 9/30/2014	8/16/2014	12/16/2014	ENTRY POINT	
MCL, SINGLE SAMPLE	CHLORIDE	7/1/2014 - 9/30/2014	11/28/2014	12/28/2014	ENTRY POINT	
MONITORING, ROUTINE MAJOR	DI(2-ETHYLHEXYL) PHTHALATE	4/1/2015 - 6/30/2015	9/24/2015		ENTRY POINT	9/9/2015
MONITORING, ROUTINE MAJOR	DI(2-ETHYLHEXYL) ADIPATE	4/1/2015 - 6/30/2015	9/24/2015		ENTRY POINT	9/9/2015
MONITORING, ROUTINE MAJOR	DI(2-ETHYLHEXYL) ADIPATE	1/1/2015 - 3/31/2015	7/6/2015		ENTRY POINT	5/8/2015
MONITORING, ROUTINE MAJOR	DI(2-ETHYLHEXYL) PHTHALATE	1/1/2015 - 3/31/2015	7/6/2015		ENTRY POINT	5/8/2015
Total Violations:						17

Tuesday, March 15, 2016

Page 1 of 1

Other Compliance Schedules		
Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2013	
SUBMIT CCR TO THE DEPARTMENT	6/30/2013	
SUBMIT CCR CERTIFICATION FORM	8/9/2013	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2013	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2014	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2014	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2014	
ELECTRONIC SUBMISSION-SERVICE AREA DATA	12/31/2014	
RESPOND TO SANITARY SURVEY	4/24/2015	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2015	
SUBMIT CCR TO THE DEPARTMENT	6/30/2016	
SUBMIT CCR CERTIFICATION FORM	8/9/2016	
CROSS CONNECTION EXEMPTION	3/1/2018	

Public Notification Requirements					
Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH
Total Coliform MCL Violation	2/1/16 - 2/29/16	2	3/15/2016	3/19/2016	3/25/2016

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 5/23/2016

Page 87

Connecticut Department of Public Health Drinking Water Section						
Water Quality Monitoring and Compliance Schedule						
PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source	
CT0189971	39 HOP BROOK RD - APT COMPLEX	C	36	P	GW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined
39 HOP BROOK ROAD			12			
Town(s) Served: BROOKFIELD						
Public Notification Requirements						
Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	Received
Total Coliform MCL Violation	2/1/16 - 2/29/16	1	3/15/2016	3/19/2016	3/25/2016	4/6/2016
Total Coliform MCL Violation	1/1/16 - 1/31/16	2	3/18/2016	2/16/2016	3/28/2016	3/11/2016
Chloride MCL Violation	1/1/16 - 3/31/16	2	5/13/2016		5/23/2016	
Total Coliform MCL Violation	3/1/16 - 3/31/16	2	5/26/2016		6/5/2016	

Treatment Facility



7	Treatment Facility		PWS does not have any treatment facilities	
	Facility Name:	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/ Proposed
Treatment Facility ID:				
<u>7.1</u>	Has there been any by-pass in the disinfection treatment process?	Y N N/A		
<u>7.2</u>	Is the filter backwash discharge line directly connected to a drainage pipe or sewer/septic line?	Y N N/A		
<u>7.3</u>	Have there been any interruptions in disinfection treatment (UV, chlorine, etc.)?	Y N N/A		
<u>7.4</u>	Has there been any recent installation or repair to the treatment process?	Y N N/A		
<u>7.5</u>	Have there been any low or inadequate disinfection residual levels?	Y N N/A		
<u>7.6</u>	Is there any evidence of filter or media contamination?	Y N N/A		
<u>7.7</u>	For ultraviolet (UV) disinfection systems, is the well(s) discharge flow rate (pre-UV) above the rated manufacturer's capacity of the UV unit?	Y N N/A		
<u>7.8</u>	For surface water treatment plants was the required inactivation CT being achieved during the time of the recent coliform positive test results?	Y N N/A		
<u>7.9</u>	Is the water treated with a phosphate inhibitor without the system being chlorinated?	Y N N/A		

7.1 Has there been any by-pass in the disinfection treatment process?

- Does the treatment system have a bypass?
 - more typical for a UV unit
- Verify the bypass valve is closed.
- If treatment provided is for treating a Maximum Contaminant Level (MCL) a bypass is a significant deficiency and must be removed



7.2 Is the filter backwash discharge line directly connected to a drainage pipe or sewer /septic line?



7.3 Have there been any interruptions in disinfection treatment (UV, chlorine, etc.)?

- Disinfection – chlorine feed system
 - Review daily treatment logs
 - Discuss with operator or person handling feed system if day tank ran out, chemical metering pump lost prime (air bound), leak in feed line, etc.
- UV unit
 - Does UV unit have an operating on/off light, dose meter, frequency of checking status, any alarm or is the unit working
 - Quartz sleeve not cleaned
 - Lamp failed and last time replaced
- Failure due to power outage



Drinking Water Section


7.4 Has there been any recent installation or repair to the treatment process?

- Filter media changed
- Filter cartridge changed
- Chemical metering pump replaced
- Use of different chemical
- Etc.



7.5 Have there been any low or inadequate disinfection residual levels?

- Review treatment logs
 - were levels lower than normal
- For disinfection system approved for 4 log inactivation of viruses, did chlorine residual drop below approved minimum
 - Required backup components



7.6 Is there any evidence of filter or media contamination?

- Was media replaced
- Filter cartridge replaced
 - Not properly stored or handled
- Recommend sample before or after filter



7.7 For ultraviolet (UV) disinfection systems, is the well(s) discharge flow rate (pre-UV) above the rated manufacturer's capacity of the UV unit?

- UV unit operating in excess of rated flow may provide inadequate disinfection
- Determine flow rate of water being treated (typically well pump rate)
 - Meter readings
 - Pump records or other
- Examine UV unit
 - May have flow rating
 - Obtain model number and research

7.8 For surface water treatment plants was the required inactivation CT being achieved during the time of the recent coliform positive test results?

Review CT records

Surface Water Quality Data

Date	Min. Cl ₂ Residual At 1/2 Hr. (mg/L)	Contact Time (minutes)	Actual C x T	Temp (°C)	pH	Required Tables	CT Met
1/							
2/							
3/							
4/							
5/							
6/							
7/							
8/							
9/							
10/							
11/							
12/							
13/							
14/							
15/							
16/							
17/							
18/							
19/							
20/							
21/							
22/							
23/							
24/							
25/							
26/							
27/							
28/							
29/							
30/							
31/							

Chapter IV


Table C-3. CT Values for Inactivation of Giardia Cysts by Free Chlorine at 10°C

CHLORINE CONCENTRATION (mg/L)	pH=6.5					pH=7.0					pH=7.5								
	Log Inactivation					Log Inactivation					Log Inactivation								
	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	0.5	1.0	1.5	2.0	2.5	3.0	
<0.4	12	24	37	49	61	73	15	29	44	56	73	88	17	35	52	69	87	104	120
0.5	13	25	38	50	63	75	15	30	45	60	75	90	18	36	54	71	89	107	128
0.6	13	26	39	52	65	78	15	31	46	61	77	92	18	37	55	73	92	110	129
0.8	11	23	35	47	59	71	16	31	47	63	79	94	19	37	55	73	92	110	129
1.2	13	27	40	53	67	80	16	32	48	63	79	95	19	38	56	74	92	111	130
1.4	14	27	41	55	68	82	16	33	49	65	82	98	19	39	57	75	93	112	131
1.5	14	28	42	56	69	83	17	33	50	66	83	99	20	40	58	76	94	113	132
1.8	14	29	43	57	72	85	17	34	51	67	84	101	20	41	61	81	102	122	141
2	15	29	44	58	73	87	17	35	52	69	87	104	21	41	62	83	103	124	142
2.2	15	30	45	59	74	88	18	35	53	70	88	105	21	42	64	85	106	127	145
2.4	15	30	45	60	75	90	18	36	54	71	89	107	22	43	65	86	108	129	147
2.6	15	31	46	61	77	92	18	37	55	73	92	110	22	44	66	87	109	131	150
2.8	16	31	47	62	78	93	19	37	56	74	93	111	22	45	67	89	112	134	151
3	16	32	48	63	79	95	19	38	57	75	94	113	23	46	69	91	114	137	155

Source: AWWA, 1991.

7.9 Is the water treated with a phosphate inhibitor without the system being chlorinated?

Adding phosphate to water without a chemical disinfectant may result in a biofilm growth which can harbor bacteria



Storage Facility

8	Storage Facility		PWS does not have storage facilities	
	Facility Name:	Potential Defect	Description of Defect and Corrective Action Taken/Proposed	Date Corrected/ Proposed
	Storage Facility ID:			
	Storage Type:			
8.1	Are there any holes or unprotected openings in the atmospheric tank(s)?	Y N N/A		
8.2	Is the hatch on the atmospheric tank not sealed properly?	Y N N/A		
8.3	Are the vents on the atmospheric tank <u>not</u> suitably protected and/or screened?	Y N N/A		
8.4	Is the overflow on the atmospheric tank <u>not</u> suitably protected and/or screened?	Y N N/A		
8.5	Is the overflow not equipped with an air gap?	Y N N/A		
8.6	Was the last atmospheric tank inspection performed more than 10 years ago or does its interior need cleaning or repainting?	Y N N/A		
8.7	Does the air compressor for the hydro-pneumatic storage tank lack an air filter or is the air filter in poor condition?	Y N N/A		
8.8	Is there any evidence of tank failure?	Y N N/A		
8.9	Has there been any work or maintenance conducted on the tank (i.e. cleaning, inspection, repairs, painting, etc.) after which it was not disinfected?	Y N N/A		
8.10	Does the in-ground storage tank not meet minimum separation distance requirements to drains, septic or sewer components?	Y N N/A		

Refer to Storage Tank Design and Construction Guideline on DPH's website

If raw source water samples are clean (absent bacteria) focus should be on tanks and treatment. Special sampling before and after these components is recommended.

8.1 Are there any holes or unprotected openings in the atmospheric tank(s)?

- Inspect tank for openings
- Are vents, overflows, hatches, level tubes, level probes/floats, etc. sealed watertight to the tank.



8.2 Is the hatch on the atmospheric tank not sealed properly?



- Needs watertight gasket
- Should extend above grade

Roof hatches



Not acceptable

- Flush type
- With drain



Acceptable

- Closes tightly
- Continuous gasket
- Raised curb
- Overlapping cover
- Sealed to tank watertight

8.3 Are vents on the atmospheric tank not suitably protected and/or screened?

- Protected and shielded to keep out rain and runoff
- Fine mesh screen (i.e. 24 mesh stainless steel) to keep insects out





8.4 Is the overflow on the atmospheric tank not suitably protected and/or screened?



- Protected and shielded to keep out rain or runoff
- Three typical options
 - Screen, flap valve and duck bill valve (or combination)
- Fine screen supported on coarse screen



8.5 Is the overflow not equipped with an air gap?



8.6 Was the last atmospheric tank inspection performed more than 10 years ago or does its interior need cleaning or repainting?

- 10 year inspection required for sanitary conditions and structural integrity (Guideline on DPH's website)
- Sediment, corrosion or biofilm deposits may harbor bacteria
- Inadequate disinfection upon completion of work



8.7 Does the air compressor for the hydropneumatic storage tank lack an air filter or is the air filter in poor condition?



8.9 Has there been any work or maintenance conducted on the tank (i.e. cleaning, inspection, repairs, painting, etc.) after which it was not disinfected?

Inadequate disinfection after completion of work may result in a bacterial contamination



8.10 Does the in-ground storage tank not meet minimum separation distance requirements to drains, septic or sewer components?

- Section 19-13-B102(f)(5)(B) minimum distances from in ground tank
 - 50 feet from subsurface sewage disposal system or sanitary sewer
 - 25 feet from watercourse, storm drain or other source of pollution
 - 25 feet from sewer or septic tight pipe





p. 8 - Level 2 Assessment Form



STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

Revised Total Coliform Rule Level 2 Assessment Form

PWS ID#: CT		PWS Name:			Town:	
RCTR Level 2 Assessor Information						
Salutation	First Name		Last Name		RCTR Level 2 Credential Number	
Business Phone	(Ext.) ()	E-mail Address				
<input type="checkbox"/> Check here to certify that the RCTR Level 2 Assessor is not an employee of the public water system identified on this form.						
Contact Information for the Public Water System						
Salutation	First Name		Last Name			
Organization			Job Title			
Mailing Address Line One				Mailing Address Line Two		
City			State	ZIP Code		
Business Phone	(Ext.) ()	Fax	Mobile Phone	Emergency Phone	E-mail Address	
Certification						
I certify that the information contained herein which is being submitted to the Connecticut Department of Public Health for a drinking water regulatory compliance purpose is complete and accurate and understand that any false statement contained herein is punishable as a criminal offense under section 53a-157b of the Connecticut General Statutes.						
Signature of Water System Owner/Legal Contact:				Date:		
Printed Name of Water System Owner/Legal Contact: _____						

Form to be completed based on an examination of the distribution system, water sources, treatment facilities, storage facilities and relevant operational practices data and documents available to the PWS and returned to the department as soon as practical but no later than 30 days after the system has identified that it had exceeded a level 2 treatment technique trigger.

Please return this form to the Drinking Water Section at:

Mail: State of Connecticut
Department of Public Health
Drinking Water Section
410 Capitol Avenue, MS# 51WAT
P.O. Box 340308
Hartford, CT 06134-0308

Email: dwdcompliance@ct.gov
Fax: 860-509-7359

Drinking Water Section

Technical Questions?



Call or email anyone who presented today

Main phone number: 860-509-7333

vicky.carrier@ct.gov

john.czaja@ct.gov

william.sullivan@ct.gov

steve.wallet@ct.gov



Sampling Plan Water Quality Monitoring or Implementation Questions?

Call Carissa Madonna
Or Christopher Roy

Main Phone Number is 860-509-7333

- 💧 Carissa Madonna, carissa.madonna@ct.gov
- 💧 Christopher Roy, christopher.roy@ct.gov

Tell your Co-Workers about Upcoming Training Events

- Potential RTCR November 22, 2016 here at DOT
- DWS Lead & Copper Rule Compliance Operator Training Course at Goodwin College on November 21, 2016
- ATCAVE 2017 is on February 28, 2017



THANK
YOU!