| PWS ID PWS Name | | | Clas | ssification | Population | Owner Type | Primary Source | |
|--|-------------------|-------------|---------|-------------|------------|-------------|----------------|-----------------|
| CT0350011 AQUARION WATER CO OF CT-NOROTON SYSTEM | | | | С | 18,737 | Р | SWP | |
| Local Address (v | vhere applicable) | Service | Resider | ntial | Commercia | al Industri | al Combine | ed Agricultural |
| | | Connections | | | | | 6,844 | |

| | | | 0,0 1 1 |
|--|--------------------------|--------------------------|----------------------|
| Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD | | | |
| Monitor | ing Requirements | | |
| Water System Facility: DISTRIBUTION SYSTEM (WSF ID: | <u> </u> | | |
| Chlorine Residual (1012) | | 20 rou | tine (RT) per month |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| Select from Inventory of Active Sampling Points | 11/1/23 - 11/30/23 | | Complete |
| | 12/1/23 - 12/31/23 | | Complete |
| | 1/1/24 - 1/31/24 | | Complete |
| | 2/1/24 - 2/29/24 | | Complete |
| | 3/1/24 - 3/31/24 | | · |
| | 4/1/24 - 4/30/24 | | |
| | 5/1/24 - 5/31/24 | | |
| | 6/1/24 - 6/30/24 | | |
| | 7/1/24 - 7/31/24 | | |
| | 8/1/24 - 8/31/24 | | |
| | 9/1/24 - 9/30/24 | | |
| | 10/1/24 - 10/31/24 | | |
| Asbestos (1094) | | 1 routine | (RT) per nine years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| HOLMES SCHOOL SS (05408) | 1/1/21 - 12/31/29 | | |
| Total Coliform (3100) | | 3 re | peat (RP) per period |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| Select from Inventory of Active Sampling Points | 10/13/23 - 10/18/23 | | Complete |
| Total Coliform (3100) | | 20 rou | tine (RT) per month |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| Select from Inventory of Active Sampling Points | 11/1/23 - 11/30/23 | | Complete |
| | 12/1/23 - 12/31/23 | | Complete |
| | 1/1/24 - 1/31/24 | | Complete |
| | 2/1/24 - 2/29/24 | | Complete |
| | 3/1/24 - 3/31/24 | | |
| | 4/1/24 - 4/30/24 | | |
| | 5/1/24 - 5/31/24 | | |
| | 6/1/24 - 6/30/24 | | |
| | 7/1/24 - 7/31/24 | | |
| | 8/1/24 - 8/31/24 | | |
| | 9/1/24 - 9/30/24 | | |
| | 10/1/24 - 10/31/24 | | |
| Disinfectant Byproducts - TTHM & HAA5 (DBP) | | 4 rout | ine (RT) per quarter |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| UNITED METHODIST (05426) | 10/1/23 - 12/31/23 | 11/1-11/30 | Complete |
| | 1/1/24 - 3/31/24 | 2/1-2/28 | Complete |
| | 4/1/24 - 6/30/24 | 5/1-5/31 | |
| | 7/1/24 - 9/30/24 | 8/1-8/31 | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

| Connecticut Department of Public Health Drinking Water Section |
|--|
| Water Quality Monitoring and Compliance Schedule |

| PWS ID PWS Name | | | | Clas | sification | Population | Owner Type | Primary Source |
|------------------|-------------------------------------|-------------|---------|-------|------------|-------------|------------|-----------------|
| CT0350011 | AQUARION WATER CO OF CT-NOROTON SYS | TEM | | | С | 18,737 | Р | SWP |
| Local Address (v | vhere applicable) | Service | Resider | ntial | Commercia | al Industri | al Combine | ed Agricultural |
| | | Connections | | | | | 6,844 | |

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

Sampling Point (Sampling Point ID)

ENTRY POINT - REWAK (3)

| Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD | | | |
|--|---|--------------------------|-----------------------|
| Monitorin | ng Requirements | | |
| Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00 | 0600) | | |
| Disinfectant Byproducts - TTHM & HAA5 (DBP) | | 4 rout | ine (RT) per quarter |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| OX RIDGE SCHOOL SS (05428) | 10/1/23 - 12/31/23 | 11/1-11/30 | Complete |
| | 1/1/24 - 3/31/24 | 2/1-2/28 | Complete |
| | 4/1/24 - 6/30/24 | 5/1-5/31 | |
| | 7/1/24 - 9/30/24 | 8/1-8/31 | |
| TOKENEKE RD DARIEN (05429) | 10/1/23 - 12/31/23 | 11/1-11/30 | Complete |
| | 1/1/24 - 3/31/24 | 2/1-2/28 | Complete |
| | 4/1/24 - 6/30/24 | 5/1-5/31 | |
| | 7/1/24 - 9/30/24 | 8/1-8/31 | |
| 9 FAIRMEAD RD SS (05430) | 10/1/23 - 12/31/23 | 11/1-11/30 | Complete |
| | 1/1/24 - 3/31/24 | 2/1-2/28 | Complete |
| | 4/1/24 - 6/30/24 | 5/1-5/31 | |
| | 7/1/24 - 9/30/24 | 8/1-8/31 | |
| Lead And Copper (PBCU) | | 30 routine | (RT) per three years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| Select from Inventory of Active Sampling Points | 1/1/21 - 12/31/23 | 6/1-9/30 | Complete |
| | 1/1/24 - 12/31/26 | 6/1-9/30 | · |
| | 1/1/27 - 12/31/29 | 6/1-9/30 | |
| Physical Parameters (PPS) | | 20 rou | tine (RT) per month |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| Select from Inventory of Active Sampling Points | 11/1/23 - 11/30/23 | | Complete |
| | 12/1/23 - 12/31/23 | | Complete |
| | 1/1/24 - 1/31/24 | | Complete |
| | 2/1/24 - 2/29/24 | | Complete |
| | 3/1/24 - 3/31/24 | | · |
| | 4/1/24 - 4/30/24 | | <u> </u> |
| | 5/1/24 - 5/31/24 | | |
| | 6/1/24 - 6/30/24 | | |
| | 7/1/24 - 7/31/24 | | |
| | 8/1/24 - 8/31/24 | | |
| | 9/1/24 - 9/30/24 | | |
| | 10/1/24 - 10/31/24 | | |
| Water System Facility: ENTRY POINT - REWAK WELL (WSF | | | |
| Net Gross Alpha (4000) | | 1 routine | (RT) per nine years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/17 - 12/31/25 | | Complete |
| Uranium (4006) | , | 1 routine | e (RT) per nine years |
| | | | , pere ,ears |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Monitoring Period

1/1/17 - 12/31/25

Collection Period

Compliance Status

Complete

| PWS ID PWS Name | | | Cla | ssification | Population | Owner Type | Primary Source | |
|--|-------------------|-------------|---------|-------------|------------|-------------|----------------|-----------------|
| CT0350011 AQUARION WATER CO OF CT-NOROTON SYSTEM | | | | С | 18,737 | Р | SWP | |
| Local Address (v | vhere applicable) | Service | Resider | ntial | Commerci | al Industri | al Combine | ed Agricultural |
| | | Connections | | | | | 6,844 | |

| | | | 0,044 |
|--|--------------------------|--------------------------|--------------------------|
| Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD | | | |
| Monitoring | g Requirements | | |
| Water System Facility: ENTRY POINT - REWAK WELL (WSF I | <u> </u> | | |
| Combined Radium-226/228 (4010) | , | 1 routine | e (RT) per nine years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/17 - 12/31/25 | | Complete |
| Gross Beta Particle Activity (4100) | | 1 routine | (RT) per three years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/23 - 12/31/25 | | • |
| | 1/1/26 - 12/31/28 | | |
| Man-Made Beta Particle & Photon Emitters (4101) | | 1 routine | (RT) per three years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/23 - 12/31/25 | | |
| | 1/1/26 - 12/31/28 | | |
| Tritium (4102) | | 1 routine | (RT) per three years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/23 - 12/31/25 | | |
| | 1/1/26 - 12/31/28 | | |
| Strontium-90 (4174) | | 1 routine | (RT) per three years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/23 - 12/31/25 | | |
| | 1/1/26 - 12/31/28 | | |
| Inorganic Chemicals (IOCS) | | 1 routine | (RT) per three years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/21 - 12/31/23 | | Out of Service |
| | 1/1/24 - 12/31/26 | | |
| | 1/1/27 - 12/31/29 | | |
| Nitrate And Nitrite (NOX) | | 1 r | outine (RT) per year |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/23 - 12/31/23 | | Out of Service |
| | 1/1/24 - 12/31/24 | | |
| | 1/1/25 - 12/31/25 | | |
| Pesticides, Herbicides and PCBs-Phase II (SOC2) | | 2 routine | (RT) per three years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/23 - 12/31/25 | | |
| | 1/1/26 - 12/31/28 | | |
| Pesticides, Herbicides and PCBs-Phase V (SOC5) | | 2 routine | (RT) per three years |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 1/1/23 - 12/31/25 | | |
| | 1/1/26 - 12/31/28 | | |
| Organic Chemicals (VOCS) | | 1 rout | tine (RT) per quarter |
| Sampling Point (Sampling Point ID) | Monitoring Period | Collection Period | Compliance Status |
| ENTRY POINT - REWAK (3) | 10/1/23 - 12/31/23 | | Out of Service |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

| | Conne | cticut Department of Pu Water Quality Monitoria | | | | _ | | | ction | |
|------------------|-------------|--|--------------------------|------------|-----------|-------|-------------------|-------|-------------|--------------|
| PWS ID | PWS Nam | | ig allu v | | | | | | or Type Dr | imary Source |
| CT0350011 | | N WATER CO OF CT-NOROTON SYSTEM | | Cla | C | | L8,737 | OWI | P P | SWP |
| | 1 | | ico Po | sidential | Commer | _ | Industria | al l | Combined | |
| Local Address (w | итеге аррп | - | nections | sidentiai | Commer | Clai | maustri | dI | 6,844 | Agricultural |
| Towns Served: D | DARIEN, NE | W CANAAN, NORWALK, STAMFORD | | | | | | | | |
| | | Monitoring | g Require | ements | | | | | | |
| Water System | Facility: | ENTRY POINT - REWAK WELL (WSF | ID: 00700) | | | | | | | |
| Organic Chem | | <u> </u> | | | | | 1 | rou | tine (RT) p | er quarter |
| Sampling P | Point (Sam | oling Point ID) | Мо | nitoring P | Period | Colle | ction Per | riod | Complia | ınce Status |
| | | | 1/ | 1/24 - 3/3 | 1/24 | | | | | |
| | | | 4/ | 1/24 - 6/3 | 0/24 | | | | | |
| | | | 7/ | 1/24 - 9/3 | 0/24 | | | | | |
| Water System | Facility: | REWAK WELL (WSF ID: 1434) | | | | | | | | |
| E. Coli (3014) | | | | | | | 1 | rou | | er quarter |
| | | oling Point ID) | | nitoring P | | Colle | ction Per | riod | | ince Status |
| REWAK WE | ELL (2) | | | 1/23 - 12/ | | | | | Out o | f Service |
| | | | | 1/24 - 3/3 | - | | | | | |
| | | | | 1/24 - 6/3 | | | | | | |
| | | | 7/ | 1/24 - 9/3 | 0/24 | | | | | |
| | Mor | nthly Water System Facility (| WSF) Lev | el Mor | nitorin | g Re | equire | mei | nts | |
| Water System | Facility: I | ENTRY POINT - REWAK WELL (WSFI | D: 00700) | | | | | | | |
| Analyte | | Monitoring Requirement (Summary Ty | rpe) | Operatir | ng Limit | | | | Samples Re | q/Month |
| Chlorine | | Entry Point Chlorine Residual Monitorin | ng (CHLR) | Minimur | n: 0.2 M | G/L | | | Dai | ly |
| Start Date: | 7/1/2003 | | Compliance | History: | (| Opera | iting Limi | t | Monitori | ng |
| | | | Monitoring | Period | | - | liance Sta | | Compliar | nce Status: |
| | | | 11/1/2023 - | 11/30/20 | 23 | | | | | |
| | | | 12/1/2023 - | 12/31/20 | 23 | | | | | |
| | | | 1/1/2024 - : | 1/31/2024 | | | | | | |
| | | | 2/1/2024 - 2 | 2/29/2024 | 1 | | | | | |
| | | | 3/1/2024 - 3 | 3/31/2024 | | | | | | |
| Analyte | | Monitoring Requirement (Summary Ty | rpe) | Operatir | ng Limit | | | | Samples Re | q/Month |
| Fluoride | | Entry Point Fluoride Monitoring (FLRD) | | | n: 0.55 N | ИG/L | | | Dai | ly |
| Start Date: | 6/1/2023 | | Compliance | | (| Opera | iting Limi | t | Monitori | _ |
| | | | Monitoring | | | Comp | liance Sta | atus: | Compliar | nce Status: |
| | | | 11/1/2023 - | | | | | | | |
| | | | 12/1/2023 - | | | | | | | |
| | | | 1/1/2024 - : | | | | | | | |
| | | | 2/1/2024 - 2 | | | | | | | |
| 0 1 | | Manufacture D. 1 1/2 | 3/1/2024 - 3 | - | | | | | C 1 = | /n a 11 |
| Analyte | | Monitoring Requirement (Summary Ty | - | Operatir | _ | \4C'! | | | Samples Re | - |
| Fluoride | C /1 /2022 | Entry Point Fluoride Monitoring (FLRD) | | | m: 0.85 ľ | - | | | Dai | • |
| Start Date: | 0/1/2023 | | Compliance Monitoring | | | | iting Limi | | Monitori | _ |
| | | Offline | 11/1/2023 - | | | Lomp | liance Sta n/a | atus: | Compilar | nce Status: |
| | | Offline | 12/1/2023 - | | | | n/a | | | Y |
| | | Offline | 1/1/2024 - : | | | | n/a | | | Y |
| | | Offilite | 1/1/2024 | 1,31,2024 | • | | 11/ a | | | <u>'</u> |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

| PWS ID PWS Name | | | Cla | ssification | Population | Owner Type | Primary Source | |
|--|--------------------|-------------|---------|-------------|------------|-------------|----------------|-----------------|
| CT0350011 AQUARION WATER CO OF CT-NOROTON SYSTEM | | | | С | 18,737 | Р | SWP | |
| Local Address | (where applicable) | Service | Resider | ntial | Commercia | al Industri | al Combine | ed Agricultural |
| | | Connections | | | | | 6,844 | |

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

| Water System Facility: | ENTRY POINT - REWAK WELL (WSFI | D: 00700) | | |
|------------------------|---------------------------------------|----------------------------|-------------------|----------------------|
| Analyte | Monitoring Requirement (Summary Ty | ype) Operating Lin | nit | Samples Req/Month |
| Fluoride | Entry Point Fluoride Monitoring (FLRD |) Maximum: 0. | 85 MG/L | Daily |
| Start Date: 6/1/2023 | | Compliance History: | Operating Limit | Monitoring |
| | | Monitoring Period | Compliance Status | : Compliance Status: |
| | Offline | 2/1/2024 - 2/29/2024 | n/a | Υ |
| | | 3/1/2024 - 3/31/2024 | | |

| Other Compliance Schedules | | | | | | | | | |
|------------------------------------|------------|---------------|---|--|--|--|--|--|--|
| Compliance Schedule Activity | Due Date | Achieved Date | | | | | | | |
| SUBMIT CCR TO THE DEPARTMENT | 6/30/2024 | | | | | | | | |
| SUBMIT CCR CERTIFICATION FORM | 8/9/2024 | | | | | | | | |
| SUBMIT LEAD SERVICE LINE INVENTORY | 10/16/2024 | | | | | | | | |
| COMPLETE INITIAL LSL INVENTORY | 10/16/2024 | | _ | | | | | | |
| CROSS CONNECTION SURVEY REPORT | 3/1/2025 | | | | | | | | |

| CRUSS CU | INNECTION SURVEY REPORT | | . /رد | 1/2025 | | | | | |
|--------------------------------|-------------------------|----------------------|----------------------------|---------|---------------------------|---------------------------------|----------|-----|-----------------|
| | Wat | er System Facili | ty and Sampling P | oint Ir | ventor | У | | | |
| Water System Facility ID | Water System Facility | Sampling Point ID | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper Rule Tier | Asbestos | WQP | Stage 2 DBPR |
| 00600 | DISTRIBUTION SYSTEM | 05408 | HOLMES SCHOOL SS | Α | Υ | | Υ | | |
| | | 05408D | HOLMES SCHOOL SS - D | Α | Υ | | | | |
| | | 05408U | HOLMES SCHOOL SS - D | Α | Υ | | | | |
| | | 05411 | NORWALK STATION | Α | Υ | | | | |
| | | 05412 | CHESTNUT ST STATION | Α | Υ | | | | |
| | | 05413 | POST ROAD STATION | Α | Υ | | | | |
| | | 05414 | ST LUKE'S CHURCH | Α | Υ | | | | |
| | | 05415 | OX RIDGE SCHOOL | Α | Υ | | | | |
| | | 05416 | WHITE BRIDGE DELI | ı | Υ | | | | |
| | | 05417 | PARK LANE STATION | Α | Υ | | | | |
| | | 05418 | SPRINGDALE FLORIST | Α | Υ | | | | |
| | | 05419 | ROGERS & CASEY | ı | Υ | | | | Υ |
| | | 05420 | TOKENEKE SCHOOL | Α | Υ | | | | |
| | | 05421 | HINDLEY SCHOOL | Α | Υ | | | | |
| | | 05422 | HOLMES SCHOOL | Α | Υ | | | | |
| | | 05423 | HOLLOW TREE RIDGE | Α | Υ | | | | |
| | | 05424 | BROOKSIDE RD SS | Α | Υ | | | | |
| | | 05425 | TOKENEKE SCHOOL SS | Α | Υ | | | | |
| | | 05426 | UNITED METHODIST | Α | Υ | | | | Υ |
| | | 05427 | HINDLEY SCHOOL SS | Α | Υ | | | | |
| | | 05428 | OX RIDGE SCHOOL SS | Α | Υ | | | | Υ |
| | | 05429 | TOKENEKE RD DARIEN | Α | Υ | | | | Υ |
| | | 05430 | 9 FAIRMEAD RD SS | Α | Υ | | | | Υ |
| | | 05430D | 9 FAIRMEAD DR SS - D | Α | Υ | | | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

| PWS ID PWS Name Cla | | | | | ssification | Population | Owner Type | Primary Source |
|----------------------------------|-------------------------------------|-------------|---------|-------|-------------|-----------------------|------------|-----------------|
| CT0350011 | AQUARION WATER CO OF CT-NOROTON SYS | TEM | | | С | 18,737 | Р | SWP |
| Local Address (where applicable) | | Service | Resider | ntial | Commercia | I Industrial Combined | | ed Agricultural |
| | | Connections | | | | | 6,844 | |

| Towns Served: DARIEN, NEW CANAA | N, NORWALK, STAMFOR | D | | | | | |
|--|---------------------|----------------------------|---------|---------------------------|--------------------|----------|--------------|
| W | ater System Facil | ity and Sampling Po | oint In | ventor | у | | |
| Water System Water System Facility Facility ID | | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper | Asbestos | tage DBPF |
| | 05430U | 9 FAIRMEAD DR SS - D | A | Υ | | | |
| | 4 | GENERIC DISTRIBUTION | Α | Υ | | | |
| | DOWNSTREAM | WITHIN 5 SERVICE CON | Α | | | | |
| | PB6079 | 21 GARDINER DARIEN | Α | | 1 | | |
| | PB6080 | 69 WEST DARIEN | Α | | 1 | | |
| | PB6081 | 93 FITCH DARIEN | Α | | 1 | | |
| | PB6082 | 17 DICKINSON DARIEN | Α | | 1 | | |
| | PB6083 | 30 PEAR TREE POINT | Α | Υ | 1 | | |
| | PB6084 | 180 PEAR TREE POINT | Α | Υ | 1 | | |
| | PB6085 | 45 GOODWIVES RVR DA | Α | | 3 | | |
| | PB6086 | 85 GOODWIVES RVR DAR | Α | | 1 | | |
| | PB6087 | 11 BEACH DRIVE | Α | Υ | 1 | | |
| | PB6088 | 5 PARK DARIEN | Α | | 1 | | |
| | PB6089 | 6 BY DARIEN | Α | | 1 | | |
| | PB6090 | 4 BY ROAD DARIEN | Α | | 1 | | |
| | PB6091 | 158 MIDDLESEX DARIEN | Α | | 1 | | |
| | PB6092 | 12 MAPLE DARIEN | Α | | 1 | | |
| | PB6093 | 366 HOLOWTRE RDG DAR | Α | | 1 | | |
| | PB6094 | 18 LONG NECK POINT | Α | Υ | 1 | | |
| | PB6095 | 21 DUBOIS DARIEN | Α | | 1 | | |
| | PB6096 | 3 DICKINSON DARIEN | Α | | 1 | | |
| | PB6097 | 8 LAFORGE RD DARIEN | Α | | 3 | | |
| | PB6098 | 24 CRISTIE HILL ROAD | Α | Υ | 1 | | |
| | PB6099 | 24 CHARLES DARIEN | Α | | 1 | | |
| | PB6100 | | Α | Υ | 1 | | |
| | PB6101 | 13 PHILLIPS DARIEN | Α | • | 3 | | |
| | PB6102 | 7 HIGHLAND DARIEN | Α | | 1 | | |
| | PB6103 | 14 EDGEWOOD DARIEN | Α | | 1 | | |
| | PB6104 | 7 WOODS END DARIEN | Α | | 1 | | |
| | PB6105 | 18 PINEBROOK LA DAR | Α | | 1 | | |
| | PB6106 | 17 LAKESIDE DARIEN | Α | | 1 | | |
| | PB6107 | 64 ANDREWS DRIVE | Α | Υ | 1 | | |
| | PB6108 | 17 POND DARIEN | Α | • | 1 | | |
| | PB6109 | 2 MAYWOOD DARIEN | A | | 1 | | |
| | PB6110 | 2 ROCATON DARIEN | A | | 3 | | |
| | PB6111 | 5 CHESTNUT DARIEN | A | | 3 | | |
| | PB6112 | 19 BIRCH DARIEN | A | | 3 | | |
| | PB6113 | 10 COLONY DARIEN | A | | 3 1 | | |
| | PB6256 | 25 RAYMOND ST DAR | A | | 3 | | |
| | F DU230 | 25 NATIVIOND 31 DAIN | ^ | | J | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

| | | | | | | <u> </u> | | | |
|---------------|--------------------|-------|--------------|-------------|---------|----------------|--------------|------------|-----------------|
| PWS ID | PWS Name | | | | | Classification | Population | Owner Type | Primary Source |
| CT0350011 | AQUARION WATER CO | OF CT | -NOROTON SYS | TEM | | С | 18,737 | Р | SWP |
| Local Address | (where applicable) | | | Service | Resider | ntial Commer | cial Industr | ial Combin | ed Agricultural |
| | | | | Connections | | | | 6,844 | |

| Towns Served: DARIEN, NEW CANAAN | , NORWALK, STAMFOR | D | | | | | |
|--|--------------------|----------------------------|---------|---------------------------|--------------------|----------|---------------|
| Wa | ter System Facil | ity and Sampling Po | oint In | vento | У | | |
| Water System Water System Facility Facility ID | | Sampling Point Description | | Total Coliform Rule | Lead and Copper | Asbestos | Stage DBPF |
| | PB6257 | 12 CEDAR GATE RD DAR | A | | 3 | | |
| | PB6260 | 19 WILLIAM ST DAR | Α | | 3 | | |
| | PB6270 | 6 WOODLAND DR DAR | Α | | 3 | | |
| | PB6271 | 23 OUTLOOK DR DAR | Α | | 3 | | |
| | PB6272 | 150 GOODWVES RVR DA | Α | | 3 | | |
| | PB6273 | 61 ANDREWS DR DAR | Α | | 3 | | |
| | PB6301 | 24 HALE LANE DARIEN | Α | | 1 | | |
| | PB6303 | 58 ANDREWS DR DAR | Α | | 3 | | |
| | PB6304 | 116 RAYMOND SR DAR | Α | | 3 | | |
| | PB6306 | 5 QUEENS LAND DAR | Α | | 3 | | |
| | PB6372 | 74 HOLLOWTREE RDG | Α | | 3 | | |
| | PB6375 | 1 PHILLIPS LANE DARI | Α | | 3 | | |
| | PB6836 | 105 LEROY AVE DARIEN | Α | | 3 | | |
| | PB6841 | 5 WINDSOR ROAD DARIE | Α | | 3 | | |
| | PB8099 | 14 EDMOND STREET | Α | Υ | 1 | | |
| | PB8100 | 52 FAIRFIELD AVENUE | Α | Υ | 1 | | |
| | PB8101 | 11 OAK SHADE AVENUE | Α | Υ | 1 | | |
| | PB8102 | 12 OAK SHADE AVENUE | Α | Υ | 1 | | |
| | PB8103 | 8 PARK PLACE | Α | Υ | 1 | | |
| | PB8104 | 34 PARK PLACE | Α | Υ | 1 | | |
| | PB8105 | 40 PARK PLACE | Α | Υ | 1 | | |
| | PB8106 | 6 PINE STREET | Α | Υ | 1 | | |
| | PB8107 | 60 RAYMOND STREET | Α | Υ | 1 | | |
| | PB8109 | 5 WOODLAND DRIVE | Α | Υ | 1 | | |
| | PB8110 | 21 WOODLAND DRIVE | Α | Υ | 1 | | |
| | PB8111 | 8-A RIDGEVIEW AVE | Α | Υ | 1 | | |
| | PB8112 | 23-A ANTHONY LANE | Α | Υ | 1 | | |
| | PB8113 | 1 SILVER LAKES DRIVE | Α | Υ | 1 | | |
| | PB8114 | 2 STONEWALL LANE | Α | Υ | 1 | | |
| | PB8115 | 2 ST. NICHOLAS ROAD | Α | Υ | 1 | | |
| | PB8116 | 2 IRONWOOD LANE | Α | Υ | 1 | | |
| | PB8117 | 2 RED BARN ROAD | Α | Υ | 1 | | |
| | PB8118 | 2 LITTLEBROOK ROAD | Α | Υ | 1 | | |
| | PB8119 | 3 CLIFF AVE | Α | Υ | 1 | | |
| | PB8120 | 4 DELLWOOD ROAD | Α | Υ | 1 | | |
| | PB8121 | 4 ROCK SPRING LANE | Α | Υ | 1 | | |
| | PB8122 | 4 LOCUST HILL ROAD | Α | Υ | 1 | | |
| | PB8124 | 5 LEEDS LANE | Α | Υ | 1 | | |
| | PB8125 | 5 HIGHLAND AVE | Α | Υ | 1 | | |
| | | | | | | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

| PWS ID PWS Name Cla | | | | | ssification | Population | Owner Type | Primary Source |
|----------------------------------|-------------------------------------|-------------|---------|-------|-------------|-----------------------|------------|-----------------|
| CT0350011 | AQUARION WATER CO OF CT-NOROTON SYS | TEM | | | С | 18,737 | Р | SWP |
| Local Address (where applicable) | | Service | Resider | ntial | Commercia | I Industrial Combined | | ed Agricultural |
| | | Connections | | | | | 6,844 | |

| | Water | System Facili | ity and Sampling Po | oint Ir | nventor | У | | | |
|-------------------------------|--|----------------------|----------------------------|---------|---------------------------|---------------------------------|----------|-----|----------------|
| Water System acility ID | Water System Facility | Sampling Point ID | Sampling Point Description | Status | Total Coliform Rule | Lead and Copper Rule Tier | Asbestos | WQP | Stage 2 DBP |
| | | PB8126 | 6 MOREHOUSE DRIVE | Α | Υ | 1 | | | |
| | | PB8127 | 6 ROCK SPRING LANE | Α | Υ | 1 | | | |
| | | PB8128 | 6 LITTLEBROOK ROAD | Α | Υ | 1 | | | |
| | | PB8129 | 7 POINT O WOODS ROAD | Α | Υ | 1 | | | |
| | | PB8130 | 7 ANDREWS DRIVE | Α | Υ | 1 | | | |
| | | PB8131 | 8 RIDGEVIEW AVE | Α | Υ | 1 | | | |
| | | PB8132 | 8 OVERBROOK LANE | Α | Υ | 1 | | | |
| | | PB8133 | 8 ROCK SPRING LANE | Α | Υ | 1 | | | |
| | | PB8134 | 8 OAK PARK AVE | Α | Υ | 1 | | | |
| | | PB8135 | 9 POINT O WOODS ROAD | Α | Υ | 1 | | | |
| | | PB8136 | 9 STONY BROOK ROAD | Α | Υ | 1 | | | |
| | | PB8137 | 9 PARK PLACE | Α | Υ | 1 | | | |
| | | PB8138 | 10 ROCK SPRING LANE | Α | Υ | 1 | | | |
| | | PB8139 | 12 TOKENEKE TRAIL | Α | Υ | 1 | | | |
| | | PB8303 | PB8303 - 14 EDMOND | Α | Υ | | | | |
| | | PB8304 | 40 PEACHTREE POINT | Α | Υ | | | | |
| | | PB8892 | 15 EDGEWOOD RD | Α | | 1 | | | |
| | | PB8893 | 15 WEEDS LANDING | Α | | 1 | | | |
| | | PB8894 | 15 FIVE MILE RIVER | Α | | 1 | | | |
| | | PB8895 | 16 1/2 MAPLE ST | Α | | 1 | | | |
| | | PB8896 | 17 RAYMOND HEIGHTS | Α | | 1 | | | |
| | | UPSTREAM | WITHIN 5 SERVICE CON | Α | | | | | |
| 00700 | ENTRY POINT - REWAK WELL | 3 | ENTRY POINT - REWAK | Α | | | | | |
| 1434 | REWAK WELL | 2 | REWAK WELL | Α | | | | | |
| 44903 | INTERCONNECTION - CT1030021 - FLAX HILL | | | | | | | | |
| 48251 | INTERCONNECTION - CT0150011 - AWC MAIN | | | | | | | | |
| 48253 | INTERCONNECTION - CT1350011 - STAMFORD | | | | | | | | |
| 49515 | CHESTNUT STREET TANK 2 | | | | | | | | |
| 49517 | MANSFIELD TANK | | | | | | | | |
| 49519 | CHESTNUT STREET PUMP STATION | | | | | | | | |
| 49521 | OLD KINGS PUMP STATION | | | | | | | | |
| 49523 | PARK LANE PUMP STATION | | | | | | | | |
| 49525 | POST ROAD PUMP STATION | | | | | | | | |
| 49527 | REWAK PUMP STATION | | | | | | | | |
| 49529 | TALMADGE HILL PUMP STATION | .1 | | | | | | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

| | Connectic | ut Depa | rtment | of Public | Health | Drir | ıking | Water | Sec | ction | | | |
|-----------------------------------|------------------------------------|--------------|--|---------------------------|---------------|----------|------------------------|------------|---------|-------------------|---|--|--|
| | Wa | ter Qual | lity Mon | itoring a | and Con | nplia | nce S | chedu | le | | | | |
| PWS ID | PWS Name | | | | | Classifi | ication F | Population | Owne | er Type P | Primary Source | | |
| CT0350011 | AQUARION WAT | TER CO OF CT | -NOROTON S | SYSTEM | | (| 2 | 18,737 | | Р | SWP | | |
| Local Address | (where applicable) | | | Service Connectio | Resider | ntial Co | mmercia | l Industr | ial (| Combined 6,844 | d Agricultura | | |
| Towns Served: | DARIEN, NEW CAN | | • | | | | | | | | | | |
| | | Water Sy | stem Fac | ility and S | Sampling | Point | t Inver | ntory | | | | | |
| Water System Wa Facility ID | ter System Facility | | Sampling Poi | nt Sampling Descriptio | | Sta | Tot Colif tus Ru | orm Cop | per | Asbestos | Stage WQP 2 DBP | | |
| 58 REV | VAK WELL STATION | J | | | | | | | | | | | |
| 60644 REV | VAK CLEARWELL | | | | | | | | | | | | |
| | ERCONNECTION - 150011 - AWC MA | IN | | | | | | | | | | | |
| | ERCONNECTION - 350011 - STAMFOR | RD | | | | | | | | | | | |
| | ERCONNECTION - 350011 - STAMFOR | RD | | | | | | | | | | | |
| | ERCONNECTION - 350011 - STAMFOR | RD | | | | | | | | | | | |
| | | | Certifie | d Operato | or Inforn | nation | 1 | | | | | | |
| Water Syster | n Facility: DISTR | IBUTION SY | STEM (WSI | F ID: 00600) | | | | | | | | | |
| Facility Classif | ication: CLASS 2 D | ISTRIBUTION | SYSTEM | | | | | | | | Certification | | |
| Operator Nam | e | | Operator T | уре | Certification | on(s) | | | | | Expiration | | |
| HORN, ROBER | Г | | CHIEF OPERA | TOR | DISTRIBUT | ION SYS | ГЕМ ОРЕ | RATOR - C | LASS II | I | 6/30/2025 | | |
| | | | | | WATER TR | EATMEN | IT PLANT | OPERATO | R - CLA | ASS III | 6/30/2025 | | |
| Water Syster | n Facility: REWA | K WELL STA | ATION (WSF | ID: 58) | | | | | | | | | |
| Facility Classif | ication: CLASS 2 TF | REATMENT PI | LANT | | | | | | | | Certification | | |
| Operator Nam | e | | Operator T | уре | Certification | on(s) | | | | | Expiration | | |
| MEDD, DAVID | | | CHIEF OPERA | TOR | WATER TR | EATMEN | IT PLANT | OPERATO | R - CLA | ASS IV | Expiration 6/30/2025 6/30/2025 Certification Expiration 6/30/2024 | | |
| REPPUCCI, ED | WARD | | ASSIGNED OF | PERATOR | WATER TR | EATMEN | IT PLANT | OPERATO | R - CLA | ASS IV | 6/30/2026 | | |
| | | | | | DISTRIBUT | ION SYS | ГЕМ ОРЕ | RATOR - C | LASS II | | 6/30/2026 | | |
| | | | Co | ontact Info | ormation | า | | | | | | | |
| Name | | | | Organization | | | | | | Job Title | | | |
| Mr. John P. W | alsh | | | Aquarion Wa | ter Compan | У | | Vice Pres | ident | | | | |
| Mailing Addre | ss Line One | | Mailing Addr | ess Line Two | | | | City | | State | Zip Code | | |
| 835 Main Stre | et | | Mail Stop 70 | 0 | | | Bridgep | ort | | СТ | 06604 | | |
| Business Pho | one Extension | Fax | Мо | bile Phone | Emergence | y Phone | Email Ad | ddress | | | | | |
| 203-337-58 | 52 | 203-337-5 | 5938 | | 781-413 | -6175 | jwalsh@ | aquarion | water.c | com | | | |
| Contact Role(s |): Legal Contact | | | | | | | | | | | | |
| Name | | | | Organization | | | | | | Job Title | | | |
| Mr. Robert J. I | | | | Aquarion Wa | ter Compan | y of Ct | | Vp-Suppl | y & Ut | ility | | | |
| Mailing Addre | ss Line One | | Mailing Addr | ess Line Two | | | | City | | State | Zip Code | | |
| | | | t and the second se | | | | 1 | | | - 1 I | | | |

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Shelton

rulrich@aquarionwater.com

Emergency Phone Email Address

203-395-3205

 CT

06484

505 Huntington St.

Mobile Phone

Fax

203-929-5297

Aquarion Water Company of Ct

Contact Role(s): Administrative Contact

Extension

Business Phone

203-926-4320

| Connecticut Department of Public Health | Drinking | g Water | Section | |
|---|------------|--------------|---------|-------|
| Water Quality Monitoring and Con | npliance S | Schedul | e | |
| DIA/C NI | Cl:f:+: | Demoderation | O | Delin |

| PWS ID PWS Name CI | | | | | on P | opulation | Owner Type | Primary Source |
|----------------------------------|-------------------------------------|-------------|---------|------------|-------|------------|------------|-----------------|
| CT0350011 | AQUARION WATER CO OF CT-NOROTON SYS | TEM | | С | | 18,737 | Р | SWP |
| Local Address (where applicable) | | Service | Resider | itial Comm | ercia | l Industri | al Combine | ed Agricultural |
| | | Connections | | | | | 6,844 | |

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

Please note the following:

- 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- 2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
- 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

http://www.ct.gov/dph/publicdrinkingwater

End of schedule