

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0700011</b>	<b>CTWC - JENSSENS BEECHWOOD SYSTEM</b>	C	750	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			296				

Towns Served: KILLINGWORTH

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Asbestos (1094)** **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		

**Total Coliform (3100)** **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

**Lead And Copper (PBCU)** **10 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/23	6/1-9/30	Complete
	1/1/24 - 12/31/24	6/1-9/30	
	1/1/25 - 12/31/25	6/1-9/30	

**Physical Parameters (PPS)** **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT (WSF ID: 00701)**

**Net Gross Alpha (4000)** **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/23 - 12/31/23		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0700011</b>	<b>CTWC - JENSSENS BEECHWOOD SYSTEM</b>	C	750	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			296				

Towns Served: KILLINGWORTH

### Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00701)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		
<b>Uranium (4006)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0700011	CTWC - JENSENS BEECHWOOD SYSTEM	C	750	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			296				

Towns Served: KILLINGWORTH

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	10/7/2023	10/5/2023
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	1/5/2024	10/10/2023
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CAP - ADDRESS DEFICIENCY	11/30/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2029	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	1 BEECHWOOD	1 BEECHWOOD RD	A	Y			
		1 STONEWALL	1 STONEWALL DRIVE	A	Y			
		1 WHITEWOOD	1 WHITEWOOD ROAD	A	Y			
		11 PLEASANT	11 PLEASANT TRAIL	A	Y	3		
		17 STONEWAL	17 STONEWALL DRIVE	A	Y			
		18 PLEASANT	18 PLEASANT TRAIL	A	Y	3		
		18 WOODLAND	18 WOODLAND TRAIL	A	Y			
		1850	BEECHWOOD DISTRIBUTI	A	Y			
		18801	LEAD COPPER SITE 1 B	A	Y			
		18802	LEAD COPPER SITE 2 B	A	Y			
		18803	LEAD COPPER SITE 3 B	A	Y			
		18804	LEAD COPPER SITE 4 B	A	Y			
		18805	LEAD COPPER SITE 5 B	A	Y			
		18806	LEAD COPPER SITE 6 B	A	Y			
		18807	LEAD COPPER SITE 7 B	A	Y			
		18808	LEAD COPPER SITE 8 B	A	Y			
		18809	LEAD COPPER SITE 9 B	A	Y			
		18810	LEAD COPPER SITE 10	A	Y			
		18811	14 BEECHWOOD RD	A				1
		18812	15 BEECHWOOD RD	A				1
		18813	6 COUNTRY CLUB TRAIL	A				1
		18814	10 LIVEMORE TRAIL	A				1
18815	2 PLEASANT TRAIL	A				1		
18816	5 STONEWALL DR	A				1		
18817	28 WHITEWOOD RD	A				1		
18818	16 WOODLAND TRAIL	A				1		
18819	20 WOODLAND TRAIL	A				1		
18820	27 WOODLAND TRAIL	A				1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0700011</b>	<b>CTWC - JENSENS BEECHWOOD SYSTEM</b>	C	750	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			296				

Towns Served: KILLINGWORTH

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		18821	3 BEECHWOOD RD	A		3		
		18822	8 BEECHWOOD RD	A		3		
		18823	10 BEECHWOOD RD	A		3		
		18824	1 BOULDER TRAIL	A		3		
		18825	6 BOULDER TRAIL	A		3		
		18826	7 BOULDER TRAIL	A		3		
		18827	8 BOULDER TRAIL	A		3		
		18828	9 BOULDER TRAIL	A		3		
		18829	10 BOULDER TRAIL	A		3		
		18830	12 BOULDER TRAIL	A		3		
		18831	13 BOULDER TRAIL	A		3		
		18832	15 BOULDER TRAIL	A		3		
		18833	16 BOULDER TRAIL	A		3		
		18834	17 BOULDER TRAIL	A		3		
		18835	18 BOULDER TRAIL	A		3		
		18836	41 BOULDER TRAIL	A		3		
		18837	42 BOULDER TRAIL	A		3		
		18838	43 BOULDER TRAIL	A		3		
		18839	44 BOULDER TRAIL	A		3		
		18840	45 BOULDER TRAIL	A		3		
		18841	46 BOULDER TRAIL	A		3		
		18842	7 BRIDLEPATH TRAIL	A		3		
		18843	9 BRIDLEPATH TRAIL	A		3		
		18844	14 BRIDLEPATH TRAIL	A		3		
		18845	16 BRIDLEPATH TRAIL	A		2		
		18846	18 BRIDLEPATH TRAIL	A		3		
		18847	27 BRIDLEPATH TRAIL	A		3		
		18848	30 BRIDLEPATH TRAIL	A		3		
		18849	31 BRIDLEPATH TRAIL	A		3		
		18850	32 BRIDLEPATH TRAIL	A		3		
		18851	33 BRIDLEPATH TRAIL	A		3		
		18852	34 BRIDLEPATH TRAIL	A		3		
		18853	42 BRIDLEPATH TRAIL	A		3		
		18854	43 BRIDLEPATH TRAIL	A		3		
		18855	44 BRIDLEPATH TRAIL	A		3		
		18856	8 COUNTRY CLUB TRL	A		3		
		18857	9 COUNTRY CLUB TRL	A		3		
		18858	10 COUNTRY CLUB TRL	A		3		
		18859	12 COUNTRY CLUB TRL	A		3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0700011</b>	<b>CTWC - JENSENS BEECHWOOD SYSTEM</b>	C	750	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			296				

Towns Served: KILLINGWORTH

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		18860	14 COUNTRY CLUB TRL	A		3		
		18861	16 COUNTRY CLUB TRL	A		3		
		18862	3 HILLDALE TRAIL	A		3		
		18863	7 HILLDALE TRAIL	A		3		
		18864	9 HILLDALE TRAIL	A		3		
		18865	11 HILLDALE TRAIL	A		3		
		18866	15 HILLDALE TRIAL	A		3		
		18867	2 LIVEMORE TRAIL	A		3		
		18868	3 LIVEMORE TRAIL	A		3		
		18869	4 LIVEMORE TRAIL	A		3		
		18870	18 LIVEMORE TRAIL	A		3		
		18871	19 LIVEMORE TRAIL	A		3		
		18872	20 LIVEMORE TRAIL	A		3		
		18873	21 LIVEMORE TRAIL	A		3		
		18874	7 PLEASANT TRAIL	A		3		
		18875	10 PLEASANT TRAIL	A		3		
		18876	11 PLEASANT TRAIL	A		3		
		18877	12 PLEASANT TRAIL	A		3		
		18878	14 PLEASANT TRAIL	A		3		
		18879	18 PLEASANT TRAIL	A		3		
		18880	19 PLEASANT TRAIL	A	Y	3		
		18881	2 STONEWALL DR	A		3		
		18882	4 STONEWALL DR	A		3		
		18883	6 STONEWALL DR	A		3		
		18884	7 STONEWALL DR	A		3		
		18885	9 STONEWALL DR	A		3		
		18886	18 STONEWALL DR	A		3		
		18887	19 STONEWALL DR	A		3		
		18888	20 STONEWALL DR	A		3		
		18889	2 SWANLAKE TRAIL	A		3		
		18890	4 SWANLAKE TRAIL	A		3		
		18891	8 SWAN LAKE TRAIL	A		3		
		18892	14 SWAN LAKE TRAIL	A		3		
		18893	22 SWAN LAKE TRAIL	A		3		
		18894	24 SWAN LAKE TRAIL	A		3		
		18895	26 SWAN LAKE TRAIL	A		3		
		18896	36 SWAN LAKE TRAIL	A		3		
		18897	42 SWAN LAKE TRAIL	A		3		
		18898	44 SWAN LAKE TRAIL	A		3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0700011</b>	<b>CTWC - JENSENS BEECHWOOD SYSTEM</b>	C	750	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		296					

Towns Served: KILLINGWORTH

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		18899	2 WHITEWOOD RD	A		3		
		18900	3 WHITEWOOD RD	A		3		
		18901	6 WHITEWOOD RD	A		3		
		18902	10 WHITEWOOD RD	A		3		
		18903	11 WHITEWOOD RD	A		3		
		18904	12 WHITEWOOD RD	A		3		
		18905	22 WHITEWOOD RD	A		3		
		18906	23 WHITEWOOD RD	A		3		
		18907	25 WHITEWOOD RD	A		3		
		18908	41 WHITEWOOD RD	A		3		
		18909	42 WHITEWOOD RD	A		3		
		18910	1 WOODLAND TRAIL	A		1		
		18911	2 WOODLAND TRAIL	A		3		
		18912	9 WOODLAND TRAIL	A		3		
		18913	11 WOODLAND TRAIL	A		3		
		18914	12 WOODLAND TRAIL	A		3		
		18915	14 WOODLAND TRAIL	A		3		
		18916	17 WOODLAND TRAIL	A		3		
		18917	28 WOODLAND TRAIL	A		3		
		18918	29 WOODLAND TRAIL	A		3		
		18919	44 WOODLAND TRAIL	A		3		
	2 BRIDLEPAT	2 BRIDLEPAT	2 BRIDLEPATH TRAIL	A	Y			
	2 COUNTRY	2 COUNTRY	2 COUNTRY CLUB	A	Y	3		
	20 BEECHWOOD	20 BEECHWOOD	20 BEECHWOOD ROAD	A	Y			
	20 BOULDER	20 BOULDER	20 BOULDER TRAIL	A	Y			
	21 COUNTRY	21 COUNTRY	21 COUNTRY CLUB	A	Y	3		
	22 WOODLAND	22 WOODLAND	22 WOODLAND TRAIL	A	Y			
	25 WHITEWOOD	25 WHITEWOOD	25 WHITEWOOD ROAD	A	Y	3		
	29 BRIDLEPA	29 BRIDLEPA	29 BRIDLEPATH TRAIL	A	Y			
	3 BRIDLEPAT	3 BRIDLEPAT	3 BRIDLEPATH TRAIL	A	Y			
	3 WOODLAND	3 WOODLAND	3 WOODLAND TRAIL	A	Y			
	36 SWAN LAK	36 SWAN LAK	36 SWAN LAKE TRAIL	A	Y			
	38 BRIDLEPA	38 BRIDLEPA	38 BRIDLEPATH TRAIL	A	Y			
	4	4	DISTRIBUTION SYSTEM	A	Y			
	4 WOODLAND	4 WOODLAND	4 WOODLAND TRAIL	A	Y			
	42 BOULDER	42 BOULDER	42 BOULDER TRAIL	A	Y	3		
	42 WOODLAND	42 WOODLAND	42 WOODLAND TRAIL	A	Y			
	46 WOODLAND	46 WOODLAND	46 WOODLAND TRAIL	A	Y			
	5 BRIDLEPAT	5 BRIDLEPAT	5 BRIDLEPATH TRAIL	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0700011	CTWC - JENSENS BEECHWOOD SYSTEM	C	750	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		296					

Towns Served: KILLINGWORTH

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		8 BEECHWOOD	8 BEECHWOOD ROAD	A	Y	3		
		BAC 104	11 CHRIS DRIVE	A	Y			
		BWD5000	BEECHWOOD SMPL STAT	A	Y			
		BWDCLUBH	BWD CLUBHOUSE	A	Y			
		BWDMC	MAINTENANCE CENTER	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT	3	ENTRY POINT	A				
52803	BEECHWOOD ATM STORAGE							
52805	BRIDLE PATH ATM STORAGE							
52807	BEECHWOOD PRESSURE STORAGE							
52809	BRIDLE PATH PRESSURE STORAGE							
57347	TREATMENT PLANT							
731	WELL 3	2	WELL 3	A				
732	WELL 4	2	WELL 4	A				
923	WELL 2	2	WELL 2	A				

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
JARISH, KEVIN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2024
HINES, DAVE	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2024
KORNATZ, CHRISTOPHER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2024

**Water System Facility: TREATMENT PLANT (WSF ID: 57347)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2024
ANDREWS, PAUL M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2024

### Contact Information

Name		Organization			Job Title			
Mr. Craig J. Patla		Connecticut Water Company			Vp, Service Delivery			
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 West Main Street						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-664-6140				800-391-1924	craig.patla@ctwater.com			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
<b>CT0700011</b>	<b>CTWC - JENSENS BEECHWOOD SYSTEM</b>	<b>C</b>	<b>750</b>	<b>P</b>	<b>GW</b>			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
		296						
Towns Served: KILLINGWORTH								
Contact Role(s): <b>Legal Contact, Owner</b>								
Name			Organization			Job Title		
<b>Mr. Gerald McDermott</b>			The Connecticut Water Company			Manager, Service Del		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 West Main Street						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-664-6125					ctwcdphadmin@ctwater.com			
Contact Role(s): <b>Administrative Contact</b>								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***



# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0709133</b>	<b>M&amp;M REALTY HOLDINGS LLC</b>	C	87	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
257 ROUTE 80			1				

Towns Served: KILLINGWORTH

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

### Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		

### Total Coliform (3100) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

### Lead And Copper (PBCU) 5 routine (RT) per six months

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

### Physical Parameters (PPS) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

### Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0709133</b>	<b>M&amp;M REALTY HOLDINGS LLC</b>	C	87	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
257 ROUTE 80			1				

Towns Served: KILLINGWORTH

## Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

## Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
E. Coli M&R Violation	10/10/22 - 6/30/23	3	5/24/2024		6/3/2024	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage 2</i>	<i>WQP DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y				
		MM1-A	UNIT 1A	A	Y	N	Y	Y	
		MM1-B	UNIT 1B	A	Y	N	Y	Y	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0709133</b>	<b>M&amp;M REALTY HOLDINGS LLC</b>	C	87	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
257 ROUTE 80			1				

Towns Served: KILLINGWORTH

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MM2-A	UNIT 2A	A	Y	N	Y	Y
		MM2-B	UNIT 2B	A	Y	N	Y	Y
		MM2-C	UNIT 2C	A	Y	N	Y	Y
		MM2-D	UNIT 2D	A	Y	N	Y	Y
		MM3-A	UNIT 3A	A	Y	N	Y	Y
		MM3-B	UNIT 3B	A	Y	N	Y	Y
		MM3-C	UNIT 3C	A	Y	N	Y	Y
		MM3-D	UNIT 3D	A	Y	N	Y	Y
		MM3-E	UNIT 3E	A	Y	N	Y	Y
		MM3-F	UNIT 3F	A	Y	N	Y	Y
		MM4-A	UNIT 4A	A	Y	N	Y	Y
		MM4-B	UNIT 4B	A	Y	N	Y	Y
		MM4-C	UNIT 4C	A	Y	N	Y	Y
		MM4-D	UNIT 4D	A	Y	N	Y	Y
		PH601	FLOOR L CAFETERIA	A	Y	N		
		PH602	FLOOR M CAFETERIA	A		N		
		PH603	FLOOR M W/FOUNTAIN	A		N		
		PH604	FLOOR U CAFETERIA	A		N		
		PH605	FLOOR U W/CAFETERIA	A		N		
00700	ENTRY POINT	3	ENTRY POINT	A				
10951	WELL #1	2	RAW WATER	A				

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
BRAIG, ALLEN L.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024
BRAIG, SUSAN R.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2025

### Contact Information

Name		Organization			Job Title		
<b>Mr. Eugene Gargiulo</b>		M&M Realty Holdings, LLC			Owner / Member		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
104 Commerce Circle					Durham	CT	06422
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-349-6370		860-349-6364			estimate.gargiulo@comcast.net		
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0709133</b>	<b>M&amp;M REALTY HOLDINGS LLC</b>	<b>C</b>	<b>87</b>	<b>P</b>	<b>GW</b>		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
257 ROUTE 80			1				

Towns Served: KILLINGWORTH

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**