

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720011	SCWA, BARRETT DIVISION (BAR)	C	300	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			75				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		

Total Haloacetic Acids (2456) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
21 MARLA AVENUE (BAR05)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	

Total Trihalomethanes (2950) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
1876 CENTER GROTON (BAR02)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	

Total Coliform (3100) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Lead And Copper (PBCU) 5 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/23	6/1-9/30	Complete
	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720011	SCWA, BARRETT DIVISION (BAR)	C	300	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			75				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720011	SCWA, BARRETT DIVISION (BAR)	C	300	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			75				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.3 MG/L	Continuous
Start Date: 10/1/2020		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 7/1/2003		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2011	
CROSS CONNECTION EXEMPTION	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720011	SCWA, BARRETT DIVISION (BAR)	C	300	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			75				

Towns Served: LEDYARD

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BAR01	19 MARLA AVENUE	A	Y	3		
		BAR02	1876 CENTER GROTON	A		3		Y
		BAR03	41 LAKE STREET	A		3		
		BAR04	11 MARLA AVENUE	A		3		
		BAR05	21 MARLA AVENUE	A		3		Y
		BAR06	3 MARLA AVENUE	A		3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
	UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A				
1729	WELL 4A	2	WELL 4A	A				
51595	ATMOSPHERIC TANK							
51597	HYDROPNEUMATIC TANK							
687	BARRETT DIVISION TREATMENT PLANT							
790	WELL 4	2	WELL 4	A				

Certified Operator Information

Water System Facility: BARRETT DIVISION TREATMENT PLANT (WSF ID: 687)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BELAIR, BRANDON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2024
RICKEY, JR., RAYMOND R	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
MCGARRY, THOMAS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024

Contact Information

Name		Organization			Job Title		
Mr. Joseph Cansler		SCWA			General Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
P.O. Box 415		1649 Route 12			Gales Ferry	CT	06335-0415
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-464-0232		860-464-2876	860-941-3406		j.cansler@waterauthority.org		
Contact Role(s): Administrative Contact							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0720011	SCWA, BARRETT DIVISION (BAR)	C	300	L	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
			75					
Towns Served: LEDYARD								
Name			Organization			Job Title		
Dr. Edward C. Monahan			Southeastern CT Wtr. Authority			Chairman		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
1649 Route 12			PO Box 415			Gales Ferry	CT	06335-0415
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-464-0232		860-464-2876	860-941-9246		ed.monahan@comcast.net			
Contact Role(s): Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012) 3 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete

Asbestos (1094) 2 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		

Total Alkalinity (1927) 2 routine (RT) per six months

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		Complete
	7/1/24 - 12/31/24		

Total Haloacetic Acids (2456) 2 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
11 FERRYVIEW DR (TWR-FVH04)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	
30 LINCOLN DR. (TWR-FVH25)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	

Total Trihalomethanes (2950) 2 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
2 WHIPOORWILL DRIVE (TWR-FVH17)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	
8 PALMER DRIVE (TWR-FVH19)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	

Total Coliform (3100) 3 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)	3 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Lead And Copper (PBCU)	20 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

Physical Parameters (PPS)	3 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT - TOWER LARGE (WSF ID: 00700)**

Total Alkalinity (1927)	1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - TL (3)	10/27/23 - 11/9/23		Complete
	11/10/23 - 11/23/23		Complete
	11/24/23 - 12/7/23		Complete
	12/8/23 - 12/21/23		Complete
	12/22/23 - 1/4/24		Complete
	1/5/24 - 1/18/24		Complete
	1/19/24 - 2/1/24		Complete
	2/2/24 - 2/15/24		Complete
	2/16/24 - 2/29/24		Complete
	3/1/24 - 3/14/24		Complete
	3/15/24 - 3/28/24		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: ENTRY POINT - TOWER LARGE (WSF ID: 00700)

Total Alkalinity (1927) 1 routine (RT) per two weeks

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/29/24 - 4/11/24		
	4/12/24 - 4/25/24		
	4/26/24 - 5/9/24		
	5/10/24 - 5/23/24		
	5/24/24 - 6/6/24		

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - TL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - TL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - TL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - TL (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		

Nitrate And Nitrite (NOX) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - TL (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - TL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - TL (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: ENTRY POINT - TOWER SMALL (WSF ID: 00701)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **ENTRY POINT - TOWER SMALL (WSF ID: 00701)**

Total Alkalinity (1927)		1 routine (RT) per two weeks		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - TS (3)	10/27/23 - 11/9/23		Complete	
	11/10/23 - 11/23/23		Complete	
	11/24/23 - 12/7/23		Complete	
	12/8/23 - 12/21/23		Complete	
	12/22/23 - 1/4/24		Complete	
	1/5/24 - 1/18/24		Complete	
	1/19/24 - 2/1/24		Complete	
	2/2/24 - 2/15/24		Complete	
	2/16/24 - 2/29/24		Complete	
	3/1/24 - 3/14/24		Complete	
	3/15/24 - 3/28/24			
	3/29/24 - 4/11/24			
	4/12/24 - 4/25/24			
	4/26/24 - 5/9/24			
5/10/24 - 5/23/24				
5/24/24 - 6/6/24				
Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - TS (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			
Nitrate And Nitrite (NOX)		1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - TS (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25			
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - TS (3)	1/1/21 - 12/31/23		Complete	
	1/1/24 - 12/31/26			
	1/1/27 - 12/31/29			
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - TS (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - TS (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **ENTRY POINT - TOWER SMALL (WSF ID: 00701)**

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - TS (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: **ENTRY POINT - FERRY VIEW HEIGHT (WSF ID: 00702)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - FVH (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - FVH (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - FVH (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - FVH (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - FVH (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - FVH (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - FVH (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - FVH (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **ENTRY POINT - FERRY VIEW HEIGHT (WSF ID: 00702)**

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: **WELL 3 (WSF ID: 1395)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **WELL 2 (WSF ID: 1396)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **WELL 1 (WSF ID: 1397)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **WELL 1 (WSF ID: 1397)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **WELL 3A (WSF ID: 1730)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3A (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **WELL 2B - FVH (WSF ID: 823)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2B - FVH (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **WELL 2B - FVH (WSF ID: 823)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/24 - 10/31/24		

Water System Facility: **WELL 2A - FVH (WSF ID: 824)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2A - FVH (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **WELL 3 - FVH (WSF ID: 825)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 - FVH (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **WELL 1 - FVH (WSF ID: 826)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 - FVH (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **WELL 1 - FVH (WSF ID: 826)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **WELL 4 - FVH (WSF ID: 837)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4 - FVH (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT - TOWER LARGE (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		
	1/1/2024 - 1/31/2024		
	2/1/2024 - 2/29/2024		
	3/1/2024 - 3/31/2024		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Water System Facility: ENTRY POINT - TOWER LARGE (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.9 PH	Daily
Start Date: 6/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	<spaces> ()	Maximum: 8.5 PH	Daily
Start Date: 6/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Water System Facility: ENTRY POINT - TOWER SMALL (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.9 PH	Daily
Start Date: 6/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		885					

Towns Served: LEDYARD

Water System Facility: ENTRY POINT - TOWER SMALL (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	<spaces> ()	Maximum: 8.5 PH	Daily
Start Date: 6/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Water System Facility: ENTRY POINT - FERRY VIEW HEIGHT (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		TWR-FVH01	5 FRIAR TUCK DRIVE	A	Y			
		TWR-FVH02	4 WHIPOORWILL DR	A	Y			
		TWR-FVH03	2 PALMER DR	A	Y		Y	
		TWR-FVH04	11 FERRYVIEW DR	A		3		Y
		TWR-FVH05	12 NUGGET HILL DR	A		3		
		TWR-FVH06	32 NORMAN DRIVE	A		3		
		TWR-FVH07	4 HERMITAGE DR	A		1		
		TWR-FVH08	27 EAGLE RIDGE RD	A		3		
		TWR-FVH09	17 OSPREY DR	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		TWR-FVH10	60 KINGS HIGHWAY	A		2		
		TWR-FVH11	30 WASHINGTON DR	A		3		
		TWR-FVH12	1 PHEASANT RUN DR	A		3		
		TWR-FVH13	12 OSPREY DR	A		3		
		TWR-FVH14	46 ROBIN HOOD DR	A		3		
		TWR-FVH15	1 FRIAR TUCK DRIVE	A	Y			
		TWR-FVH16	7 FRIAR TUCK DRIVE	A	Y			
		TWR-FVH17	2 WHIPOORWILL DRIVE	A	Y			Y
		TWR-FVH18	6 WHIPOORWILL DRIVE	A	Y			
		TWR-FVH19	8 PALMER DRIVE	A	Y			Y
		TWR-FVH20	18 NORMAN DRIVE	A	Y			
		TWR-FVH21	5 FRIAR TUCK DRIVE	A	Y			
		TWR-FVH22	18 OAKWOOD	A			Y	
		TWR-FVH23	1 NORMAN DRIVE	A				
		TWR-FVH24	34 OSPREY DRIVE	A				
		TWR-FVH25	30 LINCOLN DR.	A	Y			Y
		TWR-FVH27	7 LINCOLN DR.	A	Y			
		TWR-FVH28	3 BLUEBIRD DR.	A	Y			
		TWR-FVH30	4 WHIPPOORWILL DR.	A	Y			
		TWR-FVH31	14 HERMITAGE DR.	A	Y			
		TWR-FVH32	6 HERMITAGE DR.	A	Y			
		TWR-FVH33	19 HERMITAGE DR.	A	Y			
		TWR-FVH41	792 LONG COVE RD	A	Y			
		TWR-FVH42	13 LAUREL LEAF DR	A	Y			
		TWR-FVH43	8 WHIPPOORWILL DR	A	Y			
		TWR-FVH44	10 PARKWOOD DR	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - TOWER LARGE	3	ENTRY POINT - TL	A				
00701	ENTRY POINT - TOWER SMALL	3	ENTRY POINT - TS	A				
00702	ENTRY POINT - FERRY VIEW HEIGHT	3	ENTRY POINT - FVH	A				
128	TOWER LARGE TREATMENT PLANT	3	EP - TOWER LARGE TP	A				
1395	WELL 3	2	WELL 3	A				
1396	WELL 2	2	WELL 2	A				
1397	WELL 1	2	WELL 1	A				
1730	WELL 3A	2	WELL 3A	A				
468	TOWER SMALL TREATMENT PLANT	3	EP - TOWER SMALL TP	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			885				

Towns Served: LEDYARD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
49564	FERRY VIEW TREATMENT PLANT	3	EP - FERRY VIEW	A				
49566	TOWER LARGE TANK							
49568	TOWER SMALL ATM TANK							
49570	TOWER SMALL PRESSURE TANK							
49572	TOWER SMALL PUMP STATION							
49574	FERRY VIEW PUMP STATION							
49576	FERRY VIEW ATM TANK							
49578	FERRY VIEW PRESSURE TANK							
53112	EAGLE RIDGE RD PUMP STATION							
53114	EAGLE RIDGE RD TANK							
823	WELL 2B - FVH	2	WELL 2B - FVH	A				
824	WELL 2A - FVH	2	WELL 2A - FVH	A				
825	WELL 3 - FVH	2	WELL 3 - FVH	A				
826	WELL 1 - FVH	2	WELL 1 - FVH	A				
837	WELL 4 - FVH	2	WELL 4 - FVH	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
BELAIR, BRANDON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2024
RICKEY, JR., RAYMOND R	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024
MCGARRY, THOMAS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024

Water System Facility: TOWER LARGE TREATMENT PLANT (WSF ID: 128)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BELAIR, BRANDON W.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024
RICKEY, JR., RAYMOND R	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024
MCGARRY, THOMAS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720041	SCWA, TOWER-FERRY VIEW DIVISION	C	2,567	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		885					

Towns Served: LEDYARD

Certified Operator Information

Water System Facility: TOWER SMALL TREATMENT PLANT (WSF ID: 468)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BELAIR, BRANDON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2024
RICKEY, JR., RAYMOND R	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024
MCGARRY, THOMAS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024

Water System Facility: FERRY VIEW TREATMENT PLANT (WSF ID: 49564)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BELAIR, BRANDON W.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024
RICKEY, JR., RAYMOND R	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024
MCGARRY, THOMAS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024

Contact Information

Name		Organization			Job Title		
Mr. Joseph Cansler		SCWA			General Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
P.O. Box 415		1649 Route 12			Gales Ferry	CT	06335-0415
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-464-0232		860-464-2876	860-941-3406		j.cansler@waterauthority.org		

Contact Role(s): Administrative Contact

Name		Organization			Job Title		
Dr. Edward C. Monahan		Southeastern CT Wtr. Authority			Chairman		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
1649 Route 12		PO Box 415			Gales Ferry	CT	06335-0415
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-464-0232		860-464-2876	860-941-9246		ed.monahan@comcast.net		

Contact Role(s): Legal Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720101	ASH WATER COMPANY, LLC	C	108	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
39 ASH DRIVE			6				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		

Total Coliform (3100) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Lead And Copper (PBCU) 5 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/28	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT - WELLS 2 & 3 (WSF ID: 00701)**

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 3 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720101	ASH WATER COMPANY, LLC	C	108	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
39 ASH DRIVE			6				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLS 2 & 3 (WSF ID: 00701)**

Nitrate And Nitrite (NOX) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELLS 2 & 3 (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per nine years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELLS 2 & 3 (3)	1/1/20 - 12/31/28		

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELLS 2 & 3 (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver

Pesticides, Herbicides and PCBs - Phase II & V (SOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELLS 2 & 3 (3)	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELLS 2 & 3 (3)	1/1/23 - 12/31/23		Complete

Organic Chemicals (VOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELLS 2 & 3 (3)	1/1/26 - 12/31/28		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	3/18/2024
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW020	BLDG 4 LAUNDRY ROOM	A	Y	3		
		MW020-1	APT 1	A	Y	3		
		MW020-10	APT 10	A	Y	3		
		MW020-13	APT 13	A	Y	3		
		MW020-14A	APT 14A	A	Y	3		
		MW020-18	APT 18	A	Y	3		
		MW020-2	APT 2	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720101	ASH WATER COMPANY, LLC	C	108	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
39 ASH DRIVE		6					

Towns Served: LEDYARD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MW020-20	APT 20	A	Y	3		
		MW020-24	APT 24	A	Y	3	Y	
		MW020-25	UNIT 25	A	Y	3		
		MW020-30	APT 30	A	Y	3		
		MW020-33	APT 33	A	Y	3		
		MW020-4	APT 4	A	Y	3		
		MW020-8	APT 8	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - WELLS 2 & 3	3	EP - WELLS 2 & 3	A				
54063	WELL 2	2	WELL 2	A				
54065	WELL 3	2	WELL 3	A				
54067	MASS ATMOSPHERIC TANK							
54069	MASS PRESSURE TANK							
54071	PUMP STATION							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2024

Contact Information

Name		Organization			Job Title		
Mr. Nathan B. Weiss		Ash Water & Sunny Waters LLC			Member		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
PO Box 577					Gales Ferry	CT	06335-0577
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-464-6789		860-464-6329		860-464-5678	NathanWeiss@Comcast.net		

Contact Role(s): Legal Contact, Owner

Name		Organization			Job Title		
Mr. Mark Coen		Ash Water Company, LLC			Member		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
P.O. Box 577					Gales Ferry	CT	06335-0577
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-446-8088				860-446-8088			

Contact Role(s): Legal Contact, Owner

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0720101	ASH WATER COMPANY, LLC	C	108	P	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
39 ASH DRIVE			6					
Towns Served: LEDYARD								
Name			Organization			Job Title		
Mr. Matt J. Riley			Afreehold Management			Member		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
PO Box 827						Norwich	CT	06360
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-222-3997	12	860-222-3998		860-367-2220	matt@freeholdre.com			
Contact Role(s): Administrative Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720313	SCWA, LEDYARD CENTER DIVISION	C	652	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22	5			

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/15 - 12/31/23		Complete
	1/1/24 - 12/31/32		

Total Haloacetic Acids (2456) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
1 COLBY DRIVE (LYD02)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	

Total Trihalomethanes (2950) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
41A IRON STREET (LYD07)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	

Total Coliform (3100) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Lead And Copper (PBCU) 10 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/23	6/1-9/30	Complete
	1/1/24 - 12/31/24	6/1-9/30	
	1/1/25 - 12/31/25	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720313	SCWA, LEDYARD CENTER DIVISION	C	652	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22	5			

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720313	SCWA, LEDYARD CENTER DIVISION	C	652	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22	5			

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.5 MG/L	Continuous
Start Date: 10/1/2020			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023	Y	
	12/1/2023 - 12/31/2023	Y	
	1/1/2024 - 1/31/2024	Y	
	2/1/2024 - 2/29/2024		
	3/1/2024 - 3/31/2024		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LYD01	10 FAIRWAY DRIVE	A	Y	N	Y	
		LYD02	1 COLBY DRIVE	A		N		Y
		LYD03	1B COLBY DRIVE	A		N		
		LYD04	14 FAIRWAY DRIVE	A		N		
		LYD05	14B FAIRWAY DRIVE	A		N		
		LYD07	41A IRON STREET	A	Y			Y
		LYD08	9 REUVEN DR.	A	Y	3		
		LYD09	113 SPICER HILL RD.	A	Y	N		
		LYD10	6 SEABURY AVE.	A	Y	3		
		LYD11	24 SEABURY AVE.	A	Y	3		
		LYD12	55 IRON ST.	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720313	SCWA, LEDYARD CENTER DIVISION	C	652	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		22	5				

Towns Served: LEDYARD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LYD13	59 IRON ST.	A	Y	3		
		LYD14	77 IRON ST.	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10340	WELL #1	2	WELL	A				
50168	WELL #2	2	WELL #2	A				
50170	ATMOSPHERIC TANK							
50172	PRESSURE TANK							
58406	TREATMENT PLANT							
62510	SPICER HILL BOOSTER STATION							

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 58406)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BELAIR, BRANDON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2024
RICKEY, JR., RAYMOND R	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
MCGARRY, THOMAS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024

Contact Information

Name	Organization	Job Title			
Mr. Joseph Cansler	SCWA	General Manager			
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code	
P.O. Box 415	1649 Route 12	Gales Ferry	CT	06335-0415	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-464-0232		860-464-2876	860-941-3406		j.cansler@waterauthority.org

Contact Role(s): **Administrative Contact**

Name	Organization	Job Title			
Dr. Edward C. Monahan	Southeastern CT Wtr. Authority	Chairman			
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code	
1649 Route 12	PO Box 415	Gales Ferry	CT	06335-0415	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-464-0232		860-464-2876	860-941-9246		ed.monahan@comcast.net

Contact Role(s): **Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0720313	SCWA, LEDYARD CENTER DIVISION	C	652	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22	5			

Towns Served: LEDYARD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727031	SCWA, CHRISWOOD DIVISION (CWD)	C	164	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			43				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094) 1 routine (RT) per nine years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		

Total Coliform (3100) 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Lead And Copper (PBCU) 5 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/23	6/1-9/30	Complete
	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/22 - 12/31/24		
	1/1/25 - 12/31/27		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727031	SCWA, CHRISWOOD DIVISION (CWD)	C	164	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			43				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		
	1/1/2024 - 1/31/2024		
	2/1/2024 - 2/29/2024		
	3/1/2024 - 3/31/2024		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2011	
CROSS CONNECTION EXEMPTION	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP	2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		CWD01	35 BARTON LN	A	Y				
		CWD02	38 BARTON LN	A		1			
		CWD03	37 CHRISWOOD TRACE	A		N			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727031	SCWA, CHRISWOOD DIVISION (CWD)	C	164	L	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		43					

Towns Served: LEDYARD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CWD04	19 CHRISWOOD TRACE	A		N		
		CWD05	46 CHRISWOOD TRACE	A		N		
		CWD06	43 CHRISWOOD TRACE	A		N		
		CWD07	39 CHRISWOOD TRACE	A		N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
469	CWD PUMPHOUSE							
51599	ATMOSPHERIC TANK							
51601	HYDROPNEUMATIC TANK							
834	WELL 2	2	WELL 2	A				
835	WELL 3	2	WELL 3	A				
836	WELL 4	2	WELL 4	A				

Certified Operator Information

Water System Facility: CWD PUMPHOUSE (WSF ID: 469)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BELAIR, BRANDON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2024
RICKEY, JR., RAYMOND R	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
MCGARRY, THOMAS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2024

Contact Information

Name			Organization			Job Title		
Mr. Joseph Cansler			SCWA			General Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P.O. Box 415			1649 Route 12			Gales Ferry	CT	06335-0415
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-464-0232		860-464-2876	860-941-3406		j.cansler@waterauthority.org			
Contact Role(s): Administrative Contact								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source			
CT0727031	SCWA, CHRISWOOD DIVISION (CWD)	C	164	L	GW			
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
		43						
Towns Served: LEDYARD								
Name			Organization			Job Title		
Dr. Edward C. Monahan			Southeastern CT Wtr. Authority			Chairman		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
1649 Route 12			PO Box 415			Gales Ferry	CT	06335-0415
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-464-0232		860-464-2876	860-941-9246		ed.monahan@comcast.net			
Contact Role(s): Legal Contact								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727051	LEDYARD WPCA, GALES FERRY SYSTEM	C	2,369	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			589	51			

Towns Served: GROTON, LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012) 4 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		

Total Haloacetic Acids (2456) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HENNY PENNY RT. 12 (AR34706)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	

Total Trihalomethanes (2950) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOLMBERG ORCHARD (AR34708)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	

Total Coliform (3100) 4 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Lead And Copper (PBCU) 20 routine (RT) per six months

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727051	LEDYARD WPCA, GALES FERRY SYSTEM	C	2,369	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			589	51			

Towns Served: GROTON, LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	4 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		AR34706	HENNY PENNY RT. 12	A				Y
		AR34708	HOLMBERG ORCHARD	A				Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		GF002	1026 LONG COVE ROAD	A	Y			
		GF003	RT 12 NEAR INCH	A	Y			
		GF004	DUNKIN DONUTS GF	A	Y			
		GF005	MCDONALDS GF	A	Y			
		GF007	BLUFF ROAD METER	A	Y			
		GF008	GF LIBRARY	A	Y			
		GF009	FD FIRE DEPT	A	Y			
		GF010	DOW CHEMICAL	A	Y			
		GF011	CHEM BLDG RT 12	A	Y			
		GF012	JW LONG MID SCH	A	Y			
		GF013	23 CARDINAL LANE	A			1	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727051	LEDYARD WPCA, GALES FERRY SYSTEM	C	2,369	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			589	51			

Towns Served: GROTON, LEDYARD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		GF014	GF PUMPHOUSE HYD	A			Y	
		GF015	17 INCHCLIFFE DR	A		1		
		GF016	34R TANAGER LANE	A		1		
		GF017	16 HARVARD TERR	A		1		
		GF018	10 SLEEP HOLLOW PNT	A		1		
		GF019	4 SMITH POND WAY	A		1		
		GF020	8 WOODBRIDGE CIRC	A		1		
		GF021	76 STONYBROOK RD	A		1		
		GF022	10 RIDGE ROAD	A		1		
		GF023	1085 LONG COVE RD	A		1		
		GF024	UNITED WAY BLDG	A	Y			
		GF025	12 WOODRIDGE CIRC	A		1		
		GF026	1 SLEEP HOLLOW PNT	A		1		
		GF027	1010 LONG COVE RD	A		1		
		GF028	25 INCHCLIFFE DR	A		1		
		GF029	44 INCECLIFFE RD	A		1		
		GF030	72 INCHCLIFFE DR	A		1		
		GF031	58 HURLBUTT DR	A		1		
		GF032	8 NAOMI DRIVE	A				
		GF033	4 ALJEAN HEIGHTS LA	A	Y	3		
		GF034	59 INCHCLIFFE DR.	A		3		
		GF035	240 AVERY HILL RD.	A		1		
		GF036	5 WINDWARD LANE	A		1		
		GF037	14 WOODRIDGE CIRCLE	A		1		
		GF038	57 INCHCLIFFE DR.	A		3		
		GF039	9 WOODLAND LANE	A	Y	1		
		GF040	213 AVERY HILL RD.	A	Y	1		
		GF041	41 OVERLOOK RD	A		3		
		GF042	14 NAOMI DRIVE	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21644	INTERCONNECTION - CT0590011 - GROTON							
53565	HOLMBERG ORCHARD TANK							
58943	HOLMBERG PUMP STATION							
58945	AVERY HILL HYDRO TANK							

Certified Operator Information

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727051	LEDYARD WPCA, GALES FERRY SYSTEM	C	2,369	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			589	51			

Towns Served: GROTON, LEDYARD

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
DUARTE, MAURICIO E	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026

Contact Information

Name		Organization	Job Title			
Mr. Fred Allyn, III		Town of Ledyard	Mayor			
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
741 Colonel Ledyard Highway				Ledyard	CT	06339-1511
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-464-3221		860-464-8455			mayor@ledyardct.org	

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0723011	MASHANTUCKET PEQUOT TRIBAL NATION	C	41,000	N	GU		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			300				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012) **15 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete

Chlorine Residual (1012) **40 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 1/31/24		
	2/1/24 - 2/29/24		
	3/1/24 - 3/31/24		

Asbestos (1094) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/16 - 12/31/24		
	1/1/25 - 12/31/33		

Total Haloacetic Acids (2456) **4 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		
	1/1/24 - 3/31/24		
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Total Trihalomethanes (2950) **4 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/23 - 12/31/23		
	1/1/24 - 3/31/24		
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Total Coliform (3100) **15 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete

Total Coliform (3100) **40 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 1/31/24		
	2/1/24 - 2/29/24		
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0723011	MASHANTUCKET PEQUOT TRIBAL NATION	C	41,000	N	GU		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			300				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100) **40 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/24 - 10/31/24		

Lead And Copper (PBCU) **30 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/28	6/1-9/30	

Physical Parameters (PPS) **40 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 1/31/24		
	2/1/24 - 2/29/24		
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Physical Parameters (PPS) **15 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete

Water System Facility: **ENTRY POINT #1 - WTP (WSF ID: 00700)**

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0723011	MASHANTUCKET PEQUOT TRIBAL NATION	C	41,000	N	GU		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			300				

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **ENTRY POINT #1 - WTP (WSF ID: 00700)**

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs - Phase II & V (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT #1 - WTP (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2009	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		
	1/1/2024 - 1/31/2024		
	2/1/2024 - 2/29/2024		
	3/1/2024 - 3/31/2024		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 2/1/2009	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		
	1/1/2024 - 1/31/2024		
	2/1/2024 - 2/29/2024		
	3/1/2024 - 3/31/2024		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 2/1/2009	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0723011	MASHANTUCKET PEQUOT TRIBAL NATION	C	41,000	N	GU		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			300				

Towns Served: LEDYARD

Water System Facility: ENTRY POINT #1 - WTP (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 2/1/2009		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	Y

Water System Facility: MASHANTUCKET PEQUOT WTP (WSFID: 311)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2009		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
	Offline	11/1/2023 - 11/30/2023	n/a
		12/1/2023 - 12/31/2023	Y
	Offline	1/1/2024 - 1/31/2024	n/a
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 2/1/2009		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 2/1/2009		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	Y

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	6/15/2020	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0723011	MASHANTUCKET PEQUOT TRIBAL NATION	C	41,000	N	GU		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		300					

Towns Served: LEDYARD

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		D-1	2 MG TANK	A	Y			
		D-10	CASINO KITCHEN	A	Y			
		D-11	WATER TREATMENT PLT.	A	Y			
		D-12	4 PEQUOT CIRCLE	A	Y		N	
		D-13	CENTRAL PLANT	A	Y			
		D-14	PHASE 4 CASINO	A	Y			
		D-15	BISTRO KITCHEN	A	Y		N	
		D16	D-16 NORWICH SPA	A	Y			
		D-16	PEQUOT TOWER SALON	A	Y			
		D-17	COMMUNITY CENTER	A	Y		N	
		D-18	CASINO WELL HOUSE	A	Y			
		D-19	9 ANNE WAMPEY	A	Y		N	
		D-2	TWO TREES	A	Y			
		D-20	4 PEQUOT VILLAGE	A	Y		N	
		D-21	TRIBAL OFFICES	A	Y		1	
		D-22	MUSEUM	A	Y			
		D-23	11 AMOS GEORGE DRIVE	A			1	
		D-24	12 AMOS GEORGE DRIVE	A			1	
		D-25	13 AMOS GEORGE DRIVE	A			1	
		D-26	14 AMOS GEORGE DRIVE	A			1	
		D-27	15 AMOS GEORGE DRIVE	A			1	
		D-28	1 ELIZABETH GEO.DR.	A			3	
		D-29	2 ELIZABETH GEO.DR.	A			3	
		D-3	SERVICE BAR	A	Y		N	
		D-30	3 ELIZABETH GEO.DR.	A			3	
		D-31	4 ELIZABETH GEO.DR.	A			3	
		D-32	5 ELIZABETH GEO.DR.	A			3	
		D-33	6 ELIZABETH GEO.DR.	A			3	
		D-34	7 ELIZABETH GEO.DR.	A			3	
		D-35	8 ELIZABETH GEO.DR.	A			3	
		D-36	9 ELIZABETH GEO.DR.	A			3	
		D-37	10 ELIZABETH GEO.DR.	A			3	
		D-38	11 ELIZABETH GEO.DR.	A			3	
		D-39	12 ELIZABETH GEO.DR.	A			3	
		D-4	WASTE W.T.P.	A	Y			
		D-40	13 ELIZABETH GEO.DR.	A			3	
		D-41	14 ELIZABETH GEO.DR.	A			3	
		D-42	15 ELIZABETH GEO.DR.	A			3	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0723011	MASHANTUCKET PEQUOT TRIBAL NATION	C	41,000	N	GU		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			300				

Towns Served: LEDYARD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		D-5	DAY CARE CENTER	A	Y	N		
		D-6	PUBLIC SAFETY	A	Y			
		D-7	HEALTH & HUMAN SERV.	A	Y	N		
		D-8	BOOSTER STATION	A	Y			
		D-9	INDIAN HEALTH SERV.	A	Y	N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		IDSE-5	5D-12 4 PEQUOT	A	Y			
		IDSE-8	D-6 PUBLIC SA	A	Y			
		LOI 1	LOI 1 2MG TANK	A	Y			
		LOI 2	LOI 2 PEQUOT ACADEMY	A	Y			
		LOI-1	LOI-1 2 MG TANK	A	Y			
		LOI-2	LOI-2 PEQUOT ACADEMY	A	Y			
		MGM-1	MGM-1 CENTER BAR	A	Y			
		MGM-2	MGM-2 G SPA SALON	A	Y			
		MGM-3	MGM-3 CENTRAL PLANT	A	Y			
		TP-1	TP-1 COMBINED POE	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT #1 - WTP	3	ENTRY POINT	A				
310	COMBINED RAW WELL INTO FP	1	COMBINED RAW WELLS	A				
311	MASHANTUCKET PEQUOT WTP	5	EP TREATMENT PLANT	A				
47831	WELL 6	2	WELL 6	A				
51098	WELL 3B	2	WELL 3B	A				
51100	PEQUOT TRAIL HIGH SERVICE TANK							
51102	CONCRETE ATMOSPHERIC TANK							
51104	CLEARWELL							
51106	PEQUOT TRAIL HS BOOSTER STATION							
51108	LAKE OF ISLE PUMP STATION							
51880	CLEARWELL PUMP STATION							
51882	WESTERN PUMP STATION							
52434	LAKE OF ISLES STORAGE TANK							
842	WELL 2	2	WELL 2	A				
843	WELL 3A	2	WELL 3	A				
845	WELL 5	2	WELL 5	A				

Certified Operator Information

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0723011	MASHANTUCKET PEQUOT TRIBAL NATION	C	41,000	N	GU		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			300				

Towns Served: LEDYARD

Certified Operator Information

Water System Facility: **MASHANTUCKET PEQUOT WTP (WSF ID: 311)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COLLI, SR., STEVEN M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2024

Contact Information

Name		Organization			Job Title	
Mr. Bryan Charity		Mashantucket Pequot Tribal			Assistant Director	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
2 Matts Path		PO Box 3060		Mashantucket	CT	06338-3060
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-396-7552				860-396-6100	bcharity@mptn-nsn.gov	

Contact Role(s): **Administrative Contact, Legal Contact**

Name		Organization			Job Title	
Mr. Keith Gove						
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
103 Pequot Trail		P.O. Box 3201		Mashantucket	CT	06338
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-312-2502					kgove@mptn-nsn.gov	

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727091	LEDYARD WPCA - LEDYARD CENTER	C	3,294	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			708	24			

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		

Total Haloacetic Acids (2456) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LEDYARD TOWN HALL (LC009)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Total Trihalomethanes (2950) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
13 VILLAGE DRIVE (LC160)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Total Coliform (3100) 7 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
10/1/24 - 10/31/24			

Lead And Copper (PBCU) 20 routine (RT) per six months

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

Physical Parameters (PPS) 7 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727091	LEDYARD WPCA - LEDYARD CENTER	C	3,294	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			708	24			

Towns Served: LEDYARD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	7 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT TTHM OPERATIONAL EVALUATION RPT	10/30/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LC001	VILLAGE MARKET	A	Y			Y
		LC002	AJS RESTAURANT	A	Y			
		LC003	GALLUP HILL SCHOOL	A	Y			
		LC004	PUMPKIN HILL MARKET	A	Y		Y	
		LC005	130 GALLUP HILL RD	A	Y			
		LC006	LAKESIDE CONDOS	A	Y			
		LC007	82 TOWN FARM ROAD	I	Y			
		LC008	HOLDRIDGE NURSERY	A	Y			
		LC009	LEDYARD TOWN HALL	A	Y			Y
		LC010	LEDYARD HIGH SCHOOL	A	Y			
		LC011	LEDYARD CENTRAL SCHO	A	Y			
		LC012	5 SABLE DRIVE	A	Y			
		LC013	BILL LIBRARY	A	Y			
		LC014	LEDYARD CENTER TANK	A	Y			
		LC100	8 POWDER HORN DRIVE	A	Y	3		
		LC101	1 ROBIN LANE	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727091	LEDYARD WPCA - LEDYARD CENTER	C	3,294	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			708	24			

Towns Served: LEDYARD

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		LC102	14 ROBIN LANE	A	Y	3		
		LC103	1 SACHEM LANE	A		3		
		LC104	1 WHITEWOOD LANE	A	Y	3		
		LC105	12 WHITEWOOD LANE	A	Y	3		
		LC106	4 ASPEN LANE	A	Y	3		
		LC107	3 CHESTNUT LANE	A	Y	3		
		LC108	5 CARRIAGE TRAIL	A	Y	3		
		LC109	11 CARRIAGE TRAIL	A	Y	3		
		LC110	13 CARTRIDGE TERRACE	A	Y	3		
		LC111	21 CARTRIDGE TERRACE	A	Y	3		
		LC112	2 FIFERS LANE	A	Y	3		
		LC113	3 MODEL PARK ROAD	A	Y	3		
		LC114	11 HICKORY DRIVE	A	Y	3		
		LC115	19 HICKORY DIRVE	A	Y	3		
		LC116	25 HICKORY DRIVE	A	Y	3		
		LC117	11 VILLAGE DRIVE	A	Y	3		Y
		LC118	20 VILLAGE DRIVE	A	Y	3		
		LC119	5 COUNTRY CLUB	A	Y	3		
		LC120	18 COUNTRY CLUB	A	Y	3		
		LC121	34 COUNTRY CLUB	A	Y	3		
		LC122	11 BLACKSMITH DRIVE	A	Y	3		
		LC123	14 BLACKSMITH DRIVE	A	Y	3		
		LC124	22 BLACKSMITH DRIVE	A	Y	3		
		LC125	32 BLACKSMITH DRIVE	A	Y	3		
		LC126	46 BLACKSMITH DRIVE	A	Y	3		
		LC127	6 BLACKWATCH LANE	A	Y	3		
		LC128	12 BLACKWATCH LANE	A	Y	3		
		LC129	10 OLD FORT LANE	A	Y	3		
		LC130	3 PENNYWISE LANE	A	Y	3		
		LC131	9 PENNYWISE LANE	A	Y	3		
		LC132	13 PENNYWISE LANE	A	Y	3		
		LC133	1 MUSTER LANE	A	Y	3		
		LC134	12 MUSTER LANE	A	Y	3		
		LC135	1 THOMPSON STREET	A	Y	3		
		LC136	7 THOMPSON STREET	A	Y	3		
		LC137	5 TOWN FARM ROAD	A	Y	3		
		LC138	15 TOWN FARM ROAD	A	Y	3		
		LC139	23 TOWN FARM ROAD	A	Y	3		
		LC140	105 GALLUP HILL ROAD	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727091	LEDYARD WPCA - LEDYARD CENTER	C	3,294	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			708	24			

Towns Served: LEDYARD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LC141	139 GALLUP HILL ROAD	A	Y	3		
		LC142	149 GALLUP HILL ROAD	A	Y	3		
		LC143	163 GALLUP HILL ROAD	A	Y	3		
		LC144	8 HIGHLAND DRIVE	A	Y	3		
		LC145	16 HIGHLAND DRIVE	A	Y	3		
		LC146	25 HIGHLAND DRIVE	A	Y	3		
		LC147	42 HIGHLAND DRIVE	A	Y	3		
		LC148	53 HIGHLAND DRIVE	A	Y	3		
		LC149	58 HIGHLAND DRIVE	A	Y	3		
		LC150	11 MEETINGHOUSE	A	Y	3		
		LC151	27 MEETINGHOUSE	A	Y	3		
		LC152	53 MEETINGHOUSE	A	Y	3		
		LC153	57 MEETINGHOUSE	A	Y	3		
		LC154	69 MEETINGHOUSE	A	Y	3		
		LC155	82 MEETINGHOUSE	A	Y	3		
		LC156	101 MEETINGHOUSE	A	Y	3		
		LC157	122 MEETINGHOUSE	A	Y	3		
		LC158	139 MEETINGHOUSE	A	Y	3		
		LC159	140 MEETINGHOUSE	A	Y	3		
		LC160	13 VILLAGE DRIVE	A	Y	3		Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				

56934 ATMOSPHERIC TANK

56938 INTERCONNECTION -
CT0590011 - GROTON

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
DUARTE, MAURICIO E	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026

Contact Information

Name		Organization			Job Title	
Mr. Fred Allyn, III		Town of Ledyard			Mayor	
Mailing Address Line One		Mailing Address Line Two			City	State
741 Colonel Ledyard Highway					Ledyard	CT
Zip Code	Business Phone		Extension	Fax	Mobile Phone	Emergency Phone
06339-1511	860-464-3221			860-464-8455		
Email Address						
mayor@ledyardct.org						
Contact Role(s): Administrative Contact, Legal Contact						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0727091	LEDYARD WPCA - LEDYARD CENTER	C	3,294	L	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			708	24			

Towns Served: LEDYARD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule