

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

#### Chlorine Residual (1012) 60 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

#### Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
500 SOUTH BROAD ST (MWDAS500)	1/1/20 - 12/31/28		Complete

#### Total Coliform (3100) 60 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

#### Disinfectant Byproducts - TTHM & HAA5 (DBP) 8 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
25 SCHWINKS DR (MWDBACT033)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	
130 HIGH HILL RD (MWDBACT036)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	
528 JOHNSON AVE (MWDBB100)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	
343 WEST MAIN ST (MWDBB300)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

#### Disinfectant Byproducts - TTHM & HAA5 (DBP) 8 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/24 - 9/30/24	8/1-8/31	
285 PRESTON AVE (MWDBH200)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	
168 CHAMBERLAIN HWY (MWDEL200)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	
55 MICHAEL DR (MWDEL300)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	
664 WEST MAIN ST (MWDM1000)	10/1/23 - 12/31/23	11/1-11/30	Complete
	1/1/24 - 3/31/24	2/1-2/28	Complete
	4/1/24 - 6/30/24	5/1-5/31	
	7/1/24 - 9/30/24	8/1-8/31	

#### Lead And Copper (PBCU) 60 routine (RT) per six months

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/23 - 12/31/23		Complete
	1/1/24 - 6/30/24		
	7/1/24 - 12/31/24		

#### Physical Parameters (PPS) 60 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **MERIMERE WTP ENTRY POINT (WSF ID: 00700)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **MERIMERE WTP ENTRY POINT (WSF ID: 00700)**

<b>Dibromochloropropane (DBCP) (2931)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
<b>Ethylene Dibromide (EDB) (2946)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MERIMERE (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Monitoring Requirements

**Water System Facility: MERIMERE WTP ENTRY POINT (WSF ID: 00700)**

<b>Organic Chemicals (VOCS)</b>				<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	1/1/25 - 12/31/25			

**Water System Facility: ELMERE WTP ENTRY POINT (WSF ID: 00701)**

<b>Net Gross Alpha (4000)</b>				<b>1 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - ELMERE (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

<b>Uranium (4006)</b>				<b>1 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - ELMERE (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

<b>Combined Radium-226/228 (4010)</b>				<b>1 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - ELMERE (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

<b>Inorganic Chemicals (IOCS)</b>				<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - ELMERE (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			

<b>Nitrate And Nitrite (NOX)</b>				<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - ELMERE (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			

<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>				<b>2 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - ELMERE (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

<b>Organic Chemicals (VOCS)</b>				<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - ELMERE (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			

**Water System Facility: BROAD BROOK WTP ENTRY POINT (WSF ID: 00702)**

<b>Inorganic Chemicals (IOCS)</b>				<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - BROAD BROOK (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **BROAD BROOK WTP ENTRY POINT (WSF ID: 00702)**

<b>Inorganic Chemicals (IOCS)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 12/31/25		

<b>Nitrate And Nitrite (NOX)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>			<b>1 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>			<b>2 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Organic Chemicals (VOCS)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: **BRADLEY HUBBARD WTP ENTRY POINT (WSF ID: 00703)**

<b>Net Gross Alpha (4000)</b>			<b>1 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Uranium (4006)</b>			<b>1 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Combined Radium-226/228 (4010)</b>			<b>1 routine (RT) per three years</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

<b>Inorganic Chemicals (IOCS)</b>			<b>1 routine (RT) per year</b>
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

**Water System Facility: BRADLEY HUBBARD WTP ENTRY POINT (WSF ID: 00703)**

<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>		<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			

**Water System Facility: EVANSVILLE WTP ENTRY POINT (WSF ID: 00704)**

<b>Nickel (1036)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - EVANSVILLE (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			
<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - EVANSVILLE (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

**Water System Facility: EVANSVILLE WTP ENTRY POINT (WSF ID: 00704)**

<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 12/31/25		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

**Water System Facility: MULE WELL WTP ENTRY POINT (WSF ID: 00705)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

**Water System Facility: MULE WELL WTP ENTRY POINT (WSF ID: 00705)**

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

**Water System Facility: COLUMBUS PARK WELL WTP ENTRY POINT (WSF ID: 00706)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/23		Out of Service
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

**Water System Facility: PLATT LINCOLN WTP ENTRY POINT (WSF ID: 00707)**

<b>Dibromochloropropane (DBCP) (2931)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/23		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **PLATT LINCOLN WTP ENTRY POINT (WSF ID: 00707)**

<b>Dibromochloropropane (DBCP) (2931)</b>	<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			
<b>Ethylene Dibromide (EDB) (2946)</b>	<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			
<b>Pesticides, Herbicides and PCBs - Phase II &amp; V (SOCS)</b>	<b>2 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
EP - PLATT LINCOLN (3)	10/1/23 - 12/31/23		Complete	
	1/1/24 - 3/31/24			
	4/1/24 - 6/30/24			
	7/1/24 - 9/30/24			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **COLUMBUS PARK WELL (WSF ID: 1356)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COLUMBUS PARK WELL (2)	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		

Water System Facility: **PLATT WELL (WSF ID: 1357)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PLATT WELL (2)	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **LINCOLN WELL (WSF ID: 1358)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LINCOLN WELL (2)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **EVANSVILLE AVENUE WEST WELL (WSF ID: 1359)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EVANSVILLE AVENUE WE (2)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

## Monitoring Requirements

**Water System Facility: EVANSVILLE AVENUE WEST WELL (WSF ID: 1359)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

**Water System Facility: EVANSVILLE AVENUE EAST WELL (WSF ID: 1360)**

<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EVANSVILLE AVENUE EA (2)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

**Water System Facility: BROAD BROOK WATER TREATMENT PLANT (WSF ID: 150)**

<b>Total Organic Carbon (2920)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - BROAD BROOK TP (5)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

**Water System Facility: MERIMERE WATER TREATMENT PLANT (WSF ID: 152)**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

## Monitoring Requirements

**Water System Facility: MERIMERE WATER TREATMENT PLANT (WSF ID: 152)**

<b>Total Organic Carbon (2920)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - MERIMERE WTP (5)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
9/1/24 - 9/30/24			
10/1/24 - 10/31/24			

**Water System Facility: ELMERE WATER TREATMENT PLANT (WSF ID: 153)**

<b>Total Organic Carbon (2920)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - ELMERE WTP (5)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
9/1/24 - 9/30/24			
10/1/24 - 10/31/24			

**Water System Facility: BRADLEY HUBBARD WATER TREATMENT PLANT (WSF ID: 154)**

<b>Total Organic Carbon (2920)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - BRADLEY WTP (5)	11/1/23 - 11/30/23		
	12/1/23 - 12/31/23		
	1/1/24 - 1/31/24		
	2/1/24 - 2/29/24		
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **BRADLEY HUBBARD WATER TREATMENT PLANT (WSF ID: 154)**

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: **BRADLEY HUBBARD RESERVOIR (WSF ID: 2139)**

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	11/1/23 - 11/30/23		Out of Service
	12/1/23 - 12/31/23		Out of Service
	1/1/24 - 1/31/24		Out of Service
	2/1/24 - 2/29/24		Out of Service
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	10/1/23 - 12/31/23		Out of Service
	1/1/24 - 3/31/24		
	4/1/24 - 6/30/24		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **BRADLEY HUBBARD RESERVOIR (WSF ID: 2139)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/24 - 9/30/24		

<b>Surface Water Inorganic Chemicals (RIOCI)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

<b>Surface Water Color and Turbidity (RPPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	10/1/23 - 12/31/23		Out of Service
	1/1/24 - 3/31/24		
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

<b>Surface Water Pesticides (RSOC)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: **MERIMERE RESERVOIR (WSF ID: 2141)**

<b>Total Alkalinity (1927)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MERIMERE RESERVOIR (1)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MERIMERE RESERVOIR (1)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **MERIMERE RESERVOIR (WSF ID: 2141)**

<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	3/1/24 - 3/31/24			
	4/1/24 - 4/30/24			
	5/1/24 - 5/31/24			
	6/1/24 - 6/30/24			
	7/1/24 - 7/31/24			
	8/1/24 - 8/31/24			
	9/1/24 - 9/30/24			
	10/1/24 - 10/31/24			
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
MERIMERE RESERVOIR (1)	10/1/23 - 12/31/23		Complete	
	1/1/24 - 3/31/24		Complete	
	4/1/24 - 6/30/24			
	7/1/24 - 9/30/24			
<b>Surface Water Inorganic Chemicals (RIOCI)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
MERIMERE RESERVOIR (1)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			
<b>Surface Water Color and Turbidity (RPPS)</b>		<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
MERIMERE RESERVOIR (1)	10/1/23 - 12/31/23		Complete	
	1/1/24 - 3/31/24		Complete	
	4/1/24 - 6/30/24			
	7/1/24 - 9/30/24			
<b>Surface Water Pesticides (RSOC)</b>		<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
MERIMERE RESERVOIR (1)	1/1/23 - 12/31/23		Complete	
	1/1/24 - 12/31/24			
	1/1/25 - 12/31/25			
<b>Water System Facility: BROAD BROOK RESERVOIR (WSF ID: 2142)</b>				
<b>Total Alkalinity (1927)</b>		<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
BROAD BROOK RES (1)	11/1/23 - 11/30/23		Complete	
	12/1/23 - 12/31/23		Complete	
	1/1/24 - 1/31/24		Complete	
	2/1/24 - 2/29/24		Complete	
	3/1/24 - 3/31/24		Complete	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **BROAD BROOK RESERVOIR (WSF ID: 2142)**

#### Total Alkalinity (1927) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

#### Total Organic Carbon (2920) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		Complete
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

#### Total Coliform (3100) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

#### Surface Water Inorganic Chemicals (RIOCI) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

#### Surface Water Color and Turbidity (RPPS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **BROAD BROOK RESERVOIR (WSF ID: 2142)**

<b>Surface Water Pesticides (RSOC)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

Water System Facility: **ELMERE RESERVOIR (WSF ID: 2145)**

<b>Total Alkalinity (1927)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

<b>Total Organic Carbon (2920)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

## Monitoring Requirements

Water System Facility: **ELMERE RESERVOIR (WSF ID: 2145)**

### Surface Water Inorganic Chemicals (RIOCI) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ELMERE RESERVOIR (1)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

### Surface Water Color and Turbidity (RPPS) 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ELMERE RESERVOIR (1)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

### Surface Water Pesticides (RSOC) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ELMERE RESERVOIR (1)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **MERIMERE WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Water System Facility: **MERIMERE WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

### Water System Facility: **ELMERE WTP ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Water System Facility: **ELMERE WTP ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

### Water System Facility: **BROAD BROOK WTP ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Water System Facility: **BROAD BROOK WTP ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

### Water System Facility: **BRADLEY HUBBARD WTP ENTRY POINT (WSFID: 00703)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Average: 1.2 MG/L	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

**Water System Facility: BRADLEY HUBBARD WTP ENTRY POINT (WSFID: 00703)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
	Offline	2/1/2024 - 2/29/2024	n/a
		3/1/2024 - 3/31/2024	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
<b>Start Date:</b> 7/1/2003			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 7/1/2004			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

**Water System Facility: EVANSVILLE WTP ENTRY POINT (WSFID: 00704)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 6/1/2005			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

**Water System Facility: EVANSVILLE WTP ENTRY POINT (WSFID: 00704)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

**Water System Facility: MULE WELL WTP ENTRY POINT (WSFID: 00705)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.5 MG/L	Continuous
<b>Start Date:</b> 6/1/2020			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	11/1/2023 - 11/30/2023	Y	
	12/1/2023 - 12/31/2023	Y	
	1/1/2024 - 1/31/2024	Y	
	2/1/2024 - 2/29/2024	Y	
	3/1/2024 - 3/31/2024		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		
	1/1/2024 - 1/31/2024		
	2/1/2024 - 2/29/2024		
	3/1/2024 - 3/31/2024		
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	11/1/2023 - 11/30/2023	Y	
	12/1/2023 - 12/31/2023	Y	
	1/1/2024 - 1/31/2024	Y	
	2/1/2024 - 2/29/2024	Y	
	3/1/2024 - 3/31/2024		
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
<b>Start Date:</b> 7/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	11/1/2023 - 11/30/2023		
	12/1/2023 - 12/31/2023		
	1/1/2024 - 1/31/2024		
	2/1/2024 - 2/29/2024		
	3/1/2024 - 3/31/2024		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
<b>Start Date:</b> 1/1/2004			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	11/1/2023 - 11/30/2023		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Water System Facility: **MULE WELL WTP ENTRY POINT (WSFID: 00705)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
<b>Start Date:</b> 1/1/2004		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

### Water System Facility: **COLUMBUS PARK WELL WTP ENTRY POINT (WSFID: 00706)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 6/1/2005		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.85 PH	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 1/1/2004		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		11/1/2023 - 11/30/2023	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility: COLUMBUS PARK WELL WTP ENTRY POINT (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 1/1/2004		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

### Water System Facility: PLATT LINCOLN WTP ENTRY POINT (WSFID: 00707)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 6/1/2005		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
	Offline	2/1/2024 - 2/29/2024	n/a
		3/1/2024 - 3/31/2024	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		11/1/2023 - 11/30/2023	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Water System Facility: **PLATT LINCOLN WTP ENTRY POINT (WSFID: 00707)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
<b>Start Date:</b> 7/1/2003			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 7/1/2003			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

### Water System Facility: **BROAD BROOK WATER TREATMENT PLANT (WSFID: 150)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 1/1/2002			
		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

## Water System Facility: **BROAD BROOK WATER TREATMENT PLANT (WSFID: 150)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

## Water System Facility: **MERIMERE WATER TREATMENT PLANT (WSFID: 152)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Water System Facility: ELMERE WATER TREATMENT PLANT (WSFID: 153)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
		11/1/2023 - 11/30/2023	
		12/1/2023 - 12/31/2023	
		1/1/2024 - 1/31/2024	
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 8/1/2020		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	Y
		3/1/2024 - 3/31/2024	

### Water System Facility: BRADLEY HUBBARD WATER TREATMENT PLANT (WSFID: 154)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
	Offline	2/1/2024 - 2/29/2024	n/a
		3/1/2024 - 3/31/2024	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

## Water System Facility: **BRADLEY HUBBARD WATER TREATMENT PLANT (WSFID: 154)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
	Offline	2/1/2024 - 2/29/2024	n/a
		3/1/2024 - 3/31/2024	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Monitoring Compliance Status:</b>
		<b>Monitoring Period</b>	<b>Operating Limit Compliance Status:</b>
	Offline	11/1/2023 - 11/30/2023	n/a
	Offline	12/1/2023 - 12/31/2023	n/a
	Offline	1/1/2024 - 1/31/2024	n/a
	Offline	2/1/2024 - 2/29/2024	n/a
		3/1/2024 - 3/31/2024	Y

## Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2010	
ADDRESS CONTAMINATION	1/30/2019	
WATERSHED SURVEY REPORT	3/1/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

## Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00500	LINCOLN WELL - TOWER EFFLUENT							
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MWDAS500	500 SOUTH BROAD ST	A			Y	
		MWDBACT020	269 MAIN ST S MERIDN	I	Y			
		MWDBACT021	214 EVANSVILLE AVE	A	Y			
		MWDBACT022	220 COE AVE	A	Y			
		MWDBACT023	528 JOHNSON AVE	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDBACT024	583 WEST MAIN ST	A	Y			
		MWDBACT025	168 CHAMBERLAIN HWY	I	Y			
		MWDBACT026	474 CHAMBERLAIN HWY	I	Y			
		MWDBACT027	260 SHERMAN AVE	I	Y			
		MWDBACT028	10 BEE ST	A	Y			
		MWDBACT029	766 NORTH COLONY RD	A	Y			
		MWDBACT030	2090 NO BROAD ST	A	Y			
		MWDBACT030X	1966 NO. BROAD ST	I	Y			
		MWDBACT031	61 PRATT ST	A	Y			
		MWDBACT032	117 PARKER AVE	A	Y			
		MWDBACT033	25 SCHWINKS DR	A	Y			Y
		MWDBACT034	121 GRAVEL ST	A	Y			
		MWDBACT035	1101 EAST MAIN ST	A	Y			
		MWDBACT036	130 HIGH HILL RD	A	Y			Y
		MWDBACT037	22 EAST RD	A	Y			
		MWDBACT038	285 PRESTON AVE	I	Y			
		MWDBACT039	1248 SO. BROAD ST	I	Y			
		MWDBACT040	1258 SOUTH BROAD ST	A	Y	N		
		MWDBACT041	329 CHAMBERLAIN HWY	A				
		MWDBB100	528 JOHNSON AVE	A				Y
		MWDBB200	269 MAIN ST S MERIDN	A				
		MWDBB300	343 WEST MAIN ST	A				Y
		MWDBB400	61 PRATT ST	A				
		MWDBBE00	1285 SO MERIDEN RD	I				Y
		MWDBH100	538 PRESTON AVE	A				
		MWDBH200	285 PRESTON AVE	A				Y
		MWDBH300	390 BEE ST	A				
		MWDBH400	1295 EAST MAIN ST	A				
		MWDBHE00	800 WESTFIELD RD	A				
		MWDEL100	66 KENSINGTON AVE	A				
		MWDEL200	168 CHAMBERLAIN HWY	A				Y
		MWDEL300	55 MICHAEL DR	A				Y
		MWDEL400	1966 NO BROAD ST	A				
		MWDELE00	658 CHAMBERLAIN HWY	A				
		MWDETP10	1248 SO BROAD ST	A				
		MWDETP20	125 SCOTT ST	A				
		MWDETP30	22 EAST RD	A				
		MWDLC001	16 AKRON ST	A		2		
		MWDLC002	41 CASS ST	A		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		MWDL003	98 HORTON AVE	A		3		
		MWDL004	37 MONTOWESE DR	A		1		
		MWDL005	210 CATHERINE DR	A		1		
		MWDL005OLD	106 NEW CHESHIRE RD	I		N		
		MWDL006	42 OLD FARM DR	A		1		
		MWDL007	253 RESERVOIR AV	A		3		
		MWDL008	333 RESERVOIR AV	A		3		
		MWDL009	102 SCHOONER LN	A		3		
		MWDL010	53 FOURTH ST	I		2		
		MWDL011	38 SURRY DR	A		3		
		MWDL012	455 WESTFIELD RD	A		1		
		MWDL013	340 HICKS AV	A		3		
		MWDL014	76 BAILY AVE	I		2		
		MWDL015	6 ARTIZAN ST	A		3		
		MWDL016	99 BRIARWOOD DR	A		3		
		MWDL017	22 KIM LN	A		2		
		MWDL018	70 SMITHFIELD AVE	A		3		
		MWDL019	3 KIRKLAND PL	A		3		
		MWDL020	27 NORTH ST	I		2		
		MWDL021	8 OAKLAND CT	A		2		
		MWDL022	66 NANCY LN	A		3		
		MWDL023	32 PROSPECT TER	A		3		
		MWDL024	31 CASTLE DR	A		3		
		MWDL025	246 GWEN RD	A		3		
		MWDL026	405 KENSINGTON	A		3		
		MWDL027	870 NORTH COLONY RD	A		3		
		MWDL028	660 NORTH COLONY RD	A		2		
		MWDL029	375 BROWNSTONE RIDGE	I		1		
		MWDL030	604 GRACEY AVE	A		1		
		MWDL030OLD	570 BROWNSTONE RIDGE	I		3		
		MWDL031	26 LORI LN	A		1		
		MWDL031OLD	25 SUZY CT	I		N		
		MWDL032	93 O'BRIEN DR	A		1		
		MWDL033	28 NEWTON ST	A		1		
		MWDL034	6 NORRIE PL	A		3		
		MWDL035	32 PARKER AV NORTH	A		2		
		MWDL036	498 PARKER AVE	A		1		
		MWDL036OLD	215 SOUTH COLONY ST	I		N		
		MWDL037	145 PETTIT DR	A		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		MWDLC037OLD	110 POMEROY AVE	I		3		
		MWDLC038	25 STEVENSON RD	A		3		
		MWDLC040	336 ELM ST	A		3		
		MWDLC041	425 POMEROY AVE	A		3		
		MWDLC042	177 THORPE AVE	A		1		
		MWDLC043	112 STEVENSON RD	A		3		
		MWDLC044	110 DRYDEN DR	A		3		
		MWDLC045	74 CYNROSE PL	A		1		
		MWDLC046	156 METACOMET DR	A		1		
		MWDLC046OLD	3 ABBEY LANE	I		1		
		MWDLC047	26 ALLEN AVE	I		1		
		MWDLC048	92 DRAPER AVE	A		1		
		MWDLC049	91 GOODSPEED AVE	A		3		
		MWDLC050	63 PRESTON AVE	A		3		
		MWDLC051	220 WESTVIEW RD	A		1		
		MWDLC052	312 GRAVEL ST	A		3		
		MWDLC053	34 TREMONT ST	I		1		
		MWDLC054	153 PETTIT DR	A		1		
		MWDLC054OLD	108 WILLIS AVE	I		3		
		MWDLC055	165 NATCHAUG DR	A		3		
		MWDLC056	70 FIESTA HEIGHTS	A		3		
		MWDLC057	10 KEATS RD	A		3		
		MWDLC058	20 MILDRED RD	A		3		
		MWDLC059	438 YALE AVE	A		3		
		MWDLC060	116 VETERAN ST	A		1		
		MWDLC061	76 SAGE HILL RD	A		1		
		MWDLC062	258 NO. WALL ST.	A		3		
		MWDLC062OLD	99 ALANBY DR	I		3		
		MWDLC063	142 GODEK HILL RD.	A		1		
		MWDLC063OLD	41 SO THIRD ST	I		2		
		MWDLC064	71 ARLINGTON NO.	A		1		
		MWDLC064OLD	64 MURRAY ST	I		1		
		MWDLC065	89 BETHANN CIRCLE	A		1		
		MWDLC066	18 STEPHEN DR	A		1		
		MWDLC066OLD	26 KENNEDY DR	I		N		
		MWDLC067	162 HILLCREST AVE	A		3		
		MWDLC068	52 CARL ST	A		3		
		MWDLC069	336 CROWN ST	I		3		
		MWDLC070	55 SHELLEY RD	A		3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		MWDL071	102 WILLIAMS ST	A		1		
		MWDL072	104 WHITNEY DR	A		1		
		MWDL072OLD	58 JEROME AVE	I		3		
		MWDL073	132 STEVENSON RD	A		1		
		MWDL074	39 HILLWOOD LA	I		3		
		MWDL075	38 FARM HILL RD	A		3		
		MWDL076	55 EATON AVE	A		3		
		MWDL077	181 DANA LANE	I	Y	3		
		MWDL077OLD	156 METACOMET DR	I		2		
		MWDL078	67 SPERRY LANE	A	Y	1		
		MWDL078OLD	258 N WALL ST	I		3		
		MWDL079	35 FAIR STREET	A	Y	1		
		MWDL079OLD	142 GODEK HILL RD	I		1		
		MWDL080	57 DEBBIE DRIVE	I	Y	N		
		MWDL080OLD	71 ARLINGTON NO	I		1		
		MWDL081	62 FAIRWAY DRIVE	A	Y	1		
		MWDL081OLD	MWDL081	I	Y			
		MWDL082	439 SOUTH CURTIS	A		2		
		MWDL083	30 PINEHURST DR	I		3		
		MWDL084	24 ROCKLEDGE DR	A		3		
		MWDL085	11 HILL TOP RD	A	Y	1		
		MWDL086	89 SYLVAN VALLEY RD	A	Y	1		
		MWDL087	165 AMITY ST	A	Y	1		
		MWDL088	27 ANTONIO AVE	A	Y	1		
		MWDL089	19 RIDGEVIEW RD	A	Y	1		
		MWDL090	100 BARR ROAD	A	Y	1		
		MWDL091	240 HICKS AV	A	Y	1		
		MWDL092	607 GRACEY AV	A	Y	1		
		MWDL093	36 BLUEBERRY LN	A	Y	1		
		MWDL094	398 BRADLEY AVE	A	Y	1		
		MWDL095	28 BRIAN CT	A	Y	1		
		MWDL096	555 GRACEY AV	A	Y	1		
		MWDL097	366 GRACEY AV	A		1		
		MWDL098	74 CAREY AVE	A	Y	1		
		MWDL099	62 SILVER LAKE RD	A		1		
		MWDL100	242 CARRIAGE DR EAST	A	Y	1		
		MWDL101	1672 NORTH COLONY RD	A	Y	1		
		MWDL102	1404 NORTH COLONY RD	A	Y	1		
		MWDL103	111 CATHERINE DR	A	Y	1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		MWDLC104	1261 NORTH COLONY RD	A	Y	1		
		MWDLC105	301 COLUMBUS AVE	A	Y	1		
		MWDLC106	200 DRYDEN DR	A	Y	1		
		MWDLC107	45 NANCY LN	A	Y	1		
		MWDLC108	78 EAST VIEW TER	A	Y	1		
		MWDLC109	202 EATON AVE	A	Y	1		
		MWDLC110	42 EMPIRE AVE	A	Y	1		
		MWDLC111	29 CATHERINE DR	A	Y	1		
		MWDLC112	192 FINCH AVE	A		1		
		MWDLC113	266 GRACEY AVE	A	Y	1		
		MWDLC114	1359 OLD NO COLONY R	A	Y	1		
		MWDLC115	47 PARKER RD	A	Y	1		
		MWDLC116	40 PASCO ST	A	Y	1		
		MWDLC117	35 PEARL ST	A	Y	1		
		MWDLC118	28 EMPIRE AVE	A	Y	1		
		MWDLC119	187 WOODLAND ST	A	Y	1		
		MWDLC120	91 ROLLING HILLS DR	A	Y	1		
		MWDLC121	46 BLUEBERRY LN	A		1		
		MWDLC122	512 SO CURTIS ST	A		1		
		MWDLC123	28 REM DR	A	Y	1		
		MWDLC124	672 BROWNSTONE RIDGE	A	Y	1		
		MWDLC125	61 SUNSET DR	A	Y	1		
		MWDLC126	89 SYLVAN VALLEY RD	A	Y	1		
		MWDLC127	54 VALE AVE	A	Y	1		
		MWDLC128	91 ROLLING HILLS DR	A	Y	1		
		MWDLC129	105 RIVERSIDE DR	A	Y	1		
		MWDLC130	160 CORRIGAN AV	A	Y	1		
		MWDLC131	67 WILDWOOD RD	A	Y	1		
		MWDLC132	43 HOBSON AV	A	Y	1		
		MWDLC133	20 LOU ANN TER	A	Y	1		
		MWDLC134	274 YALE AVE	A	Y	1		
		MWDLC135	141 VALLEY VIEW DR	A		1		
		MWDLC136	290 BEE ST	A		1		
		MWDLC137	4 MONTOWESE DR	A		1		
		MWDLC138	162 SAGAMORE RD	A		1		
		MWDLC139	347 BALDWIN AV	A		1		
		MWDLC140	10 PARKVIEW ST	A		1		
		MWDLC141	44 GODEK HILL RD	A		1		
		MWDLC142	52 GODEK HILL RD	A		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>WQP 2 DBPR</i>	<i>Stage</i>
		MWDL143	66 GODEK HILL RD	A		1			
		MWDL144	40 DAVIS ST	A		1			
		MWDL145	106 MIDLAND DR	A		1			
		MWDL146	185 MILLER AVE	A		1			
		MWDL147	166 STEPHEN DR	A		1			
		MWDL148	70 STEPHEN DR	A		1			
		MWDL149	59 OAK RIDGE DR	A		1			
		MWDL150	59 O'BRIAN DR	A		1			
		MWDL151	826 PADDOCK AV	A		1			
		MWDL152	27 PALMER DR	A		1			
		MWDL153	164 MILLBROOK RD	A		1			
		MWDL154	104 CARRIAGE DR EAST	A		1			
		MWDL155	88 ISABELLE DR	A		1			
		MWDL156	176 CART PATH	A		1			
		MWDL157	21 DIVOT DR	A		1			
		MWDL158	66 DOGLEG DR	A		1			
		MWDL159	30 EAGLE CT	A		1			
		MWDL160	71 FAIRWAY DR	A		1			
		MWDL161	265 FAIWAY DR	A		1			
		MWDL162	473 MURDOCK AV	A		1			
		MWDL163	47 PRANN CT	A		1			
		MWDL164	77 ROYAL OAK	A		1			
		MWDL165	261 ROYAL OAK	A		1			
		MWDL166	38 TUXIS CIR	A		1			
		MWDL167	32 ALLEN AVE	A		1			
		MWDM1000	664 WEST MAIN ST	A					Y
		MWDM2000	412 WEST MAIN ST	A					
		MWDM3000	15 LINCOLN ST	A					
		MWDM4000	142 EAST MAIN ST	A					
		MWDME000	78 RESERVOIR RD	A					
		MWDPL500	540 WEST MAIN ST	A					
		MWDTT001	585 MAIN ST	A					
		MWDTT002	168 CHAMBERLAIN HWY	A					
		MWDTT003	167 LEWIS AVE	A					
		MWDTT004	105 MILLER ST	A					
		MWDTT005	281 EAST MAIN ST	A					
		MWDTT006	50 YALE AVE	A					
		MWDTT007	61 TULIP DR	A					
		MWDTT008	692 EAST MAIN ST	A					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDTT009	1966 NO BROAD ST	A				
		MWDTT010	553 NORTH COLONY RD	A				
		MWDTT011	341 SO BROAD ST	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	MERIMERE WTP ENTRY POINT	3	EP - MERIMERE	A				
00701	ELMERE WTP ENTRY POINT	3	EP - ELMERE	A				
00702	BROAD BROOK WTP ENTRY POINT	3	EP - BROAD BROOK	A				
00703	BRADLEY HUBBARD WTP ENTRY POINT	3	EP - BRADLEY HUBBARD	A				
00704	EVANSVILLE WTP ENTRY POINT	3	EP - EVANSVILLE	A				
00705	MULE WELL WTP ENTRY POINT	3	EP - MULE WELL	A				
00706	COLUMBUS PARK WELL WTP ENTRY POINT	3	EP - COLUMBUS PARK	A				
00707	PLATT LINCOLN WTP ENTRY POINT	3	EP - PLATT LINCOLN	A				
1355	MULE WELL	2	MULE WELL	A				
1356	COLUMBUS PARK WELL	2	COLUMBUS PARK WELL	A				
1357	PLATT WELL	2	PLATT WELL	A				
1358	LINCOLN WELL	2	LINCOLN WELL	A				
1359	EVANSVILLE AVENUE WEST WELL	2	EVANSVILLE AVENUE WE	A				
1360	EVANSVILLE AVENUE EAST WELL	2	EVANSVILLE AVENUE EA	A				
150	BROAD BROOK WATER TREATMENT PLANT	5	CFE - BROAD BROOK TP	A				
151	PLATT LINCOLN TREATMENT STATION	5	IESWTR - PLATT EP	A				
152	MERIMERE WATER TREATMENT PLANT	5	CFE - MERIMERE WTP	A				
153	ELMERE WATER TREATMENT PLANT	5	CFE - ELMERE WTP	A				
154	BRADLEY HUBBARD WATER TREATMENT PLANT	5	CFE - BRADLEY WTP	A				
155	EVANSVILLE WATER TREATMENT PLANT	5	IESWTR - EVANSVIL EP	A				
156	MULE TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
157	COLUMBUS PARK WELL TREATMENT STATION	5	IESWTR - COLUMBUS EP	A				
2139	BRADLEY HUBBARD RESERVOIR	1	BRADLEY HUBBARD RES	A				
2140	KENMERE RESERVOIR	1	KENMERE RESERVOIR	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
2141	MERIMERE RESERVOIR	1	MERIMERE RESERVOIR	A				
2142	BROAD BROOK RESERVOIR	1	BROAD BROOK RES	A				
2143	HALLMERE RESERVOIR	1	RESERVOIR	A				
2144	STOCKING BROOK DIVERSION	1	RESERVOIR	A				
2145	ELMERE RESERVOIR	1	ELMERE RESERVOIR	A				
2146	MALONEY CANAL DIVERSION	1	RESERVOIR	A				
2147	MCKONE CANAL DIVERSION	1	RESERVOIR	A				
30040	BRADLEY HUBBARD RESERVOIR							
30041	MERIMERE RESERVOIR							
30042	ELMERE RESERVOIR							
30043	BROAD BROOK RESERVOIR							
45119	INTERCONNECTION - CT0930011 - RWA							
49588	JOHNSON AVE TANK							
49590	CARPENTER AVE ATMOSPHERIC TANK							
49592	FLEMING ROAD TANK							
49594	ELMERE TANK							
49596	MERIMERE TANK							
49598	COLLINSDALE TANK 1							
49600	COLLINSDALE TANK 2							
49602	SCHWINKS HILL TANK 1							
49604	SCHWINKS HILL TANK 2							
49606	CARPENTER AVE PRESSURE TANK 1							
49608	CARPENTER AVE PRESSURE TANK 2							
49610	BROAD BROOK CLEARWELL							
49612	BRADLEY-HUBBARD TANK							
49614	FINCH AVE PUMP STATION							
49616	JOHNSON AVE PUMP STATION							
49618	EAST ROAD PUMP STATION							
49620	CARPENTER AVE PUMP STATION							
49622	PARKER AVE PUMP STATION							
49624	SCHWINK DRIVE PUMP STATION							
49626	COLLINSDALE PUMP STATION							
53151	JOHNSON AVE EAST TANK							
53153	JOHNSON AVE WEST TANK							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					17,630		

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
59159	PLATT LINCOLN CLEARWELL						
59163	EVANSVILLE CLEARWELL						
59916	BROAD BROOK WTP BACKWASH SUPPLY TANK						
62377	ELMERE WTP CLEARWELL						

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
TERAPANE, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
MESKILL, RICHARD J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
CARON, SCOTT A	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
SEGALINE, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2024
PAVELOPS, SCOTT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2024
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2025
		WATER TREATMENT PLANT OPERATOR IN TRAINING	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2024
QUILTY, JOSEPH	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2024
BOSTROM, PARTRICK	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2025

**Water System Facility: BROAD BROOK WATER TREATMENT PLANT (WSF ID: 150)**

**Facility Classification:** CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRADY, SEAN P	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
MESKILL, RICHARD J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2024

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Certified Operator Information

#### Water System Facility: **BROAD BROOK WATER TREATMENT PLANT (WSF ID: 150)**

**Facility Classification:** CLASS 4 TREATMENT PLANT **Certification Expiration**

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026

#### Water System Facility: **PLATT LINCOLN TREATMENT STATION (WSF ID: 151)**

**Facility Classification:** CLASS 1 TREATMENT PLANT **Certification Expiration**

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRADY, SEAN P	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
MESKILL, RICHARD J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026

#### Water System Facility: **MERIMERE WATER TREATMENT PLANT (WSF ID: 152)**

**Facility Classification:** CLASS 3 TREATMENT PLANT **Certification Expiration**

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARON, SCOTT A	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
MESKILL, RICHARD J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026

#### Water System Facility: **ELMERE WATER TREATMENT PLANT (WSF ID: 153)**

**Facility Classification:** CLASS 3 TREATMENT PLANT **Certification Expiration**

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARON, SCOTT A	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
MESKILL, RICHARD J.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2024
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHLINGTON, WALLINGFORD

### Certified Operator Information

**Water System Facility: ELMERE WATER TREATMENT PLANT (WSF ID: 153)**

**Facility Classification:** CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026

**Water System Facility: BRADLEY HUBBARD WATER TREATMENT PLANT (WSF ID: 154)**

**Facility Classification:** CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROBERTS, CHAD M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
MESKILL, RICHARD J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024

**Water System Facility: EVANSVILLE WATER TREATMENT PLANT (WSF ID: 155)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRADY, SEAN P	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
MESKILL, RICHARD J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024
PETER, ROBERT F	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2024
		WATER TREATMENT PLANT OPERATOR IN TRAINING	3/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2025

**Water System Facility: MULE TREATMENT STATION (WSF ID: 156)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARON, SCOTT A	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
MESKILL, RICHARD J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0800011</b>	<b>MERIDEN WATER DIVISION</b>	C	58,441	L	SW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Certified Operator Information

**Water System Facility: MULE TREATMENT STATION (WSF ID: 156)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026

**Water System Facility: COLUMBUS PARK WELL TREATMENT STATION (WSF ID: 157)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARON, SCOTT A	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2025
MESKILL, RICHARD J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2024

### Contact Information

Name		Organization			Job Title	
<b>Mr. Richard J. Meskill</b>		Meriden Water Division			Director, Utilities	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Meriden Water Division		117 Parker Ave.		Meriden	CT	06450
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-630-4256		203-630-4285		203-537-1091	rmeskill@meridenct.gov	

**Contact Role(s): Administrative Contact**

Name		Organization			Job Title	
<b>Mr. Timothy Coon</b>		City of Meriden			City Manager	
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
142 East Main St.				Meriden	CT	06450
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-630-4123		203-630-4274			tcoon@meridenct.gov	

**Contact Role(s): Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**