

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)	180 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
Asbestos (1094)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
Total Coliform (3100)	180 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	12 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
10 JONES HILL (WH) (02060)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
PLATT LANE SS (MILFORD) (02081)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
OLD ORONOQUE SS (MLFRD) (02098)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
135 SUMMER LN, NOH (02149)	7/1/25 - 9/30/25	9/1-9/30	Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
121 FLAT ROCK RD, BR (02155)	10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26 7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	12/1-12/31 3/1-3/31 6/1-6/30 9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete Complete Complete
STILLMAN (NO HVN) (02193)	7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete
388 BRIDGEPORT (MLFD) (03071)	7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete
91 COUNTRY LN, OR (03115)	7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete
6 LAWCREST DR, NOH (05112)	7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete
135 SNTNEL HILL, NOH (05120)	7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete
510 LIGHTHOUSE (NH) (06106)	7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete
16 VICTOR HILL, BR (06110)	7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete
Lead And Copper (PBCU)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
50 routine (RT) per three years			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Lead And Copper (PBCU)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water Quality Parameters Orthophosphate, Total Alkalinity, T (WQP8)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		

Water System Facility: **NORTH CHESHIRE WELLFIELD TREATMENT ST (WSF ID: 00700)**

Inorganic Chemicals (IOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - NORTH CHESHIRE TP (3)	1/1/25 - 12/31/27		Complete
Nitrate And Nitrite (NOX)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - NORTH CHESHIRE TP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - NORTH CHESHIRE TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - NORTH CHESHIRE TP (3)	1/1/23 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: NORTH CHESHIRE WELLFIELD TREATMENT ST (WSF ID: 00700)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - NORTH CHESHIRE TP (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: SOUTH CHESHIRE WELLFIELD TREATMENT ST (WSF ID: 00701)

Gross Beta Particle Activity (4100)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - SOUTH CHESHIRE TP (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - SOUTH CHESHIRE TP (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Tritium (4102)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - SOUTH CHESHIRE TP (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Strontium-90 (4174)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - SOUTH CHESHIRE TP (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - SOUTH CHESHIRE TP (3)	1/1/25 - 12/31/27		Complete	

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - SOUTH CHESHIRE TP (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: **SOUTH CHESHIRE WELLFIELD TREATMENT ST (WSF ID: 00701)**

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - SOUTH CHESHIRE TP (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - SOUTH CHESHIRE TP (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Organic Chemicals (VOCS)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - SOUTH CHESHIRE TP (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: NORTH SLEEPING GIANT WELLFIELD TR ST (WSF ID: 00702)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - N SLEEPING GIANT TR ST (3)	1/1/25 - 12/31/27			Complete
	1/1/26 - 12/31/28			
	1/1/27 - 12/31/29			

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - N SLEEPING GIANT TR ST (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - N SLEEPING GIANT TR ST (3)	1/1/17 - 12/31/25			Complete
	1/1/26 - 12/31/34			

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - N SLEEPING GIANT TR ST (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Organic Chemicals (VOCS)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - N SLEEPING GIANT TR ST (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: **SOUTH SLEEPING GIANT WELLFIELD TR ST (WSF ID: 00703)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: **SOUTH SLEEPING GIANT WELLFIELD TR ST (WSF ID: 00703)**

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT-SOUTH SLEEPING GIANT TR ST (3)		1/1/25 - 12/31/27		
			Complete	
Nitrate And Nitrite (NOX)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT-SOUTH SLEEPING GIANT TR ST (3)		1/1/25 - 12/31/25		
			Complete	
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)			1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT-SOUTH SLEEPING GIANT TR ST (3)		1/1/17 - 12/31/25		
			Complete	
		1/1/26 - 12/31/34		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT-SOUTH SLEEPING GIANT TR ST (3)		1/1/23 - 12/31/25		
			Complete	
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT-SOUTH SLEEPING GIANT TR ST (3)		1/1/25 - 12/31/25		
			Complete	
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Water System Facility: **MOUNT CARMEL WELLFIELD TREATMENT STATION (WSF ID: 00704)**

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - MOUNT CARMEL WELL FIELD TP (3)		1/1/23 - 12/31/25		
			Complete	
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - MOUNT CARMEL WELL FIELD TP (3)		1/1/25 - 12/31/25		
			Complete	
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)			1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - MOUNT CARMEL WELL FIELD TP (3)		1/1/17 - 12/31/25		
			Complete	
		1/1/26 - 12/31/34		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: MOUNT CARMEL WELLFIELD TREATMENT STATION (WSF ID: 00704)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - MOUNT CARMEL WELL FIELD TP (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Organic Chemicals (VOCS)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT - MOUNT CARMEL WELL FIELD TP (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Inorganic Chemicals (IOCS)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP-LAKE GAILLARD TP (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP-LAKE GAILLARD TP (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP-LAKE GAILLARD TP (3)	1/1/17 - 12/31/25			Complete
	1/1/26 - 12/31/34			

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP-LAKE GAILLARD TP (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Organic Chemicals (VOCS)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP-LAKE GAILLARD TP (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: LAKE SALTONSTALL WATER TREATMENT PLANT (WSF ID: 00706)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
CFS-SALTONSTALL TP (5)	8/1/25 - 8/31/25			Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: LAKE SALTONSTALL WATER TREATMENT PLANT (WSF ID: 00706)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SALTONSTALL TP (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SALTONSTALL TP (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SALTONSTALL TP (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SALTONSTALL TP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SALTONSTALL TP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SALTONSTALL TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: LAKE SALTONSTALL WATER TREATMENT PLANT (WSF ID: 00706)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-SALTONSTALL TP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: ENTRY POINT - WEST RIVER WTP (WSF ID: 00707)

Net Gross Alpha (4000)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WEST RIVER WTP (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Uranium (4006)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WEST RIVER WTP (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WEST RIVER WTP (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Inorganic Chemicals (IOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WEST RIVER WTP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WEST RIVER WTP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WEST RIVER WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WEST RIVER WTP (3)	1/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: ENTRY POINT - WEST RIVER WTP (WSF ID: 00707)

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: LAKE WHITNEY WATER TREATMENT PLANT (WSF ID: 00708)

Bromate (1011)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE WHITNEY (3)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Total Organic Carbon (2920)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
CFE - LAKE WHITNEY (5)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Net Gross Alpha (4000)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE WHITNEY (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Uranium (4006)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: LAKE WHITNEY WATER TREATMENT PLANT (WSF ID: 00708)

Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE WHITNEY (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE WHITNEY (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE WHITNEY (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE WHITNEY (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE WHITNEY (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE WHITNEY (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: HOUSATONIC WELLFIELD TREATMENT PLANT (WSF ID: 00709)

Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOUSATONIC WELLFIELD ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOUSATONIC WELLFIELD ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: HOUSATONIC WELLFIELD TREATMENT PLANT (WSF ID: 00709)

Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOUSATONIC WELLFIELD ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOUSATONIC WELLFIELD ENTRY POINT (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOUSATONIC WELLFIELD ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOUSATONIC WELLFIELD ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOUSATONIC WELLFIELD ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Water System Facility: DERBY WELLFIELD TREATMENT PLANT (WSF ID: 00710)

Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - DERBY WELLFIELD TP (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - DERBY WELLFIELD TP (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - DERBY WELLFIELD TP (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - DERBY WELLFIELD TP (3)	1/1/24 - 12/31/26		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: **DERBY WELLFIELD TREATMENT PLANT (WSF ID: 00710)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - DERBY WELLFIELD TP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - DERBY WELLFIELD TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - DERBY WELLFIELD TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Water System Facility: **LAKE GAILLARD (WSF ID: 2207)**

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE GAILLARD (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE GAILLARD (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE GAILLARD (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Pesticides (RSOC)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE GAILLARD (1)	1/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: LAKE GAILLARD (WSF ID: 2207)

Surface Water Pesticides (RSOC)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per year
		1/1/26 - 12/31/26			
		1/1/27 - 12/31/27			

Water System Facility: LAKE WHITNEY (WSF ID: 2220)

Bromide (1004)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per month
	LAKE WHITNEY (1)	8/1/25 - 8/31/25		Complete	
		9/1/25 - 9/30/25		Complete	
		10/1/25 - 10/31/25		Complete	
		11/1/25 - 11/30/25		Complete	
		12/1/25 - 12/31/25		Complete	
		1/1/26 - 1/31/26			
		2/1/26 - 2/28/26			
		3/1/26 - 3/31/26			
		4/1/26 - 4/30/26			
		5/1/26 - 5/31/26			
		6/1/26 - 6/30/26			
		7/1/26 - 7/31/26			

Total Alkalinity (1927)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per month
	LAKE WHITNEY (1)	8/1/25 - 8/31/25		Complete	
		9/1/25 - 9/30/25		Complete	
		10/1/25 - 10/31/25		Complete	
		11/1/25 - 11/30/25		Complete	
		12/1/25 - 12/31/25		Complete	
		1/1/26 - 1/31/26			
		2/1/26 - 2/28/26			
		3/1/26 - 3/31/26			
		4/1/26 - 4/30/26			
		5/1/26 - 5/31/26			
		6/1/26 - 6/30/26			
		7/1/26 - 7/31/26			

Total Organic Carbon (2920)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per month
	LAKE WHITNEY (1)	8/1/25 - 8/31/25		Complete	
		9/1/25 - 9/30/25		Complete	
		10/1/25 - 10/31/25		Complete	
		11/1/25 - 11/30/25		Complete	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: LAKE WHITNEY (WSF ID: 2220)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE WHITNEY (1)	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE WHITNEY (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE WHITNEY (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE WHITNEY (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE WHITNEY (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: LAKE SALTONSTALL (WSF ID: 2221)

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE SALTONSTALL (1)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: LAKE SALTONSTALL (WSF ID: 2221)

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE SALTONSTALL (1)	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE SALTONSTALL (1)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE SALTONSTALL (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE SALTONSTALL (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE SALTONSTALL (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Monitoring Requirements

Water System Facility: LAKE SALTONSTALL (WSF ID: 2221)

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE SALTONSTALL (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: WEST RIVER RAW INTAKE (WSF ID: 48228)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WEST RIV. RAW INTAKE (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WEST RIV. RAW INTAKE (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WEST RIV. RAW INTAKE (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WEST RIV. RAW INTAKE (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Monthly Water System Facility (WSF) Level Monitoring Requirements

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: NORTH CHESHIRE WELLFIELD TREATMENT ST (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.35 MG/L	Continuous
Start Date: 7/1/2011			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.1 MG/L	2
Start Date: 5/1/2025			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: NORTH CHESHIRE WELLFIELD TREATMENT ST (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.01 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 2 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.6 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

Water System Facility: SOUTH CHESHIRE WELLFIELD TREATMENT ST (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.75 MG/L	Continuous	
Start Date: 7/1/2011		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: SOUTH CHESHIRE WELLFIELD TREATMENT ST (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.1 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.01 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: SOUTH CHESHIRE WELLFIELD TREATMENT ST (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 2.0 MG/L	2
Start Date: 5/1/2025		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Monitoring
		9/1/2025 - 9/30/2025	Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.80 MG/L	2
Start Date: 5/1/2025		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Monitoring
		9/1/2025 - 9/30/2025	Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: NORTH SLEEPING GIANT WELLFIELD TR ST (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.70 MG/L	Continuous
Start Date: 7/1/2011		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Monitoring
		9/1/2025 - 9/30/2025	Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Monitoring
		9/1/2025 - 9/30/2025	Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: NORTH SLEEPING GIANT WELLFIELD TR ST (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.1 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.01 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 2.0 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: NORTH SLEEPING GIANT WELLFIELD TR ST (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.8 MG/L	2
Start Date: 5/1/2025		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: SOUTH SLEEPING GIANT WELLFIELD TR ST (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 1.1 MG/L	Continuous
Start Date: 10/1/2021		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: SOUTH SLEEPING GIANT WELLFIELD TR ST (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.1 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point pH Monitoring (PHRD)	Minimum: 0.01 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 2.0 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.80 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: MOUNT CARMEL WELLFIELD TREATMENT STATION (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.80 MG/L	Continuous
Start Date: 4/1/2011			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.1 MG/L	2
Start Date: 5/1/2025			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: MOUNT CARMEL WELLFIELD TREATMENT STATION (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.01 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 2.0 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.0 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

Water System Facility: LAKE GAILLARD TREATMENT PLANT (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily	
Start Date: 1/1/2002		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: LAKE GAILLARD TREATMENT PLANT (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.09 MG/L	2
Start Date: 3/1/2025		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.15 MG/L	2
Start Date: 3/1/2025		Compliance History:	Operating Limit
		Monitoring Period	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: LAKE GAILLARD TREATMENT PLANT (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.0 PH	Daily	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 1.2 MG/L	2	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.8 MG/L	2	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: LAKE GAILLARD TREATMENT PLANT (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2001			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	

Water System Facility: LAKE SALTONSTALL WATER TREATMENT PLANT (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: **LAKE SALTONSTALL WATER TREATMENT PLANT (WSFID: 00706)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.15 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.09 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.0 PH	Daily	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: LAKE SALTONSTALL WATER TREATMENT PLANT (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 1.2 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.8 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186	
Start Date: 1/1/2002		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: LAKE SALTONSTALL WATER TREATMENT PLANT (WSFID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	

Water System Facility: ENTRY POINT - WEST RIVER WTP (WSFID: 00707)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.15 MG/L	2
Start Date: 3/1/2025			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: **ENTRY POINT - WEST RIVER WTP (WSID: 00707)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.09 MG/L	2	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.0 PH	2	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 1.2 MG/L	2	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: ENTRY POINT - WEST RIVER WTP (WSID: 00707)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.8 MG/L	2
Start Date: 3/1/2025		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: LAKE WHITNEY WATER TREATMENT PLANT (WSID: 00708)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2005		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: **LAKE WHITNEY WATER TREATMENT PLANT (WSID: 00708)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.15 MG/L	2	
Start Date: 3/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.09 MG/L	2	
Start Date: 3/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.0 PH	Daily	
Start Date: 3/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily	
Start Date: 3/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: LAKE WHITNEY WATER TREATMENT PLANT (WSID: 00708)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 1.2 MG/L	2	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.8 MG/L	2	
Start Date: 3/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186	
Start Date: 5/1/2005		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186	
Start Date: 5/1/2005		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: HOUSATONIC WELLFIELD TREATMENT PLANT (WSFID: 00709)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 1.25 MG/L	Continuous
Start Date: 8/1/2021			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.1 MG/L	2
Start Date: 5/1/2025			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: HOUSATONIC WELLFIELD TREATMENT PLANT (WSID: 00709)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.01 MG/L	2	
Start Date: 5/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.0 PH	Daily	
Start Date: 5/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily	
Start Date: 5/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 1.6 MG/L	2	
Start Date: 5/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: HOUSATONIC WELLFIELD TREATMENT PLANT (WSFID: 00709)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.0 MG/L	2	
Start Date: 5/1/2025		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

Water System Facility: DERBY WELLFIELD TREATMENT PLANT (WSFID: 00710)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point RDC (EPRD)	Minimum: 1.0 MG/L	Continuous	
Start Date: 6/1/2011		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
	Offline	8/1/2025 - 8/31/2025	n/a	Y
	Offline	9/1/2025 - 9/30/2025	n/a	Y
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
	Offline	8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
	Offline	8/1/2025 - 8/31/2025	n/a	Y
	Offline	9/1/2025 - 9/30/2025	n/a	Y
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: **DERBY WELLFIELD TREATMENT PLANT (WSFID: 00710)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.1 MG/L	2	
Start Date: 5/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.01 MG/L	2	
Start Date: 5/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.0 PH	Daily	
Start Date: 5/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily	
Start Date: 5/1/2025		Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: DERBY WELLFIELD TREATMENT PLANT (WSFID: 00710)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 2.0 MG/L	2
Start Date: 5/1/2025		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Monitoring
		9/1/2025 - 9/30/2025	Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.0 MG/L	2
Start Date: 5/1/2025		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Monitoring
		9/1/2025 - 9/30/2025	Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: WEST RIVER WATER TREATMENT PLANT (WSFID: 184)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Monitoring
		9/1/2025 - 9/30/2025	Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Monitoring
		9/1/2025 - 9/30/2025	Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility: WEST RIVER WATER TREATMENT PLANT (WSFID: 184)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	

Water System Facility: FOUNTAIN LAKE PUMP STATION (WSFID: 200)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.001 MG/L	Daily
Start Date: 4/1/2009			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos Rule Tier	WQP 2 DBPR Stage
					Lead and Copper Rule	Asbestos Rule Tier	WQP 2 DBPR Stage	
00500	HOUSATONIC WELLFIELD RAW ENTRY POINT	2	RAW ENTRY POINT	A				
00600	DISTRIBUTION SYSTEM	01076	1405 HIGHLAND, CH	I	Y			
		01076A	1392 HIGHLAND, CH	I	Y			
		01076B	1425 HIGHLAND, CH	I	Y			
		01146	PROSPECT TANK	A	Y			
		01146A	35 CORNWALL INTERNAL	A	Y			
		01146B	35 CORNWALL HYDRANT	A	Y			
		01150	250 MAPLE, CH	A	Y			
		01150 A	264 MAPLE, CH	A	Y			
		01150 B	94 MITCHELL, CH	A	Y			
		01162	1686 RTE 70, CH	A	Y			Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
	01163	84 SO MAIN ST, CH		I			
	01164	414 N BROOKSVALE, CH		I			
	01175	885 SO MAIN ST, CH		I	Y		
	01175A	925 SOUTH MAIN, CH		I	Y		
	01175B	850 SOUTH MAIN, CH		I	Y		
	01181	500 CORNWALL AVE, CH		I			
	02050	6 POINT BEACH MI		A			
	02060	10 JONES HILL (WH)		A	Y		Y
	02060A	5 JONES HILL, WH		A	Y		
	02060B	12 OCEAN AVE, WH		A	Y		
	02061	21 ELM STREET, WH		A	Y		
	02061A	31 ELM STREET, WH		A	Y		
	02061B	27 KIMBERLY AVE, WH		A	Y		
	02062	24 OCEAN AVE, WH		I			Y
	02065	36 CHERRY HILL RD BR		A	Y		
	02065 A	32 CHERRY HILL RD BR		A	Y		
	02065 B	41 MONTOYA DR HYD		A	Y		
	02073	1645 RTE 80, NB		I	Y		
	02073A	5 CHURCH STREET, NB		I	Y		
	02073B	1675 RTE 80, NB		I	Y		
	02074	1720 FOXON ROAD, NB		A	Y		
	02074A	1719 FOXON ROAD, NB		A	Y		
	02074B	1739 FOXON ROAD, NB		A	Y		
	02075	539 FOXON RD, EH		A	Y		
	02075A	580 FOXON RD, EH		A	Y		
	02075B	7 SYLVAN HILL HYD		A	Y		
	02077	153 SPRING ST, WH		A	Y		
	02077A	154 SPRING ST, WH		A	Y		
	02077B	153B SPRING ST, WH		A	Y		
	02081	PLATT LANE SS (MILFO		A	Y		Y
	02084	233 GRAND AVENUE, NH		A	Y		
	02084A	255 GRAND AVENUE, NH		A	Y		
	02084B	229 GRAND AVENUE, NH		A	Y		
	02085	1260 QUINNIPAC, NH		I	Y		
	02085A	490 FOXON BLVD, NH		I	Y		
	02085B	320 FOXON BLVD		I	Y		
	02087	244 PLATT AVE, WH		A	Y		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
	02087A	265 PLATT AVE, WH		A	Y		
	02087B	852 JONES HILL, WH		A	Y		
	02088	503 NEW HVN AVE, MI		A	Y		
	02088A	524 NEW HVN AVE, MI		A	Y		
	02088B	500 NEW HVN AVE, MI		A	Y		
	02092	90 SARGENT DR, NH		A	Y		
	02092A	100 SARGENT DR, NH		A	Y		
	02092B	60 SARGENT DR, NH		A	Y		
	02098	OLD ORONOQUE SS (MLF		A	Y		
	02113 D	204 MELBA ST, MI		I	Y		Y
	02113A	254 MELBA ST, MI		I	Y		
	02113B	180 PLATT ST, MF		I	Y		
	02114	OLD FIELD LN MILFORD		A			
	02115	W POND RD TNK, NB		A			
	02116	321 EASTERN ST, NH		A	Y		
	02116A	390 EASTERN ST, NH		A	Y		
	02116B	325 EASTERN ST, NH		A	Y		
	02120	311 STATE ST, NOH		A	Y		
	02120A	325 STATE ST, NOH		A	Y		
	02120B	303 STATE ST, NOH		A	Y		
	02123	350 WHITNEY AVE, NH		A	Y		
	02123A	362 WHITNEY AVE, NH		A	Y		
	02123B	340 WHITNEY AVE, NH		A	Y		
	02125	415 STATE ST, NOH		A	Y		
	02125 A	395 STATE ST, NOH		A	Y		
	02125 B	410 STATE ST, NOH		A	Y		
	02126	196 S MONTOWESE, BR		A	Y		
	02126A	199 S MONTOWESE, BR		A	Y		
	02126B	202 S MONTOWESE, BR		A	Y		
	02132	238 QUINNIPAC, NOH		A	Y		
	02132A	232 QUINNIPAC, NOH		A	Y		
	02132B	244 QUINNIPAC, NOH		A	Y		
	02135	282 QUINNIPAC, NH		A	Y		
	02135A	282 QUINNIPAC, NH		A	Y		
	02135B	282 QUINNIPAC, NH		A	Y		
	02138	321 CROWN ST, NH		I	Y		
	02138A	337 CROWN ST, NH		I	Y		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
	02138B	305 CROWN ST, NH		I	Y		
	02144	952 GRAND AVE, NH		A			
	02145	935 GRAND AVE, NH		A	Y		
	02145A	952 GRAND AVE, NH		A	Y		
	02145B	170 OLIVE ST, NH		A	Y		
	02149	135 SUMMER LN, NOH		A			Y
	02150	58 MIDDLETOWN, NH		A	Y		
	02150A	72 MIDDLETOWN, NH		A	Y		
	02150B	34 MIDDLETOWN, NH		A	Y		
	02153	230 THIMBLE IS, BR		A	Y		
	02153A	230A THIMBLE IS, BR		A	Y		
	02153B	230B THIMBLE IS, BR		A	Y		
	02155	121 FLAT ROCK RD, BR		A			Y
	02170	120 ELLSWORTH, NH		A			
	02175	525 HOWARD AVE, NH		A			
	02177	1450 CHAPEL ST, NH		A	Y		
	02177A	630 GEORGE ST, NH		A	Y		
	02177B	659 GEORGE ST, NH		A	Y		
	02178	2047 BRIDGEPORT, MI		A	Y		
	02178A	2051 BRIDGEPORT, MI		A	Y		
	02178B	2028 BRIDGEPORT, MI		A	Y		
	02179	309 CONGRESS AVE, NH		A	Y		
	02179A	300 GEORGE ST, NH		A	Y		
	02179B	290 CONGRESS AVE, NH		A	Y		
	02180	950 CAMPBELL AVE, WH		A	Y		
	02180A	975 CAMPBELL AVE, WH		A	Y		
	02180B	935 CAMPBELL AVE, WH		A	Y		
	02192	30 STILLMAN RD, NOH		A			Y
	02193	STILLMAN (NO HVN)		A	Y		Y
	02199	184 CAMPBELL AVE, WH		A	Y		
	02199A	185 CAMPBELL AVE, WH		A	Y		
	02199B	152 CAMPBELL AVE, WH		A	Y		
	03069	1470 BOSTON POST, MI		A	Y		
	03069A	1460 BOSTON POST, MI		A	Y		
	03069B	1492 BOSTON POST, MI		A	Y		
	03070	115 BOSTON POST, OR		A	Y		
	03070A	111 BOSTON POST, OR		A	Y		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
		03070B	121 BOSTON POST, OR	A	Y			
		03071	388 BRIDGEPORT (MLFD	A	Y			Y
		03071A	417 BRIDGEPORT, MI	A	Y			
		03071B	394 BRIDGEPORT, MI	A	Y			
		03080	617 ORANGE CNTR, OR	A	Y			
		03080A	205 MEETINGHOUSE, OR	A	Y			
		03080B	625 ORANGE CNTR, OR	A	Y			
		03110	962 GRASSY HILL, OR	A	Y			Y
		03110 A	278 HYLAND TERR, HYD	A	Y			
		03110 B	967 GRASSY HILL HYD	A	Y			
		03115	91 COUNTRY LN, OR	A				Y
		03119	367 (AKA 265) FORD	A				
		03149	25 MORRIS ST, WH	A	Y			
		03149A	461 DERBY AVENUE, WH	A	Y			
		03149B	544 DERBY AVE, WH	A	Y			
		03152	349 NAUGATUCK, MI	A	Y			
		03152A	379 NAUGATUCK, MI	A	Y			
		03152B	341 NAUGATUCK, MI	A	Y			
		03155	HYD RTE 34@RTE 121	I				
		03156	HYD RTE 34@FERNBRK	I				
		03157	HYD RTE 34@WILLARD	I				
		03158	HYD WILLARD@RAINBOW	I				
		04091	100 POND LILY, NH	I	Y			
		04091A	70 POND LILY, NH	I	Y			
		04091B	140 POND LILY, NH	I	Y			
		04095	140 POND LILY AV, NH	A	Y			
		04095A	100 POND LILY AV, NH	A	Y			
		04095B	140+POND LILY AV, NH	A	Y			
		04125	1978 STATE ST, HA	A	Y			
		04125A	1959 STATE ST, HA	A	Y			
		04125B	1985 STATE ST, HA	A	Y			
		04130	11 PINE ST - HAMDEN	A				
		04144	36 FAIRVIEW AVE, HA	I	Y			
		04144A	16 FAIRVIEW AVE, HA	I	Y			
		04144B	56 FAIRVIEW AVE, HA	I	Y			
		04145	615 FITCH STREET, NH	A	Y			
		04145A	625 FITCH STREET, NH	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
		04145B	537 FITCH STREET, NH	A	Y		
		04154	250 BLAKE RD, HA	A			
		04170	22 VICTORY DR., NH	A			
		05095	419 WASHINGTON, NOH	I	Y		
		05095A	404 WASHINGTON, NOH	I	Y		
		05095B	417 WASHINGTON, NOH	I	Y		
		05096	366 WSHGTN AVE, NOH	A	Y		
		05096A	345 WASHINGTON AVE.	A	Y		
		05096B	386 WASHINGTON AVE.	A	Y		
		05102	1671 WHITNEY AVE, HA	A	Y		
		05102A	1658 WHITNEY AVE, HA	A	Y		
		05102B	1697 WHITNEY AVE, HA	A	Y		
		05104	370 BASSETT RD, NOH	A			
		05112	6 LAWNCREST DR, NOH	A			Y
		05115	402 CLINTONVILLE, NOH	I	Y		
		05115A	343 CLINTONVILLE, NOH	I	Y		
		05115B	456 CLINTONVILLE, NOH	I	Y		
		05116	432 CLINTONVILLE RD	A	Y		
		05116A	410 CLINTONVILLE RD	A	Y		
		05116B	456 CLINTONVILLE RD	A	Y		
		05120	135 SNTNEL HILL, NOH	A			Y
		05135	HAMDEN TOWN HALL	A	Y		
		05135 A	2384 WHITNEY AVE, HA	A	Y		
		05135 B	2373 WHITNEY AVE, HA	A	Y		
		05140	150 SANFORD ST, HA	A			
		05189	1795 DIXWELL AVE, HA	A	Y		
		05189A	1814 DIXWELL AVE, HA	A	Y		
		05189B	1776 DIXWELL AVE, HA	A	Y		
		06050	390 COSEY BEACH, EH	A			
		06068	401 FORBES AVE, NH	A	Y		
		06068A	429 FORBES AVE, NH	A	Y		
		06068B	416 FORBES AVE, NH	A	Y		
		06070	826 WOODWARD AVE	A	Y		
		06070A	810 WOODWARD AVE	A	Y		
		06070B	835 WOODWARD AVE	A	Y		
		06081	120 WOODWARD AVE, NH	A			
		06083	200 NORTH MAIN, BR	A	Y		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
	06083A	186 NORTH MAIN, BR		A	Y		
	06083B	226 NORTH MAIN, BR		A	Y		
	06087	480 SHORT BEACH, EH		A	Y		
	06087A	UPSTREAM		A	Y		
	06087B	DOWNSTREAM		A	Y		
	06089	667 COE AVE, EH		A	Y		Y
	06089A	23 HEMINGWAY, EH		A	Y		
	06089B	620 COE AVE, EH		A	Y		
	06097	938 WEST MAIN, BR		A	Y		
	06097A	906 WEST MAIN, BR		A	Y		
	06097B	972 WEST MAIN, BR		A	Y		
	06106	510 LIGHTHOUSE (NH)		A	Y		Y
	06106A	38 TOWNSEND AVE, NH		A	Y		
	06106B	50 MORRIS COVE, NH		A	Y		
	06107	BRSHY PLN RD TNK, BR		A	Y		
	06107A	271 BRUSHY PLNS, BR		A	Y		
	06107B	320 BRUSHY PLNS, BR		A	Y		
	06110	16 VICTOR HILL, BR		A			Y
	06148	202 EAST MAIN, BR		A			
	06149	100 DOUBLE BEACH, BR		A			
	0700706	- DISTRIBUTION		A	Y		
	07127	1 LAUREL VIEW DR, HA		A	Y		
	07127A	1A LAUREL VIEW, HA		A	Y		
	07127B	1B LAUREL VIEW, HA		A	Y		
	07128	HIGH ROCK PS		A	Y		
	07128 A	715 WESTWOODS HYD		A	Y		
	07128 B	822 FANS ROCK, HA		A	Y		
	07139	184 DOWNS RD, BE		I			
	07159	3835 WHITNEY AVE, HA		A			
	07160	1130 SHERMAN AVE, HA		I	Y		
	07160A	1180 SHERMAN AVE		I	Y		
	07160B	26 ROSSOTTO AVE		I	Y		
	07161	2995 WHITNEY AVE, HA		A	Y		
	07161A	3010 WHITNEY AVE		A	Y		
	07161B	2989 WHITNEY AVE		A	Y		
	07185	3837 WHITNEY AVE, HA		A	Y		
	07185 -	DISTRIBUTION		A	Y		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
	07185A	3825 WHITNEY AVE, HA		A	Y		
	07185B	3850 WHITNEY AVE, HA		A	Y		
	08058	25 NEWTON RD, WO		A			
	08062	1201 WHALLEY, NH		A	Y		
	08062A	1185 WHALLEY AVE, NH		A	Y		
	08062B	1220 WHALLEY AVE, NH		A	Y		
	08174	RIMMON ROAD TNK, WO		A	Y		
	08174A	353 RIMMON ROAD, WO		A	Y		
	08174B	BEAVER RD METER, SE		A	Y		
	09201	300 BURWELL RD, WH		A			
	09205	42 SHINGLE HILL, WH		A			
	09207	499 DERBY AVE, WH		A			
	09209	3 HRSHESHOE HILL, NOH		A			
	09212	50 WEST AVE, MI		A			
	09213	FORD STREET TANKS		A	Y		
	09215	114 KIMBERLY AVE, HA		A			
	09216	29 MAIN ST (ST PK)		A			
	09220	MANSFIELD DR, NB		A			
	09223	45 SLTNSTAL PL, EH		A			
	09227	51 RDGEWOOD TER NOH		A			
	09231	1862 MERIDEN RD, WL		A			
	09240	KMBRLY LN TNK, WL		A			
	09242	99 FORD RD, AN		A			
	09244	400 BRMGHAM BLVD, AN		A			
	09250	75 CHATFIELD ST DE		A			
	09402	RABBIT ROCK PS		A	Y		
	09405	HIGH ROCK TNK		A			
	09414	CHERRY HILL PS		A	Y		
	4	GENERIC DISTRIBUTION		A			
	60001	230 BEAVER ST., AN		I	Y		
	60003	1 MAIN ST. ANS		I	Y		
	60004	191 HOWARD AVE. ANS		I	Y		
	60005	80 PULASKI HWY. ANS		A	Y		
	60006	1 DIVISION ST. ANS		I	Y		
	60006A	-BIRM DISTRIBUTION		I	Y		
	60006B	-BIRM DISTRIBUTION		I	Y		
	60007	67 PLATT ST. ANS		I	Y		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
	60008	GREAT HILL RD. ANS		I	Y		
	60009	30 HILL ST PS, AN		A	Y		
	60009A	18 N SPRING ST HYD		A	Y		
	60009B	1 BERKSHIRE RD HYD		A	Y		
	60018	380 BIRMINGHAM, AN		A	Y		
	60018A	108-126 GH RD, AN		A	Y		
	60018B	390 BIRMINGHAM, AN		A	Y		
	60103	130 DIVISION ST. DBY		A	Y		
	60103A	300 SEYMOUR RD, DE		A	Y		
	60103B	16 SPRING ST, DE		A	Y		
	60104	57 DERBY AVE. DBY		I	Y		
	60109	151 OLIVIA ST. DBY		I	Y		
	60110	210 CHATFIELD ST DBY		I	Y		
	60112	FORD ROAD TANK, AN		A			
	60113	KIMBERLY LN TNKS, AN		A			
	60116	FOUNTAIN LK TANK, AN		A			
	60117	HAWKSTONE INTRCNCTN		A			
	61201	HOUSATONIC WELLS EFF		A	Y		
	61202	DERBY WELL #1 EFF		A	Y		
	AS-01	200 SUNSET DR. ANS		A			
	AS-02	112 HODGE AVE. ANS		A			
	BLC01	-BIR DISTPB/CU BLC0		A	Y		
	BLC-01	11 DEMPSEY CT., AN		A		1	
	BLC02	-BIR DISTPB/CU BLC0		A	Y		
	BLC-02	13 DEMPSEY CT. ANS		A		1	
	BLC03	-BIR DISTPB/CU BLC0		A	Y		
	BLC-03	1 MACINTOSH LA. ANS		A		1	
	BLC04	-BIR DISTPB/CU BLC0		A	Y		
	BLC-04	27 WINESAP CT. ANS		A		1	
	BLC05	-BIR DISTPB/CU BLC0		A	Y		
	BLC-05	11 SHORTELL DR. ANS		A		1	
	BLC06	-BIR DISTPB/CU BLC0		A	Y		
	BLC-06	7 SHORTELL DR. ANS		A		1	
	BLC07	-BIR DISTPB/CU BLC0		A	Y		
	BLC-07	20 WINESAP CT. ANS		A		1	
	BLC08	-BIR DISTPB/CU BLC0		A	Y		
	BLC-08	9 DEMPSEY CT. ANS		A		1	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
		BLC09	-BIR DISTPB/CU BLC0	A	Y			
		BLC-09	16 SHORTELL DR. ANS	A		1		
		BLC10	-BIR DISTPB/CU BLC1	A	Y			
		BLC-10	5 BENANTO DR. DBY	A		1		
		BLC11	-BIR DISTPB/CU BLC1	A	Y			
		BLC-11	19 GARDNERS LA. ANS	A		1		
		BLC12	-BIR DISTPB/CU BLC1	A	Y			
		BLC-12	17 BUSWELL ST. ANS	A		1		
		BLC13	-BIR DISTPB/CU BLC1	A	Y			
		BLC-13	200 N. STATE ST. ANS	A		1		
		BLC14	-BIR DISTPB/CU BLC1	A	Y			
		BLC-14	29 MANNERS AVE. SEY	A		1		
		BLC15	-BIR DISTPB/CU BLC1	A	Y			
		BLC-15	4 SAVELLE RD. ANS	A		1		
		BLC16	-BIR DISTPB/CU BLC1	A	Y			
		BLC-16	28 BARTHOLOMEW ANS	A		1		
		BLC17	-BIR DISTPB/CU BLC1	A	Y			
		BLC-17	37 CORTLAND PL. ANS	A		1		
		BLC18	-BIR DISTPB/CU BLC1	A	Y			
		BLC-18	103 JEWETT ST. ANS	A		1		
		BLC19	-BIR DISTPB/CU BLC1	A	Y			
		BLC-19	9 CHERRY ST. ANS	A		1		
		BLC20	-BIR DISTPB/CU BLC2	A	Y			
		BLC-20	27 MANNERS AVE. SEY	A		1		
		BLC21	5 MACINTOSH LA. ANS	A		1		
		BLC22	-BIR DISTPB/CU BLC2	A	Y			
		BLC-22	54 FINNEY ST. ANS	A		1		
		BLC23	-BIR DISTPB/CU BLC2	A	Y			
		BLC-23	9 BENZ ST. ANS	A		1		
		BLC24	-BIR DISTPB/CU BLC2	A	Y			
		BLC-24	40 FRANKLIN AVE. DBY	A		1		
		BLC25	-BIR DISTPB/CU BLC2	A	Y			
		BLC-25	13 EDGEWOOD AVE. ANS	A		1		
		BLC26	-BIR DISTPB/CU BLC2	A	Y			
		BLC-26	14 DWIGHT ST. ANS	A		1		
		BLC27	-BIR DISTPB/CU BLC2	A	Y			
		BLC-27	84 DWIGHT ST. ANS	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
		BLC-28	13 MACINTOSH LA. ANS	A		1	
		BLC29	-BIR DISTPB/CU BLC2	A	Y		
		BLC-29	15 SHORTELL DR. ANS	A		1	
		BLC30	-BIR DISTPB/CU BLC3	A	Y		
		BLC-30	3 BENANTO DR. DBY	A		1	
		BLC-31	9 SHORTELL DR. ANS	A		1	
		BLC-32	2 BEECHWOOD DR. ANS	A		1	
		BLC33	-BIR DISTPB/CU BLC3	A	Y		
		BLC-33	44 CONDON DR. ANS	A		1	
		BLC34	-BIR DISTPB/CU BLC3	A	Y		
		BLC-34	9 HART LA. ANS	A		1	
		BLC35	-BIR DISTPB/CU BLC3	A	Y		
		BLC-35	79 ROCKWOOD AVE. ANS	A		1	
		BLC36	-BIR DISTPB/CU BLC3	A	Y		
		BLC-36	9 ALCOTT ST. ANS	A		1	
		BLC37	-BIR DISTPB/CU BLC3	A	Y		
		BLC-37	120 GREAT HILL ANS	A		1	
		BLC38	-BIR DISTPB/CU BLC3	A	Y		
		BLC-38	62 BEAVER ST. ANS	A		1	
		BLC-39	834 S. MAIN ST. SEY	A		1	
		BLC40	-BIR DISTPB/CU BLC4	A	Y		
		BLC-40	238 SENTINELHILL DBY	A		1	
		DLC-01	22 GRANDVIEW , DE	A		1	
		DLC-02	3 DANIELLE CT., DE	A		1	
		DLC-03	75 HARRISON AVE., DE	A		1	
		DLC-04	29R BELLEVIEW, DE	A		1	
		DLC-05	69 HARRISON AVE., DE	A		1	
		DLC-06	10 GARFIELD AVE., DE	A		1	
		DLC-07	7 GRANDVIEW, DE	A		1	
		DLC-08	1 DEVON VIEW, DE	A		1	
		DLC-09	5 DEVON VIEW, DE	A		1	
		DLC-10	4 DEVON VIEW, DE	A		1	
		DLC-11	4 KRAKOW ST, DE	A		1	
		DLC-12	40 PINE ST, DE	A		1	
		DLC-13	243 MARSHALL LN, DE	A		1	
		DLC-14	5 DANIELLE CT, DE	A		1	
		DLC-15	47 GRANDVIEW, DE	A		1	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
	DLC-16	64 SENTINEL HILL, DE		A		1	
	DLC-17	19 BELLEVUE, DE		A		1	
	DOWNSTREAM	WITHIN 5 SERVICE CON		A			
	L0001	90 ALPS RD, BR		A		1	
	L0002	23 AVON ROAD, BR		A		1	
	L0003	2 BROCKETTS LN, BR		A		1	
	L0004	17 CHAPEL DR, BR		A		1	
	L0005	1 CYNTHIA CT, BR		A		1	
	L0006	15 FERN CT, BR		A		1	
	L0007	18 GOULD LN, BR		A		1	
	L0008	2 MILO DR, BR		A		1	
	L0009	10 PENT RD, BR		A		1	
	L0010	9 SHORE DR, BR		A		1	
	L0011	28 SIDE HILL RD, BR		A		1	
	L0012	4 STONE GATE DR, BR		A		1	
	L0013	29 STONY CREEK, BR		A		1	
	L0014	4 WHITE BIRCH LN, BR		A		1	
	L0015	32 WINDMILL HILL, BR		A		1	
	L0016	120 BATES DR, CH		A		1	
	L0017	20 HERITAGE DR, CH		A		1	
	L0018	374 N BROOKSVALE, CH		A		1	
	L0019	108 PAUL NEY RD, CH		A		1	
	L0020	170 ROMULUS RD, CH		A		1	
	L0021	85 THISTLE CT, CH		A		1	
	L0022	410 WALLINGFORD, CH		A		1	
	L0023	12 WINGED FOOT, CH		A		1	
	L0024	146 GEORGE ST, EH		A		1	
	L0025	33 MEADOW ST, EH		A		1	
	L0026	3 TIMBERLAND DR, EH		A		1	
	L0027	36 VIKING ST, EH		A		1	
	L0028	60 WILLOW RD, EH		A		1	
	L0029	10 DELSOLE RD, HA		A		1	
	L0030	122 DORRANCE ST, HA		A		1	
	L0031	23 HAMPSHIRE, HA		A		1	
	L0032	20 HUNTINGTON, HA		A		1	
	L0033	240 IVES ST, HA		A		1	
	L0034	25 LAURA RD, HA		A		1	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
	L0035	19 ROBERTSON DR, HA	A			1	
	L0036	77 RUSSO DR, HA	A			1	
	L0037	122 SHERMAN AVE, HA	A			1	
	L0038	420 STILL HILL, HA	A			1	
	L0039	6 SUNNYSIDE AVE, HA	A			1	
	L0040	94 TANGLEWOOD, HA	A			1	
	L0041	27 CEDAR HILL RD, MI	A			1	
	L0042	133 CORONA DR, MI	A			1	
	L0043	227 FORD ST, MI	A			1	
	L0044	95 HAYSTACK RD, MI	A			1	
	L0045	18 ROSELLE ST, MI	A			1	
	L0046	40 TURNOR AVE, MI	A			1	
	L0047	11 VICTORY DR, MI	A			1	
	L0048	93 WELCHS PT RD, MI	A			1	
	L0049	54 WILDFLOWER DR, MI	A			1	
	L0050	52 CART RD, NH	A			1	
	L0051	747 QUINNIPAC, NH	A			1	
	L0052	1 BLUE RIDGE LN, NOH	A			1	
	L0053	22 GILES AVE, NOH	A			1	
	L0054	39 HILLTOP TERR, NOH	A			1	
	L0055	8 NETTLETON AVE, NOH	A			1	
	L0056	130 NORTH HILL, NOH	A			1	
	L0057	1 PEZ CT, NOH	A			1	
	L0058	96 ROCK RD, NOH	A			1	
	L0059	96 SENTNL HILL, NOH	A			1	
	L0060	473 FAIRWAY RD, OR	A			1	
	L0061	362 RACEBROOK RD, OR	A			1	
	L0062	707 SO HICKORY, OR	A			1	
	L0063	265 CONNECTICUT, WH	A			1	
	L0064	80 HONOR RD, WH	A			1	
	L0065	183 PAINTER AVE, WH	A			1	
	L0066	64 ROOSEVELT AVE, WH	A			1	
	L0067	5 VIEW ST, WH	A			1	
	L0068	68 WEST SPRING, WH	A			1	
	L0069	19 ZEGMONT ST, WH	A			1	
	UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	NORTH CHESHIRE WELLFIELD TREATMENT ST	3	ENTRY POINT - NORTH	A			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
00701	SOUTH CHESHIRE WELLFIELD TREATMENT ST	3	ENTRY POINT - SOUTH	A			
00702	NORTH SLEEPING GIANT WELLFIELD TR ST	3	ENTRY POINT - N SLEE	A			
00703	SOUTH SLEEPING GIANT WELLFIELD TR ST	3	ENTRY POINT-SOUTH SL	A			
00704	MOUNT CARMEL WELLFIELD TREATMENT STATION	3	ENTRY POINT - MOUNT	A			
00705	LAKE GAILLARD TREATMENT PLANT	3	EP-LAKE GAILLARD TP	A			
		5	CFE - LAKE GAILLARD	A			
00706	LAKE SALTONSTALL WATER TREATMENT PLANT	3	EP-SALTONSTALL TP	A			
		5	CFE-SALTONSTALL TP	A			
00707	ENTRY POINT - WEST RIVER WTP	3	EP- WEST RIVER WTP	A			
00708	LAKE WHITNEY WATER TREATMENT PLANT	3	EP - LAKE WHITNEY	A			
		5	CFE - LAKE WHITNEY	A			
00709	HOUSATONIC WELLFIELD TREATMENT PLANT	3	HOUSATONIC WELLFIELD	A			
00710	DERBY WELLFIELD TREATMENT PLANT	3	ENTRY POINT - DERBY	A			
00711	ENTRY POINT - FOUNTAIN LAKE PUMP STATION	3	ENTRY POINT	A			
00712	ENTRY POINT - HILL STREET PUMP STATION	3	ENTRY POINT	A			
1147	NORTH CHESHIRE WELL #6	2	N CHESHIRE WELL #6	A			
1193	SEYMOUR WELL 5	2	HOUSATONIC WELL 5	A			
1194	SEYMOUR WELL 6	2	HOUSATONIC WELL 6	A			
1196	SEYMOUR WELL 7	2	HOUSATONIC WELL 7	A			
1346	NORTH CHESHIRE WELL #1	2	N CHESHIRE WELL #1	A			
1349	NORTH CHESHIRE WELL #4	2	N CHESHIRE WELL #4	A			
1350	NORTH CHESHIRE WELL #5	2	N CHESHIRE WELL #5	A			
1382	SOUTH CHESHIRE WELL #1	2	S CHESHIRE WELL #1	A			
1383	SOUTH CHESHIRE WELL #2	2	S CHESHIRE WELL #2	A			
1384	NORTH SLEEPING GIANT WELL #1	2	N SLEEPING GIANT W#1	A			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
1385	NORTH SLEEPING GIANT WELL #2	2	N SLEEPING GIANT W#2	A			
1386	NORTH SLEEPING GIANT WELL #4	2	N SLEEPING GIANT W#4	A			
1387	SOUTH SLEEPING GIANT WELL #1	2	S SLEEPING GIANT W#1	A			
1388	MOUNT CARMEL WELL #1A	2	MOUNT CARMEL WELL 1	A			
1389	MOUNT CARMEL WELL #2	2	MOUNT CARMEL WELL 2	A			
1405	DERBY WELL 1	2	DERBY WELL 1	A			
184	WEST RIVER WATER TREATMENT PLANT	3	EP - WEST RIVER TP	A			
		5	CFE - WEST RIVER TP	A			
200	FOUNTAIN LAKE PUMP STATION						
20399	INTERCONNECTION - CT0378011 EAST DERBY						
2205	LAKE HAMMONASSET	1	LAKE HAMMONASSET	A			
2206	LAKE MENUNKETUC	1	LAKE MENUNKETUC	A			
2207	LAKE GAILLARD	1	LAKE GAILLARD	A			
2208	IRON WORKS STREAM DIVERSION	1	IRON WORKS STREAM	A			
2209	LITTLE MEADOW DIVERSION	1	LITTLE MEADOW DIV	A			
2210	NORTHFORD DIVERSION	1	NORTHFORD DIVERSION	A			
2211	LUMPACK DIVERSION	1	LUMPACK DIVERSION	A			
2212	LITTLE GULPH DIVERSION	1	RESERVOIR	A			
2213	ROUND HILL DIVERSION	1	RESERVOIR	A			
2214	BIG GULPH DIVERSION	1	BIG GULPH DIVERSION	A			
2215	LAKE BETHANY	1	LAKE BETHANY	A			
2216	LAKE WATROUS	1	LAKE WATROUS	A			
2217	LAKE CHAMBERLAIN	1	RESERVOIR	A			
2218	LAKE GLEN	1	LAKE GLEN	A			
2219	LAKE DAWSON	1	LAKE DAWSON	A			
2220	LAKE WHITNEY	1	LAKE WHITNEY	A			
2221	LAKE SALTONSTALL	1	LAKE SALTONSTALL	A			
2222	FARM RIVER DIVERSION	1	FARM RIVER DIVERSION	A			
2223	FURNACE POND	1	FURNACE POND	I			
30059	LAKE GLEN						
30060	LAKE WATROUS						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined 115,707
					Agricultural

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility Facility ID	Sampling Point ID	Sampling Point Description	Total	Lead and	Stage
			Coliform Status	Copper Rule	
30061	LAKE GAILLARD				
30062	LAKE DAWSON				
30063	LAKE SALTONSTALL				
32897	KIMBERLY LANE STANDPIPE #1				
32899	KIMBERLY LANE STANDPIPE #2				
32917	FORD STREET PUMP STATION				
32919	FORD STREET STANDPIPE				
32929	CITY OF DERBY STANDPIPE (STRANG RD)				
32931	CITY OF DERBY PUMP STATION (STRANG RD)				
32937	COON HOLLOW HYDRO TANK #2				
32939	COON HOLLOW PUMP STATION				
32941	FOUNTAIN LAKE STANDPIPE				
48228	WEST RIVER RAW INTAKE	1	WEST RIV. RAW INTAKE	A	
49761	INTERCONNECTION -CT0608011 CTWC GUILFORD				
49805	WEST RIVER	1	WEST RIVER	A	
49811	BURWELL HILL #2 TANK				
49813	WEST AVENUE TANK				
49815	FORD STREET #1 TANK				
49817	FORD STREET #2 TANK				
49821	HIGH ROCK TANK				
49823	MALTBY TANK				
49825	MILL ROCK BASIN #1 TANK				
49827	MILL ROCK BASIN #2 TANK				
49829	NORTH BRANFORD TANK				
49831	NORTHWEST CHESHIRE TANK				
49833	PROSPECT #1 TANK				
49835	PROSPECT #2 TANK				
49837	RABBIT ROCK TANK				
49839	SALTONSTALL RIDGE TANK				
49841	SHINGLE HILL #1A TANK				
49843	SHINGLE HILL #2 TANK				
49845	WHITNEY-WINTERGREEN TANK				
49847	YORK HILL #1 TANK				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBINGTON, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility Facility ID	Sampling Point ID	Sampling Point Description	Total	Lead and	Stage
			Coliform Status	Copper Rule	
49849	YORK HILL #2 TANK				
49851	WOODBRIDGE TANK				
49853	LAKE GAILLARD #1 TANK				
49855	LAKE GAILLARD #2 TANK				
49861	WEST RIVER #1 TANK				
49863	WEST RIVER #2 TANK				
49865	NORTHFORD NORTH TANK				
49867	NORTHFORD SOUTH TANK				
49869	CLINTONVILLE PUMP STATION				
49871	LAKE GAILLARD PUMP STATION				
49873	LAKE SALTONSTALL PUMP STATION				
49875	NORTH CHESHIRE WELLFIELD PUMP STATION				
49879	SOUTH CHESHIRE PUMP STATION				
49913	SPRING STREET PUMP STATION				
49915	WHITNEY-WINTERGREEN PUMP STATION				
49917	NORTH BRANFORD PUMP STATION				
49919	BURWELL HILL PUMP STATION				
49921	WOODBRIDGE PUMP STATION				
49923	RABBIT ROCK PUMP STATION				
49925	GRASSY HILL PUMP STATION				
49927	RAYNHAM HILL PUMP STATION				
49929	HIGH ROCK PUMP STATION				
49931	CHERRY HILL PUMP STATION				
49935	WEST HILLS PUMP STATION				
49937	DOGBURN ROAD PUMP STATION				
49939	LINSLEY LAKE ROAD PUMP STATION				
49941	COBBLESTONE DRIVE PUMP STATION				
49945	NORTHWEST CHESHIRE PUMP STATION				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBINGTON, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Water System Facility and Sampling Point Inventory

Water System Facility Facility ID	Sampling Point ID	Sampling Point Description	Total	Lead and	Stage
			Coliform Status	Copper Rule	
51530 TALMADGE ROAD PUMP STATION					
52398 CHESHIRE PUMP STATION					
52402 HILLSIDE AVE PUMP STATION					
52404 LAKE WHITNEY PUMP STATION					
52406 SANFORD STREET PUMP STATION					
52416 STATE STREET PUMP STATION					
52418 LAKE SALTONSTALL TANK #1					
52420 LAKE SALTONSTALL TANK #2					
52422 NORTH CHESHIRE WTF CLEARWELL #1					
52424 NORTH CHESHIRE WTF CLEARWELL #2					
52426 SOUTH CHESHIRE WTF CLEARWELL					
52430 LAKE WHITNEY CLEARWELL #1					
52432 LAKE WHITNEY CLEARWELL #2					
54984 INTERCONNECTION - CT1240011 CTWC VALLEY					
55012 INTERCONNECTION - CT1240011- CTWC VALLEY					
55349 NORTH SLEEPING GIANT WELL #2R	2	NSG WELL 2R		A	
56282 GRASSY HILL TANK					
56412 HILL STREET PUMP STATION					
61045 INTERCONNECTION - CT1310011 SOUTHBINGTON					
61166 NORTH SLEEPING GIANT WELL #1R	2	NORTH SLEEPING GIANT		A	
61318 INTERCONNECTION - CT1480011 WALLINGFORD					
61612 BURWELL HILL TANK #1 REPLACEMENT					
62033 SEYMOUR WELL 4B	2	SEYMOUR WELL 4B		A	
63096 DERBY TANK					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 3 DISTRIBUTION SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)	
HILL, JAMES M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2027 12/31/2027
ADAMO, THOMAS C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
BARGER, THOMAS C.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2028
WITTNEBEN, MATTHEW S	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 3/31/2027

Water System Facility: **WEST RIVER WATER TREATMENT PLANT (WSF ID: 184)**

Facility Classification: CLASS 4 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
GIORDANO, STEVEN M	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
HILL, JAMES M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 12/31/2027
GIERLA, EDWARD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
CULBERTSON, JESSE	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
TEOFILO, ERIC T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2027

Water System Facility: **LAKE SALTONSTALL WATER TREATMENT PLANT (WSF ID: 00706)**

Facility Classification: CLASS 4 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
GIERLA, EDWARD M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
HILL, JAMES M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 12/31/2027
WHITNEY, ERIC H	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2028
BEENEY, JR., KEVIN L	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR IN TRAINING WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026 9/30/2026

Water System Facility: **LAKE GAILLARD TREATMENT PLANT (WSF ID: 00705)**

Facility Classification: CLASS 4 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
GIERLA, EDWARD M.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
HILL, JAMES M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2027 12/31/2027
WHITNEY, ERIC H	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2028
BEENEY, JR., KEVIN L	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR IN TRAINING WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026 9/30/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBURG, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Certified Operator Information

Water System Facility: NORTH SLEEPING GIANT WELLFIELD TR ST (WSF ID: 00702)

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
CULBERTSON, JESSE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
GIORDANO, STEVEN M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
HILL, JAMES M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
TEOFILO, ERIC T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2027

Water System Facility: SOUTH SLEEPING GIANT WELLFIELD TR ST (WSF ID: 00703)

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
CULBERTSON, JESSE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
GIORDANO, STEVEN M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
HILL, JAMES M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
TEOFILO, ERIC T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2027

Water System Facility: MOUNT CARMEL WELLFIELD TREATMENT STATION (WSF ID: 00704)

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
CULBERTSON, JESSE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
HILL, JAMES M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2027
GIERLA, EDWARD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
TEOFILO, ERIC T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2027

Water System Facility: NORTH CHESHIRE WELLFIELD TREATMENT ST (WSF ID: 00700)

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
CULBERTSON, JESSE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
GIORDANO, STEVEN M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
HILL, JAMES M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
GIERLA, EDWARD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
TEOFILO, ERIC T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2027

Water System Facility: SOUTH CHESHIRE WELLFIELD TREATMENT ST (WSF ID: 00701)

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
CULBERTSON, JESSE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
GIORDANO, STEVEN M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBINGTON, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

Certified Operator Information

Water System Facility: **SOUTH CHESHIRE WELLFIELD TREATMENT ST (WSF ID: 00701)**

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
HILL, JAMES M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 12/31/2027
TEOFILO, ERIC T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2027

Water System Facility: **LAKE WHITNEY WATER TREATMENT PLANT (WSF ID: 00708)**

Facility Classification: CLASS 4 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
CULBERTSON, JESSE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
HILL, JAMES M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 12/31/2027
GIERLA, EDWARD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
GIROLIMON, ERIC S	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR IN TRAINING WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2028 12/31/2028

Water System Facility: **DERBY WELLFIELD TREATMENT PLANT (WSF ID: 00710)**

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
GIORDANO, STEVEN M	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
HILL, JAMES M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 12/31/2027
GIERLA, EDWARD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
CULBERTSON, JESSE	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
TEOFILO, ERIC T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2027

Water System Facility: **HOUSATONIC WELLFIELD TREATMENT PLANT (WSF ID: 00709)**

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
GIORDANO, STEVEN M	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
HILL, JAMES M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 12/31/2027
GIERLA, EDWARD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
CULBERTSON, JESSE	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
TEOFILO, ERIC T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/31/2027

Contact Information

Name	Organization	Job Title		
Mr. Larry L. Bingaman	Regional Water Authority	President & Ceo		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
90 Sargent Drive		New Haven	CT	06511
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0930011	REGIONAL WATER AUTHORITY	C	418,900	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					115,707

Towns Served: ANSONIA, BETHANY, BRANFORD, CHESHIRE, DERBY, EAST HAVEN, HAMDEN, MERIDEN, MILFORD, NEW HAVEN, NORTH BRANFORD, NORTH HAVEN, ORANGE, PROSPECT, SEYMOUR, SOUTHBINGTON, WALLINGFORD, WEST HAVEN, WOLCOTT, WOODBRIDGE

203-562-4020		203-624-6129	203-668-1604	203-668-1604	lbingaman@rwater.com
--------------	--	--------------	--------------	--------------	----------------------

Contact Role(s): **Owner**

Name	Organization	Job Title		
Mr. Thomas C. Barger	Regional Water Authority	Water Quality Mgr		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
90 Sargent Drive		New Haven	CT	06511
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-401-2710		203-603-4965		
				tbarger@rwater.com

Contact Role(s): **Administrative Contact**

Name	Organization	Job Title		
Ms. Rochelle Kowalski	Sccrwa	Vp of Finance		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
Regional Water Authority	90 Sargent Drive	New Haven	CT	06511
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
				rkowalski@rwater.com

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.