Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES				С	27,620	L	SW
Local Address (where applicable)		Service	Resider	itial Commerci		al Industri	al Combine	ed Agricultural
	C		5,112	2	1,336	10	569	

	Connections	5,112	1,33	36	10	569	
Towns Served: NEW LONDON, WATERFORD			'	1	1		
Monito	ring Requ	irement	S				
Water System Facility: DISTRIBUTION SYSTEM (WSF ID): 00600)						
Chlorine Residual (1012)					30 ro	utine (RT)	per month
Sampling Point (Sampling Point ID)	/	Monitoring	Period	Colle	ction Period		nce Status
Select from Inventory of Active Sampling Points	1	1/1/23 - 11	/30/23			Cor	nplete
	1	2/1/23 - 12	/31/23			Cor	nplete
		1/1/24 - 1/	31/24			Cor	nplete
		2/1/24 - 2/	29/24			Cor	nplete
Asbestos (1094)					1 routin	e (RT) per	nine year
Sampling Point (Sampling Point ID)	/	Monitoring	Period	Colle	ction Period	Complia	nce Status
67 LONGVIEW ST (NLDPU022A)	-	1/1/21 - 12,	/31/29				
Total Coliform (3100)					30 ro	utine (RT)	per month
Sampling Point (Sampling Point ID)	/	Monitoring	Period	Colle	ction Period	Complia	nce Status
Select from Inventory of Active Sampling Points	1	1/1/23 - 11	/30/23			Cor	nplete
	1	2/1/23 - 12	/31/23			Cor	nplete
		1/1/24 - 1/	31/24			Cor	nplete
		2/1/24 - 2/	29/24			Cor	nplete
		3/1/24 - 3/	31/24				
		4/1/24 - 4/	30/24				
		5/1/24 - 5/	31/24				
		6/1/24 - 6/	30/24				
		7/1/24 - 7/	31/24				
		8/1/24 - 8/					
		9/1/24 - 9/	30/24				
	1	0/1/24 - 10	/31/24				
Disinfectant Byproducts - TTHM & HAA5 (DBP)					4 rou	tine (RT) p	•
Sampling Point (Sampling Point ID)		Monitoring	Period	Colle	ction Period	Complia	nce Status
PEQUOT HOSE CO (NLDPU002)	1	0/1/23 - 12	/31/23	10)/1-10/31	Cor	nplete
		1/1/24 - 3/		1	L/1-1/31	Cor	nplete
		4/1/24 - 6/	30/24	4	1/1-4/30		
		7/1/24 - 9/	30/24	7	7/1-7/31		
FIRE HQ BANK STREET (NLDPU003)	1	0/1/23 - 12	/31/23	10)/1-10/31	Cor	nplete
		1/1/24 - 3/	31/24	1	L/1-1/31	Cor	nplete
		4/1/24 - 6/	30/24	4	1/1-4/30		
		7/1/24 - 9/	30/24	7	7/1-7/31		
CONN COLLEGE (NLDPU004)	1	0/1/23 - 12	/31/23	10)/1-10/31	Cor	nplete
		1/1/24 - 3/		1	L/1-1/31	Cor	nplete
		4/1/24 - 6/	30/24	2	1/1-4/30		
		7/1/24 - 9/	30/24	7	7/1-7/31		
GAM OCEAN BEACH (NLDPU050X)	1	0/1/23 - 12	/31/23	10)/1-10/31	Cor	nplete
		1/1/24 - 3/	31/24	1	L/1-1/31	Cor	nplete
		4/1/24 - 6/	30/24		1/1-4/30		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Page 1 Schedule Generation Date: 4/3/2024

	Water Quality Monitoring and Compliance Schedule									
PWS ID	PWS Name		Classification Population Owner Type Pr		Prir	mary Source				
СТ0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES				С	27,620	L	SW		
Local Address (where applicable)		Service	Residen	itial	Commercia	al Industri	al Combine	ed	Agricultural	
		Connections	5,112	2	1,336	10	569			

Connecticut Department of Public Health Drinking Water Section

	3,112	550 10	309
Towns Served: NEW LONDON, WATERFORD			·
Monitoria	ng Requirements		
Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 0	0600)		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	·	4 rout	ine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/24 - 9/30/24	7/1-7/31	
Lead And Copper (PBCU)		30 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/23	6/1-9/30	Complete
	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)		30 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		
Water System Facility: LAKE KONOMOC WTP ENTRY POIN	IT (WSF ID: 00701)		
Net Gross Alpha (4000)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine	(RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 r	outine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

	Connecticut Department o	f Public H	ealth D	rinking	g Wat	ter S	ection	
	Water Quality Monit	toring and	d Compl	liance	Sched	dule		
PWS ID	PWS Name	<u> </u>					wner Type Pr	imary Sourc
T0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			С	27,62	20	L	SW
ocal Address	(where applicable)	Service	Residential	Commerc	ial Indu	ustrial	Combined	Agricultur
		Connections	5,112	1,336		10	569	
Towns Served	: NEW LONDON, WATERFORD				'			
	Monit	oring Requ	irements	5				
Water Systei	m Facility: LAKE KONOMOC WTP ENTRY I	POINT (WSF I	D: 00701)					
Nitrate And	Nitrite (NOX)					:	1 routine (R	T) per vea
	Point (Sampling Point ID)		Monitoring F	Period C	Collection		=	ance Status
EP - LAKE	KONOMOC TP (3)		1/1/23 - 12/	31/23			Со	mplete
			1/1/24 - 12/	31/24				
			1/1/25 - 12/3	31/25				
Pesticides, I	Herbicides and PCBs - Phase II & V (SOCS)				2	routir	ne (RT) per t	three years
	Point (Sampling Point ID)		Monitoring F	Period C	Collection			ance Status
EP - LAKE	KONOMOC TP (3)		1/1/23 - 12/3	31/25				
			1/1/26 - 12/3					
Organic Che	micals (VOCS)		· · · · ·	•			1 routine (R	T) per vea
_	Point (Sampling Point ID)		Monitoring I	Period C	Collection		= =	ance Status
	KONOMOC TP (3)		1/1/23 - 12/3					mplete
	. ,		1/1/24 - 12/3					•
			1/1/25 - 12/3					
Water Systei	m Facility: LAKE KONOMOC WATER TREA							
Total Organ	ic Carbon (2920)					1 r	outine (RT)	per month
Sampling	Point (Sampling Point ID)		Monitoring F	Period C	Collection	n Perio	d Compli	ance Status
CFE- LAK	E KONOMOC TP (5)	:	11/1/23 - 11/	/30/23			Со	mplete
			12/1/23 - 12/	/31/23			Со	mplete
			1/1/24 - 1/3	31/24			Со	mplete
			2/1/24 - 2/2	29/24			Со	mplete
			3/1/24 - 3/3	31/24				
			4/1/24 - 4/3	30/24				
			5/1/24 - 5/3	31/24				
			6/1/24 - 6/3	30/24				
			7/1/24 - 7/3					
			8/1/24 - 8/3					
			9/1/24 - 9/3					
							<u> </u>	
Water Systei	m Facility: LAKE KONOMOC RESERVOIR (
Total Alkaliı	,					1 r	outine (RT)	per month
	Point (Sampling Point ID)		Monitoring F	Period C	Collection			ance Status
	NOMOC RESERVOIR (1)		11/1/23 - 11/					mplete
	• •		12/1/23 - 12/					mplete
			1/1/24 - 1/3					mplete
			2/1/24 - 2/2					mplete
		_	3/1/24 - 3/3					
				0/0/				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

4/1/24 - 4/30/24 5/1/24 - 5/31/24 6/1/24 - 6/30/24

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES				С	27,620	L	SW
Local Address (where applicable)		Service	Resider	ntial	Commercia	al Industri	al Combine	ed Agricultural
	C		5,11	2	1,336	10	569	

	3,112	30 10	309
Towns Served: NEW LONDON, WATERFORD			
Monito	oring Requirements		
Water System Facility: LAKE KONOMOC RESERVOIR (WSF ID: 2162)		
Total Alkalinity (1927)	,	1 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/24 - 7/31/24		·
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		
Total Organic Carbon (2920)		1 rou	tine (RT) per month
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		
Total Coliform (3100)		1 rout	ine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		
Surface Water Inorganic Chemicals (RIOC)		1 re	outine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		
Surface Water Color and Turbidity (RPPS)			ine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		
Surface Water Pesticides (RSOC)		1 r	outine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	1/1/23 - 12/31/23		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

			D 111 77	LI DI LI	, , , , , , , , , , , , , , , , , , ,	
C	conne	cticut Department of			- C	ction
		Water Quality Monitor	oring and			
	WS Name					ner Type Primary Sour
		DON DEPT. OF PUBLIC UTILITIES		С	27,620	L SW
ocal Address (wh	ere appli	cable)		Residential Comm		Combined Agricultur
			Connections	5,112 1,3	36 10	569
Towns Served: NE	W LONDO					
Mater System Fa	acility: I	IVIONITO LAKE KONOMOC RESERVOIR (V	oring Requi	rements		
Surface Water F	•	•	V3F ID. 2102)		1	routine (RT) per yea
Sampling Poi			٨	Monitoring Period	Collection Period	Compliance Status
Samping 1 of	ine (Samp	g : 6 12)		/1/24 - 12/31/24	Concetion remod	Compliance Status
				/1/25 - 12/31/25		
	N //	this Water Seaton Forth			na Danvinson	nto.
		thly Water System Facili			ng Requireme	nts
•	acility: L	AKE KONOMOC WATER TREAT				C D /04
Analyte		Monitoring Requirement (Summa	ry Type)	Operating Limit		Samples Req/Month
Chlorine	0 /4 /0000	Entry Point RDC (EPRD)	Gli	Minimum: 0.2		Daily
Start Date: 10	0/1/2003		Monitorii	ce History:	Operating Limit Compliance Status	Monitoring Compliance Status
				3 - 11/30/2023	Y	
				3 - 12/31/2023	Υ	
				- 1/31/2024	Υ	
				- 2/29/2024		
				- 3/31/2024		
Analyte		Monitoring Requirement (Summa	ry Type)	Operating Limit	t	Samples Req/Month
Fluoride		<spaces> ()</spaces>		Minimum: 0.55		Daily
Start Date: 1/	/1/2023		Compliar	ce History:	Operating Limit	Monitoring
			Monitorii	ng Period	Compliance Status	_
			11/1/202	3 - 11/30/2023	•	
			12/1/202	3 - 12/31/2023		
			1/1/2024	- 1/31/2024		
			2/1/2024	- 2/29/2024		
			3/1/2024	- 3/31/2024		
Analyte		Monitoring Requirement (Summa	ry Type)	Operating Limit	t	Samples Req/Month
Fluoride		Entry Point Fluoride Monitoring (F	-LRD)	Maximum: 0.8	5 MG/L	Daily
Start Date: 1/	/1/2023			ce History:	Operating Limit	Monitoring
			Monitorii	ng Period	Compliance Status	
			11/1/202	3 - 11/30/2023	Y	
			12/1/202	3 - 12/31/2023	Υ	
			1/1/2024	- 1/31/2024	Υ	
			2/1/2024	- 2/29/2024		
			3/1/2024	- 3/31/2024		
Analyte		Monitoring Requirement (Summa	ry Type)	Operating Limit	t	Samples Req/Month
рН		Entry Point pH Monitoring (PHRD)		Minimum: 6.4	PH	Daily

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Compliance History:

11/1/2023 - 11/30/2023 12/1/2023 - 12/31/2023

Monitoring Period

Monitoring

Compliance Status:

Operating Limit

Compliance Status:

Start Date: 1/1/2005

C	Conne	cticut Department of	Public H	ealth D	rinkir	ng V	Water S	Section	1	
		Water Quality Monit	oring and							
PWS ID P	WS Name	!		Cla	ssificatio		-	wner Type	e Pri	mary Source
		OON DEPT. OF PUBLIC UTILITIES			С		27,620	L		SW
Local Address (wh	ere applic	able)	Service	Residential	Comme	rcial	Industrial	Combir	ned	Agricultural
			Connections	5,112	1,33	6	10	569		
Towns Served: NE		•								
Water System Fa		AKE KONOMOC WATER TREAT								
Analyte		Monitoring Requirement (Summa		Operatii	_			Sample		q/Month
рН		Entry Point pH Monitoring (PHRD			m: 6.4 Pl	1			Dail	У
Start Date: 1/	/1/2005			nce History:			ating Limit	Mon		
			Monitori			Com	oliance Stat	us: Com	pliar	nce Status:
				- 1/31/2024						
				- 2/29/2024						
A m = 1: -4:		Manitoring Passings and 10:		- 3/31/2024				Canada	. D.	a /N/c in the
Analyte Phosphate (as		Monitoring Requirement (Summa Entry Point Phosphate Monitoring		Operation	ng Limit m: 0.2 M	IC/I		sample	s ке 2	q/Month
Start Date: 1/		Entry Point Phosphate Monitoring		nce History:				D.4 a.u.		
Start Date. 1/	/1/2003		Monitori	-	`	-	ating Limit oliance Stat	Mon		ng nce Status:
				3 - 11/30/20		COIIII	Jilance Stat	us. com	Pilai	ice status.
				3 - 12/31/20						
				- 1/31/2024						
				- 2/29/2024						
			3/1/2024	- 3/31/2024	1					
Analyte		Monitoring Requirement (Summa	ary Type)	Operatii	ng Limit			Sample	s Re	q/Month
Turbidity		CFE Maximum Turbidity (MAXT)		Maximu	m: 1 NTI	J			186	5
Start Date: 10	0/1/2003		Compliar	nce History:		Oper	ating Limit	Mon	itori	ng
			Monitori	ng Period			oliance Stat	us: Com	pliar	nce Status:
			11/1/202	3 - 11/30/20	023		Υ			
				3 - 12/31/20			Υ			
				- 1/31/2024			Υ			
				- 2/29/2024						
				- 3/31/2024						
Analyte		Monitoring Requirement (Summa	ary Type)	Operatii	_			Sample		q/Month
Turbidity		CFE 95% Turbidity (95PT)	6 !!		bidity Lin	nit: (0.3 NTU		186	
Start Date: 10	0/1/2003			nce History:		-	ating Limit	Mon		
			Monitori	3 - 11/30/20		Com	oliance Stat	us: Com	pııar	nce Status:
				3 - 11/30/20 3 - 12/31/20			<u>т</u> Ү			
				- 1/31/2024			Y			
				- 2/29/2024			<u>'</u>			
				- 3/31/2024						
		Other C	ompliance							
Compliance Sched	lule Activi				Date		Achieve	d Date		
SUBMIT CCR TO TH				6/30	/2024					
SUBMIT CCR CERT	TFICATION	I FORM		8/9/	/2024					
SUBMIT LEAD SER	VICE LINE	INVENTORY		10/16	5/2024					
COMPLETE INITIAL	I I CL INIVE	NTODV		10/10	2/2024					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

10/16/2024

3/1/2025

COMPLETE INITIAL LSL INVENTORY

CROSS CONNECTION SURVEY REPORT

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

	<u> </u>							
PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
СТ0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES				С	27,620	L	SW
Local Address (where applicable)		Service	Resider	ntial	Commerci	al Industri	al Combine	ed Agricultural
		Connections	5,112	2	1,336	10	569	

	Wat	er System Facili	ty and Sampling P	oint Ir	ventor	У			
Water System acility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP	Stage 2 DBF
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Υ				
		DOWNSTREAM	WITHIN 5 SERVICE CON	Α					
		NLDPU001	NLWPC	Α	Υ				
		NLDPU002	PEQUOT HOSE CO	Α	Υ				Υ
		NLDPU003	FIRE HQ BANK STREET	Α	Υ				Υ
		NLDPU004	CONN COLLEGE	Α	Υ				Υ
		NLDPU005	109 CRYSTAL AVE.	Α	Υ				
		NLDPU006	107 COLMAN ST.	Α	Υ				
		NLDPU007	LOMBARDI AUTO	Α	Υ				
		NLDPU008	L & M HOSPITAL	Α	Υ				
		NLDPU009	120 BROAD STREET	Α	Υ				
		NLDPU010	20 NAMEAUG ST	Α	Υ	N		Υ	
		NLDPU013	29 WEST ST.	Α	Υ	1			
		NLDPU014	41 WOODLAWN ROAD	Α	Υ	1			
		NLDPU015	298 CRYSTAL AVE.	1	Υ	1			
		NLDPU016	552 OCEAN AVE.	Α	Υ	1			
		NLDPU017	46 SUMMIT AVE.	Α	Υ	1			
		NLDPU018	311 VAUXHALL ST. ALT	Α	Υ	1			
		NLDPU021	22 ADDISON ST.	Α	Υ	1			
		NLDPU022	150 ASHCRAFT RD.	1	Υ	1	Υ		
		NLDPU022A	67 LONGVIEW ST	Α			Υ		
		NLDPU023	34 CHAPEL DR.	1	Υ	1			
		NLDPU024	278 CRYSTAL AVE.	1	Υ	1			
		NLDPU025	12 FINCH AVE.	A	Υ	1			
		NLDPU026	83 THAMES ST.	Α	Υ	1			
		NLDPU028	20 FINCH AVE.	Α	Y	1			
		NLDPU029	113 RIVERVIEW AVE.	Α	Υ	1			
		NLDPU030	366 VAUXHALL ST.	1	Y	1			
		NLDPU033	959 PEQUOT AVE.	A	Y	1			
		NLDPU034	17 THAMES ST.	Α	Y	1			
		NLDPU035	88 VAUXHALL ST.	1	Y	1			
		NLDPU040	310 VAUXHALL ST.	i	Y	1			
		NLDPU041	200 LEDYARD ST.	i	Y	1			
		NLDPU042	95 THAMES ST.	A	Ϋ́	1			
		NLDPU043	273 OCEAN AVE.	A	Y	1			
		NLDPU044	123 VAUXHALL ST.	A	Y	1			
		NLDPU045	US COAST GUARD	A	Y	N			
		NLDPU046	20 PENNY LN	A	Y	1			
		NLDPU047	22 PENNY LN	A	Y	1			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

	<u> </u>			1				
PWS ID	PWS Name			Classificat	tion P	opulation	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			С		27,620	L	SW
Local Address (v	vhere applicable)	Service	Residen	ntial Comr	nercial	Industri	al Combine	ed Agricultural
		Connections	5.112	2 1.3	336	10	569	

Towns Se	rved: NEW LONDON, WATERFOR	D						
	Water	System Facil	ity and Sampling P	oint In	vento	γ		
Water System Facility IL	Water System Facility		Sampling Point Description	Status	Total Coliform Rule	Lead and Copper	Asbestos	Stage WQP 2 DBPI
		NLDPU048	25 PENNY LN	А	Υ	1		
		NLDPU049	611 OCEAN AVE B2	Α	Υ	1		
		NLDPU050	WOW OCEAN BEACH	1				Υ
		NLDPU050X	GAM OCEAN BEACH	Α				Υ
		NLDPU051	226 THAMES ST	Α	Υ	1		
		NLDPU052	19 STARR ST	Α	Υ	1		
		NLDPU053	11 WALDEN AVE	Α	Υ	1		
		NLDPU054	30 GORTON ST	Α	Υ	1		
		NLDPU055	91 BLINMAN ST	Α	Υ	1		
		NLDPU056	999 BANK ST	Α	Υ	1		
		NLDPU057	38 GLENWOOD AVE	Α	Υ	1		
		NLDPU058	1182 OCEAN AVE	Α	Υ	1		
		NLDPU059	30 DARROW ST	Α	Υ	1		
		NLDPU060	32 HARRIS RD	Α	Υ	1		
		NLDPU061	611 OCEAN AVE A2	Α	Υ	1		
		NLDPU062	501 BAYONET ST	Α	Υ	1		
		NLDPU063	40 CENTER ST	Α	Υ	1		
		NLDPU064	32 CAPE ANN CT	Α	Υ	1		
		NLDPU065	80 BECKWITH ST	Α	Υ	1		
		NLDPU066	999 BANK ST	Α	Υ	1		
		NLDPU067	68 FEDERAL ST	Α	Υ	1		
		NLDPU068	36 BELDEN ST	Α	Υ	1		Υ
		NLDPU069	171 LOWER BLVD	Α	Υ	1		
		NLDPU070	320 CONNECTICUT AVE	Α	Υ	1		
		NLDPU071	557 MONTAUK AVE	Α	Υ	1		
		NLDPU072	767 MONTAUK AVE	Α	Υ	1		
		NLDPU073	44 THAMES ST	Α	Υ	1		
		NLDPU074	298 VAUXHALL ST	Α	Υ	1		
		NLDPU075	52 SHERMAN ST	Α	Υ	1		
		NLDPU076	95 COLMAN ST	Α	Υ	1		
		NLDPU077	18 FARMINGTON AVE	Α	Υ	1		
		UPSTREAM	WITHIN 5 SERVICE CON	Α				
00701	LAKE KONOMOC WTP ENTRY POINT	3	EP - LAKE KONOMOC TP	Α				
199	LAKE KONOMOC WATER TREATMENT PLANT	5	CFE- LAKE KONOMOC TP	Α				
2162	LAKE KONOMOC RESERVOIR	1	LAKE KONOMOC RESERVO	Α				
2163	BARNES RESERVOIR	1	RESERVOIR	Α				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 4/3/2024

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Cla	ssification	Population	Owner Type	Primary Source
СТ0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES				С	27,620	L	SW
Local Address (v	vhere applicable)	Service	Resider	ntial	Commerci	al Industri	al Combine	ed Agricultural
		Connections	5,11	2	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

	Water 9	System Facili	ity and Samp	ling Point Ir	vento	ſy		
Water					Total	Lead and		
System	Water System Facility		Sampling Point		-	Copper		Stage
Facility ID		ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2 DBPR
2164	BOGUE BROOK RESERVOIR	1	RESERVOIR	A				
2165	FAIRY LAKE RESERVOIR	1	RESERVOIR	A				
2166	BECKWITH POND	1	RESERVOIR	Α				
2167	GREAT SWAMP DIVERSION	1	RESERVOIR	Α				
2169	HUNTS BROOK DIVERSION	1	RESERVOIR	Α				
30065	GREAT SWAMP DIVERSION							
30070	LAKE KONOMOC INTAKE							
49682	WILLIAMS STREET PUMP STATION							
53892	LAKE KONOMOC WTP CLEARWELL							
53894	BECKWITH POND RAW WATER PUMP STATION							
53896	TREMONT STREET STORAGE TANK							
53898	MANATUCK HILL STORAGE TANK							
53902	LAKE KONOMOC WTP PUMP STATION							
53904	LAKE KONOMOC WTP RAW WATER PUMP STATION							
54140	GREAT SWAMP DIVERSION PUMP STATION							
58948	INTERCONNECTION - CT0450011 - EAST LYME							
61782	CT COLLEGE HYDRO TANK							
61805	BECKWITH ROAD PUMP STATION							
61807	INDUSTRIAL DRIVE PUMP STATION							
61809	DAYTON PLACE PUMP STATION							

Certified Operator Information

Water System Facility:	DISTRIBUTION SYSTEM	(WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM							
Operator Name	Operator Type	Certification(s)	Expiration				
LANCASTER, JR., MICHAEL W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2024				
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2025				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

CT0950011 NE	W LONDON D	EPT. OF PUE	BLIC UTILITIE	S		(27,620	L	SW
Local Address (whe	re applicable)			Service	Residentia	I Co	mmercial	Industria	l Combined	Agricultura
				Connection	ns 5,112		1,336	10	569	
Towns Served: NEW	V LONDON, WA	ATERFORD		·						
			Certifi	ed Operato	r Informat	tion	1			
Water System Fac	cility: LAKE	ОМОМОС	WATER TR	REATMENT PLA	NT (WSF ID:	: 199)			
Facility Classification	on: CLASS 3 TR	EATMENT P	LANT		-		-			Certification
Operator Name			Operator	Туре	Certification(s)				Expiration
BROWNE, KEITH T			CHIEF OPER	RATOR	WATER TREATMENT PLANT OPERATOR - CLASS III 3/3					
MCVICKER, JONATHAN ASSIGNE				OPERATOR	DISTRIBUTION	I SYS	ГЕМ ОРЕГ	RATOR - CLA	SS III	3/31/2026
					WATER TREAT	MEN	T PLANT	OPERATOR	- CLASS IV	3/31/2026
			C	Contact Info	rmation					
Name				Organization	on Job Title					
Mr. Thomas Londre	egan			City of New Lo	London City Attorney					
Mailing Address Lin	e One		Mailing Add	dress Line Two	o City			City	State	Zip Code
38 Huntington Street							New Lon	don	СТ	06320
Business Phone	Extension	Fax	N	Nobile Phone	Emergency Ph	none	Email Ad	dress		
860-447-3171										
Contact Role(s): Le	egal Contact									
Name				Organization	on Job T					
Mr. Joseph M. Lanz	zafame			New London F	n Public Utilities Public Utilities Dir					
Mailing Address Lin	e One		Mailing Add	dress Line Two				City	State	Zip Code
15 Masonic Street							New Lon	don	СТ	06320
Business Phone	Extension	Fax	N	Nobile Phone	Emergency Ph	none	Email Ad	dress		
860-373-1868		860-447-	5297		860-447-52	21	jlanzafan	ne@newlor	idonct.org	
Contact Role(s): A	dministrative (Contact								
Name				Organization					Job Title	
Mr. Michael Passer	о			City of New Lo	ondon			Mayor		

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

Classification | Population | Owner Type | Primary Source

City

mpassero@newlondonct.org

New London

Emergency Phone Email Address

860-625-7516

Contact Role(s): Owner Please note the following:

Mailing Address Line One

Extension

181 State Street

Business Phone

860-447-5201

PWS ID

T00F0044

PWS Name

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.

Mailing Address Line Two

Mobile Phone

2. If a Collection Period is specified, all water quality samples must be collected during the specified period.

Fax

860-447-7971

3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

http://www.ct.gov/dph/publicdrinkingwater

End of schedule

Zip Code 06230

State

CT