

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1462011	CTWC - NORTHERN REG-RESERVOIR HEIGHTS	C	62	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22				

Towns Served: VERNON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012) 1 routine (RT) per month

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete

Total Coliform (3100) 1 routine (RT) per month

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Disinfectant Byproducts - TTHM & HAA5 (DBP) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
1-30 BRIDLE PATH LN (3066)	1/1/23 - 12/31/23	9/9-9/15	Complete
	1/1/24 - 12/31/24	9/9-9/15	
	1/1/25 - 12/31/25	9/9-9/15	

Lead And Copper (PBCU) 5 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/23	6/1-9/30	Complete
	1/1/24 - 12/31/24	6/1-9/30	
	1/1/25 - 12/31/25	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per month

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1462011	CTWC - NORTHERN REG-RESERVOIR HEIGHTS	C	62	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			22				

Towns Served: VERNON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION EXEMPTION	3/1/2029	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	3066	1-30 BRIDLE PATH LN	A	Y	3		Y
		30661	4 BRIDLE PATH LN	A		N		
		30662	1 AMY DRIVE	A	Y	N		
		30663	2 AMY DRIVE	A	Y	N		
		30664	3 AMY DRIVE	A	Y	N		
		30665	4 AMY DRIVE	A	Y	N		
		30666	5 AMY DRIVE	A	Y	N		
		30667	6 AMY DRIVE	A	Y	N		
		30668	1 BRIDGE PATH LN	A	Y	N		
		30669	2 BRIDGE PATH LN	A	Y	N		
		30670	3 BRIDGE PATH LN	A	Y	N		
		30671	5 BRIDGE PATH LN	A	Y	N		
		30672	6 BRIDGE PATH LN	A	Y	N		
		30673	7 BRIDGE PATH LN	A	Y	N		
		30674	8 BRIDGE PATH LN	A	Y	N		
		30675	9 BRIDGE PATH LN	A	Y	N		
		30676	363 LAKE ST	A	Y	N		
		30677	375 LAKE ST	A	Y	N		
		30678	379 LAKE ST	A	Y	N		
		30679	383 LAKE ST	A	Y	N		
		30680	387 LAKE ST	A	Y	N		
		30681	395 LAKE ST	A	Y	N		
		30682	401 LAKE ST	A	Y	N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1462011	CTWC - NORTHERN REG-RESERVOIR HEIGHTS	C	62	P	SWP		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		22					

Towns Served: VERNON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		30683	409 LAKE ST	A	Y	N		
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
24170	INTERCONNECTION - CT0770021 -BRIDLE PATH							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
GREEN, III, CLIFFORD	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2026
LABIANCA, MICHAEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2024

Contact Information

Name			Organization			Job Title		
Mr. Craig J. Patla			Connecticut Water Company			Vp, Service Delivery		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 West Main Street						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-664-6140				800-391-1924	craig.patla@ctwater.com			

Contact Role(s): **Legal Contact, Owner**

Name			Organization			Job Title		
Mr. Paul C. Lowry			Connecticut Water Company			Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
93 W Main Street						Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-292-2809		860-654-1903		800-208-5700	ctwcdphadmin@ctwater.com			

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1463011	VERNON VILLAGE INC.	C	430	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			206				

Towns Served: SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Haloacetic Acids (2456)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
325 KELLY RD M48 (M48)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	
Total Trihalomethanes (2950)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
325 KELLY RD M27 (M27)	1/1/23 - 12/31/23	7/1-7/31	Complete
	1/1/24 - 12/31/24	7/1-7/31	
	1/1/25 - 12/31/25	7/1-7/31	
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/24	6/1-9/30	
	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	11/1/23 - 11/30/23		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1463011	VERNON VILLAGE INC.	C	430	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			206				

Towns Served: SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	12/1/23 - 12/31/23		Complete
	1/1/24 - 1/31/24		Complete
	2/1/24 - 2/29/24		Complete
	3/1/24 - 3/31/24		
	4/1/24 - 4/30/24		
	5/1/24 - 5/31/24		
	6/1/24 - 6/30/24		
	7/1/24 - 7/31/24		
	8/1/24 - 8/31/24		
	9/1/24 - 9/30/24		
	10/1/24 - 10/31/24		

Water System Facility: ENTRY POINT - WELL 1 (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Strontium-90 (4174)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1463011	VERNON VILLAGE INC.	C	430	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			206				

Towns Served: SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 1 (WSF ID: 00700)

Strontium-90 (4174) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

Pesticides, Herbicides and PCBs-Phase II (SOC2) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Pesticides, Herbicides and PCBs-Phase V (SOC5) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

Water System Facility: ENTRY POINT - WELLS 2 AND 3 (WSF ID: 00701)

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1463011	VERNON VILLAGE INC.	C	430	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			206				

Towns Served: SOUTH WINDSOR, VERNON

Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLS 2 AND 3 (WSF ID: 00701)**

	1 routine (RT) per three years		
Gross Beta Particle Activity (4100)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Tritium (4102)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Strontium-90 (4174)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	1/1/22 - 12/31/24		Complete
	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	1/1/23 - 12/31/23		Complete
	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
<i>Sampling Point (Sampling Point ID)</i>			
ENTRY POINT (3)	10/1/23 - 12/31/23		Complete
	1/1/24 - 3/31/24		Complete
	4/1/24 - 6/30/24		
	7/1/24 - 9/30/24		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1463011	VERNON VILLAGE INC.	C	430	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			206				

Towns Served: SOUTH WINDSOR, VERNON

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **VERNON VILLAGE TREATMENT PLANT (WSFID: 287)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.5 MG/L	Daily
Start Date: 11/1/2015		Compliance History:	Operating Limit Compliance Status:
		Monitoring Period	Monitoring Compliance Status:
		11/1/2023 - 11/30/2023	Y
		12/1/2023 - 12/31/2023	Y
		1/1/2024 - 1/31/2024	Y
		2/1/2024 - 2/29/2024	
		3/1/2024 - 3/31/2024	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
CROSS CONNECTION EXEMPTION	3/1/2021	
SUBMIT CCR TO THE DEPARTMENT	6/30/2024	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		A01	LOT A01	A	Y	3	Y	
		A04	LOT A04	A	Y			
		C12	LOT C12	A	Y	3	Y	
		C5	#5 CONNECTICUT	A	Y		Y	Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		J07	LOT J07	A	Y	3	Y	
		J1	JOHN & MASS AVE	A	Y			Y
		L01	LOT L01	A	Y	3	Y	
		L03	LOT L03	A	Y	3	Y	
		M19	LOT M19	A	Y	3	Y	
		M27	325 KELLY RD M27	A				Y
		M43	#43 MASS AVE	A				
		M48	325 KELLY RD M48	A				Y
		M56	#56 MASS AVE	A	Y	3		
		M66	LOT M66	A	Y	3	Y	
		MASSAVE27	#27 MASS AVE	A	Y	3		Y
		ME2	MAINE #2 UNIT	A	Y			Y
		O07	LOT O07	A	Y	3	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1463011	VERNON VILLAGE INC.	C	430	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			206				

Towns Served: SOUTH WINDSOR, VERNON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		R15	#15 RHODE ISLAND	A				Y
		R20	LOT R20	A	Y	3	Y	
		S09	LOT S09	A	Y	3	Y	
		T03	LOT T03	A	Y	3	Y	
		U03	LOT U03	A	Y	3	Y	
		U08	LOT U08	A	Y	3	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		V09	LOT V09	A	Y	3	Y	
		V18	LOT V18	A	Y	3	Y	
		V5	#5 VERMONT AVE	A	Y		Y	Y
00700	ENTRY POINT - WELL 1	3	ENTRY POINT	A				
00701	ENTRY POINT - WELLS 2 AND 3	3	ENTRY POINT	A				
170	WELL 3	2	WELL 3	A				
171	WELL 2	2	WELL 2	A				
172	WELL 1	2	WELL 1	A				
287	VERNON VILLAGE TREATMENT PLANT	5	AFTER GAC FILTERS	A				
51447	ATMOSPHERIC TANK - WELL 1							
51449	HYDROPNEUMATIC TANK - WELL 1							
51451	HYDROPNEUMATIC TANK - WELLS 2 & 3							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
CLEMENT, FREDRIC H.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2024

Water System Facility: VERNON VILLAGE TREATMENT PLANT (WSF ID: 287)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CLEMENT, FREDRIC H.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2024
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2024

Contact Information

Name		Organization		Job Title		
Vernon Village Inc.						
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
325 Kelly Road				Vernon	CT	06066

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1463011	VERNON VILLAGE INC.	C	430	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
		206					

Towns Served: SOUTH WINDSOR, VERNON

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-432-4032					

Contact Role(s):	Owner	
Name	Organization	Job Title
Mrs. Joanne Hollis	Vernon Village Inc	President

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
325 Kelly Road		Vernon	CT	06066

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-644-8120		860-644-8620		860-508-1908	vernonvillage@att.net

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule