

*Owner Occupied and Scattered Site Rehabilitation Programs*

**ADDENDUM ACKNOWLEDGEMENT**

**Addendum # 3  
August 5, 2016**

Project # 5077 Property Address: 71-73 Worth Street, Bridgeport, CT

Addendum Description

The addendum modifies the Bid Specification and Drawings prepared by Martinez Couch and Associates, LLC and Consultants to the following particulars;

A. General


1. Addendum is issued to respond to request for information received during bid phase. Bidders are reminded that all requests for information should be directed to Mr. Richard Couch, P.E. of Martinez Couch and Associates, LLC.

Bidder Request for Information 1: Date: 08-03-2016

1. In regards to the soil 2” removal: the lead plan calls for the entire property. At the walk through it was mentioned about soil in the front yard. Is the 2” of soil removal the front yard or the entire property?

RFI – Response #1

Yes, 2” of soil removal for the entire property should be included in the re-bid. The Amended Lead – Based Paint Abatement Plan, dated March 9<sup>th</sup>, 2016 indicates excavate the top two inches of soil for the entire property; rototill, retest, and bring in new clean soil. The new soil must be under 200 ppm.



Bidder Request for Information 1 – Date: 08-03-2016

2. The lead inspection was done back in November of 2014; There has been work done on the house since that time. DSW did work on this house. The scope of work calls for dust clean-up of all rooms with regards to windows. By looking at the lead survey work performed by Gilberto there is 22 spaces listed, which include staircases. If no lead work is transpiring inside the building, Is this still a part of the re-bid process?

RFI – Response #1

Yes, the dust clean-up for all interior rooms on all three floors is a part of the re- bid process.

The bid due date is not extended by this addendum

