

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670011	CTWC - LONDON PARK DIVISION	C	221	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		78			

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Chlorine Residual (1012)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Haloacetic Acids (2456)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
28 LAURA DR (LONP008)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
Total Trihalomethanes (2950)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
10 JAN DR (LONP007)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	5 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670011	CTWC - LONDON PARK DIVISION	C	221	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/26 - 6/30/26		
Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		Complete
	1/1/27 - 12/31/27		
Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Water System Facility: WELL 2	(WSF ID: 1061)		
E. Coli (3014)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670011	CTWC - LONDON PARK DIVISION	C	221	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: WELL 2 (WSF ID: 1061)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		4/1/26 - 6/30/26		

Water System Facility: WELL 3 (WSF ID: 1063)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	WELL 3 (2)	7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 10/1/2014		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 3/1/2007		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility	Sampling Point	Sampling Point	Total Coliform		Lead and Copper	Stage	
Facility ID	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2 DBPR

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670011	CTWC - LONDON PARK DIVISION	C	221	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	78				

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory								
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR	Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y	3		
	DOWNSTREAM	WITHIN 5 SERVICE CON		A				
	LONP001	106 LONDON RD		A	Y	3		
	LONP002	140 JAN DR		A	Y	3		
	LONP003	146 JAN DR		A	Y	3		
	LONP004	121 JAN DR		A	Y	3		
	LONP005	126 JAN DR		A	Y	3		
	LONP006	102 JAN DR		A	Y	3		
	LONP007	10 JAN DR		A		3		Y
	LONP008	28 LAURA DR		A		3		Y
	LONP009	60 LONDON RD		A		3		
	LONP010	66 LONDON RD		A		3		
	LONP011	72 LONDON RD		A		3		
	LONP012	76 LONDON RD		A		3		
	LONP013	84 LONDON RD		A		3		
	LONP014	90 LONDON RD		A		3		
	LONP015	102 LONDON RD		A		3		
	LONP016	106 LONDON RD		A		3		
	LONP017	120 LONDON RD		A		3		
	LONP018	126 LONDON RD		A		3		
	LONP019	10 JAN DR		A		3		
	LONP020	16 JAN DR		A		3		
	LONP021	20 JAN DR		A		3		
	LONP022	28 JAN DR		A		3		
	LONP023	29 JAN DR		A		3		
	LONP024	32 JAN DR		A		3		
	LONP025	37 JAN DR		A		3		
	LONP026	38 JAN DR		A		3		
	LONP027	43 JAN DR		A		3		
	LONP028	44 JAN DR		A		3		
	LONP029	50 JAN DR		A		3		
	LONP030	53 JAN DR		A		3		
	LONP031	54 JAN DR		A		3		
	LONP032	62 JAN DR		A		3		
	LONP033	66 JAN DR		A		3		
	LONP034	67 JAN DR		A		3		
	LONP035	73 JAN DR		A		3		
	LONP036	78 JAN DR		A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670011	CTWC - LONDON PARK DIVISION	C	221	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	78				

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory								
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR	Stage
	LONP037	81 JAN DR		A		3		
	LONP038	85 JAN DR		A		3		
	LONP039	86 JAN DR		A		3		
	LONP040	92 JAN DR		A		3		
	LONP041	93 JAN DR		A		3		
	LONP042	98 JAN DR		A		3		
	LONP043	107 JAN DR		A		3		
	LONP044	108 JAN DR		A		3		
	LONP045	121 JAN DR		A		3		
	LONP046	122 JAN DR		A		3		
	LONP047	126 JAN DR		A		3		
	LONP048	131 JAN DR		A		3		
	LONP049	132 JAN DR		A		3		
	LONP050	140 JAN DR		A		3		
	LONP051	145 JAN DR		A		3		
	LONP052	1 CAROLYN DR		A		3		
	LONP053	2 CAROLYN DR		A		3		
	LONP054	9 CAROLYN DR		A		3		
	LONP055	10 CAROLYN DR		A		3		
	LONP056	17 CAROLYN DR		A		3		
	LONP057	18 CAROLYN DR		A		3		
	LONP058	21 CAROLYN DR		A		3		
	LONP059	27 CAROLYN DR		A		3		
	LONP060	28 CAROLYN DR		A		3		
	LONP061	32 CAROLYN DR		A		3		
	LONP062	33 CAROLYN DR		A		3		
	LONP063	38 CAROLYN DR		A		3		
	LONP064	39 CAROLYN DR		A		3		
	LONP065	42 CAROLYN DR		A		3		
	LONP066	43 CAROLYN DR		A		3		
	LONP067	48 CAROLYN DR		A		3		
	LONP068	51 CAROLYN DR		A		3		
	LONP069	58 CAROLYN DR		A		3		
	LONP070	3 LAURA DR		A		3		
	LONP071	9 LAURA DR		A		3		
	LONP072	10 LAURA DR		A		3		
	LONP073	15 LAURA DR		A		3		
	LONP074	20 LAURA DR		A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670011	CTWC - LONDON PARK DIVISION	C	221	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	78				

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR Stage
					WQP 2	DBPR	
	LONP075	21 LAURA DR		A		3	
	LONP076	27 LAURA DR		A		3	
	LONP077	33 LAURA DR		A		3	
	LONP078	34 LAURA DR		A		3	
	LONP079	39 LAURA DR		A		3	
	LONP080	40 LAURA DR		A		3	
	UPSTREAM	WITHIN 5 SERVICE CON		A			
00700	ENTRY POINT	3	ENTRY POINT	A			
1061	WELL 2	2	WELL 2	A			
1063	WELL 3	2	WELL 3	A			
459	TREATMENT PLANT						
59073	ATMOSPHERIC TANK						
59075	BOOSTER PUMPS						

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 459)**

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
LABIANCA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 12/31/2026

Contact Information

Name	Organization	Job Title			
Mr. Craig J. Patla	Connecticut Water Company	Vp, Service Delivery			
Mailing Address Line One	Mailing Address Line Two	City State Zip Code			
93 West Main Street		Clinton CT 06413			
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-664-6140				800-391-1924	craig.patla@ctwater.com

Contact Role(s): **Legal Contact, Owner**

Name	Organization	Job Title			
Mr. Paul C. Lowry	Connecticut Water Company	Manager			
Mailing Address Line One	Mailing Address Line Two	City State Zip Code			
93 W Main Street		Clinton CT 06413			
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-944-9655		860-654-1903		800-208-5700	ctwcdphadmin@ctwater.com

Contact Role(s): **Administrative Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670011	CTWC - LONDON PARK DIVISION	C	221	P	GW
Local Address (where applicable)	Service Connections	Residential 78	Commercial	Industrial	Combined Agricultural

Towns Served: HEBRON

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670021	ABBY WATER LLC	C	100	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		25			Agricultural

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670021	ABBY WATER LLC	C	100	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		25			Agricultural

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Di(2-Ethylhexyl) - Phthalate (2039)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/31		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670021	ABBY WATER LLC	C	100	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	25				

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	3	Y	Y
	AW15	15 ABBY DR		A	Y	3		
	AW16	16 ABBY DR		A	Y	3		
	AW-169	169 NORTH ST		A	Y	3		
	AW-175	175 NORTH ST		A	Y	3		
	AW-181	181 NORTH ST		A	Y	3		
	AW-186	186 NORTH ST		A	Y	3		
	AW-187	187 NORTH ST		A	Y	3		
	AW-192	192 NORTH ST		A	Y	3		
	AW-193	193 NORTH ST		A	Y	3		
	AW-215	215 NORTH ST		A	Y	3		
	AW-221	221 NORTH ST		A	Y	3	Y	Y
	AW24	24 ABBY DR		A	Y	3		
	AW29	29 ABBY DR		A	Y	3		
	AW35	35 ABBY DR		A	Y	3		
	AW4	4 ABBY DR		A	Y	3	Y	Y
	AW41	41 ABBY DR		A	Y	3	Y	Y
	AW44	44 ABBY DR		A	Y	3		
	AW47	47 ABBY DR		A	Y	3	Y	Y
	AW50	50 ABBY DR		A	Y	3		
	AW70	70 ABBY DR		A	Y	3		
	AW9	9 ABBY DR		A	Y	3		
	DOWNSTREAM	WITHIN 5 SERVICE CON		A				
	UPSTREAM	WITHIN 5 SERVICE CON		A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1064	WELL 1	2	WELL 1	A				
56799	ATMOSPHERIC STORAGE TANK							
56801	HYDROPNEUMATIC TANK							
56803	BOOSTER PUMPS							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NAPIERATA, KYLE	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027 9/30/2027
LAFRAMBOISE, PAUL F.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027 9/30/2027
LAFRAMBOISE, ERIC	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670021	ABBY WATER LLC	C	100	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	25				Agricultural

Towns Served: HEBRON

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

**Certification
Expiration**

Operator Name	Operator Type	Certification(s)	Certification Expiration
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026

Contact Information

Name		Organization			Job Title		
Mr. Paul F. Laframboise		Laframboise Water Services			President		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
647 Thompson Road, Route 193		P.O. Box 303			Thompson	CT	06277-0303
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-923-9543	104	860-923-9971		800-624-2327	kristen@thewaterexperts.com		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670041	HEBRON ARMS APARTMENTS	C	39	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	
Lead And Copper (PBCU)	5 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Gross Beta Particle Activity (4100)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Man-Made Beta Particle & Photon Emitters (4101)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Tritium (4102)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670041	HEBRON ARMS APARTMENTS	C	39	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Tritium (4102)	1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status
	1/1/29 - 12/31/31
Strontium-90 (4174)	1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25 Complete
	1/1/26 - 12/31/28
	1/1/29 - 12/31/31
Inorganic Chemicals (IOCS)	1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25 Complete
	1/1/26 - 12/31/28
	1/1/29 - 12/31/31
Nitrate And Nitrite (NOX)	1 routine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25 Complete
	1/1/26 - 12/31/26 Complete
	1/1/27 - 12/31/27
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status
ENTRY POINT (3)	1/1/26 - 12/31/28
	1/1/29 - 12/31/31
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status
ENTRY POINT (3)	1/1/26 - 12/31/28 1/1-12/31 Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25 Complete
	1/1/29 - 12/31/31
Organic Chemicals (VOCS)	1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period Collection Period Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25 Complete
	1/1/26 - 12/31/28
	1/1/29 - 12/31/31

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
RESPOND TO SANITARY SURVEY	9/2/2023	
CROSS CONNECTION EXEMPTION	3/1/2029	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670041	HEBRON ARMS APARTMENTS	C	39	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	13				

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
					Stage	Stage	Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		4-1	BLDG 116 #2 KITCHEN	A	Y		
		4-108	APRT 5 KIT SINK	A	Y	2	
		4-108A	APRT 3 KIT SINK	A	Y	2	
		4-16	APRT 2 KIT SINK	A	Y	2	
		4-16A	APRT 4 KIT SINK	A	Y	2	
		4-180	APRT 2 KIT SINK	A	Y	2	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
1080	WELL 1	2	WELL 1	A			

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM				Certification Expiration
Operator Name	Operator Type	Certification(s)		
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV		6/30/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING		6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II		9/30/2027

Contact Information

Name	Organization	Job Title			
Mr. Andrew Minicucci	Hebron Country Manor, LLC	Manager			
Mailing Address Line One	Mailing Address Line Two	City State Zip Code			
580 Lake Rd.		Andover CT 06232			
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-742-5940		860-742-9155		860-462-4369	clark.robyn@comcast.net
Contact Role(s): Legal Contact, Owner					
Name	Organization	Job Title			
Ms. Laura M. Bergman	Hebron Arms Apartments	Property Manager			
Mailing Address Line One	Mailing Address Line Two	City State Zip Code			
580 Lake Road		Andover CT 06232			
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-622-9200				860-742-5940	rentaloffice580@gmail.com
Contact Role(s): Administrative Contact					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670041	HEBRON ARMS APARTMENTS	C	39	P	GW
Local Address (where applicable)	Service Connections	Residential 13	Commercial	Industrial	Combined

Towns Served: HEBRON

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670051	HILLSIDE CONDOMINIUMS	C	96	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		32			Agricultural

Towns Served: COLUMBIA, HEBRON, LEBANON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670051	HILLSIDE CONDOMINIUMS	C	96	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: COLUMBIA, HEBRON, LEBANON

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)				1 routine (RT) per year
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)				1 (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25	1/1/12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	12/12/2020	
RESPOND TO SANITARY SURVEY	11/23/2023	
CROSS CONNECTION EXEMPTION	3/1/2029	

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Status	Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		4-1	BLDG 102 UNIT A2	A	Y	2	
		4-2	BLDG 104 UNIT A2	A	Y	2	
		4-3	BLDG 106 UNIT B2	A	Y	2	
		4-4	BLDG 108 UNIT A1	A	Y	2	
		4-5	BLDG 108 UNIT B1	A	Y	2	
	DOWNSTREAM	WITHIN 5 SERVICE CON		A			
	UPSTREAM	WITHIN 5 SERVICE CON		A			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670051	HILLSIDE CONDOMINIUMS	C	96	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		32			

Towns Served: COLUMBIA, HEBRON, LEBANON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
					Rule Tier	WQD	DBPR	
00700	ENTRY POINT	3	ENTRY POINT	A				
1082	WELL 1	2	WELL 1	A				
51433	ATMOSPHERIC TANK							
51435	HYDROPUANEATIC TANK							
51437	HILLSIDE CONDO TREATMENT PLANT							
56034	BOOSTER PUMPS							

Certified Operator Information

Water System Facility: HILLSIDE CONDO TREATMENT PLANT (WSF ID: 51437)

Facility Classification:		Certification Expiration
Operator Name	Operator Type	Certification(s)
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I
		WATER TREATMENT PLANT OPERATOR - CLASS II

Contact Information

Name	Organization	Job Title
Mr. Abdul Akberzai	Amirzai Property Trust, LLC	
Mailing Address Line One	Mailing Address Line Two	City
8 Brewer St		State
Business Phone	Extension	Zip Code
203-895-8126	860-899-1519	East Hartford
Mobile Phone	Emergency Phone	Email Address
		9/30/2027
		9/30/2027
203-895-8126	860-922-2700	amjeedakbarzai@yahoo.com

Contact Role(s): Administrative Contact, Legal Contact, Owner

Name	Organization	Job Title
Mr. Amjeed Akbarzai	Amirzai Property Trust, LLC	
Mailing Address Line One	Mailing Address Line Two	City
102 Wellswood Road,		State
Business Phone	Extension	Zip Code
203-895-8126	860-899-1519	Amston
Mobile Phone	Emergency Phone	Email Address
		CT
		06231
203-715-3059	amjeedakbarzai@yahoo.com	

Contact Role(s): Owner

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670331	CTWC - AMSTON LAKE DIVISION	C	910	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		325			Agricultural

Towns Served: COLCHESTER, HEBRON, LEBANON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Chlorine Residual (1012)	1 routine (RT) per month					
Sampling Point (Sampling Point ID)						
Select from Inventory of Active Sampling Points	Monitoring Period	Collection Period	Compliance Status			
	8/1/25 - 8/31/25		Complete			
	9/1/25 - 9/30/25		Complete			
	10/1/25 - 10/31/25		Complete			
	11/1/25 - 11/30/25		Complete			
	12/1/25 - 12/31/25		Complete			
Asbestos (1094)	1 routine (RT) per nine years					
Sampling Point (Sampling Point ID)						
Select from Inventory of Active Sampling Points	Monitoring Period	Collection Period	Compliance Status			
	1/1/23 - 12/31/31					
Total Coliform (3100)	1 routine (RT) per month					
Sampling Point (Sampling Point ID)						
Select from Inventory of Active Sampling Points	Monitoring Period	Collection Period	Compliance Status			
	8/1/25 - 8/31/25		Complete			
	9/1/25 - 9/30/25		Complete			
	10/1/25 - 10/31/25		Complete			
	11/1/25 - 11/30/25		Complete			
	12/1/25 - 12/31/25		Complete			
	1/1/26 - 1/31/26					
	2/1/26 - 2/28/26					
	3/1/26 - 3/31/26					
	4/1/26 - 4/30/26					
	5/1/26 - 5/31/26					
	6/1/26 - 6/30/26					
	7/1/26 - 7/31/26					
Disinfectant Byproducts - TTHM & HAAs (DBP)	1 routine (RT) per year					
Sampling Point (Sampling Point ID)						
23 DEEPWOOD DRI H (AMS037)	Monitoring Period	Collection Period	Compliance Status			
	1/1/25 - 12/31/25	8/1-8/31	Complete			
	1/1/26 - 12/31/26	8/1-8/31				
	1/1/27 - 12/31/27	8/1-8/31				
Lead And Copper (PBCU)	10 routine (RT) per year					
Sampling Point (Sampling Point ID)						
Select from Inventory of Active Sampling Points	Monitoring Period	Collection Period	Compliance Status			
	1/1/25 - 12/31/25	6/1-9/30	Complete			
	1/1/26 - 12/31/26	6/1-9/30				
	1/1/27 - 12/31/27	6/1-9/30				
Physical Parameters (PPS)	1 routine (RT) per month					
Sampling Point (Sampling Point ID)						
Select from Inventory of Active Sampling Points	Monitoring Period	Collection Period	Compliance Status			
	8/1/25 - 8/31/25		Complete			
	9/1/25 - 9/30/25		Complete			
	10/1/25 - 10/31/25		Complete			
	11/1/25 - 11/30/25		Complete			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670331	CTWC - AMSTON LAKE DIVISION	C	910	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		325			Agricultural

Towns Served: COLCHESTER, HEBRON, LEBANON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT - ISLAND BEACH WELL (WSF ID: 00701)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Uranium (4006)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670331	CTWC - AMSTON LAKE DIVISION	C	910	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		325			Agricultural

Towns Served: COLCHESTER, HEBRON, LEBANON

Monitoring Requirements

Water System Facility: ENTRY POINT - ISLAND BEACH WELL (WSF ID: 00701)

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Organic Chemicals (VOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Water System Facility: ENTRY POINT - CHURCH ST WELL (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - CHURCH ST (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - CHURCH ST (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26		Complete	
	1/1/27 - 12/31/27			

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - CHURCH ST (3)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - CHURCH ST (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Organic Chemicals (VOCS)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - CHURCH ST (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26		Complete	
	1/1/27 - 12/31/27			

Water System Facility: ISLAND BEACH WELL (WSF ID: 481)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670331	CTWC - AMSTON LAKE DIVISION	C	910	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: COLCHESTER, HEBRON, LEBANON

Monitoring Requirements

Water System Facility: ISLAND BEACH WELL (WSF ID: 481)

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ISLAND BEACH WELL (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: CHURCH ST WELL (WSF ID: 58775)

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
CHURCH ST WELL (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - ISLAND BEACH WELL (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004	Compliance History: Monitoring Period	Operating Limit	Monitoring
	8/1/2025 - 8/31/2025	Compliance Status:	Compliance Status:
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670331	CTWC - AMSTON LAKE DIVISION	C	910	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: COLCHESTER, HEBRON, LEBANON

Water System Facility: ENTRY POINT - ISLAND BEACH WELL (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
Start Date: 1/1/2004		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily	
Start Date: 1/1/2012		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

Water System Facility: ENTRY POINT - CHURCH ST WELL (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
Start Date: 4/1/2015		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily	
Start Date: 7/1/2014		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory				
Water System	Water System Facility	Sampling Point	Sampling Point	Stage
				Total Lead and Coliform Copper

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670331	CTWC - AMSTON LAKE DIVISION	C	910	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	325				Agricultural

Towns Served: COLCHESTER, HEBRON, LEBANON

Facility ID	ID	Description	Status	Rule	Rule Tier	Asbestos	WQP 2	DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
	AMS001	18 ISLAND BEACH ROAD	A	Y				Y
	AMS002	8 AMES ROAD	A	Y				
	AMS003	57 AMES ROAD	A	Y				
	AMS004	4 WOODACRES ROAD	A	Y	3			
	AMS005	37 AMES ROAD	A	Y				
	AMS006	42 AMES ROAD	A	Y				
	AMS007	31 AMES ROAD	A	Y	3			
	AMS008	121 DEEPWOOD DRIVE	A	Y	3			
	AMS009	136 DEEPWOOD DRIVE	A	Y	3			
	AMS010	247 DEEPWOOD DRIVE	A	Y	3			
	AMS011	2 WOODACRES ROAD	A	Y	3			
	AMS012	519 DEEPWOOD DRIVE	A	Y	3			
	AMS013	489 DEEPWOOD DRIVE	A	Y	3			
	AMS014	440 DEEPWOOD DRIVE	A	Y	3			
	AMS015	163 DEEPWOOD DR L	A	Y	3			
	AMS016	465 DEEPWOOD DRI L	A	Y	3			
	AMS017	348 DEEPWOOD DR L	A	Y	3			
	AMS018	25 W WOODLAND L	A	Y	3			
	AMS019	66 BEECH LEB	A	Y	3			
	AMS020	257 DEEPWOOD DR L	A	Y	3			
	AMS021	14 KELLYS CORNER L	A	Y	3			
	AMS022	13 ST RONAN HEB	A	Y	3			
	AMS023	44 AMES RD HEB	A	Y	3			
	AMS024	52 HILLCREST HEB	A	Y	3			
	AMS025	15 TURNER RD HEB	A	Y	3			
	AMS026	13 JACKMAN HEB	A	Y	3			
	AMS027	22 RONDALY HEB	A	Y	3			
	AMS028	19 WOODSIDE HEB	A	Y	3			
	AMS029	242 DEEPWOOD DRIVE H	A	Y	3			
	AMS030	11 WOODLAND LEB	A	Y	3			
	AMS031	250 DEEPWOOD DRI H	A	Y	3			
	AMS032	7 MEADOWBROOK H	A	Y	3			
	AMS033	267 DEEPWOOD DR H	A	Y	3			
	AMS034	13 OAKLAND HEB	A	Y	3			
	AMS035	11 WOODSIDE HEB	A	Y	3			
	AMS036	8 BANGOR HEB	A	Y	3			
	AMS037	23 DEEPWOOD DRI H	A	Y				Y
	AMS038	287 DEEPWOOD DR COL	A	Y				
	AMS039	13 WOODACRES RD COL	A	Y				
	AMS040	231 DEEPWOOD DRI H	A	Y				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670331	CTWC - AMSTON LAKE DIVISION	C	910	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	325				Agricultural

Towns Served: COLCHESTER, HEBRON, LEBANON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	1	1	1
	AMS041	24 OAKLAND HEB		A	Y			
	AMS042	40 HILLCREST HEB		A	Y			
	AMS043	36 HILLCREST HEB		A	Y			
	AMS044	118 N POND RD		A	Y	1		
	AMS045	22 WOODSIDE RD		A	Y	1		
	AMS046	23 WOODSIDE RD		A	Y	1		
	AMS047	17 BEECH RD		A	Y	1		
	AMS048	48 BEECH RD		A	Y	1		
	AMS049	365 DEEPWOOD DR		A	Y	1		
	AMS050	373 DEEPWOOD DR		A	Y	1		
	AMS051	32 AMES RD		A	Y	3		
	AMS052	5 BANGOR RD		A	Y	3		
	AMS053	51 BASS LAKE RD		A	Y	3		
	AMS054	123 DEEPWOOD DR		A	Y	3		
	AMS055	160 DEEPWOOD DR		A	Y	3		
	AMS056	207 DEEPWOOD DR		A	Y	3		
	AMS057	219 DEEPWOOD DR		A	Y	3		
	AMS058	225 DEEPWOOD DR		A	Y	3		
	AMS059	23 ELSMERE RD		A	Y	3		
	AMS060	1 FRANCIS RD		A	Y	3		
	AMS061	17 HILLCREST DR		A	Y	3		
	AMS062	9 JACKMAN RD		A	Y	3		
	AMS063	51 LAKE RD		A	Y	3		
	AMS064	6 MEADOW BROOK RD		A	Y	3		
	AMS065	109 N POND RD		A	Y	3		
	AMS066	9 OAKLAND RD		A	Y	3		
	AMS067	6 RONDALY RD		A	Y	3		
	AMS068	31 SAINT RONAN RD		A	Y	3		
	AMS069	5 TURNER RD		A	Y	3		
	AMS070	16 WOOD ACRES RD		A	Y	3		
	AMS071	47 BEECH RD		A	Y	3		
	AMS072	33 CATHERINE ST		A	Y	3		
	AMS073	133 DEEPWOOD DR		A	Y	3		
	AMS074	74 ISLAND BEACH RD		A	Y	3		
	AMS075	86 LAKEVIEW HTS		A	Y	3		
	AMS076	72 LEDGE RD		A	Y	3		
	AMS077	21 MANION LN		A	Y	3		
	AMS078	21 RYAN TER		A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670331	CTWC - AMSTON LAKE DIVISION	C	910	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	325				

Towns Served: COLCHESTER, HEBRON, LEBANON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
					Rule Tier	WQD	DBPR	
		AMS079	11 SUNSET DR	A	Y		3	
		AMS080	56 W WOODLAND DR	A	Y		3	
		AMS081	95 DEEPWOOD DR	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - ISLAND BEACH WELL	3	ENTRY POINT	A				
00702	ENTRY POINT - CHURCH ST WELL	3	EP - CHURCH ST	A				
481	ISLAND BEACH WELL	2	ISLAND BEACH WELL	A				
48843	ISLAND BEACH PUMPHOUSE							
52595	ST RONAN RD TANK							
52597	ISLAND BEACH TANK							
52601	ISLAND BEACH PUMP STATION							
58775	CHURCH ST WELL	2	CHURCH ST WELL	A				
58777	CHURCH ST TREATMENT PLANT							

Certified Operator Information

Water System Facility: ISLAND BEACH PUMPHOUSE (WSF ID: 48843)

Facility Classification: CLASS 2 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
LABIANCA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 12/31/2026

Water System Facility: CHURCH ST TREATMENT PLANT (WSF ID: 58777)

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
LABIANCA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 12/31/2026

Contact Information

Name	Organization	Job Title
Mr. Craig J. Patla	Connecticut Water Company	Vp, Service Delivery
Mailing Address Line One	Mailing Address Line Two	City
93 West Main Street		State
		Zip Code
Business Phone	Extension	Fax
860-664-6140		Mobile Phone
		Emergency Phone
		Email Address
		800-391-1924 craig.patla@ctwater.com

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0670331	CTWC - AMSTON LAKE DIVISION	C	910	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		325			Agricultural

Towns Served: COLCHESTER, HEBRON, LEBANON

Contact Role(s): **Legal Contact, Owner**

Name	Organization	Job Title		
Mr. Paul C. Lowry	Connecticut Water Company	Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
93 W Main Street		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-944-9655		860-654-1903		800-208-5700
				ctwcdphadmin@ctwater.com

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0671021	WELLSWOOD ESTATES FOUNDATION, INC.	C	112	P	GW
Local Address (where applicable)	Service Connections	Residential 28	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0671021	WELLSWOOD ESTATES FOUNDATION, INC.	C	112	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/27 - 12/31/27		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
CROSS CONNECTION EXEMPTION	3/1/2025	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos	WQP 2 DBPR	Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0671021	WELLSWOOD ESTATES FOUNDATION, INC.	C	112	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	28				

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
					Stage	Stage	Stage
	DOWNSTREAM	WITHIN 5 SERVICE CON	A				
	UNIT 10	UNIT 10	A	Y	2	Y	Y
	UNIT 11	UNIT 11	A	Y	2	Y	Y
	UNIT 12	UNIT 12	A	Y	2	Y	Y
	UNIT 13	UNIT 13	A	Y	2	Y	Y
	UNIT 14	UNIT 14	A	Y	2	Y	Y
	UNIT 15	UNIT 15	A	Y	2	Y	Y
	UNIT 16	UNIT 16	A	Y	2	Y	Y
	UNIT 17	UNIT 17	A	Y	2	Y	Y
	UNIT 18	UNIT 18	A	Y	2	Y	Y
	UNIT 19	UNIT 19	A	Y	2	Y	Y
	UNIT 2	UNIT 2	A	Y	2	Y	Y
	UNIT 20	UNIT 20	A	Y	2	Y	Y
	UNIT 21	UNIT 21	A	Y	2	Y	Y
	UNIT 22	UNIT 22	A	Y	2	Y	Y
	UNIT 23	UNIT 23	A	Y	2	Y	Y
	UNIT 24	UNIT 24	A	Y	2	Y	Y
	UNIT 25	UNIT 25	A	Y	2	Y	Y
	UNIT 26	UNIT 26	A	Y	2	Y	Y
	UNIT 27	UNIT 27	A	Y	2	Y	Y
	UNIT 28	UNIT 28	A	Y	2	Y	Y
	UNIT 4	UNIT 4	A	Y	2	Y	Y
	UNIT 5	UNIT 5	A	Y	2	Y	Y
	UNIT 6	UNIT 6	A	Y	2	Y	Y
	UNIT 7	UNIT 7	A	Y	2	Y	Y
	UNIT 8	UNIT 8	A	Y	2	Y	Y
	UNIT 9	UNIT 9	A	Y	2	Y	Y
	UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A			
1081	WELL #1	2	WELL 1	A			
1631	WELL 2	2	WELL 2	A			
51355	ATMOSPHERIC STORAGE TANK						
57105	BOOSTER PUMPS						

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0671021	WELLSWOOD ESTATES FOUNDATION, INC.	C	112	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	28				

Towns Served: HEBRON

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROWLEY, BRENDAN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2028 12/31/2028

Contact Information

Name	Organization	Job Title		
Ms. Kathy Dubay	Investors Management Assoc	Assoc Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
24 Windham Street		Willimantic	CT	06226
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-423-3936	10	860-423-5198		860-423-3936 kathy@imaservices.com

Contact Role(s): **Administrative Contact**

Name	Organization	Job Title		
Mr. Lisa Ferreria		President		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
80 Wellswood Road #26		Amston	CT	06231
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
				Email Address lferreira@crec.org

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672021	CTWC - WELLSWOOD VILLAGE DIV	C	60	P	GW
Local Address (where applicable)	Service Connections	Residential 21	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672021	CTWC - WELLSWOOD VILLAGE DIV	C	60	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)				1 routine (RT) per year
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		Complete
		1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)				1 routine (RT) per six years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/20 - 12/31/25		Complete
		1/1/26 - 12/31/31		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Water System Facility: WELL 1 (WSF ID: 1632)

E. Coli (3014)				1 routine (RT) per month
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)		8/1/25 - 8/31/25		Complete
		9/1/25 - 9/30/25		Complete
		10/1/25 - 10/31/25		Complete
		11/1/25 - 11/30/25		Complete
		12/1/25 - 12/31/25		Complete
		1/1/26 - 1/31/26		
		2/1/26 - 2/28/26		
		3/1/26 - 3/31/26		
		4/1/26 - 4/30/26		
		5/1/26 - 5/31/26		
		6/1/26 - 6/30/26		
		7/1/26 - 7/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	
CROSS CONNECTION EXEMPTION	3/1/2030	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672021	CTWC - WELLSWOOD VILLAGE DIV	C	60	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	21				

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
					Stage	Stage	Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
		WELL001	23 VILLAGE LANE	P	Y	N	
		WELL002	24 VILLAGE LANE	P	Y	N	
		WELL003	14 VILLAGE LANE	P	Y	N	
		WELL004	8 VILLAGE LANE	P	Y	N	
		WELL005	6 COTTAGE LANE	P	Y	N	
		WELL006	11 COTTAGE LANE	P	Y	N	
		WELL007	12 COTTAGE LANE	P	Y	N	
		WELL008	5 VILLAGE LN	A	Y	3	
		WELL009	3 COTTAGE LN	A	Y	N	
		WELL010	8 COTTAGE LN	A	Y	N	
		WELL011	10 COTTAGE LN	A	Y	N	
		WELL012	9 COTTAGE LN	A	Y	N	
		WELL013	18 VILLAGE LN	A	Y	N	
		WELL014	26 VILLAGE LN	A	Y	N	
		WELL015	7 COTTAGE LN	A	Y	N	
		WELL016	16 VILLAGE LN	A	Y	N	
		WELL017	10 VILLAGE LN	A	Y	N	
		WELL018	22 VILLAGE LN	A	Y	N	
		WELL019	21 VILLAGE LN	A	Y	N	
		WELL020	13 VILLAGE LN	A	Y	N	
		WELL021	20 VILLAGE LN	A	Y	N	
00700	ENTRY POINT	3	ENTRY POINT	A			
1632	WELL 1	2	WELL 1	A			
1633	WELL 2	2	WELL 2	A			
52709	ATMOSPHERIC TANK						
52712	PRESSURE TANK						
52713	PUMP STATION						

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:	SMALL WATER SYSTEM	Certification Expiration
Operator Name	Operator Type	Certification(s)
GREEN, III, CLIFFORD	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III 3/31/2026
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II 6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III 12/31/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672021	CTWC - WELLSWOOD VILLAGE DIV	C	60	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		21			

Towns Served: HEBRON

Contact Information

Name		Organization			Job Title		
Mr. Craig J. Patla		Connecticut Water Company			Vp, Service Delivery		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
93 West Main Street					Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-664-6140				800-391-1924	craig.patla@ctwater.com		

Contact Role(s): **Legal Contact, Owner**

Name		Organization			Job Title		
Mr. Paul C. Lowry		Connecticut Water Company			Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
93 W Main Street					Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-944-9655		860-654-1903		800-208-5700	ctwcdphadmin@ctwater.com		

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672031	CTWC - HEBRON CENTER DIVISION	C	1,927	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		92	8		

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Chlorine Residual (1012)	2 routine (RT) per month			
Sampling Point (Sampling Point ID)				
Select from Inventory of Active Sampling Points	Monitoring Period	Collection Period	Compliance Status	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	
Asbestos (1094)	1 routine (RT) per nine years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28			
Total Coliform (3100)	2 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			
Disinfectant Byproducts - TTHM & HAAs (DBP)	1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
RHAM HIGH SCHOOL (HEB002)	1/1/25 - 12/31/25	8/1-8/31	Complete	
	1/1/26 - 12/31/26	8/1-8/31		
	1/1/27 - 12/31/27	8/1-8/31		
Lead And Copper (PBCU)	20 routine (RT) per six months			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete	
	1/1/26 - 6/30/26			
	7/1/26 - 12/31/26			
Physical Parameters (PPS)	2 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672031	CTWC - HEBRON CENTER DIVISION	C	1,927	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		12/1/25 - 12/31/25		Complete
		1/1/26 - 1/31/26		
		2/1/26 - 2/28/26		
		3/1/26 - 3/31/26		
		4/1/26 - 4/30/26		
		5/1/26 - 5/31/26		
		6/1/26 - 6/30/26		
		7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/24 - 12/31/26		
		1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		Complete
		1/1/27 - 12/31/27		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		Complete
		4/1/26 - 6/30/26		

Water System Facility: **WELL 1 (WSF ID: 4632)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672031	CTWC - HEBRON CENTER DIVISION	C	1,927	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: WELL 1 (WSF ID: 4632)

E. Coli (3014) 1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL 2 (WSF ID: 4633)

E. Coli (3014) 1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL 3 (WSF ID: 4634)

E. Coli (3014) 1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 3 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672031	CTWC - HEBRON CENTER DIVISION	C	1,927	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: HEBRON

Monitoring Requirements

Water System Facility: WELL 3 (WSF ID: 4634)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			

Water System Facility: COUNTRY MANOR WELL (WSF ID: 61131)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
COUNTRY MANOR WELL (2)	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			

Water System Facility: WALL ST WELL 1 (WSF ID: 62208)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WALL ST WELL (2)	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			

Monthly Water System Facility (WSF) Level Monitoring Requirements

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672031	CTWC - HEBRON CENTER DIVISION	C	1,927	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		92	8		

Towns Served: HEBRON

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		COUN001	A5 KITCHEN SINK	A	Y		N	
		COUN002	BUILDING C TANK TOP	A	Y			
		COUN003	BUILDING A	A	Y			
		COUN004	162 WALL ST APT 5B	A	Y		N	
		COUN005	OFFICE SINK	A	Y			
		COUN006	APT 1 BLDG A	A	Y		N	
		COUN007	APT 2 BLDG A	A	Y		N	
		COUN008	APT 3 BLDG A	A	Y		N	
		COUN009	APT 4 BLDG A	A	Y		N	
		COUN010	APT 6 BLDG A	A	Y		N	
		COUN011	APT 7 BLDG A	A	Y		N	
		COUN012	APT 8 BLDG A	A	Y		N	
		COUN013	APT 1 BLDG B	A	Y		N	
		COUN014	APT 2 BLDG B	A	Y		N	
		COUN015	APT 3 BLDG B	A	Y		N	
		COUN016	APT 4 BLDG B	A	Y		N	
		COUN017	APT 6 BLDG B	A	Y		N	
		COUN018	APT 7 BLDG B	A	Y		N	
		COUN019	APT 8 BLDG B	A	Y		N	
		COUN020	APT 1 BLDG C	A	Y		N	
		COUN021	APT 2 BLDG C	A	Y		N	
		COUN022	APT 3 BLDG C	A	Y		N	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672031	CTWC - HEBRON CENTER DIVISION	C	1,927	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		92	8		

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Asbestos	WQP 2	DBPR	Stage
						Rule	Rule Tier				
	COUN023	APT 4 BLDG C		A	Y			N			
	COUN024	APT 5 BLDG C		A	Y			N			
	COUN025	APT 6 BLDG C		A	Y			N			
	COUN026	APT 7 BLDG C		A	Y			N			
	COUN027	APT 9 BLDG C		A	Y			N			
	DOWNSTREAM	WITHIN 5 SERVICE CON		A							
	HEB001	RHAM MIDDLE SCHOOL		A		Y					
	HEB002	RHAM HIGH SCHOOL		A		Y					Y
	HEB003	11 WALL ST		A			3				
	HEB004	14 TIMBERTPOST WAY		A			N				
	HEB005	59 BUTTONWOOD RD		A			N				
	HEB006	10 TIMBERPOST WAY		A			N				
	HEB007	12 TIMBERPOST WAY		A			N				
	HEB008	20 BUTTONWOOD RD		A			N				
	HEB009	21 BUTTONWOOD RD		A			N				
	HEB010	27 BUTTONWOOD RD		A			N				
	HEB011	29 BUTTONWOOD RD		A			N				
	HEB012	39 BUTTONWOOD RD		A			N				
	HEB013	41 BUTTONWOOD RD		A			N				
	HEB014	54 BUTTONWOOD RD		A			N				
	HEB015	63 BUTTONWOOD RD		A			N				
	HEB016	64 BUTTONWOOD RD		A			N				
	HEB017	65 BUTTONWOOD RD		A			N				
	HEB018	71 BUTTONWOOD RD		P			N				
	HEB019	73 BUTTONWOOD RD		A			N				
	HEB020	77 BUTTONWOOD RD		A			N				
	HEB021	8 TIMBERTPOST WAY		P			N				
	HEB022	19 BUTTONWOOD RD		P			N				
	HEB023	2 TIMBERPOST WAY		A			N				
	HEB024	24 BUTTONWOOD RD		A			N				
	HEB025	31 BUTTONWOOD RD		A			N				
	HEB026	32 BUTTONWOOD RD		A		Y		N			
	HEB027	34 BARBERS WAY		A		Y		N			
	HEB028	35 BUTTONWOOD		A			N				
	HEB029	38 BARBERS WA		A			N				
	HEB030	4 TIMBERPOST WAY		A			N				
	HEB031	42 BUTTONWOOD RD		A			N				
	HEB032	44 BARBERS WAY		A			N				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672031	CTWC - HEBRON CENTER DIVISION	C	1,927	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		92	8		

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
					Stage	Y	Y
	HEB033	47 BUTTONWOOD RD	A		N		
	HEB034	14 MILL LANDING RD	A	Y	N		Y
	HEB035	29 MILL LANDING RD	A	Y	N		
	HEB036	39 MILL LANDING RD	P	Y	N		
	HEB037	46 MILL LANDING RD	P	Y	N		
	HEB039	SINOR CENTER	P	Y			
	HEB040	10 JEREMY WAY	P	Y	N		
	HEB041	13 JEREMY WAY	P	Y	N		
	HEB042	14 JEREMY WAY	A	Y	N		
	HEB043	16 JEREMY WAY	A	Y	N		
	HEB044	22 MILL LANDING RD	A	Y	N		
	HEB045	12 MILL LANDING RD	A	Y	N		
	HEB046	16 MILL LANDING RD	A	Y	N		
	HEB047	24 MILL LANDING RD	A	Y	N		
	HEB048	26 MILL LANDING RD	A	Y	N		
	HEB049	31 MILL LANDING RD	A	Y	N		
	HEB050	32 MILL LANDING RD	A	Y	N		
	HEB051	33 MILL LANDING RD	A	Y	N		
	HEB052	34 MILL LANDING RD	A	Y	N		
	HEB053	42 MILL LANDING RD	A	Y	N		
	HEB054	43 MILL LANDING RD	A	Y	N		
	HEB055	44 MILL LANDING RD	P	Y	N		
	HEB056	47 MILL LANDING RD	P	Y	N		
	HEB057	48 MILL LANDING RD	P	Y	N		
	HEB058	2 RIVER RD	P	Y	N		
	HEB059	3 RIVER RD	P	Y	N		
	HEB060	4 RIVER RD	A	Y	N		
	HEB061	6 RIVER RD	A	Y	N		
	HEB062	8 RIVER RD	A	Y	N		
	HEB063	9 RIVER RD	A	Y	N		
	HEB064	10 RIVER RD	A	Y	N		
	HEB065	18 RIVER RD	A	Y	N		
	HEB066	22 RIVER RD	A	Y	N		
	HEB067	26 RIVER RD	A	Y	N		
	HEB068	31 RIVER RD	A	Y	N		
	HEB069	34 RIVER RD	A	Y	N		
	HEB070	36 RIVER RD	A	Y	N		
	HEBE065	18 RIVER RD.	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672031	CTWC - HEBRON CENTER DIVISION	C	1,927	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		92	8		

Towns Served: HEBRON

Water System Facility and Sampling Point Inventory					
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier
	UPSTREAM	WITHIN 5 SERVICE CON	A		Stage 2
00700	ENTRY POINT	3	ENTRY POINT	A	
1734	HEBRON CENTER TREATMENT STATION				
4632	WELL 1	2	WELL 1	P	
4633	WELL 2	2	WELL 2	P	
4634	WELL 3	2	WELL 3	P	
52641	ATMOSPHERIC TANK				
52643	PRESSURE TANK				
52647	PUMP STATION				
60849	WELL 2 (STONECROFT)	2	WELL 2 (STONECROFT)	I	
60850	WELL 1 (STONECROFT)	2	WELL 1 (STONECROFT)	I	
61131	COUNTRY MANOR WELL	2	COUNTRY MANOR WELL	A	
62208	WALL ST WELL 1	2	WALL ST WELL	A	

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)	
GREEN, III, CLIFFORD	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2026
LABIANCA, MICHAEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027

Water System Facility: **HEBRON CENTER TREATMENT STATION (WSF ID: 1734)**

Facility Classification: CLASS 2 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
LABIANCA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026

Contact Information

Name	Organization			Job Title		
Mr. Craig J. Patla	Connecticut Water Company			Vp, Service Delivery		
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6140				800-391-1924	craig.patla@ctwater.com	
Contact Role(s):	Legal Contact, Owner					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0672031	CTWC - HEBRON CENTER DIVISION	C	1,927	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		92	8		Agricultural

Towns Served: HEBRON

Name	Organization	Job Title
Mr. Paul C. Lowry	Connecticut Water Company	Manager
Mailing Address Line One	Mailing Address Line Two	City
93 W Main Street		Clinton
Business Phone	Extension	State
860-944-9655	860-654-1903	Zip Code
Emergency Phone	Email Address	
	800-208-5700	ctwcdphadmin@ctwater.com

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.