

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012) 40 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		

Total Coliform (3100) 40 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Disinfectant Byproducts - TTHM & HAA5 (DBP) 4 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
377 S CHERRY ST (WWD0001)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
5 STERLING DRIVE (WWD0057)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
CHIMNEY HILL BLEEDER (WWD0058)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
MCGUIRE COURT (WWD0059)	7/1/25 - 9/30/25	9/1-9/30	Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					13,204

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP) **4 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	

Lead And Copper (PBCU) **30 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	

Physical Parameters (PPS) **40 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **PISTAP AUG POND WTP ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Uranium (4006) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Combined Radium-226/228 (4010) **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Inorganic Chemicals (IOCS) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: PISTAP AUG POND WTP ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26		Complete
	1/1/27 - 12/31/27		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		Complete
	1/1/27 - 12/31/27		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		Complete
	1/1/27 - 12/31/27		

Water System Facility: OAK STREET WELLS #2 & #3 ENTRY POINT (WSF ID: 00701)

Net Gross Alpha (4000) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Uranium (4006) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Combined Radium-226/228 (4010) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	1/1/25 - 12/31/27		Complete

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		Complete
	1/1/27 - 12/31/27		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: OAK STREET WELLS #2 & #3 ENTRY POINT (WSF ID: 00701)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Organic Chemicals (VOCS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-OAK STREET 2 & 3 (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: RIDGELAND WELLFIELD - WELL#1 ENTRY POINT (WSF ID: 00702)

Net Gross Alpha (4000) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Uranium (4006) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Combined Radium-226/228 (4010) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/25 - 12/31/27		Complete

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		Complete
	1/1/27 - 12/31/27		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-RIDGELAND WELL 1 (3)	1/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					13,204
					Agricultural

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: RIDGELAND WELLFIELD - WELL#1 ENTRY POINT (WSF ID: 00702)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26		Complete
	1/1/27 - 12/31/27		

Water System Facility: OAK STREET WELL #2 (WSF ID: 1390)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
OAK STREET WELL #2 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: OAK STREET WELL #3 (WSF ID: 1391)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
OAK STREET WELL #3 (2)	8/1/25 - 8/31/25		Out of Service
	9/1/25 - 9/30/25		Out of Service
	10/1/25 - 10/31/25		Out of Service
	11/1/25 - 11/30/25		Out of Service
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL #1 (WSF ID: 1392)

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	8/1/25 - 8/31/25		Out of Service
	9/1/25 - 9/30/25		Out of Service

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT	C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					13,204
					Agricultural

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: WELL #1 (WSF ID: 1392)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	10/1/25 - 10/31/25		Out of Service
	11/1/25 - 11/30/25		Out of Service
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: PISTAPAUG POND (WSF ID: 2273)

Total Alkalinity (1927)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
PISTAPAUG POND (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		

Total Organic Carbon (2920)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
PISTAPAUG POND (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
PISTAPAUG POND (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
PISTAPAUG POND (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		Complete
	1/1/27 - 12/31/27		

Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
PISTAPAUG POND (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Monitoring Requirements

Water System Facility: **PISTAPPAUG POND (WSF ID: 2273)**

Surface Water Color and Turbidity (RPPS)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Surface Water Pesticides (RSOC)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
PISTAPPAUG POND (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: **PISTAPPAUG WATER TREATMENT PLANT (WSF ID: 289)**

Total Organic Carbon (2920)	Monitoring Period	Collection Period	Compliance Status
<i>Sampling Point (Sampling Point ID)</i>			
EP - PISTAPPAUG TP (5)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **PISTAPPAUG POND WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility: PISTAPAug POND WTP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
Start Date: 7/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2
Start Date: 7/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Water System Facility: OAK STREET WELLS #2 & #3 ENTRY POINT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility: **OAK STREET WELLS #2 & #3 ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.2 MG/L	2
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Water System Facility: **RIDGELAND WELLFIELD - WELL#1 ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2005	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility: RIDGELAND WELLFIELD - WELL#1 ENTRY POINT (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
	Offline	8/1/2025 - 8/31/2025	n/a Y
	Offline	9/1/2025 - 9/30/2025	n/a Y
	Offline	10/1/2025 - 10/31/2025	n/a Y
	Offline	11/1/2025 - 11/30/2025	n/a Y
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.2 MG/L	2
Start Date: 7/1/2003			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: BARNES CHLORINATION ST ENTRY POINT (WSFID: 00703)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: PISTAPAug WATER TREATMENT PLANT (WSFID: 289)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility: **PISTAPUG WATER TREATMENT PLANT (WSFID: 289)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2027	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WWD0001	377 S CHERRY ST	A	Y			Y
		WWD0002	134 S TURNPIKE RD	A	Y			
		WWD0002A	129 S. TURNPIKE ROAD	A	Y			
		WWD0003	60 GAYLORD FARMS	A	Y			
		WWD0004	60 PARKER FARMS RD	A	Y			
		WWD0005	200 HIGHLAND AVE	A	Y			
		WWD0006	508 MAIN STREET, YAL	A	Y			
		WWD0007	42 N PLAINS IND RD	A	Y			
		WWD0008	600 NORTHROP RD	A	Y			
		WWD0009	225 POND HILL RD	A	Y			
		WWD0010	636 BARNES RD	A	Y			
		WWD0011	HIGHLAND SAMP STA	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		WWD0012	CL HOUSE SAMP STA	I	Y			
		WWD0012A	PRV VAULT SAMP STA	A	Y			
		WWD0013	1 ASHLEY LANE	A				
		WWD0014	141 HOPE HILL RD	A				
		WWD0015	1194 N COLONY RD	A				
		WWD0016	1 BERNADETTE LN	A		1		
		WWD0017	83 BRENTWOOD DR	A		1		
		WWD0018	254 BRENTWOOD DR	A		1		
		WWD0019	17 BRIARWOOD LN	A		1		
		WWD0020	15 BUTTONWOOD CIR	A		1		
		WWD0021	29 BUTTONWOOD CIR	A		1		
		WWD0022	9 CASSELLA DR	A		1		
		WWD0023	15 CASSELLA DR	A		1		
		WWD0024	809 CLINTONVILLE RD	A		1		
		WWD0025	108 COLONIAL HILL RD	A		1		
		WWD0026	4 COUNTRY WAY	A		1		
		WWD0027	18 COUNTRY WAY	A		1		
		WWD0028	1038 E CENTER ST	A		1		
		WWD0029	5 HAYLEDGE COURT	A		1		
		WWD0030	24 MAPLEVIEW RD	A		1		
		WWD0031	18 MELLOR DR	A		1		
		WWD0032	36 MELLOR DR	A		1		
		WWD0033	5 NOD BROOK RD	A		3		
		WWD0034	31 NOD BROOK RD	A		1		
		WWD0035	46 NOD BROOK RD	A		1		
		WWD0036	742 NORTH FARMS RD	A		1		
		WWD0037	161 PARKER FARMS RD	A		1	Y	
		WWD0038	5 PARTRIDGE RUN	A		1		
		WWD0039	40 SAW MILL DR	A		3		
		WWD0040	70 SAW MILL DR	A		1		
		WWD0041	80 SAW MILL DR	A		1		
		WWD0042	85 SAW MILL DR	A		1		
		WWD0043	41 STAFFORDSHIRE COM	A		1		
		WWD0044	112 SUMMERHILL DR	A		1		
		WWD0045	21 TWIN OAK FARM RD	A		1		
		WWD0046	5 WOODS EDGE CIR	A		1		
		WWD0047	5 KIRTLAND COURT	A			Y	
		WWD0048	35 STILLWOOD RD	A			Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		WWD0050	519 MAIN ST, YALES	A	Y			
		WWD0051	50 N PLAINS IND RD	A	Y			
		WWD0052	500 MAIN ST, YALES	I	Y			
		WWD0053	61 SAW MILL DR	A		1		
		WWD0054	1675 WHIRLWIND RD	A				
		WWD0055	135 N MAIN ST	A				
		WWD0056	3 TECHNOLOGY DRIVE	A				
		WWD0057	5 STERLING DRIVE	A				Y
		WWD0058	CHIMNEY HILL BLEEDER	A				Y
		WWD0059	MCGUIRE COURT	A				Y
		WWD0060	57 HALL RD	A				
		WWD0061	1145 OLD COLONY RD	A	Y			
		WWD0062	59 N PLAINS IND RD	A	Y			
		WWD0063	48 N PLAINS IND RD	A	Y			
		WWD0064	980 N MAIN ST EXT	A	Y			
		WWD0065	415 S CHERRY ST	A	Y			
		WWD0066	17 WEATHERSIDE DR	A		1		
		WWD0067	736 NORTH FARMS RD	A		1		
		WWD0068	159 GRIEB ROAD	A		1		
		WWD0069	163 GRIEB ROAD	A		1		
		WWD0070	53 N. PLAINS ROAD	A	Y			
00700	PISTAPAug POND WTP ENTRY POINT	3	ENTRY POINT	A				
00701	OAK STREET WELLS #2 & #3 ENTRY POINT	3	EP-OAK STREET 2 & 3	A				
00702	RIDGELAND WELLFIELD - WELL#1 ENTRY POINT	3	EP-RIDGELAND WELL 1	A				
00703	BARNES CHLORINATION ST ENTRY POINT	3	EP-BARNES	A				
00704	OAK STR W #2 FINISHED (AIR STRIP. TOWER)	3	EP-OAK STR WELL #2	A				
00705	OAK STR W #3 FINISHED (GREENSAND)	3	EP-OAK STR WELL #3	A				
1390	OAK STREET WELL #2	2	OAK STREET WELL #2	A				
1391	OAK STREET WELL #3	2	OAK STREET WELL #3	A				
1392	WELL #1	2	WELL #1	A				
2270	MACKENZIE RESERVOIR	1	RESERVOIR	A				
2271	ULBRICH RESERVOIR	1	RESERVOIR	A				
2272	LANES POND	1	RESERVOIR	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
2273	PISTAP AUG POND	1	PISTAP AUG POND	A				
289	PISTAP AUG WATER TREATMENT PLANT	5	EP - PISTAP AUG TP	A				
290	OAK STREET TREATMENT STATION	1	OAK STREET TREATMENT	A				
291	RIDGELAND TREATMENT STATION - WELL #1	5	IESWTR - ENTRY POINT	A				
30092	PISTAP AUG POND							
54826	ULBRICH RAW WATER PUMP STATION							
54828	MACKENZIE RAW WATER PUMP STATION							
54830	SUNRISE CIRCLE PUMP STATION							
54832	HILLHOUSE STORAGE TANK							
54834	CHESHIRE ROAD PUMP STATION							
54836	MASONIC GROUND STORAGE TANK							
54838	MASONIC STORAGE TANK							
54840	WESTSIDE STORAGE TANK							
54842	PARKER FARMS PUMP STATION							
54844	BARNES PUMP STATION							
54846	BARNES STORAGE TANK							
54848	CARPENTER STORAGE TANK							
54852	PISTAP AUG POND RAW WATER PUMP STATION							
54854	PISTAP AUG POND STORAGE TANK							
61316	INTERCONNECTION - CT0930011 - RWA							
62040	BARNES BOOSTER STATION							
62865	PISTAP AUG IN PLANT CLEARWELL							
62866	OAK STREET CLEARWELL							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
PAWLOWSKI, JAY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2028
GORMAN, CARL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2026
AMWAKE, NEIL H.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
DEGROAT, KYLE J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2028
ZEMKE, DENNIS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2026
JACKSON IV, SHELBY P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
PEPE, ANTHONY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR IN TRAINING	3/31/2026
WINTERS, FRANK A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2028
CABELUS, MICHAEL R	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2028

Water System Facility: PISTAPAug WATER TREATMENT PLANT (WSF ID: 289)

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
DEGROAT, KYLE J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2028
PAWLOWSKI, JAY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
GORMAN, CARL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2026
ZEMKE, DENNIS	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
JACKSON IV, SHELBY P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
PEPE, ANTHONY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR IN TRAINING	3/31/2026
CROSBY JR, ALLEN T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	12/26/2023
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026

Water System Facility: OAK STREET TREATMENT STATION (WSF ID: 290)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
DEGROAT, KYLE J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2028

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Certified Operator Information

Water System Facility: OAK STREET TREATMENT STATION (WSF ID: 290)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PAWLOWSKI, JAY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
JACKSON IV, SHELBY P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
PEPE, ANTHONY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR IN TRAINING	3/31/2026
CROSBY JR, ALLEN T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026
		WATER TREATMENT PLANT OPERATOR IN TRAINING	12/26/2023

Water System Facility: RIDGELAND TREATMENT STATION - WELL #1 (WSF ID: 291)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
DEGROAT, KYLE J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2028
PAWLOWSKI, JAY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
JACKSON IV, SHELBY P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
PEPE, ANTHONY	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR IN TRAINING	3/31/2026
CROSBY JR, ALLEN T	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026
		WATER TREATMENT PLANT OPERATOR IN TRAINING	12/26/2023

Contact Information

Name		Organization		Job Title		
Mr. Jay Pawlowski		Wallingford Water Department				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
377 South Cherry Street				Wallingford	CT	06492
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-949-2660		203-949-2678		203-907-5641	jay.pawlowski@wallingfordct.gov	

Contact Role(s): Administrative Contact

Name		Organization		Job Title		
Mr. Neil H. Amwake		Town of Wallingford		General Manager		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
377 South Cherry St				Wallingford	CT	06492
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-949-2670		203-949-2678		860-922-6286	neil.amwake@wallingfordct.gov	

Contact Role(s): Legal Contact, Owner

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1480011	WALLINGFORD WATER DEPARTMENT			C	37,267	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						13,204	

Towns Served: NORTH HAVEN, WALLINGFORD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.