



DEPARTMENT OF ADMINISTRATIVE SERVICES

PROPOSED CHANGE OF THE CONNECTICUT STATE BUILDING CODE AND FIRE SAFETY CODE

DATE SUBMITTED: April 12, 2024

CODE INFORMATION

Proposed change to: [X] Building Code [ ] Fire Safety Code

Code section(s): IBC Section 903.2.8 Exception 2

PROPONENT INFORMATION

Name: Raymond Marcotte, BO

Representing: Self

Telephone: (b) 860 757- 9266

Email: Raymond.Marcotte@hartford.gov

Address: (b) 260 Constitution Plaza Hartford CT 06103

PROPOSAL INFORMATION

Description of change and reason for change (attach additional information as needed):

Please see attached reason for the proposed change.

Proposed text change, addition or deletion (attach additional information as needed):

Please see attached proposed additional exception to IBC Section 903.2.8 Exception 2.

Supporting data and documents (attach additional information as needed)

[X] This Proposal is original material. (Note: Original material is considered to be the submitter's own idea based on or as a result of his/her own experience, thought or research and, to the best of his/her knowledge, is not copied from another source.)

[ ] This Comment is not original material, its source (if known) is as follows: (such as material / code development proposal from a prior development cycle or proposal submitted to model code committee etc.)

[X] I would like to make an in-person presentation of my proposal.

Release

I hereby grant the State of Connecticut full rights to the use of this material without benefit to me, including, but not limited to, publication and reproduction rights.

Handwritten signature of Raymond Marcotte

Proponent's Signature

Raymond Marcotte, BO

Printed Name

PLEASE EMAIL (PREFERRED) TO DAS.CodesStandards@CT.GOV OR MAIL OR FAX (SEE BELOW)

Department of Administrative Services
Office of the State Building Inspector
450 Columbus Boulevard, Suite 1303
Hartford, CT 06103
Tel: 860-713-5900 Fax: 860-713-7410
Affirmative Action/Equal Opportunity Employer

Attachment to Proposed Change of the CT State Building Code

Raymond Marcotte

April 12, 2024

*The reason for the change to the 2022 CT Code.*

In a Change of Occupancy, specifically a two-family dwelling to a 3-family dwelling, the IEBC refers the Examiners to IBC 903.2.8 - Group R Sprinkler Provisions. Within that section the only exception in the Code to not install sprinklers is where the newly introduced “fire area” (typically a third floor) must have a dedicated means of egress to the level of exit discharge. The only recourse for the homeowner is to hire an architect to develop a Code Path that precludes the use of sprinklers.

*Proposed change to the Code:*

Add an exception to IBC Section 903.2.8 Exception 2 which states:

A means of egress in the newly introduced fire area shall be allowed to be shared with one other unit not on the same story or floor in a 1-hour stair enclosure, or in a compliant exterior stair, to the level of exit discharge.