



October 22, 2018

Mr. Joseph Stein
POSITIVELY ELECTRIC, INC.
18 Good Hill Road
Weston, CT 06883

Dear Mr. Stein:

RE: I-08-18 Temporary electrical service above the flood elevation

This is in response to your email dated October 22, 2018 where you request a formal interpretation to the following question:

Question

Is it the intent of either the 2016 or 2018 State Building Code to require a temporary electrical service that is being installed in order to construct a single family dwelling to be located above the flood base elevation of the municipality?

Answer - 1

No. Neither the 2016 nor 2018 State Building Code would require a temporary electrical service to be installed above the base flood elevation of the municipality.

Sincerely,

Joseph V. Cassidy, P.E.
State Building Inspector

c: Daniel Tierney, Deputy State Building Inspector
William Marr, Greenwich Building Official