



May 24, 2017

Mr. Elliott T. Hambrook, EIT
Sr. Staff Engineer
Gale Associates, Inc.
703 Hebron Avenue
Glastonbury, CT 06033

RE: I-07-17 Follow-up to State Building Code Interpretation (I-10-06 Revised) related to Roof Edges

Dear Mr. Hambrook:

This is in response to your letter dated May 9, 2017 in which you are seeking a clarification to the following question:

Question (1):

Do edge metal profile system that are required by Section 1504.5 of the 2012 International Building Code portion of the 2016 State Building and are found in National Roofing Contractors Association (NRCA) roofing manual approved by Underwriters Laboratories (UL) and Intertek Testing Services (ITS) certifying compliance with ANSI/SPRI ES and are constructed by a NRCA Authorized Fabricator required to be tested for each individual project in which they are used?

Answer:

No, the various edge metal flashing found within NRCA Roofing Manual have been tested for compliance with ANSI/SPRI ES-1 by either UL or ITS which are approved testing agencies provided they are constructed and installed in accordance with their listing.

Sincerely,

Daniel Tierney
Deputy State Building Inspector

DT:bags