

2015 Connecticut Fire Prevention Code Errata

Item #1 Page 7 of 55

(Amd) ~~1.12.19~~ Permits as specified by the ordinance shall be required in accordance with Table 1.12.19(a).

Replace with

(Amd) **1.12.8** Permits as specified by the ordinance shall be required in accordance with Table 1.12.8(a).

Justification: Technical change to correct numbering.

Item #2 Page 7 of 55

(Amd) ~~Table 1.12.19(a) Permit Requirements~~

Replace with

(Amd) **Table 1.12.8(a) Permit Requirements**

Justification: Technical change to correct numbering.

Item #3 Page 7 of 55

Table 1.12.19(a) Permit Requirements

Replace Table Title Number with

Table 1.12.8(a) Permit Requirements

Justification: Technical change to correct numbering.

Item #4 Page 14 of 55

Remove

(Del) ~~1.13.12.2~~ Delete section.

Justification: Technical change to delete only subsection 1.13.12.2.

Item #5 **Page 19 of 55**

(Amd) 2.2 NFPA Publications

Add to list of adopted standards: NFPA 720 *Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment*, 2012 edition

Justification: NFPA 720 is referenced by the CSFSC for the installation of CO detectors, as well as by section 13.7.1.5 of this code that refers you to the CSFSC.

Item 5a **Page 20 of 55**

(Amd) Table 2.2 NFPA Publications.

NFPA 1600, *Standard on Disaster/Emergency Management and Business Continuity Programs*, 2011 edition.

Replace with

NFPA 1600, *Standard on Disaster/Emergency Management and Business Continuity Programs*, 2010 edition.

Justification: Technical correction--there is no 2011 edition, 2010 is the correct publication year.

Item #6 **Page 20 of 55**

(Amd) ~~**2.3.3 ASME Publications.** American Society of Mechanical Engineers, Three Park Avenue, New York, NY 10016-5990~~

Replace with

(Amd) **2.3.4 ASME Publications.** American Society of Mechanical Engineers, Three Park Avenue, New York, NY 10016-5990

Justification: Technical change to correct numbering.

Item #7 **Page N/A**

(Add) ~~**2.3.16 Regulations of Connecticut State Agencies.** State of Connecticut – Department of Public Safety, 1111 Country Club Road, Middletown, CT 06457-2389~~

State Building Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-252 of the Connecticut General Statutes.

Connecticut State Fire Safety Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-292 of the Connecticut General Statutes.
--

Connecticut Fireworks and Special Effects Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-357 of the Connecticut General Statutes.
--

Connecticut Gas Equipment and Piping Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-329 of the Connecticut General Statutes.
Connecticut Safety Code for Elevators and Escalators. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-192 of the Connecticut General Statutes.
Connecticut Tent and Portable Shelter Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-140 of the Connecticut General Statutes.
Connecticut Explosives Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-349 of the Connecticut General Statutes.
Connecticut Model Rocketry Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-367 of the Connecticut General Statutes.

Replace with

(Add) 2.3.19 Regulations of Connecticut State Agencies

REGULATIONS OF CONNECTICUT STATE AGENCIES	State of Connecticut Department of Administrative Services 165 Capitol Avenue Hartford, CT 06106
Connecticut State Fire Safety Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-292 of the Connecticut General Statutes.	
State Building Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-252 of the Connecticut General Statutes.	
Connecticut Safety Code for Elevators and Escalators. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-192 of the Connecticut General Statutes.	
REGULATIONS OF CONNECTICUT STATE AGENCIES	State of Connecticut Department of Consumer Protection 165 Capitol Avenue Hartford, CT 06106
Connecticut Tent and Portable Shelter Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-140 of the Connecticut General Statutes.	
REGULATIONS OF CONNECTICUT STATE AGENCIES	State of Connecticut Department of Emergency Services and Public Protection 1111 Country Club Road Middletown, , CT 06457
Connecticut Explosives Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-349 of the Connecticut General Statutes.	
Connecticut Model Rocketry Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-367 of the Connecticut General Statutes.	
Connecticut Fireworks and Special Effects Code. See the Regulations of Connecticut State Agencies adopted under the authority of section 29-357 of the Connecticut General Statutes.	

Justification: Technical change to indicate the appropriate state agency for each regulation and to correct numbering.

~~(Amd) **3.3.22* Building.** Any structure used or intended for supporting or sheltering any use or occupancy. For application of this code, each portion of a building that is completely separated from other portions by fire walls which have been designed and constructed in accordance with the State Building Code and have been approved by the building official shall be considered separate buildings.~~

Replace with

(Amd) **3.3.30* Building.** Any structure used or intended for supporting or sheltering any use or occupancy. For application of this code, each portion of a building that is completely separated from other portions by fire walls which have been designed and constructed in accordance with the State Building Code and have been approved by the building official shall be considered separate buildings.

Justification: Technical change to correct numbering.

Item #9 **Page 21 of 55**

~~(Amd) **3.3.26 Certificate of Fitness.** A written document issued by the State Fire Marshal to any person for the purpose of granting permission to such person to conduct or engage in any operation or act for which certification is required. Where specified in this code, certificate of fitness shall mean license.~~

Replace with

(Amd) **3.3.40 Certificate of Fitness.** A written document issued by the State Fire Marshal to any person for the purpose of granting permission to such person to conduct or engage in any operation or act for which certification is required. Where specified in this code, certificate of fitness shall mean license.

Justification: Technical change to correct numbering.

Item #10 **Page 21 of 55**

~~(Amd) **3.3.66 Dwelling Unit.** One or more rooms arranged for the use of one or more individuals living together, providing complete, independent living facilities, including permanent provisions for living, sleeping, eating, cooking and sanitation. A dwelling unit shall not allow more than six lodgers or boarders where care is not provided.~~

Replace with

(Amd) **3.3.97 Dwelling Unit.** One or more rooms arranged for the use of one or more individuals living together, providing complete, independent living facilities, including permanent provisions for living, sleeping, eating, cooking and sanitation. A dwelling unit shall not allow more than six lodgers or boarders where care is not provided.

Justification: Technical change to correct numbering.

Item #11 **Page 22 of 55**

~~(Add) **3.3.138.4.1 In-home Group B Occupancies.** Customary in-home business occupancies located within a single-family dwelling unit that provide professional services that employ a maximum of one employee within the dwelling in addition to the residents of the dwelling unit. In-home Group B occupancies shall be classified as a single-family dwelling.~~

Replace with

(Add) **3.3.182.5.1 In-home Group B Occupancies.** Customary in-home business occupancies located within a single-family dwelling unit that provide professional services that employ a maximum of one employee within the dwelling in addition to the residents of the dwelling unit. In-home Group B occupancies shall be classified as a single-family dwelling.

Justification: Technical change to correct numbering.

Item #12 **Page 22 of 55**

~~(Amd) **3.3.138.9* Dormitory.** A building or a space in a building in which group sleeping accommodations are provided for more than 16 persons who are not members of the same family in one room, or a series of closely associated rooms, under joint occupancy and single management, with or without meals, and with or without individual cooking facilities.~~

Replace with

(Amd) **3.3.182.9* Dormitory.** A building or a space in a building in which group sleeping accommodations are provided for more than 16 persons who are not members of the same family in one room, or a series of closely associated rooms, under joint occupancy and single management, with or without meals, and with or without individual cooking facilities.

Justification: Technical change to correct numbering.

Item # 13 **Page N/A**

~~(Del) **3.3.94 Dormitory.** A building or a space in a building in which group sleeping accommodations are provided for more than 16 persons who are not members of the same family in one room, or a series of closely associated rooms, under joint occupancy and single management, with or without meals, and with or without individual cooking facilities.~~

Replace with

(Amd) **3.3.94* Dormitory.** A building or a space in a building in which group sleeping accommodations are provided for more than 16 persons who are not members of the same family in one room, or a series of closely associated rooms, under joint occupancy and single management, with or without meals, and with or without individual cooking facilities.

Justification: Technical change for consistency with the model code, which includes the definition of the term “dormitory” twice in Chapter 3, Definitions.

Item #14 **Page 22 of 55**

~~(Amd) **3.3.138.10* Educational Occupancy.** An occupancy used for educational purposes through grade 12 by 6 or more persons for 4 or more hours per day or more than 12 hours per week. Training and skill development not within a school or academic program shall be classified as business occupancies.~~

Replace with

(Amd) **3.3.182.10* Educational Occupancy.** An occupancy used for educational purposes through grade 12 by 6 or more persons for 4 or more hours per day or more than 12 hours per week. Training and skill development not within a school or academic program shall be classified as business occupancies.

Justification: Technical change to correct numbering.

Item #15 **Page 22 of 55**

~~(Add) **3.3.138.23.1 Bed and Breakfast or Bed and Breakfast Establishment.** A building:~~

- ~~(1) That provides sleeping accommodations to the public for a fee for no more than 16 persons with guest rooms limited to the first or second floor of the structure,~~
- ~~(2) Where the owner occupies the facility or an adjacent property as his or her primary place of residence,~~
- ~~(3) Where cooking or food warming of any type is not allowed in guest rooms, and~~
- ~~(4) That has a maximum of three stories in height and does not contain a mixed occupancy.~~

Replace with

(Add) **3.3.182.26.1 Bed and Breakfast or Bed and Breakfast Establishment.** A building:

- (1) That provides sleeping accommodations to the public for a fee for no more than 16 persons with guest rooms limited to the first or second floor of the structure,
- (2) Where the owner occupies the facility or an adjacent property as his or her primary place of residence,
- (3) Where cooking or food warming of any type is not allowed in guest rooms, and
- (4) That has a maximum of three stories in height and does not contain a mixed occupancy.

Justification: Technical change to correct numbering.

Item #16 **Page 22 of 55**

~~Chapters 6 ~ 9~~

~~Reserved~~

Replace with

(Del) **6.1 Classification of Occupancy.** Delete section.

(Add) **6.1 Classification of Occupancy.** The Classification of occupancies and the designations for such shall be the same as found the CSFSC.

Chapters 7 ~ 9

Reserved

Justification: Chapter 6 in the model document was not a reserved chapter. Chapters 7 to 9 remain reserved chapters as found in the model document.

Item #17 **Page 29 of 55**

~~(Amd) **13.6.1.2* Where Required.** Fire extinguishers shall be provided pursuant to sections 13.6.1.2.1 to 13.6.1.2.6, inclusive, of this code:~~

- ~~(1) Where required by other parts of this code.~~
- ~~(2) As specified in sections 13.6.1.2.1 to 13.6.1.2.6, inclusive, of this code.~~
- ~~(3) Where required by the referenced codes and standards listed in Chapter 2 and Part II of the CSFSC.~~

Replace with

(Amd) **13.6.2* Where Required.** Fire extinguishers shall be provided pursuant to sections 13.6.2.1 to 13.6.2.6, inclusive, of this code:

- (1) Where required by other parts of this code.
- (2) As specified in sections 13.6.2.1 to 13.6.2.6, inclusive, of this code.
- (3) Where required by the referenced codes and standards listed in Chapter 2 and Part II of the CSFSC.

Justification: Technical change to correct numbering.

Item #18 **Page 29 of 55**

~~(Add) **13.6.1.2.1** Portable fire extinguishers shall be required in all occupancies, except storage Use Groups S-1 and S-2, outside and immediately adjacent to the entrance to all special hazardous areas except general storage areas. If the only entrance to a special hazardous area is from the exterior of the building, the fire extinguisher may be located just inside the entrance door.~~

Replace with

(Add) **13.6.2.1** Portable fire extinguishers shall be required in all occupancies, except storage Use Groups S-1 and S-2, outside and immediately adjacent to the entrance to all special hazardous areas except general storage areas. If the only entrance to a special hazardous area is from the exterior of the building, the fire extinguisher may be located just inside the entrance door.

Justification: Technical change to correct numbering.

Item #19 **Page 29 of 55**

~~(Add) **13.6.1.2.2** Portable fire extinguishers shall be required throughout health care occupancies, including Use Groups I-1 and I-2 occupancies.~~

Replace with

(Add) **13.6.2.2** Portable fire extinguishers shall be required throughout health care occupancies, including Use Groups I-1 and I-2 occupancies.

Justification: Technical change to correct numbering.

Item #20 **Page 29 of 55**

~~(Add) **13.6.1.2.3** Portable fire extinguishers shall be required throughout ambulatory health care occupancies, including Use Group B medical occupancies.~~

Replace with

(Add) **13.6.2.3** Portable fire extinguishers shall be required throughout ambulatory health care occupancies, including Use Group B medical occupancies.

Justification: Technical change to correct numbering.

Item #21 **Page 29 of 55**

~~(Add) **13.6.1.2.4** Portable fire extinguishers shall be required in staff locations within detention and correctional occupancies, including Use Group I-3 occupancies. Access to portable fire extinguishers may be locked.~~

Replace with

(Add) **13.6. 2.4** Portable fire extinguishers shall be required in staff locations within detention and correctional occupancies, including Use Group I-3 occupancies. Access to portable fire extinguishers may be locked.

Justification: Technical change to correct numbering.

Item #22 **Page 29 of 55**

~~(Add) 13.6.1.2.5 Portable fire extinguishers shall be required in Group R-1 bed and breakfast establishments as required by the CSFSC.~~

Replace with

(Add) **13.6.2.5** Portable fire extinguishers shall be required in Group R-1 bed and breakfast establishments as required by the CSFSC.

Justification: Technical change to correct numbering.

Item #23 **Page 30 of 55**

~~(Add) 13.6.1.2.6 Portable fire extinguishers shall be required where commercial cooking equipment is utilized.~~

Replace with

(Add) **13.6.2.6** Portable fire extinguishers shall be required where commercial cooking equipment is utilized.

Justification: Technical change to correct numbering.

Item #24 **Page 31 of 55**

~~(Amd) 13.7.2.13 Lodging and Rooming Houses and Bed and Breakfasts~~

Replace with

(Amd) **13.7.2.13 Lodging and Rooming Houses and Bed and Breakfasts.** Lodging and rooming houses, other than those meeting section 13.7.2.13.1 of this code, shall be provided with a fire alarm system in accordance with section 13.7 of this code and the CSFSC.

Justification: The text of the section was inadvertently deleted.

Item #25 **Page 31 of 55**

Insert

(Del) 13.7.2.14 One and Two Family Dwellings

Justification: Technical correction to clarify that this section is unnecessary as Section 29-291a-1a(d) exempts one- and two-family dwellings from the requirements of this code.

Item #26 **Page 42 of 55**

~~(Del) 20.7.3.6 New Interior Finish. Delete section.~~

Replace with

(Del) **20.7.3.6 Interior Finish (New Nonsprinklered Buildings)**. Delete section.

Justification: Technical change to reflect actual language in the model document.

Item #27 **Page 47 of 55**

(Del) **Chapter 25 Manufactured Home and Recreational Vehicle Sites**. Delete chapter.

Replace with

(Del) **Chapter 27 Manufactured Home and Recreational Vehicle Sites**. Delete chapter.

Justification: Technical change to correct numbering.

Item #28 **Page 48 of 55**

(Add) **30.2.1 Application**. The construction and protection of, as well as the control of hazards in, garages used for major repair and maintenance of motorized vehicles and any sales and servicing facilities associated therewith shall comply with the provisions of the CSFSC, SBC, sections 30.2 and 30.3 of this code and NFPA 30A, *Code for Motor Fuel Dispensing Facilities and Repair Garages*.

Replace with

(Amd) **30.2.1 Application**. The construction and protection of, as well as the control of hazards in, garages used for major repair and maintenance of motorized vehicles and any sales and servicing facilities associated therewith shall comply with the provisions of the CSFSC, SBC, sections 30.2 and 30.3 of this code and NFPA 30A, *Code for Motor Fuel Dispensing Facilities and Repair Garages*.

Justification: Technical change to indicate that the section was an (Amd) NOT an (Add).

Item #29 **Page 50 of 55**

(Amd) **50.2.1.6** All solid fuel cooking appliances shall be maintained as required in NFPA 96 *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations*, and in sections 14.8 and 14.9 of this code.

Replace With

(Amd) **50.2.1.6** All solid fuel cooking appliances shall be maintained as required in Section 14.8 Procedures for Inspection, Cleaning, and Maintenance for Solid Fuel Cooking, and Section 14.9 Minimum Safety Requirements: Fuel Storage, Handling, and Ash Removal for Solid Fuel Cooking, of NFPA 96, *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operation*.

Justification: Technical change to clarify that the referenced sections are of NFPA 96, not of this code.

Item #30 **Page 53 of 55**

(Add) ~~69.4.1.2~~ Cylinders, tanks or containers shall be filled, evacuated or transported only by the owner of the cylinder, tank or container or upon the owner's authorization.

Replace with

(Add) **69.4.1.3** Cylinders, tanks or containers shall be filled, evacuated or transported only by the owner of the cylinder, tank or container or upon the owner's authorization.

Justification: Technical change to correct numbering.

FINAL DRAFT