

### Range Quarterly Airflow Check:

[illegible]

Expected rate 50-75 ft/min

If result is outside of the acceptable range inform the Deputy Director.