

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0055013	MALLORY BROOK PLAZA - WELL #1			NC	36	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
380 NEW HARTFORD ROAD (ROUTE 44)					4			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
<u>Sampling Point (Sampling Point ID)</u>	<u>Monitoring Period</u>	<u>Collection Period</u>	<u>Compliance Status</u>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
<u>Sampling Point (Sampling Point ID)</u>	<u>Monitoring Period</u>	<u>Collection Period</u>	<u>Compliance Status</u>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<u>Sampling Point (Sampling Point ID)</u>	<u>Monitoring Period</u>	<u>Collection Period</u>	<u>Compliance Status</u>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Other Compliance Schedules

<u>Compliance Schedule Activity</u>	<u>Due Date</u>	<u>Achieved Date</u>
CROSS CONNECTION SURVEY REPORT	3/1/2017	
RESPOND TO SANITARY SURVEY	6/7/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
CROSS CONNECTION SURVEY REPORT	3/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2022	
CROSS CONNECTION SURVEY REPORT	3/1/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
RESPOND TO SANITARY SURVEY	10/12/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Public Notification Requirements

<u>Violation/Situation</u>	<u>Compliance Period</u>	<u>Notice Tier</u>	<u>Public Notification</u>		<u>PN Certification</u>	
			<u>Required</u>	<u>Performed</u>	<u>Due to DPH</u>	<u>Received</u>
Nitrate And Nitrite M&R Violation	1/1/21 - 12/31/21	3	2/17/2023		2/27/2023	
Total Coliform M&R Violation	1/1/22 - 3/31/22	3	5/10/2023		5/20/2023	

Water System Facility and Sampling Point Inventory

<u>Water System Facility ID</u>	<u>Water System Facility</u>	<u>Sampling Point ID</u>	<u>Sampling Point Description</u>	<u>Status</u>	<u>Total Coliform Rule</u>	<u>Lead and Copper Rule Tier</u>	<u>Asbestos</u>	<u>Stage WQP 2 DBPR</u>
---------------------------------	------------------------------	--------------------------	-----------------------------------	---------------	----------------------------	----------------------------------	-----------------	-------------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0055013	MALLORY BROOK PLAZA - WELL #1			NC	36	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
380 NEW HARTFORD ROAD (ROUTE 44)					4			
Towns Served: BARKHAMSTED								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
23090	WELL #1	2	WELL #1	A				

Contact Information

Name				Organization		Job Title			
Mr. John A Senese				Mallory Brook Plaza LLC					
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
321 Main St.						Farmington		CT	06032
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-982-6968						860-582-2403	jsenese@calcoconstructioninc.com		
Contact Role(s): Administrative Contact, Legal Contact, Owner									

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050014	AMERICAN LEGION SF / AUSTIN F. HAWES			NC	42	S	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
106 EAST RIVER ROAD				7				
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Physical Parameters (PPS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	101	KITCHEN SINK	A	Y			
		102	BATHROOM SINK	A	Y			
		103	EXTERIOR FAUCET	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20108	WELL	2	WELL	A				

Contact Information

Name				Organization				Job Title		
State of CT Dept of Revenue Services										
Mailing Address Line One			Mailing Address Line Two				City		State	Zip Code
106 East River Rd							Barkhamsted		CT	06063
Business Phone		Extension	Fax		Mobile Phone		Emergency Phone	Email Address		

Contact Role(s): **Owner**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0050014	AMERICAN LEGION SF / AUSTIN F. HAWES	NC	42	S	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
106 EAST RIVER ROAD		7			
Towns Served: BARKHAMSTED					
Name		Organization		Job Title	
Mr. David Cooley		Deep-Engineering Unit		Supv Civil Engineer	
Mailing Address Line One		Mailing Address Line Two		City	State
163 Great Hill Road				Portland	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-424-4120		860-344-2560	860-205-7552	860-424-3333	david.cooley@ct.gov
Contact Role(s): Legal Contact, Owner					
Name		Organization		Job Title	
Ms. Andrea M. Lane		State of CT Deep			
Mailing Address Line One		Mailing Address Line Two		City	State
163 Great Hill Road				Portland	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-977-9739				860-424-3333	andrea.lane@ct.gov
Contact Role(s): Administrative Contact					
Please note the following: <ol style="list-style-type: none"> 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample. 2. If a Collection Period is specified, all water quality samples must be collected during the specified period. 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule. 					

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050024	BRASS HORSE CAFE & MOTEL			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
87 NEW HARTFORD ROAD					1			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Physical Parameters M&R Violation	9/1/22 - 9/30/22	3	12/13/2023		12/23/2023	
Total Coliform M&R Violation	9/1/22 - 9/30/22	3	12/13/2023		12/23/2023	
Physical Parameters M&R Violation	6/1/22 - 6/30/22	3	12/13/2023		12/23/2023	
Total Coliform M&R Violation	6/1/22 - 6/30/22	3	12/13/2023		12/23/2023	
Physical Parameters M&R Violation	10/1/22 - 10/31/22	3	12/20/2023		12/30/2023	
Total Coliform M&R Violation	10/1/22 - 10/31/22	3	5/9/2024		5/19/2024	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20109	WELL	2	WELL	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050024	BRASS HORSE CAFE & MOTEL			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
87 NEW HARTFORD ROAD					1			
Towns Served: BARKHAMSTED								

Contact Information

Name				Organization			Job Title		
Ms. Kim Hamel				Brass Horse Cafe, LLC			President		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
87 New Hartford Road						Barkhamsted		CT	06063
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-738-2017					860-689-4088	anewdayct@aol.com			
Contact Role(s): Administrative Contact, Legal Contact, Owner									

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050044	LOG HOUSE RESTAURANT INC.			NC	25	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
110 NEW HARTFORD ROAD			Connections				4	
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20111	WELL	2	WELL	A				

Contact Information

Name				Organization			Job Title		
Mr. Gary Dileo									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
110 New Hartford Road						Winsted		CT	06098
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-379-8937						logrestaurant@sbcglobal.net			
Contact Role(s): Administrative Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0050044	LOG HOUSE RESTAURANT INC.	NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
110 NEW HARTFORD ROAD					4
Towns Served: BARKHAMSTED					
Name		Organization		Job Title	
Mr. Joseph Dileo		Log House Restuarant Inc		Property Owner	
Mailing Address Line One		Mailing Address Line Two		City	State
110 New Hartford Rd				Barkhamsted	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address

Contact Role(s): **Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050064	OLD RIVERTON INN			NC	25	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
436 EAST RIVER ROAD			Connections		1			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	101	KITCHEN 3-BAY SINK	A	Y			
		102	KITCHEN HAND SINK	A	Y			
		103	LOBBY WOMENS BATH	A	Y			
		104	LOBBY MENS ROOM	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
20113	WELL	2	WELL	A				

Contact Information

Name				Organization			Job Title		
Mrs. Sherice Levan-Bennett				Riverton Inn & Tavern, LLC.					
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
38 Center Street						West Hartland		CT	06091
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-379-8678					860-798-4733	oldrivertoninn06065@gmail.com			
Contact Role(s): Administrative Contact, Legal Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050064	OLD RIVERTON INN			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
436 EAST RIVER ROAD					1			
Towns Served: BARKHAMSTED								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050074	VILLAGE OF BOULDER RIDGE- WELL #1			NC	25	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
104 GOOSE GREEN ROAD			Connections		5			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		

Physical Parameters (PPS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25	5/1-6/30	Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25	10/1-10/31	

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2027	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	001	POOLSIDE FEMALE ROOM	A	Y			
		002	POOLSIDE MALE ROOM	A	Y			
		003	KITCHEN HANDWASH SIN	A	Y			
		004	KITCHEN 3 BAY SINK	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20114	WELL #1	2	WELL #1	A				

Contact Information

Name				Organization			Job Title		
Ms. Kristin Ebner-Martin				Ebner Camps, Inc.			Owner		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
326 West Street						Morris		CT	06763
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-626-8300						860-307-4043	kris@ebnercamps.com		
Contact Role(s):	Legal Contact, Owner								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0050074	VILLAGE OF BOULDER RIDGE- WELL #1	NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
104 GOOSE GREEN ROAD			5		
Towns Served: BARKHAMSTED					
Name		Organization		Job Title	
Mr. Darren Ley		Ebner Camps, Inc.		Facilities Director	
Mailing Address Line One		Mailing Address Line Two		City	State
326 West Street				Morris	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-626-8300					darren@ebnercamps.com
Contact Role(s): Administrative Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050104	PEOPLES S.F./MAIN PICNIC AREA			NC	26	S	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
EAST RIVER ROAD				4				
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	101	MENS BATHROOM	A	Y			
		102	WOMENS BATHROOM	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20117	WELL	2	WELL	A				

Contact Information

Name				Organization			Job Title			
Mr. David Cooley				Deep-Engineering Unit			Supv Civil Engineer			
Mailing Address Line One			Mailing Address Line Two				City		State	Zip Code
163 Great Hill Road							Portland		CT	06480
Business Phone		Extension	Fax		Mobile Phone		Emergency Phone		Email Address	
860-424-4120			860-344-2560		860-205-7552		860-424-3333		david.cooley@ct.gov	
Contact Role(s):		Legal Contact, Owner								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0050104	PEOPLES S.F./MAIN PICNIC AREA	NC	26	S	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
EAST RIVER ROAD		4			
Towns Served: BARKHAMSTED					
Name		Organization		Job Title	
Ms. Andrea M. Lane		State of CT Deep			
Mailing Address Line One		Mailing Address Line Two		City	State
163 Great Hill Road				Portland	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-977-9739				860-424-3333	andrea.lane@ct.gov
Contact Role(s): Administrative Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050124	PLEASANT VALLEY GENERAL STORE			NC	28	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
111 RIVER ROAD					1			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
20119	WELL	2	WELL	A				

Contact Information

Name				Organization			Job Title		
Mr. Frank O'neill				Motomo, LLC					
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
PO Box 171						Pleasant Valley		CT	06063
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-402-3064							cavecreekfrank@gmail.com		
Contact Role(s):		Legal Contact, Owner							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0050124	PLEASANT VALLEY GENERAL STORE	NC	28	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
111 RIVER ROAD				1	
Towns Served: BARKHAMSTED					
Name		Organization		Job Title	
Mr. Anthony F. O'Neill		Pleasant Valley General Store		Legal Contact	
Mailing Address Line One		Mailing Address Line Two		City	State
111 River Rd.				Barkhamsted	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-307-7885				860-307-7885	yetanotheraoneill@yahoo.com
Contact Role(s): Administrative Contact, Legal Contact, Owner					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050134	PLEASANT VALLEY UNITED METHODIST CHURCH			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
93 RIVER ROAD					2			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20120	WELL	2	WELL	A				

Contact Information

Name			Organization			Job Title		
Mr. Eugene R. Deroode			Pleasant Valley U. M. Church			Trustees Chairman		
Mailing Address Line One		Mailing Address Line Two			City		State	Zip Code
93 River Road		P. O. Box 181			Pleasant Valley		CT	06063
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-298-2786		860-298-2927	860-978-0957	860-379-3539	eugene.deroode@cigna.com			

Contact Role(s): **Legal Contact, Owner**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0050134	PLEASANT VALLEY UNITED METHODIST CHURCH	NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
93 RIVER ROAD			2		
Towns Served: BARKHAMSTED					
Name		Organization		Job Title	
Ms. Re Santucci		Pleasant Valley Um Church		Admin. Assistant	
Mailing Address Line One		Mailing Address Line Two		City	State
93 River Road		P.O. Box 181		Pleasant Valley	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-379-2157					pvmc@gmail.com
Contact Role(s): Administrative Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050144	RIVERTON GENERAL STORE			NC	25	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
2 MAIN STREET			Connections				1	
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20121	WELL	2	WELL	A				

Contact Information

Name				Organization			Job Title		
Ms. Leslie Dimartino				Lad Real Estate LLC			Member		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 48			2 Main Street			Riverton		CT	06065
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-379-0811						rgslad2004@gmail.com			
Contact Role(s): Administrative Contact, Legal Contact, Owner									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050144	RIVERTON GENERAL STORE			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
2 MAIN STREET							1	
Towns Served: BARKHAMSTED								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050224	WHITE PINES CAMPSITE			NC	100	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
232 OLD NORTH ROAD					1			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	4/1/26 - 4/30/26		

Physical Parameters (PPS)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	4/1/26 - 4/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTEAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22580	WELL #1	2	WELL	A				

Contact Information

Name				Organization			Job Title		
Mr. Brandon Riley				White Pines Campsites			Facilities Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
232 Old North Rd						Barkhamsted		CT	06063
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860.806.2756							briley@wps@gmail.com		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0050224	WHITE PINES CAMPSITE	NC	100	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
232 OLD NORTH ROAD			1		
Towns Served: BARKHAMSTED					
860-866-5750					
Contact Role(s): Administrative Contact					
Name		Organization		Job Title	
Mr. Carl Venezia		232 Old North, LLC.		Manager	
Mailing Address Line One		Mailing Address Line Two		City	State
15 Main Street		Suite 223		Watertown	MA
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
617-213-0664					archeracq@gmail.com
Contact Role(s): Legal Contact, Owner					
Please note the following: <ol style="list-style-type: none"> 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample. 2. If a Collection Period is specified, all water quality samples must be collected during the specified period. 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule. 					

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0055063	MALLORY BROOK PLAZA - WELL #2			NC	33	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
NEW HARTFORD ROAD (ROUTE 44)					8			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2017	
CROSS CONNECTION SURVEY REPORT	3/1/2018	
CROSS CONNECTION SURVEY REPORT	3/1/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
CROSS CONNECTION SURVEY REPORT	3/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2022	
CROSS CONNECTION SURVEY REPORT	3/1/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
RESPOND TO SANITARY SURVEY	10/12/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Nitrate And Nitrite M&R Violation	1/1/21 - 12/31/21	3	2/17/2023		2/27/2023	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
--------------------------	-----------------------	-------------------	----------------------------	--------	---------------------	---------------------------	----------	------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0055063	MALLORY BROOK PLAZA - WELL #2			NC	33	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
NEW HARTFORD ROAD (ROUTE 44)			Connections		8			
Towns Served: BARKHAMSTED								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
23091	MALLORY BROOK PLAZA - WELL #2	2	MALLORY BROOK PLAZA	A				

Contact Information

Name		Organization		Job Title		
Mr. John A Senese		Mallory Brook Plaza LLC				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
321 Main St.				Farmington	CT	06032
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-982-6968				860-582-2403	jsenese@calcoconstructioninc.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050234	MDC - LAKE MCDONOUGH - EAST BEACH			NC	25	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 219					2			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Out of Service
	7/1/25 - 9/30/25		Out of Service

Physical Parameters (PPS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Out of Service
	7/1/25 - 9/30/25		Out of Service

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24	4/1-9/30	Out of Service
	1/1/25 - 12/31/25	4/1-9/30	Out of Service
	1/1/26 - 12/31/26	4/1-9/30	

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2030	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		E_BEACH	FOUNTAIN	A	Y			
		EAST BEACH	FOUNTAIN	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
55167	EAST BEACH WELL	2	EAST BEACH WELL	A				

Contact Information

Name				Organization			Job Title			
Mr. Raymond E. Baral, Jr							Assistant Manager			
Mailing Address Line One			Mailing Address Line Two				City		State	Zip Code
1420 Farmington Ave							West Hartford		CT	06107
Business Phone		Extension	Fax		Mobile Phone		Emergency Phone	Email Address		
860-278-7850		3924					860-985-6893	rbaral@themdc.com		
Contact Role(s): Administrative Contact										

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0050234	MDC - LAKE MCDONOUGH - EAST BEACH	NC	25	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
ROUTE 219			2		
Towns Served: BARKHAMSTED					
Name		Organization		Job Title	
Mr. Christopher R. Stone		The Metropolitan District		Asst. Dist Council	
Mailing Address Line One		Mailing Address Line Two		City	State
555 Main St.		PO Box 800		Hartford	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-278-7850	3231			860-214-0503	cstone@themdc.com
Contact Role(s): Legal Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0050254	VILLAGE OF BOULDER RIDGE- WELL #2			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
104 GOOSE GREEN ROAD				2				
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Physical Parameters (PPS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Nitrite (1041) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	001	TAP RT OF BILCO	A	Y			
		002	COUNSELOR BATH F	A	Y			
		003	COUNSELOR BATH M	A	Y			
		4	DISTRIBUTION SYSTEM	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
56755	WELL #2	2	WELL #2	A				

Contact Information

Name				Organization			Job Title		
Ms. Kristin Ebner-Martin				Ebner Camps, Inc.			Owner		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
326 West Street						Morris		CT	06763
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-626-8300						860-307-4043	kris@ebnercamps.com		
Contact Role(s):		Owner							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0050254	VILLAGE OF BOULDER RIDGE- WELL #2	NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
104 GOOSE GREEN ROAD		2			
Towns Served: BARKHAMSTED					
Name		Organization		Job Title	
Mr. Darren Ley		Ebner Camps, Inc.		Facilities Director	
Mailing Address Line One		Mailing Address Line Two		City	State
326 West Street				Morris	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-626-8300					darren@ebnercamps.com
Contact Role(s): Administrative Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0055074	DOLLAR GENERAL BARKHAMSTED			NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
390 NEW HARTFORD RD				1			
Towns Served: BARKHAMSTED							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
61849	WELL 1	2	WELL 1	A				

Contact Information

Name	Organization			Job Title		
Mr. Gary Eucalitto						
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code
PO Box 748				Torrington	CT	06790
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-307-5479					eucalittogary@gmail.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0055084	2 SCHOOL ST	NC	28	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
2 SCHOOL ST			1				
Towns Served: BARKHAMSTED							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)

1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SAMPLING SITE PLAN	5/31/2024	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Physical Parameters M&R Violation	10/1/24 - 12/31/24	3	2/13/2026		2/23/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNSTREAM WITHIN 5 SERVICE CON	A	Y			
			UPSTREAM WITHIN 5 SERVICE CON	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
62990	WELL 1	2	WELL 1	A				

Contact Information

Name	Organization	Job Title
Mr. Thomas Keane	Riverton Self Storage, LLC	
Mailing Address Line One	Mailing Address Line Two	City
175 Portland Street	Floor 4	Boston
		State
		Zip Code
		MA
		02114

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 10/3/2025

Page 30

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0055084	2 SCHOOL ST	NC	28	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
2 SCHOOL ST			1		
Towns Served: BARKHAMSTED					
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
617-892-4942				617-892-4942	storage@churchilljames.com
Contact Role(s): Administrative Contact, Legal Contact					
<p>Please note the following:</p> <ol style="list-style-type: none"> 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample. 2. If a Collection Period is specified, all water quality samples must be collected during the specified period. 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule. 					

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0055094	BARKHAMSTED YOUTH BASEBALL LEAGUE			NC	30	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
366 WEST RIVER RD					1			
Towns Served: BARKHAMSTED								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SAMPLING SITE PLAN	6/6/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
62996	WELL 1	2	WELL 1	A				

Contact Information

Name				Organization		Job Title			
Mr. Marc Pericolosi									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P. O. Box 210						Pleasant Valley		CT	06063
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-216-8161					860-216-8161	dozerboy2006@gmail.com			
Contact Role(s):		Administrative Contact, Legal Contact							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0055094	BARKHAMSTED YOUTH BASEBALL LEAGUE			NC	30	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
366 WEST RIVER RD				1			
Towns Served: BARKHAMSTED							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule