

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180021	AQUARION-BUTTERNUT			C	124	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			31				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Coliform (3100)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
8 KNOLLCREST DR SS (01906)	1/1/24 - 12/31/24	8/10-8/16	Complete
	1/1/25 - 12/31/25	8/10-8/16	Complete
	1/1/26 - 12/31/26	8/10-8/16	
Lead And Copper (PBCU)		5 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180021	AQUARION-BUTTERNUT			C	124	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				31				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: **WELL 1 (WSF ID: 579)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **WELL 3 (WSF ID: 580)**

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180021	AQUARION-BUTTERNUT			C	124	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				31				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: WELL 3 (WSF ID: 580)

E. Coli (3014)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 3 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 2 (WSF ID: 643)

E. Coli (3014)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 4 (WSF ID: 644)

E. Coli (3014)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 4 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2012		Compliance History:	Monitoring
		Monitoring Period	Compliance Status:
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	
		7/1/2025 - 7/31/2025	
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	01906	8 KNOLLCREST DR SS	A	Y			Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180021	AQUARION-BUTTERNUT			C	124	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			31				

Towns Served: BROOKFIELD

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		4	DISTRIBUTION SYSTEM	A	Y			
		BUTTER002	4 KNOLLCREST	A		3		
		BUTTER003	9 KNOLLCREST	A		3		
		BUTTER004	1 BLUEBERRY	A		3		
		BUTTER005	12 KNOLLCREST	A		3		
		BUTTER006	36 KNOLLCREST	A		3		
		BUTTER007	2 KNOLLCREST	A	Y	3		
		BUTTER008	6 KNOLLCREST	A	Y	3		
		BUTTER009	7 KNOLLCREST	A	Y	3		
		BUTTER010	8 KNOLLCREST	A	Y	3		
		BUTTER011	10 KNOLLCREST	A	Y	3		
		BUTTER012	11 KNOLLCREST	A	Y	3		
		BUTTER013	13 KNOLLCREST	A	Y	3		
		BUTTER014	14 KNOLLCREST	A		3		
		BUTTER015	15 KNOLLCREST	A	Y	3		
		BUTTER017	17 KNOLLCREST	A	Y	3		
		BUTTER018	20 KNOLLCREST	A	Y	3		
		BUTTER020	22 KNOLLCREST	A	Y	3		
		BUTTER022	24 KNOLLCREST	A	Y	3		
		BUTTER023	25 KNOLLCREST	A	Y	3		
		BUTTER026	30 KNOLLCREST	A	Y	3		
		BUTTER027	32 KNOLLCREST	A	Y	3		
		BUTTER028	34 KNOLLCREST	A	Y	3		
		BUTTER029	38 KNOLLCREST	A	Y	3		
		BUTTER030	40 KNOLLCREST	A	Y	3		
		BUTTER031	3 BLUEBERRY	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB6899	16 KNOLLCREST	A		3		
		PB6900	23 KNOLLCREST	A	Y	3		
		PB6901	28 KNOLLCREST	A	Y	3		
		PB6902	27 KNOLLCREST	A		3		
		PB6903	26 KNOLLCREST	A		3		
		PB6904	21 KNOLLCREST	A		3		
		PB8512	10 KNOLLCREST DR	A		3		
		PB8598	11 KNOLLCREST DR	A		3		
		PB8599	14 KNOLLCREST DR.	A		3		
		PB8600	17 KNOLLCREST DR	A		3		
		PB8601	24 KNOLLCREST DR.	A		3		
		PB8602	25 KNOLLCREST DR	A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180021	AQUARION-BUTTERNUT			C	124	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				31				

Towns Served: BROOKFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB8603	30 KNOLLCREST DR	A		3		
		PB8604	36 KNOLLCREST DR	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
49224	STORAGE TANK							
49228	PUMP HOUSE							
579	WELL 1	2	WELL 1	A				
580	WELL 3	2	WELL 3	A				
58204	BUTTERNUT TREATMENT PLANT							
643	WELL 2	2	WELL 2	A				
644	WELL 4	2	WELL 4	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
PASSECK, PETER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
LAGO, ANTHONY V.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2025
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026

Water System Facility: **BUTTERNUT TREATMENT PLANT (WSF ID: 58204)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028

Contact Information

Name				Organization			Job Title		
Mr. Robert J. Ulrich				Aquarion Water Company of Ct			Vp-Supply & Utility		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
505 Huntington St.						Shelton		CT	06484
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-926-4320			203-929-5297			203-395-3205	rulrich@aquarionwater.com		
Contact Role(s): Administrative Contact, Legal Contact, Owner									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180021	AQUARION-BUTTERNUT			C	124	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			31				

Towns Served: BROOKFIELD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180061	CANDLEWOOD SHORES TAX DISTRICT			C	1,315	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		Complete
Total Haloacetic Acids (2456)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
55 LONGVIEW DR (CSTD070)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
Total Trihalomethanes (2950)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
24 S LAKESHORE DR (CSTD053)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/30/25 - 8/4/25		Complete
Total Coliform (3100)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		10 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180061	CANDLEWOOD SHORES TAX DISTRICT			C	1,315	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		2 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180061	CANDLEWOOD SHORES TAX DISTRICT			C	1,315	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: WELL 1 (WSF ID: 1642)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		Out of Service
	7/1/25 - 7/31/25		Out of Service
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 6 (WSF ID: 1643)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 6 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 7 (WSF ID: 1644)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 7 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180061	CANDLEWOOD SHORES TAX DISTRICT			C	1,315	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Monitoring Requirements

Water System Facility: **WELL 7 (WSF ID: 1644)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **WELL 8 (WSF ID: 1645)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 8 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **WELL 9 (WSF ID: 1646)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 9 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180061	CANDLEWOOD SHORES TAX DISTRICT			C	1,315	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Monitoring Requirements

Water System Facility: WELL 9 (WSF ID: 1646)

E. Coli (3014)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 2 (WSF ID: 556)

E. Coli (3014)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2011	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180061	CANDLEWOOD SHORES TAX DISTRICT			C	1,315	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CSTD001	21 N LAKESHORE DR	A	Y			
		CSTD002	22 N LAKESHORE DR	A	Y			
		CSTD003	18 N LAKESHORE DR	A	Y			
		CSTD004	23 N LAKESHORE DR	A	Y			
		CSTD005	24 N LAKESHORE DR	A	Y			
		CSTD006	25 N LAKESHORE DR	A	Y			
		CSTD007	28 N LAKESHORE DR	A	Y			
		CSTD008	32 N LAKESHORE DR	A	Y			
		CSTD009	34 N LAKESHORE DR	A	Y			
		CSTD010	41 N LAKESHORE DR	A	Y			
		CSTD011	37 N LAKESHORE DR	A	Y			
		CSTD012	7 SKYLINE DR	A	Y			
		CSTD013	27 SKYLINE DR	A	Y			
		CSTD014	40 SKYLINE DR	A	Y			
		CSTD015	34 SKYLINE DR	A	Y			
		CSTD016	39 SKYLINE DR	A	Y			
		CSTD017	26 SKYLINE DR	A	Y			
		CSTD018	28 SKYLINE DR	A	Y			
		CSTD019	29 SKYLINE DR	A	Y			
		CSTD020	31 SKYLINE DR	A	Y			
		CSTD021	33 SKYLINE DR	A	Y			
		CSTD022	50 SKYLINE DR	A	Y			
		CSTD023	59 SKYLINE DR	A	Y			
		CSTD025	61 SKYLINE DR	A	Y		3	
		CSTD025 - 6	GENERATED BY BATCH	A	Y			
		CSTD026	100 N LAKESHORE DR	A	Y			
		CSTD027	73 N LAKESHORE DR	A	Y			
		CSTD028	89 CLEARVIEW DR	A	Y			
		CSTD029	88 N LAKESHORE DR	A	Y			
		CSTD030	89 N LAKESHORE DR	A	Y			
		CSTD031	97 N LAKESHORE DR	A	Y			
		CSTD032	99 N LAKESHORE DR	A	Y			
		CSTD033	93 CLEARVIEW DR	A	Y			
		CSTD034	95 CLEARVIEW DR	A	Y			
		CSTD035	97 CLEARVIEW DR	A	Y			
		CSTD036	87 CLEARVIEW DR	A	Y			
		CSTD037	72 N LAKESHORE DR	A	Y		3	
		CSTD037 - 7	GENERATED BY BATCH	A	Y			
		CSTD038	133 N LAKESHORE DR	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180061	CANDLEWOOD SHORES TAX DISTRICT			C	1,315	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CSTD039	135 N LAKESHORE DR	A	Y			
		CSTD040	137 N LAKESHORE DR	A	Y			
		CSTD041	139 N LAKESHORE DR	A	Y			
		CSTD042	160 N LAKESHORE DR	A	Y			
		CSTD043	153 N LAKESHORE DR	A	Y			
		CSTD044	30 TWILIGHT LA	A	Y			
		CSTD045	35 TWILIGHT LA	A	Y			
		CSTD046	24 TWILIGHT LA	A	Y			
		CSTD047	80 S LAKESHORE DR	A	Y	3		
		CSTD048	8 DOGWOOD LA	A	Y			
		CSTD049	1 DOGWOOD LA	A	Y			
		CSTD050	3 DOGWOOD LA	A	Y			
		CSTD051	5 DOGWOOD LA	A	Y			
		CSTD052	20 S LAKESHORE DR	A	Y			
		CSTD053	24 S LAKESHORE DR	A	Y			Y
		CSTD054	26 S LAKESHORE DR	A	Y			
		CSTD055	28 S LAKESHORE DR	A	Y			
		CSTD056	52 S LAKESHORE DR	A	Y			
		CSTD057	54 S LAKESHORE DR	A	Y	1		
		CSTD057 - 5	GENERATED BY BATCH	A	Y			
		CSTD058	56 S LAKESHORE DR	A	Y			
		CSTD059	58 S LAKESHORE DR	A	Y			
		CSTD060	43 S LAKESHORE DR	A	Y			
		CSTD061	57 S LAKESHORE DR	A	Y			
		CSTD062	60 S LAKESHORE DR	A	Y			
		CSTD063	73 S LAKESHORE DR	A	Y			
		CSTD064	76 S LAKESHORE DR	A	Y			
		CSTD065	68 S LAKESHORE DR	A	Y			
		CSTD066	92 S LAKESHORE DR	A	Y			
		CSTD067	74 S LAKESHORE DR	A	Y			
		CSTD068	86 S LAKESHORE DR	P	Y			
		CSTD069	FIREHOUSE/BAYVIEW DR	P	Y			
		CSTD070	55 LONGVIEW DR	A	Y	3		Y
		CSTD070 - 5	GENERATED BY BATCH	A	Y			
		CSTD071	53 LONGVIEW DR	P	Y			
		CSTD072	48 LONGVIEW DR	P	Y			
		CSTD073	38 LONGVIEW DR	P	Y			
		CSTD074	63 CANDLEWOOD SHRS	P	Y	3		
		CSTD075	2 LILAC LA	P	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180061	CANDLEWOOD SHORES TAX DISTRICT			C	1,315	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Water System Facility and Sampling Point Inventory

<i>Water System</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		CSTD076	74 KELLOGG ST	P	Y	1		
		CSTD076 - 7	GENERATED BY BATCH	A	Y			
		CSTD077	42 CANDLEWOOD SHRS	A	Y	3		
		CSTD077 - 4	GENERATED BY BATCH	A	Y			
		CSTD078	3 LILAC	A	Y	3		
		CSTD078 - 3	GENERATED BY BATCH	A	Y			
		CSTD079	67 N LAKESHORE DR	P	Y	1		
		CSTD079 - 6	GENERATED BY BATCH	A	Y			
		CSTD080	3 TWILIGHT LA	P	Y	3		
		CSTD080 - 3	GENERATED BY BATCH	A	Y			
		CSTD081	1 TWILIGHT LA	A	Y	3		
		CSTD081 - 1	GENERATED BY BATCH	A	Y			
		CSTD082	PUMP HOUSE	P	Y			
		CSTD083	STORAGE TANK #1	P	Y			
		CSTD084	STORAGE TANK #2	P	Y			
		CSTD100	17 N LAKESHORE DR	A	Y	3		
		CSTD101	154 N LAKE SHORE DRI	A	Y	1		
		CSTD102	170 N LAKE SHORE DRI	A	Y	1		
		CSTD103	172 N LAKE SHORE DRI	A	Y	1		
		CSTD104	44 LONGVIEW DRIVE	A	Y	1		
		CSTD105	3 CIPOLLA LANE	A	Y	1		
		CSTD106	22 MOUNTAINVIEW DRIV	A	Y	1		
		CSTD107	24 MOUNTAINVIEW DRIV	A	Y	1		
		CSTD108	31 LAUREL DRIVE	A	Y	1		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1642	WELL 1	2	WELL 1	A				
1643	WELL 6	2	WELL 6	A				
1644	WELL 7	2	WELL 7	A				
1645	WELL 8	2	WELL 8	A				
1646	WELL 9	2	WELL 9	A				
49190	MAIN STORAGE TANK							
49192	AUXILARY STORAGE TANK							
50933	CANDLEWOOD SHORES TREATMENT PLANT							
556	WELL 2	2	WELL 2	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180061	CANDLEWOOD SHORES TAX DISTRICT			C	1,315	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				502				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2028

Water System Facility: **CANDLEWOOD SHORES TREATMENT PLANT (WSF ID: 50933)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2028

Contact Information

Name		Organization		Job Title		
Mr. Travis Hyatt		Scalzo Property Management				
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
2 Stony Hill Road		Suite 201		Bethel	CT	06801
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-790-6888	683	203-790-9390		203-790-6888	thyatt@scalzoproperty.com	

Contact Role(s): **Administrative Contact, Legal Contact**

Name		Organization		Job Title		
Mr. Angelo Aldana		Candlewood Shores Tax District		President		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
55 Longview Dr				Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
646-263-4599					angelo.aldana.director@candlewoodshores.com	

Contact Role(s): **Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.			C	296	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET				74				
Towns Served: BROOKFIELD, NEW FAIRFIELD								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
20 CHESTER (ARRHDPT049)	1/1/24 - 12/31/24	9/1-9/30	Complete
	1/1/25 - 12/31/25	9/1-9/30	Complete
	1/1/26 - 12/31/26	9/1-9/30	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
	1/1/28 - 12/31/30	6/1-9/30	
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.			C	296	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET				74				
Towns Served: BROOKFIELD, NEW FAIRFIELD								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

Water System Facility: **ENTRY POINT - WELLS 2 & 3 (WSF ID: 00702)**

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - WELLS 2 & 3 (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

Nitrate And Nitrite (NOX)		1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - WELLS 2 & 3 (3)	4/1/25 - 6/30/25		Complete	
	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25			
	1/1/26 - 3/31/26			

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - WELLS 2 & 3 (3)	1/1/20 - 12/31/25			
	1/1/26 - 12/31/31			

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - WELLS 2 & 3 (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver	

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - WELLS 2 & 3 (3)	1/1/26 - 12/31/28			

Organic Chemicals (VOCS)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT - WELLS 2 & 3 (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

Water System Facility: **WELL 3 (WSF ID: 56426)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.			C	296	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET				74				
Towns Served: BROOKFIELD, NEW FAIRFIELD								

Monitoring Requirements

Water System Facility: **WELL 3** (WSF ID: 56426)

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
WELL 3 (2)	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

Water System Facility: **WELL 2** (WSF ID: 626)

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
WELL 2 (2)	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT - WELLS 2 & 3** (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
Start Date: 11/1/2019	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	5/1/2025 - 5/31/2025			
	6/1/2025 - 6/30/2025			
	7/1/2025 - 7/31/2025			
	8/1/2025 - 8/31/2025			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.	C	296	P	GW

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET		74				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Water System Facility: **ENTRY POINT - WELLS 2 & 3 (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 11/1/2019	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
9/1/2025 - 9/30/2025			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	SINGLE FAMILY HOME	A	Y			
		ARRHDPT001	2 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT002	3 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT003	4 ARROWHEAD ROAD	A	Y	N		
		ARRHDPT004	9 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT005	13 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT006	14 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT007	15 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT008	18 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT009	19 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT010	22 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT011	23 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT012	24 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT013	27 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT014	28 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT015	30 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT016	31 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT017	32 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT018	33 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT019	36 ARROWHEAD ROAD	A	Y	3		Y
		ARRHDPT020	37 ARROWHEAD ROAD	A	Y	N		
		ARRHDPT021	38 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT022	40 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT023	41 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT024	42 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT025	43 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT026	44 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT027	46 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT028	47 ARROWHEAD ROAD	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.			C	296	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET			74				
Towns Served: BROOKFIELD, NEW FAIRFIELD							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		ARRHDPT029	52 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT030	54 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT031	55 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT032	56 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT033	58 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT034	60 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT035	62 ARROWHEAD ROAD	A	Y	N		
		ARRHDPT036	64 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT037	68 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT038	72 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT039	74 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT040	76 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT041	78 ARROWHEAD ROAD	A	Y	3		
		ARRHDPT042	1 CHESTER	A	Y	3		
		ARRHDPT043	6 CHESTER	A	Y	3		
		ARRHDPT044	10 CHESTER	A	Y	3		
		ARRHDPT045	15 CHESTER	A	Y	3		
		ARRHDPT046	16 CHESTER	A	Y	3		
		ARRHDPT047	18 CHESTER	A	Y	3		
		ARRHDPT048	19 CHESTER	A	Y	3		
		ARRHDPT049	20 CHESTER	A	Y	3		Y
		ARRHDPT050	23 CHESTER	A	Y	3		
		ARRHDPT051	24 CHESTER	A	Y	3		
		ARRHDPT052	29 CHESTER	A	Y	3		
		ARRHDPT053	31 CHESTER	A	Y	3		
		ARRHDPT054	34 CHESTER	A	Y	3		
		ARRHDPT055	1 TAYLOR	A	Y	3		
		ARRHDPT056	7 TAYLOR	A	Y	3		
		ARRHDPT057	15 TAYLOR	A	Y	3		
		ARRHDPT058	16 TAYLOR	A	Y	3		
		ARRHDPT059	18 TAYLOR	A	Y	3		
		ARRHDPT060	22 TAYLOR	A	Y	3		
		ARRHDPT061	5 MYRON	A	Y	3		
		ARRHDPT062	6 MYRON	A	Y	3		
		ARRHDPT063	4 MORTON	A	Y	3	Y	
		ARRHDPT064	6 MORTON	A	Y	3		
		ARRHDPT065	8 MORTON	A	Y	3		
		ARRHDPT066	89 KELLOGG	A	Y	3		
		ARRHDPT067	91 KELLOGG	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.			C	296	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET			74				
Towns Served: BROOKFIELD, NEW FAIRFIELD							

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		ARRHDPT068	94 KELLOGG	A	Y	3	Y	
		ARRHDPT069	95 KELLOGG	A	Y	3		
		ARRHDPT070	96 KELLOGG	A	Y	3		
		ARRHDPT071	97 KELLOGG	A	Y	3		
		ARRHDPT072	98 KELLOGG	A	Y	3		
		ARRHDPT073	100 KELLOGG	A	Y	N		
		ARRHDPT074	102 KELLOGG	A	Y	3		
		ARRHDPT075	104 KELLOGG	A	Y	3		
		ARRHDPT076	83 KELLOGG	A	Y	3		
		ARRHDPT077	#9 CHESTER STREET	A	Y	N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00702	ENTRY POINT - WELLS 2 & 3	3	ENTRY POINT - WELLS	A				
56426	WELL 3	2	WELL 3	A				
56430	ATMOSPHERIC TANK							
56433	PUMP STATION							
61599	TREATMENT PLANT							
626	WELL 2	2	WELL 2	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2028

Water System Facility: TREATMENT PLANT (WSF ID: 61599)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2028

Contact Information

Name				Organization			Job Title		
Mr. Joe Voves				Arrowhead Point Hoa			President		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
PO Box 143						Brookfield		CT	06804
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180091	ARROWHEAD POINT HOMEOWNERS ASSN INC.			C	296	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
92 KELLOGG STREET				74				
Towns Served: BROOKFIELD, NEW FAIRFIELD								
203-733-7417					joe@diplomaframe.com			
Contact Role(s):	Administrative Contact, Legal Contact, Owner							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180101	AQUARION-HICKORY HILLS			C	132	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						38	

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HICKORY HILL SS (02936)	1/1/24 - 12/31/24	7/1-9/30	Complete
	1/1/25 - 12/31/25	7/1-9/30	Complete
	1/1/26 - 12/31/26	7/1-9/30	
Total Trihalomethanes (2950)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HICKORY HILL SS (02936)	1/1/24 - 12/31/24	7/1-9/30	Complete
	1/1/25 - 12/31/25	7/1-9/30	Complete
	1/1/26 - 12/31/26	7/1-9/30	
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Net Gross Alpha (4000)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180101	AQUARION-HICKORY HILLS			C	132	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						38	

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/31		
Uranium (4006)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		
Combined Radium-226/228 (4010)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		

Water System Facility: WELL 4 (WSF ID: 55061)

E. Coli (3014)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 4 (2)	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25		Complete		
	10/1/25 - 12/31/25				
	1/1/26 - 3/31/26				

Water System Facility: WELL 2 [UPPER] (WSF ID: 651)

E. Coli (3014)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
LOWER WELL 2 (2)	4/1/25 - 6/30/25		Complete		
	7/1/25 - 9/30/25		Complete		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180101	AQUARION-HICKORY HILLS			C	132	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						38	

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: WELL 2 [UPPER] (WSF ID: 651)

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 3 (WSF ID: 652)

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 3 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 11/1/2019	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/21/2025
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	02936	HICKORY HILL SS	A	Y		Y	Y
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		HICKORY001	21 HICKORY HILL RD	A	Y	3		
		HICKORY002	14 HICKORY HILL RD	A	Y	3	Y	
		HICKORY003	22 HICKORY HILL RD	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180101	AQUARION-HICKORY HILLS			C	132	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							38	

Towns Served: BROOKFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		HICKORY004	26 LAUREL DR	A	Y	3		
		HICKORY005	37 LAUREL DR	A	Y	3		
		HICKORY006	9 LAUREL DR	A	Y	3		
		HICKORY007	15 HICKORY HILL RD	A	Y	3		
		HICKORY008	9 HICKORY HILL RD	A	Y	3		
		HICKORY009	17 HICKORY HILL RD	A	Y	3		
		PB8626	4 HICKORY HILL RD	A		3		
		PB8627	7 HICKORY HILL RD	A		3		
		PB8628	14 HICKORY HILL ROAD	A		3		
		PB8629	21 HICKORY HILL RD	A		3		
		PB8630	31 HICKORY HILL RD	A		3		
		PB8631	6 LAUREL DR	A		3		
		PB8632	10 LAUREL DR	A		3		
		PB8633	21 LAUREL DR	A		3		
		PB8634	28 LAUREL DR	A		3		
		PB8635	33 LAUREL DR	A		3		
		PB8637	20 HICKORY HILL RD	A		3		
		PB8720	9 HICKORY HILL RD	A	Y	3		
		PB8721	22 HICKORY HILL RD	A	Y	3		
		PB8722	33 HICKORY HILL RD	A	Y	3		
		PB8723	11 LAUREL DR	A	Y	3		
		PB8724	26 LAUREL DR	A	Y	3		
		PB8725	37 LAUREL DR	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
37275	HYDROPNEUMATIC TANK #2							
37276	ATMOSPHERIC TANK #1							
37278	ATMOSPHERIC TANK #2							
55061	WELL 4	2	WELL 4	A				
61603	TREATMENT PLANT							
651	WELL 2 [UPPER]	2	LOWER WELL 2	A				
652	WELL 3	2	WELL 3	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
HORN, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180101	AQUARION-HICKORY HILLS			C	132	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						38	

Towns Served: BROOKFIELD

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 61603)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028 6/30/2028
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2025 6/30/2027
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026 9/30/2026 9/30/2026

Contact Information

Name				Organization		Job Title		
Mr. Robert J. Ulrich				Aquarion Water Company of Ct		Vp-Supply & Utility		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
505 Huntington St.						Shelton	CT	06484
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address	
203-926-4320			203-929-5297			203-395-3205	rulrich@aquarionwater.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180131	AQUARION-INDIAN FIELDS			C	147	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS				56				
Towns Served: BROOKFIELD								

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
29 ARAPAHO DRIVE (04810)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180131	AQUARION-INDIAN FIELDS			C	147	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS			56				
Towns Served: BROOKFIELD							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

Uranium (4006)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

Combined Radium-226/228 (4010)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			

Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			

Organic Chemicals (VOCS)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180131	AQUARION-INDIAN FIELDS			C	147	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS				56				
Towns Served: BROOKFIELD								

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: WELL 1 (WSF ID: 661)

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 2 (WSF ID: 662)

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 3 (WSF ID: 663)

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 5 (WSF ID: 675)

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	4/1/25 - 6/30/25		Out of Service
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 6 (WSF ID: 676)

E. Coli (3014)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 6 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0180131	AQUARION-INDIAN FIELDS	C	147	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
INDIAN FIELDS		56			
Towns Served: BROOKFIELD					

Monitoring Requirements

Water System Facility: WELL 6 (WSF ID: 676)

E. Coli (3014)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 3/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2005	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
RESPOND TO SANITARY SURVEY	5/14/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/21/2025
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04810	29 ARAPAHO DRIVE	A	Y			Y
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB7485	13 APACHE DRIVE	A		3		
		PB7486	834 OBTUSE ROAD SOUT	A	Y	3		
		PB7487	17 CHEROKEE DRIVE	A	Y	3		
		PB7488	44 ARAPAHO ROAD	A	Y	3		
		PB7489	51 ARAPAHO ROAD	A	Y	3		
		PB7490	14 CHEROKEE DRIVE	A	Y	3		
		PB8483	4 NAVAHO DRIVE	A		3		
		PB8484	5 APACHE DR	A		1		
		PB8485	6 APACHE DR	A		1		
		PB8486	11 APACHE DR	A		1		
		PB8487	12 CHEROKEE DR	A		1		

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180131	AQUARION-INDIAN FIELDS			C	147	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS				56				
Towns Served: BROOKFIELD								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB8488	36 ARAPAHO ROAD	A		1		
		PB8489	42 ARAPAHO RD	A		1		
		PB8956	8 APACHE DRIVE	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
37026	ATMOSPHERIC TANK 1							
37028	HYDROPNEUMATIC TANK							
54357	ATMOSPHERIC TANK 2							
60164	BOOSTER PUMP STATION							
661	WELL 1	2	WELL 1	A				
662	WELL 2	2	WELL 2	A				
663	WELL 3	2	WELL 3	A				
675	WELL 5	2	WELL 5	A				
676	WELL 6	2	WELL 6	A				
880	INDIAN FIELDS TREATMENT PLANT							

Certified Operator Information

Water System Facility: INDIAN FIELDS TREATMENT PLANT (WSF ID: 880)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAGO, ANTHONY V.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028 6/30/2028
PASSECK, PETER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
COYLE, BRIAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2025 6/30/2027
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026 9/30/2026 9/30/2026

Contact Information

Name				Organization			Job Title		
Mr. Robert J. Ulrich				Aquarion Water Company of Ct			Vp-Supply & Utility		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
505 Huntington St.						Shelton		CT	06484
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-926-4320			203-929-5297			203-395-3205	rulrich@aquarionwater.com		
Contact Role(s): Administrative Contact, Legal Contact, Owner									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180131	AQUARION-INDIAN FIELDS			C	147	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
INDIAN FIELDS			56				
Towns Served: BROOKFIELD							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180171	BROOKFIELD HILLS CONDOMINIUM UNIT OWNERS			C	144	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				36				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	6/20/25 - 6/25/25		Complete
	7/25/25 - 7/30/25		Complete
	8/20/25 - 8/25/25		Complete
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180171	BROOKFIELD HILLS CONDOMINIUM UNIT OWNERS			C	144	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				36				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Water System Facility: WELL 2 (WSF ID: 639)			
E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	6/19/25 - 6/25/25		Complete
	7/24/25 - 7/30/25		Complete
	8/19/25 - 8/25/25		Complete
Water System Facility: WELL 1 (WSF ID: 640)			
E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	6/19/25 - 6/25/25		Complete
	7/24/25 - 7/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180171	BROOKFIELD HILLS CONDOMINIUM UNIT OWNERS			C	144	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				36				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: WELL 1 (WSF ID: 640)

E. Coli (3014)	1 triggered (TG) per period		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	8/19/25 - 8/25/25		Complete

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
SANITARY DEFECT CORRECTIVE ACTION	7/27/2025	
SANITARY DEFECT CORRECTIVE ACTION	9/1/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-1	UNIT 1	A	Y	3		
		4-10	UNIT 10	A	Y	3		
		4-11	UNIT 11	A	Y	3		
		4-13	UNIT 13	A	Y	3	Y	
		4-14	UNIT 14	A	Y	3		
		4-15	UNIT 15	A	Y	3		
		4-16	UNIT 16	A	Y	3		
		4-17	UNIT 17	A	Y	3		
		4-18	UNIT 18	A	Y	3		
		4-19	UNIT 19	A	Y	3		
		4-2	UNIT 2	A	Y	3		
		4-20	UNIT 20	A	Y	3		
		4-21	UNIT 21	A	Y	3		
		4-22	UNIT 22	A	Y	3		
		4-23	UNIT 23	A	Y	3		
		4-24	UNIT 24	A	Y	3		
		4-25	UNIT 25	A	Y	3		
		4-26	UNIT 26	A	Y	3		
		4-27	UNIT 27	A	Y	3		
		4-28	UNIT 28	A	Y	3		
		4-29	UNIT 29	A	Y	3		
		4-3	UNIT 3	A	Y	3		
		4-30	UNIT 30	A	Y	3		
		4-31	UNIT 31	A	Y	3		
		4-32	UNIT 32	A	Y	3		
		4-33	UNIT 33	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180171	BROOKFIELD HILLS CONDOMINIUM UNIT OWNERS			C	144	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				36				

Towns Served: BROOKFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		4-34	UNIT 34	A	Y	3		
		4-35	UNIT 35	A	Y	3		
		4-36	UNIT 36	A	Y	3		
		4-4	UNIT 4	A	Y	3		
		4-5	UNIT 5	A	Y	3		
		4-6	UNIT 6	A	Y	3		
		4-7	UNIT 7	A	Y	3		
		4-8	UNIT 8	A	Y	3		
		4-9	UNIT 9	A	Y	3		
		C	UNIT 12	A	Y	3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
55766	ATMOSPHERIC STORAGE							
55769	HYDROPNEUMATIC TANK							
639	WELL 2	2	WELL 2	A				
640	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

Contact Information

Name				Organization			Job Title		
Mr. Richard Stoeppel				Rrs Management LLC			Association Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1704 Eaton Court						Danbury		CT	06811
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-748-0894							contact@rrspropertymgmt.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180181	CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP			C	144	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				34				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
14 LAKEVIEW RD. (LAKE14)	1/1/24 - 12/31/24	8/1-8/31	Complete
	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
Total Trihalomethanes (2950)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
17 KELLOGG ST. (KELL17)	1/1/24 - 12/31/24	8/1-8/31	Complete
	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		10 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180181	CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP			C	144	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				34				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180181	CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP			C	144	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				34				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		

Water System Facility: WELL 1 (WSF ID: 1647)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 2 (WSF ID: 1648)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180181	CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP			C	144	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				34				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2007	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	11/12/2024
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	
CROSS CONNECTION EXEMPTION	3/1/2028	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		KELL10	10 KELLOGG ST.	A	Y	3	Y	Y
		KELL12	12 KELLOGG ST.	A	Y	3	Y	Y
		KELL13	13 KELLOGG ST.	A	Y	3	Y	Y
		KELL17	17 KELLOGG ST.	A	Y	3	Y	Y Y
		KELL19	19 KELLOGG ST.	A	Y	3	Y	Y
		KELL5	5 KELLOGG ST.	A	Y	3	Y	Y
		KELL9	9 KELLOGG ST.	A	Y	3	Y	Y
		LAKE11	11 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE12	12 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE13	13 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE14	14 LAKEVIEW RD.	A	Y	3	Y	Y Y
		LAKE15	15 LAKEVIEW RD.	A	Y	1	Y	Y
		LAKE17	17 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE18	18 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE20	20 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE21	21 LAKEVIEW RD.	A	Y	3		Y
		LAKE22	22 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE23	23 LAKEVIEW RD.	A	Y	3	Y	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180181	CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP			C	144	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				34				

Towns Served: BROOKFIELD, NEW FAIRFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LAKE24	24 LAKEVIEW RD	A	Y	3	Y	Y
		LAKE25	25 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE26	26 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE27	27 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE29	29 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE2A	2A LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE31	31 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE33	33 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE4	2 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE5	5 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE6	6 LAKEVIEW RD	A	Y	3	Y	Y
		LAKE7	7 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE8	8 LAKEVIEW RD.	A	Y	3	Y	Y
		LAKE9	9 LAKEVIEW RD.	A	Y	3	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1647	WELL 1	2	WELL 1	I				
1648	WELL 2	2	WELL 2	A				
53757	TREATMENT PLANT							

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 53757)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, PAUL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

Contact Information

Name				Organization		Job Title			
Mr. Christopher J. Vauthy				Candlewood Orch Owner Corp.		President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
14 Lakeview Road						Brookfield		CT	06804
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-775-2907						917-699-1120	vauthycj@gmail.com		

Contact Role(s): **Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0180181	CANDLEWOOD ORCHARDS PROPERTY OWNERS CORP	C	144	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
		34			
Towns Served: BROOKFIELD, NEW FAIRFIELD					
Name		Organization		Job Title	
Mr. Todd Zoob				Resident	
Mailing Address Line One		Mailing Address Line Two		City	State
28 Cakeview Rd				Brookfield	CT
Zip Code					
06804					
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-733-8585					toddzoob@gmail.com
Contact Role(s): Administrative Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180201	WOODCREEK VILLAGE CONDOMINIUM ASSN, INC			C	72	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	6/4/25 - 6/9/25		Complete
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180201	WOODCREEK VILLAGE CONDOMINIUM ASSN, INC			C	72	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		

Water System Facility: WELL 1 (WSF ID: 631)

E. Coli (3014)		1 triggered (TG) per period			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 1 (2)	6/3/25 - 6/9/25		Complete		

Water System Facility: WELL 2 (WSF ID: 632)

E. Coli (3014)		1 triggered (TG) per period			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 2 (2)	6/3/25 - 6/9/25		Complete		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
RESPOND TO SANITARY SURVEY	8/15/2024	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0180201	WOODCREEK VILLAGE CONDOMINIUM ASSN, INC	C	72	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				
Towns Served: BROOKFIELD							

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	8/5/2025
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Lead and Copper M&R Violation	1/1/21 - 12/31/23	3	12/3/2024		12/13/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR	
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y				
			DOWNSTREAM	WITHIN 5 SERVICE CON	A				
			UPSTREAM	WITHIN 5 SERVICE CON	A				
		WV001	81 PRANGE RD	A	Y	N			
		WV002	77 PRANGE RD	A	Y	N			
		WV003	63 PRANGE RD	A	Y	N			
		WV004	69 PRANGE RD	A	Y	N			
		WV005	57 PRANGE RD	A	Y	N			
		WV006	61 PRANGE RD	A	Y	N			
		WV007	55 PRANGE RD	A	Y	N			
		WV008	49 PRANGE RD	A	Y	N			
WV009	45 PRANGE RD	A	Y	N					
WV010	67 PRANGE RD	A		N					
00700	ENTRY POINT	3	ENTRY POINT	A					
37084	ATMOSPHERIC TANK								
60001	TRANSFER PUMPS								
631	WELL 1	2	WELL 1	A					
632	WELL 2	2	WELL 2	A					

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2028

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 10/3/2025

Page 46

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180201	WOODCREEK VILLAGE CONDOMINIUM ASSN, INC			C	72	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				24				

Towns Served: BROOKFIELD

Contact Information

Name				Organization			Job Title		
Ms. Julie Aurrichio				Rei Property Management			Property Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
2A Ives Street						Danbury		CT	06810
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-744-8400		140					jaurrichio@rei-pm.net		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180231	LAKE LILLINONAH SHORES CONDOS			C	130	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			48				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/23/25 - 7/28/25		Complete
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180231	LAKE LILLINONAH SHORES CONDOS			C	130	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				48				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Uranium (4006)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Combined Radium-226/228 (4010)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: WELL 1 (WSF ID: 629)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180231	LAKE LILLINONAH SHORES CONDOS			C	130	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				48				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: WELL 1 (WSF ID: 629)

E. Coli (3014)		1 triggered (TG) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	7/22/25 - 7/28/25		Complete

Water System Facility: WELL 2 (WSF ID: 630)

E. Coli (3014)		1 triggered (TG) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	7/22/25 - 7/28/25		Complete

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SANITARY DEFECT CORRECTIVE ACTION	4/1/2027	
CROSS CONNECTION SURVEY REPORT	3/1/2031	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LLSA001	45 HEARTHSTONE	A	Y	3		
		LLSA002	18 HEARTHSTONE	A	Y	3		
		LLSA003	13 HEARTHSTONE	A	Y	3		
		LLSA004	23 HEARTHSTONE	A	Y	3		
		LLSA005	26 HEARTHSTONE	A	Y	3		
		LLSA006	7 HEARTHSTONE	A	Y	3		
		LLSA007	22 HEARTHSTONE	A	Y	3		
		LLSA008	16 HEARTHSTONE	A	Y	3		
		LLSA009	2 HEARTHSTONE	A	Y	3		
		LLSA010	24 HEARTHSTONE	A	Y	3		
		LLSA011	30 HEARTHSTONE	A	Y	3		
		LLSA012	48 HEARTHSTONE	A	Y	3		
		LLSA013	12 HEARTHSTONE	A	Y	3		
		LLSA014	37 HEARTHSTONE	A	Y	3		
		LLSA015	25 HEARTHSTONE	A	Y	3		
		LLSA016	41 HEARTHSTONE	A	Y	3		
		LLSA017	5 HEARTHSTONE	I	Y	3		
		LLSA018	10 HEARTHSTONE	A		3		
		LLSA019	47 HEARTHSTONE	A		3		
00700	ENTRY POINT	3	ENTRY POINT	A				
51805	ATMOSPHERIC STORAGE							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180231	LAKE LILLINONAH SHORES CONDOS			C	130	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			48				

Towns Served: BROOKFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
51807	PRESSURE STORAGE							
59124	BOOSTER STATION							
629	WELL 1	2	WELL 1	A				
630	WELL 2	2	WELL 2	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

Contact Information

Name				Organization		Job Title		
Mr. Richard S. Baldelli				Lake Lillinonah Shores Condo		President Llsc #1		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Llsc No. 1			P.O. Box 97			Brookfield	CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
			203-470-7313		baldellirichard@gmail.com			

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180251	STONY HILL VILLAGE CONDOMINIUM ASSN			C	392	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			162				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		10 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Net Gross Alpha (4000)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180251	STONY HILL VILLAGE CONDOMINIUM ASSN			C	392	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			162				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Uranium (4006)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Combined Radium-226/228 (4010)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180251	STONY HILL VILLAGE CONDOMINIUM ASSN			C	392	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				162				

Towns Served: BROOKFIELD

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2029	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UNIT1	UNIT 1	A	Y	3	Y	
		UNIT10	UNIT 10	A	Y	3		
		UNIT102	UNIT 102	A	Y	3		
		UNIT112	UNIT 112	A	Y	3		
		UNIT114	UNIT 114	A	Y	3		
		UNIT121	UNIT 121	A	Y	3		
		UNIT123	UNIT 123	A	Y	3	Y	
		UNIT13	UNIT 13	A	Y	3	Y	
		UNIT134	UNIT 134	A	Y	3		
		UNIT136	UNIT 136	A	Y	3		
		UNIT137	UNIT 137	A	Y	3	Y	
		UNIT138	UNIT 138	A	Y	3	Y	
		UNIT139	UNIT 139	A	Y	3	Y	
		UNIT145	UNIT 145	A	Y	3	Y	
		UNIT146	UNIT 146	A	Y	3	Y	
		UNIT15	UNIT 15	A				
		UNIT154	UNIT 154	A	Y	3		
		UNIT158	UNIT 158	A	Y	3		
		UNIT16	UNIT 16	A	Y	3		
		UNIT17	UNIT 17	A	Y	3		
		UNIT18	UNIT 18	A	Y	3		
		UNIT24	UNIT 24	A	Y	3	Y	
		UNIT25	UNIT 25	A	Y	3		
		UNIT26	UNIT 26	A	Y	3	Y	
		UNIT3	UNIT 3	A	Y	3		
		UNIT31	UNIT 31	A	Y	3		
		UNIT32	UNIT 32	A	Y	3	Y	
		UNIT34	UNIT 34	A	Y	3		
		UNIT4	UNIT 4	A	Y	3		
		UNIT41	UNIT 41	A	Y	3	Y	
		UNIT49	UNIT 49	A	Y	3	Y	
		UNIT51	UNIT 51	A	Y	3	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0180251	STONY HILL VILLAGE CONDOMINIUM ASSN			C	392	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				162				

Towns Served: BROOKFIELD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		UNIT55	UNIT 55	A	Y	3		
		UNIT58	UNIT 58	A	Y	3		
		UNIT64	UNIT 64	A	Y	3	Y	
		UNIT79	UNIT 79	A	Y	3	Y	
		UNIT85	UNIT 85	A	Y	3	Y	
		UNIT86	UNIT 86	A	Y	3		
		UNIT97	UNIT 97	A	Y	3	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
55762	ATMOSPHERIC STORAGE							
55764	PRESSURE STORAGE							
598	WELL 2	2	WELL 2	A				
599	WELL 3	2	WELL 3	A				
60246	WELL 5	2	WELL 5	A				
62826	WELL 6	2	WELL 6	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROWLEY, BRENDAN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

Contact Information

Name				Organization		Job Title			
Mr. Timothy O'neil				Rei Property & Asset Mgmt		Property Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
2A Ives Street						Danbury		CT	06810
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-744-8400		149				203-233-3840	toneil@rei-pm.net		

Contact Role(s): Administrative Contact, Legal Contact

Name				Organization		Job Title			
Ms. Kimberly S. O'rourke				Stony Hill Village Board		Board President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1 Stony Hill Village						Brookfield		CT	06804
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-470-1465							kimberlyshv@gmail.com		

Contact Role(s): Legal Contact, Owner

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0180251	STONY HILL VILLAGE CONDOMINIUM ASSN			C	392	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			162				

Towns Served: BROOKFIELD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0184011	BROOKFIELD HOUSING AUTHORITY			C	37	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			11				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
Asbestos (1094)		1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30			
Total Haloacetic Acids (2456)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
4-4 BROOKS QUARY (C4-4)	1/1/24 - 12/31/24	8/1-8/31	Complete	
	1/1/25 - 12/31/25	8/1-8/31	Complete	
	1/1/26 - 12/31/26	8/1-8/31		
Total Trihalomethanes (2950)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
2-4 BROOKS QUARY (A2-4)	1/1/24 - 12/31/24	8/1-8/31	Complete	
	1/1/25 - 12/31/25	8/1-8/31	Complete	
	1/1/26 - 12/31/26	8/1-8/31		
Total Coliform (3100)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	Lead And Copper (PBCU)		5 routine (RT) per six months	
	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
		7/1/25 - 12/31/25		
	1/1/26 - 6/30/26			
Physical Parameters (PPS)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0184011	BROOKFIELD HOUSING AUTHORITY			C	37	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			11				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 1 (WSF ID: 1650)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0184011	BROOKFIELD HOUSING AUTHORITY			C	37	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			11				

Towns Served: BROOKFIELD

Monitoring Requirements

Water System Facility: WELL 1 (WSF ID: 1650)

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2009	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
CCTS 5: PWS OCCT INSTALLATION	5/16/2025	
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		A2-4	2-4 BROOKS QUARY	I	Y	1	Y	Y
		B3-2	3-2 BROOKS QUARY	I	Y	1	Y	Y
		BHA 1-1	APT 1-1	A	Y	1	Y	Y
		BHA 1-2	APT 1-2	A	Y	1	Y	Y
		BHA 1-3	APT 1-3	A	Y	1	Y	Y
		BHA 1-4	APT 1-4	A	Y	1	Y	Y
		BHA 2-1	APT 2-1	A	Y	1	Y	Y
		BHA 2-2	APT 2-2	A	Y	1		Y
		BHA 2-3	APT 2-3	A	Y	1		Y
		BHA 2-4	APT 2-4	A	Y	1		Y
		BHA 3-1	APT 3-1	A	Y	1		Y
		BHA 3-2	APT 3-2	A	Y	1		Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0184011	BROOKFIELD HOUSING AUTHORITY			C	37	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			11				

Towns Served: BROOKFIELD

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		BHA 3-3	APT 3-3	A	Y	1		Y
		BHA 4-1	APT 4-1	A	Y	1		
		BHA 4-2	APT 4-2	A	Y	1		
		BHA 4-3	APT 4-3	A	Y	1		
		BHA 4-4	APT 4-4	A	Y	1		
		BHA 5-1	APT 5-1	A	Y	1		
		BHA 5-2	APT 5-2	A	Y	1		
		BHA 5-3	APT 5-3	A	Y	1		
		BHA 5-4	APT 5-4	A	Y	1		
		BHA 6-1	APT 6-1	A	Y	1		
		BHA 6-2	APT 6-2	A	Y	1		
		BHA 6-3	APT 6-3	A	Y	1		
		BHA 6-4	APT 6-4	A	Y	1		
		BHA 7-1	APT 7-1	A	Y	1		
		BHA 7-2	APT 7-2	A	Y	1		
		BHA 7-3	APT 7-3	A	Y	1		
		BHA 7-4	APT 7-4	A	Y	1		
		BHA 8-1	APT 8-1	A	Y	1		
		BHA 8-2	APT 8-2	A	Y	1		
		BHA 8-3	APT 8-3	A	Y	1		
		BHA 8-4	APT 8-4	A	Y	1		
		BHA 9-1	APT 9-1	A	Y	1		
		BHA 9-2	APT 9-2	A	Y	1		
		BHA 9-3	APT 9-3	A	Y	1		
		BHA 9-4	APT 9-4	A	Y	1		
		BHA OFF	OFFICE-KITCHEN	A	Y	1		
		C4-4	4-4 BROOKS QUARY	I	Y	1	Y	Y
		D5-2	5-2 BROOKS QUARY	I	Y	1	Y	Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		E-64	6-4 BROOKS QUARY	I	Y	1	Y	Y
		F-3	3 BROOKS QUARRY RD,	I				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1650	WELL 1	2	WELL 1	A				
50373	ATMOSPHERIC STORAGE TANK							
56627	TREATMENT PLANT							
60312	BOOSTER PUMP							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0184011	BROOKFIELD HOUSING AUTHORITY			C	37	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				11				

Towns Served: BROOKFIELD

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 56627)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, ANDREW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Contact Information

Name				Organization		Job Title			
Ms. Alison Shears				Demarco Management Corporation		Property Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
3 Brooks Quarry Road						Brookfield		CT	06804
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-775-1403			860-955-2689			203-379-8570	ashears@demarcomc.com		

Contact Role(s): **Administrative Contact**

Name				Organization			Job Title		
Ms. Amelia Malanaphy				Brookfield Housing Authority			Chair		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
57 Carmen Hill Road						Brookfield		CT	06804
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
					203-885-8392		amalanaphy@yahoo.com		

Contact Role(s): **Legal Contact**

Name			Organization			Job Title		
Brookfield Housing Authority								
Mailing Address Line One		Mailing Address Line Two			City		State	Zip Code
126A Laurel Hill Rd					Brookfield		CT	06804
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-775-1403								

Contact Role(s): **Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0189971	39 HOP BROOK RD - APT COMPLEX			C	36	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
39 HOP BROOK ROAD				12				
Towns Served: BROOKFIELD								

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		Complete
Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/16/25 - 7/21/25		Complete
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0189971	39 HOP BROOK RD - APT COMPLEX			C	36	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
39 HOP BROOK ROAD				12				
Towns Served: BROOKFIELD								

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Chloride (1017)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Nitrate (1040)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Nitrite (1041)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/21 - 12/31/26		Complete
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Water System Facility: WELL 2 (WSF ID: 62389)

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	7/15/25 - 7/21/25		Complete

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION EXEMPTION	3/1/2028	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0189971	39 HOP BROOK RD - APT COMPLEX			C	36	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
39 HOP BROOK ROAD				12				
Towns Served: BROOKFIELD								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	100	COMMUNITY ROOM	A	Y	N	Y	Y
		100 - COMMU	GENERATED BY BATCH	A	Y			
		101	APT 1	A	Y	N	Y	Y
		101 - APT 1	GENERATED BY BATCH	A	Y			
		104	APT 4	A		N	Y	
		104 - APT 4	GENERATED BY BATCH	A	Y			
		106	APT 6	A		N	Y	Y
		106 - APT 6	GENERATED BY BATCH	A	Y			
		112	APT 12	A		N	Y	Y
		112 - APT 1	GENERATED BY BATCH	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTEAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
59965	ATMOSPHERIC STORAGE							
59967	BOOSTER PUMPS							
62389	WELL 2	2	WELL 2	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

Contact Information

Name				Organization			Job Title		
Mr. Adriano Echavarria				39 Hop Brook Road LLC			LLC Manager/Owner		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
95 Deer Hill Ave						Danbury		CT	06810
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
646-596-1444							echavarria11@gmail.com		

Contact Role(s): Administrative Contact, Legal Contact, Owner

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.