

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		7 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
Total Coliform (3100)		7 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		2 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
126 PWDR MILL RD,CAN (5054)	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	
	1/1/26 - 3/31/26	1/1-1/31	
133 RIVER RD, COLL (5058)	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	
	1/1/26 - 3/31/26	1/1-1/31	
Lead And Copper (PBCU)		20 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		7 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	7 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT-FILTER PLANT (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Uranium (4006)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Combined Radium-226/228 (4010)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
Inorganic Chemicals (IOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

### Monitoring Requirements

Water System Facility: ENTRY POINT-FILTER PLANT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-FILTER P (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: COLLINSVILLE WTP (WSF ID: 114)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COMBINED FILTER EFFLUENT - COLLINSVILLE (5)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: MDC NEPAUG RESERVOIR (WSF ID: 2129)

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEPAUG RESERVOIR (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

  

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NEPAUG RESERVOIR (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

### Monitoring Requirements

Water System Facility: MDC NEPAUG RESERVOIR (WSF ID: 2129)

Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
NEPAUG RESERVOIR (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
NEPAUG RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
NEPAUG RESERVOIR (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
NEPAUG RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Water System Facility: **ENTRY POINT-FILTER PLANT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.90 MG/L	2
Start Date: 9/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 1.10 MG/L	2
Start Date: 9/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 9/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 7.5 PH	Daily
Start Date: 1/1/2004	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

Water System Facility: **COLLINSVILLE WTP (WSFID: 114)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025	Y		
6/1/2025 - 6/30/2025	Y		
7/1/2025 - 7/31/2025	Y		
8/1/2025 - 8/31/2025	Y		
9/1/2025 - 9/30/2025			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2004			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025	Y		
6/1/2025 - 6/30/2025	Y		
7/1/2025 - 7/31/2025	Y		
8/1/2025 - 8/31/2025	Y		
9/1/2025 - 9/30/2025			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2005			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025	Y		
6/1/2025 - 6/30/2025	Y		
7/1/2025 - 7/31/2025	Y		
8/1/2025 - 8/31/2025	Y		
9/1/2025 - 9/30/2025			

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/3/2025
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

### Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Total Coliform M&R Violation	1/1/11 - 3/31/11	3	6/13/2012		6/23/2012	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Rule Status	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR	Stage
--------------------------	-----------------------	-------------------	----------------------------	----------------------------	---------------------------	---------------------	-------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification		Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C		6,324	P	SW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural	
		Connections	1,726	155	7	20		
Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD								
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION		A	Y		
		5050	113 HCKLBRY HIL COL		A	Y		
		5051	104 MAIN ST CANTON		A	Y		
		5053	103 DEEPWOOD DR.		A	Y	3	
		5054	126 PWDR MILL RD,CAN		A	Y		Y
		5055	CANTON COMMONS,RT44		A	Y		
		5056	7 CEMETARY RD, COL		A	Y	3	
		5057	178 KINGSWOOD DR,COL		A	Y		
		5058	133 RIVER RD, COLL		A			Y
		50801	5 BRKVIEW CRCL,CAN		A		N	
		50802	3 WHIRLING DUN COL		A		2	
		50803	9 WHIRLING DUN COL		A		2	
		50804	23 WICKHAMS FANCY		A		2	
		50805	37 WICKHAMS FANCY		A		2	
		50806	39 WICKHAMS FANCY		A		2	
		50807	44 WICKHAMS FANCY		A		2	
		50808	3 BROOKVIEW CIR,CAN		A		N	
		50809	6 BROOKVIEW CIR, CAN		A		N	
		50810	18 BROOKVIEW CIR,CAN		A		N	
		50811	14 WICKHAMS FANCY		A		2	
		50812	29 WICKHAMS FANCY		A		2	
		50813	33 WICKHAMS FANCY		A		2	
		50814	35 WICKHAMS FANCY		A		2	
		50815	50 WICKHAMS FANCY		A		2	
		50816	52 WICKHAMS FANCY		A		2	
		50817	59 WICKHAMS FANCY		A		2	
		50818	62 WICKHAMS FANCY		A		2	
		50819	1 WHIRLING DUN COL		A		2	
		50820	4 CAMILLE LN		A		N	
		50821	9 CAMILLE LN		A		N	
		50822	100 WINTERBOURNE LN		A		N	
		50823	116 WINTERBOURNE LN		A		N	
		50824	118 WINTERBOURNE LN		A		N	
		50825	126 WINTERBOURNE LN		A		N	
		50826	66 NEW RD, AV		A		1	
		50827	68 VERVILLE RD, AV		A		1	
		50828	55 ARCH ST, BLGTN		A		1	
		50829	15 BIRCH RD, CAN		A		1	
		50830	171 HL ST, CAN		A		1	
		50831	26 SECRET LAKE, CAN		A		1	
		50832	28 SECRET LAKE, CAN		A		1	
		50833	69 DYER AVE, COLL		A		1	
		50834	13 GLDRSLV AV, COLL		A		1	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS		C	6,324	P	SW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		50835	83 SIMONDS AVE, COLL	A		1		
		50836	75 TRNGTN AV, COLL	A		1		
		50837	45 ARCH ST, BLGTN	A		2		
		50838	61 ARCH ST, BLGTN	A		2		
		50839	1 WCKHMS FNCY, CAN	A		2		
		50840	2 WCKHMS FNCY, CAN	A		2		
		50841	3 WCKHMS FNCY, CAN	A		2		
		50842	4 WCKHMS FNCY, CAN	A		2		
		50843	5 WCKHMS FNCY, CAN	A		2		
		50844	6 WCKHMS FNCY, CAN	A		2		
		50845	7 WCKHMS FNCY, CAN	A		2		
		50846	CTWC - NAUG-COL	A	Y			
		50847	9 WCKHMS FNCY, CAN	A		2		
		50848	10 WCKHMS FNCY, CAN	A		2		
		50849	11 WCKHMS FNCY, CAN	A		2		
		50850	12 WCKHMS FNCY, CAN	A		2		
		50851	13 WCKHMS FNCY, CAN	A		2		
		50852	15 WCKHMS FNCY, CAN	A		2		
		50853	16 WCKHMS FNCY, CAN	A		2		
		50854	17 WCKHMS FNCY, CAN	A		2		
		50855	19 WCKHMS FNCY, CAN	A		2		
		50856	20 WCKHMS FNCY, CAN	A		2		
		50857	21 WCKHMS FNCY, CAN	A		2		
		50858	22 WCKHMS FNCY, CAN	A		2		
		50859	24 WCKHMS FNCY, CAN	A		2		
		50860	25 WCKHMS FNCY, CAN	A		2		
		50861	26 WCKHMS FNCY, CAN	A		2		
		50862	27 WCKHMS FNCY, CAN	A		2		
		50863	28 WCKHMS FNCY, CAN	A		2		
		50864	30 WCKHMS FNCY, CAN	A		2		
		50865	31 WCKHMS FNCY, CAN	A		2		
		50866	32 WCKHMS FNCY, CAN	A		2		
		50867	34 WCKHMS FNCY, CAN	A		2		
		50868	36 WCKHMS FNCY, CAN	A		2		
		50869	38 WCKHMS FNCY, CAN	A		2		
		50870	40 WCKHMS FNCY, CAN	A		2		
		50871	41 WCKHMS FNCY, CAN	A		2		
		50872	42 WCKHMS FNCY, CAN	A		2		
		50873	43 WCKHMS FNCY, CAN	A		2		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS		C	6,324	P	SW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		50874	45 WCKHMS FNCY, CAN	A		2		
		50875	46 WCKHMS FNCY, CAN	A		2		
		50876	47 WCKHMS FNCY, CAN	A		2		
		50877	48 WCKHMS FNCY, CAN	A		2		
		50878	49 WCKHMS FNCY, CAN	A		2		
		50879	51 WCKHMS FNCY, CAN	A		2		
		50880	53 WCKHMS FNCY, CAN	A		2		
		50881	54 WCKHMS FNCY, CAN	A		2		
		50882	55 WCKHMS FNCY, CAN	A		2		
		50883	56 WCKHMS FNCY, CAN	A		2		
		50884	57 WCKHMS FNCY, CAN	A		2		
		50885	58 WCKHMS FNCY, CAN	A		2		
		50886	60 WCKHMS FNCY, CAN	A		2		
		50887	61 WCKHMS FNCY, CAN	A		2		
		50888	114 WNTRBRN DN, COLL	A		2		
		50889	2 WHRLNG DN, COLL	A		2		
		50890	4 WHRLNG DN, COLL	A		2		
		50891	5 WHRLNG DN, COLL	A		2		
		50892	6 WHRLNG DN, COLL	A		2		
		50893	7 WHRLNG DN, COLL	A		2		
		50894	8 WHRLNG DN, COLL	A		2		
		50895	10 WHRLNG DN, COLL	A		2		
		50896	12 BLANCHARD RD, AV	A		3		
		50897	2 DEEPWOOD DR, AV	A		3		
		50898	8 DEEPWOOD DR, AV	A		3		
		50899	11 DEEPWOOD DR, AV	A		3		
		50900	14 DEEPWOOD DR, AV	A		3		
		50901	20 DEEPWOOD DR, AV	A	Y	3		
		50902	26 DEEPWOOD DR, AV	A		3		
		50903	33 DEEPWOOD DR, AV	A		3		
		50904	38 DEEPWOOD DR, AV	A		3		
		50905	53 DEEPWOOD DR, AV	A		3		
		50906	61 DEEPWOOD DR, AV	A		3		
		50907	67 DEEPWOOD DR, AV	A		3		
		50908	70 DEEPWOOD DR, AV	A		3		
		50909	73 DEEPWOOD DR, AV	A		3		
		50910	77 DEEPWOOD DR, AV	A		3		
		50911	78 DEEPWOOD DR, AV	A		3		
		50912	83 DEEPWOOD DR, AV	A		3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		50913	93 DEEPWOOD DR, AV	A		3		
		50914	96 DEEPWOOD DR, AV	A		3		
		50915	104 DEEPWOOD DR, AV	A		3		
		50916	115 DEEPWOOD DR, AV	A		3		
		50917	118 DEEPWOOD DR, AV	A		3		
		50918	121 DEEPWOOD DR, AV	A		3		
		50919	126 DEEPWOOD DR, AV	A		3		
		50920	127 DEEPWOOD DR, AV	A		3		
		50921	130 DEEPWOOD DR, AV	A		3		
		50922	131 DEEPWOOD DR, AV	A		3		
		50923	137 DEEPWOOD DR, AV	A		3		
		50924	142 DEEPWOOD DR, AV	A		3		
		50925	143 DEEPWOOD DR, AV	A		3		
		50926	146 DEEPWOOD DR, AV	A		3		
		50927	147 DEEPWOOD DR, AV	A		3		
		50928	21 HCKLBRY HL, AV	A		3		
		50929	55 NEW RD, AV	A		3		
		50930	127 NEW RD, AV	A		3		
		50931	232 NEW RD, AV	A		3		
		50932	7 VERVILLE RD, AV	A		3		
		50933	41 ARCH ST, BLGTN	A		3		
		50934	49 ARCH ST, BLGTN	A		3		
		50935	5 COLONY RD, CAN	A		3		
		50936	6 COLONY RD, CAN	A		3		
		50937	13 COLONY RD, CAN	A		3		
		50938	15 COLONY RD, CAN	A		3		
		50939	16 COLONY RD, CAN	A		3		
		50940	20 COLONY RD, CAN	A		3		
		50941	21 COLONY RD, CAN	A		3		
		50942	23 COLONY RD, CAN	A		3		
		50943	25 COLONY RD, CAN	A		3		
		50944	26 COLONY RD, CAN	A		3		
		50945	27 COLONY RD, CAN	A		3		
		50946	29 COLONY RD, CAN	A		3		
		50947	7 DOWD AVE, CAN	A		3		
		50948	121 DOWD AVE, CAN	A		3		
		50949	129 DOWD AVE, CAN	A		3		
		50950	17 E HL RD, CAN	A		3		
		50951	19 E HL RD, CAN	A		3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		50952	4 FOREST LN, CAN	A		3		
		50953	6 FOREST LN, CAN	A		3		
		50954	32 FOREST LN, CAN	A		3		
		50955	34 FOREST LN, CAN	A		3		
		50956	2 OLD CANTON RD, CAN	A		3		
		50957	6 CEMETERY RD, COLL	A		3		
		50958	16 COLLINS RD, COLL	A		3		
		50959	17 DYER AVE, COLL	A		3		
		50960	48 DYER AVE, COLL	A		3		
		50961	54 DYER AVE, COLL	A		3		
		50962	56 DYER AVE, COLL	A		3		
		50963	97 DYER AVE, COLL	A		3		
		50964	97A DYER AVE, COLL	A		3		
		50965	97B DYER AVE, COLL	A		3		
		50966	50 HIGH ST, COLL	A		3		
		50967	68 SIMONDS AVE, COLL	A		3		
		50968	79 SIMONDS AVE, COLL	A		3		
		50969	681SIMONDS AVE, COLL	A		3		
		50970	97 TRNGTN AV, COLL	A		3		
		50971	115B TRNGTN AV, COLL	A		3		
		50972	84A TRNGTN AV, COLL	A		3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT-FILTER PLANT	3	ENTRY POINT-FILTER P	A				
114	COLLINSVILLE WTP	3	ENTRY POINT - COLLIN	A				
		5	COMBINED FILTER EFFL	A				
2128	MDC BARKHAMSTED RESERVOIR	1	MDC BARKHAMSTED RESE	A				
2129	MDC NEPAUG RESERVOIR	1	NEPAUG RESERVOIR	A				
30019	MDC NEPAUG RESERVOIR	1	NEPAUG RES INTAKE	A				
37292	CTWC HUCKLEBERRY HILL TANK							
49477	CEMETARY ROAD PUMP STATION							
52174	WTP CLEARWELLS							
52176	WTP STANDPIPES							
58937	INTERCONNECTION - CT0040011 - AVON							

### Certified Operator Information

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0230011	CTWC - NAUGATUCK REG-COLLINSVILLE SYS			C	6,324	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1,726	155	7	20	

Towns Served: AVON, BURLINGTON, CANTON, NEW HARTFORD

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROBOTHAM, JR., PAUL C.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2025 6/30/2026
PEIL, THEODORE W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026

**Water System Facility: COLLINSVILLE WTP (WSF ID: 114)**

**Facility Classification:** CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PARISAN, CHRISTOPHER A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
BARAL, JR, RAYMOND E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2025 6/30/2026
NEGRELLI, SUSAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026 6/30/2027
RANDALL, DANIEL J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2026
MINER, ALISON	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026 6/30/2026

### Contact Information

Name				Organization		Job Title			
Mr. Craig J. Patla				Connecticut Water Company		Vp, Service Delivery			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 West Main Street						Clinton		CT	06413
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-664-6140						800-391-1924	craig.patla@ctwater.com		

**Contact Role(s): Legal Contact, Owner**

Name				Organization		Job Title			
Mr. Gerald McDermott				The Connecticut Water Company		Manager, Service Del			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 West Main Street						Clinton		CT	06413
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-664-6125							ctwcdphadmin@ctwater.com		

**Contact Role(s): Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0231011	298-302 ALBANY TURNPIKE			C	28	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE				10				

Towns Served: CANTON

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/19 - 12/31/27		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0231011	298-302 ALBANY TURNPIKE			C	28	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE			Connections	10				
Towns Served: CANTON								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Uranium (4006)		1 routine (RT) per three years	
<u>Sampling Point (Sampling Point ID)</u>	<u>Monitoring Period</u>	<u>Collection Period</u>	<u>Compliance Status</u>
ENTRY POINT-WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<u>Sampling Point (Sampling Point ID)</u>	<u>Monitoring Period</u>	<u>Collection Period</u>	<u>Compliance Status</u>
ENTRY POINT-WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<u>Sampling Point (Sampling Point ID)</u>	<u>Monitoring Period</u>	<u>Collection Period</u>	<u>Compliance Status</u>
ENTRY POINT-WELL #1 (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<u>Sampling Point (Sampling Point ID)</u>	<u>Monitoring Period</u>	<u>Collection Period</u>	<u>Compliance Status</u>
ENTRY POINT-WELL #1 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<u>Sampling Point (Sampling Point ID)</u>	<u>Monitoring Period</u>	<u>Collection Period</u>	<u>Compliance Status</u>
ENTRY POINT-WELL #1 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<u>Sampling Point (Sampling Point ID)</u>	<u>Monitoring Period</u>	<u>Collection Period</u>	<u>Compliance Status</u>
ENTRY POINT-WELL #1 (3)	1/1/25 - 12/31/27		

### Other Compliance Schedules

<u>Compliance Schedule Activity</u>	<u>Due Date</u>	<u>Achieved Date</u>
CROSS CONNECTION EXEMPTION	3/1/2026	

### Public Notification Requirements

<u>Violation/Situation</u>	<u>Compliance Period</u>	<u>Notice Tier</u>	<u>Public Notification</u>		<u>PN Certification</u>	
			<u>Required</u>	<u>Performed</u>	<u>Due to DPH</u>	<u>Received</u>
Physical Parameters M&R Violation	12/1/24 - 12/31/24	3	2/3/2026		2/13/2026	
Total Coliform M&R Violation	12/1/24 - 12/31/24	3	2/3/2026		2/13/2026	

### Water System Facility and Sampling Point Inventory

<u>Water System Facility ID</u>	<u>Water System Facility</u>	<u>Sampling Point ID</u>	<u>Sampling Point Description</u>	<u>Status</u>	<u>Total Coliform Rule</u>	<u>Lead and Copper Rule Tier</u>	<u>Asbestos</u>	<u>Stage WQP 2 DBPR</u>
00600	DISTRIBUTION SYSTEM	300-A1-B	300-A1-BATH SINK	A	Y	N		
		300-A1-K	300-A1-KITCH SK	A	Y	N		
		300-A2-B	300-A2-BATH SK	A	Y	N		
		300-A2-K	300-A2-KITCH SK	A	Y	N		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0231011	298-302 ALBANY TURNPIKE			C	28	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
298-302 ALBANY TURNPIKE				10				
Towns Served: CANTON								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		300-B1-B	300-B1-BATH SK	A	Y	N		
		300-B1-K	300-B1-KITCH SK	A	Y	N		
		300-B2-B	300-B2-BATH SK	A	Y	N		
		300-B2-K	300-B2-KITCH SK	A	Y	N		
		300-B3-B	300-B3-BATH SK	A	Y	N		
		300-B3-K	300-B3-KITCH SK	A	Y	N		
		300-B4-B	300-B4-BATH SK	A	Y	N		
		300-B4-K	300-B4-KITCH SK	A	Y	N		
		300-LAUNDRY	300-LAUNDRY SK	A	Y	N		
		302-A1-B	302-A1-BATH SK	A	Y	N		
		302-A1-K	302-A1-KITCH SK	A	Y	N		
		302-A2-B	302-A2-BATH SK	A	Y	N		
		302-A2-K	302-A2-KITCH SK	A	Y	N		
		302-B1-B	302-B1-BATH SK	A	Y	N		
		302-B1-K	302-B1-KITCH SK	A	Y	N		
		302-B2-B	302-B2-BATH SK	A	Y	N		
		302-B2-K	302-B2-KITCH SK	A	Y	N		
		302-LAUNDRY	302-LAUNDRY SK	A	Y	N		
		4	DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		TMS07	TMS07	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT-WELL #1	A				
1848	WELL #1	2	WELL #1	A				

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HELMING, TRAVIS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2028 9/30/2028

### Contact Information

Name				Organization			Job Title		
Mr. Matthew Schoenhardt				Watsul Associates, LLC			Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 912						Canton		CT	06019
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-543-4005					860-543-4005		matthew.schoenhardt@raveis.com		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0231011</b>	<b>298-302 ALBANY TURNPIKE</b>	<b>C</b>	<b>28</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
298-302 ALBANY TURNPIKE		10			
Towns Served: CANTON					
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>					
Name		Organization		Job Title	
<b>Ms. Josephine M. Schoenhardt</b>		Watsul Associates		Owner	
Mailing Address Line One		Mailing Address Line Two		City	State
51 Westledge Rd				West Simsbury	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-217-0948					joshchoenhardt@gmail.com
Contact Role(s): <b>Owner</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**