

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT	C	14,316	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					4,046

Towns Served: BERLIN, CROMWELL

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		10 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)		10 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
9 BIRCH CT (CFDW05)	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	
	1/1/26 - 3/31/26	1/1-1/31	
4 SEBETHE DRIVE (CFDW11)	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	
	1/1/26 - 3/31/26	1/1-1/31	
133 SEBETHE DRIVE (CFDW12)	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	
	1/1/26 - 3/31/26	1/1-1/31	
49 NOOKS HILL ROAD (CFDW82)	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT			C	14,316	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							4,046	

Towns Served: BERLIN, CROMWELL

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 3/31/26	1/1-1/31	
Lead And Copper (PBCU)		30 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)		10 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Gross Beta Particle Activity (4100)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT			C	14,316	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							4,046	

Towns Served: BERLIN, CROMWELL

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Tritium (4102)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Strontium-90 (4174)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: GARDINER WELL 1 (WSF ID: 1044)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GARDINER WELL 1 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT			C	14,316	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							4,046	

Towns Served: BERLIN, CROMWELL

Monitoring Requirements

Water System Facility: **GARDINER WELL 1 (WSF ID: 1044)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **GARDINER WELL 2 (WSF ID: 1146)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GARDINER WELL 2 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **GARDINER WELL 3 (WSF ID: 1910)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GARDINER WELL 3 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **GARDINER WELL 4 (WSF ID: 1911)**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT			C	14,316	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							4,046	

Towns Served: BERLIN, CROMWELL

Monitoring Requirements

Water System Facility: GARDINER WELL 4 (WSF ID: 1911)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
GARDINER WELL #4 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 4/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule									
PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source		
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT			C	14,316	L	GW		
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
							4,046		
Towns Served: BERLIN, CROMWELL									
Water System Facility: ENTRY POINT (WSFID: 00700)									
Analyte	Monitoring Requirement (Summary Type)			Operating Limit			Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)			Maximum: 0.85 MG/L			Daily		
Start Date:	5/1/2023			Compliance History:		Operating Limit	Monitoring		
				Monitoring Period		Compliance Status:	Compliance Status:		
				6/1/2025 - 6/30/2025		Y			
				7/1/2025 - 7/31/2025		Y			
				8/1/2025 - 8/31/2025		Y			
				9/1/2025 - 9/30/2025					
Analyte	Monitoring Requirement (Summary Type)			Operating Limit			Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)			Maximum: 3 MG/L			2		
Start Date:	4/1/2003			Compliance History:		Operating Limit	Monitoring		
				Monitoring Period		Compliance Status:	Compliance Status:		
				5/1/2025 - 5/31/2025					
				6/1/2025 - 6/30/2025					
				7/1/2025 - 7/31/2025					
				8/1/2025 - 8/31/2025					
				9/1/2025 - 9/30/2025					
Other Compliance Schedules									
Compliance Schedule Activity				Due Date		Achieved Date			
CERTIFY LEAD SL NOTIFICATION				7/1/2025		11/15/2024			
MAIL/HAND DELIVER NOTICE TO CONSUMERS				12/31/2025					
CROSS CONNECTION SURVEY REPORT				3/1/2026					
CERTIFY LEAD SL NOTIFICATION				7/1/2026					
Public Notification Requirements									
Violation/Situation			Compliance Period	Notice Tier	Public Notification		PN Certification		
					Required	Performed	Due to DPH	Received	
Disinfectant Byproducts - TTHM & HAA5 M&R Violation			1/1/25 - 3/31/25	3	10/1/2026		10/11/2026		
Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2	DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		CFDW01	308 MAIN STREET	A	Y				
		CFDW02	385 MAIN STREET	A	Y				
		CFDW03	72 WEST STREET	A	Y				
		CFDW04	61 NOOKS HILL ROAD	I	Y				Y
		CFDW05	9 BIRCH CT	A	Y				Y
		CFDW06	52 MISSIONARY ROAD	A	Y				
		CFDW07	15 COURT STREET	A	Y				
		CFDW08	179 SHUNPIKE RD	A	Y				
		CFDW09	1 DONALD HARRIS DR	A	Y				

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT			C	14,316	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							4,046	
Towns Served: BERLIN, CROMWELL								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CFDW10	701 MAIN STREET	A	Y			
		CFDW100	29 BELLAIRE MANOR	A		1		
		CFDW101	31 BELLAIRE MANOR	A		1		
		CFDW102	32 BELLAIRE MANOR	A		1		
		CFDW103	33 BELLAIRE MANOR	A		1		
		CFDW104	34 BELLAIRE MANOR	A		1		
		CFDW105	42 BELLAIRE MANOR	A		1		
		CFDW106	44 BELLAIRE MANOR	A		1		
		CFDW107	52 BELLAIRE MANOR	A		1		
		CFDW108	54 BELLAIRE MANOR	A		1		
		CFDW109	56 BELLAIRE MANOR	A		1		
		CFDW11	4 SEBETHE DRIVE	A	Y			Y
		CFDW110	66 TIMBER HILL RD.	A	Y			
		CFDW111	419 MAIN STREET	A	Y			
		CFDW112	5 WEST STREET	A	Y			
		CFDW113	50 COUNTY LINE DRIVE	A	Y			
		CFDW114	100 COUNTY LINE DR	A	Y			
		CFDW115	40 COMMERCE DRIVE	A	Y			
		CFDW116	5 WEST STREET	A	Y			
		CFDW117	41 WEST STREET	A	Y			
		CFDW118	51 SHUNPIKE ROAD	A	Y			
		CFDW119	1 SANFORD LANE	A	Y			
		CFDW12	133 SEBETHE DRIVE	A				Y
		CFDW120	41 BROOKVIEW RD	A	Y			
		CFDW121	156 BERLIN RD	A	Y			
		CFDW13	8 SHADOW LANE	A		1		
		CFDW14	1 COSKER LANE	A		1		
		CFDW15	10 MCDONALD AVE	A		1		
		CFDW16	96 SHADOW LANE	A		1		
		CFDW17	13 HARRISON DRIVE	A		1		
		CFDW18	15 HARRISON DRIVE	A		1		
		CFDW19	7 WEXFORD LANE	A	Y	1		
		CFDW20	8 GOODRICH AVENUE	A		1		
		CFDW21	8 SACHEM DRIVE	A		1		
		CFDW22	10 SACHEM DRIVE	A		1		
		CFDW23	5 PATRICIA LANE	A		1		
		CFDW24	7 HOLLY HILL	A	Y	1		
		CFDW25	26 EDGEWOOD STREET	A		1		
		CFDW26	3 CROSS STREET	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT			C	14,316	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							4,046	

Towns Served: BERLIN, CROMWELL

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CFDW27	7 PALMER CIRCLE	A		1		
		CFDW28	3 WEXFORD LANE	A		1		
		CFDW29	24 EVERGREEN	A		1		
		CFDW30	4 HARRISON DRIVE	A		1		
		CFDW31	7 CANNATA DRIVE	A		1		
		CFDW32	5 CANNATA DRIVE	A		1		
		CFDW33	6 SACHEM DRIVE	A		1		
		CFDW34	39 COURT STREET	A		1		
		CFDW35	64 B EVERGREEN	A		1		
		CFDW36	110 NOOKS HILL RD	A		1		
		CFDW37	6 POINDVIEW DRIVE	A		1		
		CFDW38	9 HIGH RIDGE	A		1		
		CFDW39	60 HILL SIDE	A		1		
		CFDW40	7 MCDONALD AVE	A		1		
		CFDW41	1A HOLLY HILL	A		1		
		CFDW42	136 NOOKS HILL ROAD	A		1		
		CFDW43	12 RANNEY ROAD	A	Y	1		
		CFDW44	6 PALMER CIRCLE	A	Y	1		Y
		CFDW45	103 COLES ROAD	A	Y			
		CFDW46	1 WEST STREET	A	Y			
		CFDW47	6 PROGRESS DRIVE	A		1		
		CFDW48	15 SCOTT LANE	A		1		
		CFDW49	18 SCOTT LANE	A		1		
		CFDW50	6 MARSAL LANE	A		1		
		CFDW51	1 SEQUOIA DRIVE	A		1		
		CFDW52	2 BLACKHAWK DRIVE	A		1		
		CFDW53	81 WILLOWBROOK ROAD	A		1		
		CFDW54	90 SHADOW LANE	A		1		
		CFDW55	92 SHADOW LANE	A		1		
		CFDW56	96 SHADOW LANE	A		1		
		CFDW57	1 PONDVIEW RD	A		1		
		CFDW58	3 PONDVIEW DRIVE	A		1		
		CFDW59	6 PONDVIEW DRIVE	A		1		
		CFDW60	7 PONDVIEW DRIVE	A		1		
		CFDW61	11 PONDVIEW DRIVE	A		1		
		CFDW62	17 PONDVIEW DRIVE	A		1		
		CFDW63	15 HARRISON DRIVE	A		1		
		CFDW64	17 HARRISON DRIVE	A		1		
		CFDW65	10 CANNATA DRIVE	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT			C	14,316	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							4,046	

Towns Served: BERLIN, CROMWELL

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CFDW66	1 CROSS ST	A		1		
		CFDW67	3 CROSS ST	A		1		
		CFDW68	4 CROSS ST	A		1		
		CFDW69	5 CROSS ST	A		1		
		CFDW70	6 CROSS ST	A		1		
		CFDW71	1 WINDWOOD	A		1		
		CFDW72	5 WINDWOOD	A		1		
		CFDW73	20 HIGHRIDGE	A		1		
		CFDW74	22 HIGHRIDGE	A		1		
		CFDW75	24 HIGHRIDGE	A		1		
		CFDW76	3 PATRICIA LANE	A		1		
		CFDW77	5 PATRICIA LANE	A		1		
		CFDW78	7 PATRICIA LANE	A		1		
		CFDW79	4 PATRICIA LANE	A		1		
		CFDW80	9 PATRICIA LANE	A		1		
		CFDW81	82 COURT STREET	A	Y			
		CFDW82	49 NOOKS HILL ROAD	A	Y			Y
		CFDW83	10 EVERGREEN ROAD	A	Y	1		
		CFDW84	6 KNIGHTS LANE	A	Y	1		
		CFDW85	8 PALMER CIRCLE	A	Y	1		
		CFDW86	9 PALMER CIRCLE	A	Y	1		
		CFDW90	4 ELM ROAD	A		1		
		CFDW91	379 MAIN STREET	A		1		
		CFDW92	391 MAIN STREET	A		1		
		CFDW93	3 BELLAIRE MANOR	A		1		
		CFDW94	5 BELLAIRE MANOR	A		1		
		CFDW95	10 BELLAIRE MANOR	A		1		
		CFDW96	19 BELLAIRE MANOR	A		1		
		CFDW97	21 BELLAIRE MANOR	A		1		
		CFDW98	25 BELLAIRE MANOR	A		1		
		CFDW99	27 BELLAIRE MANOR	A		1		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1044	GARDINER WELL 1	2	GARDINER WELL 1	A				
1146	GARDINER WELL 2	2	GARDINER WELL 2	A				
1910	GARDINER WELL 3	2	GARDINER WELL 3	A				
1911	GARDINER WELL 4	2	GARDINER WELL #4	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT			C	14,316	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							4,046	

Towns Served: BERLIN, CROMWELL

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
36256	TREATMENT PLANT - GARDINER WELLFIELD							
54464	SHUNPIKE RESERVOIR							
54466	SANFORD LANE PUMP STATION							
61831	EVERGREEN ADULT PUMP STATION							
61832	SOVEREIGN RIDGE PUMP STATION							
62365	COUNTRY SQUIRE AKA LONDON PS							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
PALMIERI, JOSEPH A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2028
CRESCIMANNO, DONALD	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2028
		WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027

Water System Facility: **TREATMENT PLANT - GARDINER WELLFIELD (WSF ID: 36256)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PALMIERI, JOSEPH A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2028
CRESCIMANNO, DONALD	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2028
		WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027

Contact Information

Name				Organization			Job Title			
Mr. Julius Neto				Board of Commissions			Executive Director			
Mailing Address Line One				Mailing Address Line Two			City		State	Zip Code
1 West Street							Cromwell		CT	06416
Business Phone		Extension	Fax		Mobile Phone		Emergency Phone	Email Address		
860-635-4420			860-632-0413				860-276-4645	jneto@cromwellfd.com		
Contact Role(s):		Owner								

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0330011	CROMWELL FIRE DISTRICT WATER DEPARTMENT	C	14,316	L	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					4,046
Towns Served: BERLIN, CROMWELL					
Name		Organization		Job Title	
Mr. Roger T. Hart		Cromwell Fire District - Water		Executive Director	
Mailing Address Line One		Mailing Address Line Two		City	State
1 West Street				Cromwell	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-635-4420	1004	860-635-3084		860-214-0574	rhart@cromwellfd.com
Contact Role(s): Administrative Contact, Legal Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule