

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0350011	AQUARION-DARIEN			C	18,737	P	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							6,844	

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		20 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
Asbestos (1094)		1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
HOLMES SCHOOL SS (05408)	1/1/21 - 12/31/29			
Total Coliform (3100)		20 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
UNITED METHODIST (05426)	4/1/25 - 6/30/25	5/1-5/31	Complete	
	7/1/25 - 9/30/25	8/1-8/31	Complete	
	10/1/25 - 12/31/25	11/1-11/30		
	1/1/26 - 3/31/26	2/1-2/28		
OX RIDGE SCHOOL SS (05428)	4/1/25 - 6/30/25	5/1-5/31	Complete	
	7/1/25 - 9/30/25	8/1-8/31	Complete	
	10/1/25 - 12/31/25	11/1-11/30		
	1/1/26 - 3/31/26	2/1-2/28		
TOKENEKE RD DARIEN (05429)	4/1/25 - 6/30/25	5/1-5/31	Complete	
	7/1/25 - 9/30/25	8/1-8/31	Complete	
	10/1/25 - 12/31/25	11/1-11/30		
	1/1/26 - 3/31/26	2/1-2/28		
9 FAIRMEAD RD SS (05430)	4/1/25 - 6/30/25	5/1-5/31	Complete	
	7/1/25 - 9/30/25	8/1-8/31	Complete	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0350011	AQUARION-DARIEN			C	18,737	P	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							6,844	

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Disinfectant Byproducts - TTHM & HAA5 (DBP)** **4 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	

**Lead And Copper (PBCU)** **30 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	

**Physical Parameters (PPS)** **20 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **ENTRY POINT - REWAK WELL (WSF ID: 00700)**

**Net Gross Alpha (4000)** **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

**Uranium (4006)** **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

**Combined Radium-226/228 (4010)** **1 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

**Gross Beta Particle Activity (4100)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0350011	AQUARION-DARIEN			C	18,737	P	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							6,844	

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

### Monitoring Requirements

Water System Facility: ENTRY POINT - REWAK WELL (WSF ID: 00700)

<b>Man-Made Beta Particle &amp; Photon Emitters (4101)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Tritium (4102)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Strontium-90 (4174)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>		<b>2 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>		<b>2 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - REWAK (3)	4/1/25 - 6/30/25		Out of Service
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: REWAK WELL (WSF ID: 1434)			
<b>E. Coli (3014)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
REWAK WELL (2)	4/1/25 - 6/30/25		Out of Service
	7/1/25 - 9/30/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0350011	AQUARION-DARIEN			C	18,737	P	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							6,844	

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

### Monitoring Requirements

Water System Facility: **REWAK WELL (WSF ID: 1434)**

**E. Coli (3014)** **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT - REWAK WELL (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)		Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)		Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023		Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline	5/1/2025 - 5/31/2025	n/a	Y
	Offline	6/1/2025 - 6/30/2025	n/a	Y
	Offline	7/1/2025 - 7/31/2025	n/a	Y
	Offline	8/1/2025 - 8/31/2025	n/a	Y
		9/1/2025 - 9/30/2025		

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	9/8/2023	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/21/2025
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0350011	AQUARION-DARIEN			C	18,737	P	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							6,844	

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	05408	HOLMES SCHOOL SS	A	Y		Y	
		05408D	HOLMES SCHOOL SS - D	A	Y			
		05408U	HOLMES SCHOOL SS - D	A	Y			
		05411	NORWALK STATION	A	Y			
		05412	CHESTNUT ST STATION	A	Y			
		05413	POST ROAD STATION	A	Y			
		05414	ST LUKE'S CHURCH	A	Y			
		05415	OX RIDGE SCHOOL	A	Y			
		05416	WHITE BRIDGE DELI	I	Y			
		05417	PARK LANE STATION	A	Y			
		05418	SPRINGDALE FLORIST	A	Y			
		05419	ROGERS & CASEY	I	Y			Y
		05420	TOKENEKE SCHOOL	A	Y			
		05421	HINDLEY SCHOOL	A	Y			
		05422	HOLMES SCHOOL	A	Y			
		05423	HOLLOW TREE RIDGE	A	Y			
		05424	BROOKSIDE RD SS	A	Y			
		05425	TOKENEKE SCHOOL SS	A	Y			
		05426	UNITED METHODIST	A	Y			Y
		05427	HINDLEY SCHOOL SS	A	Y			
		05428	OX RIDGE SCHOOL SS	A	Y			Y
		05429	TOKENEKE RD DARIEN	A	Y			Y
		05430	9 FAIRMEAD RD SS	A	Y			Y
		05430D	9 FAIRMEAD DR SS - D	A	Y			
		05430U	9 FAIRMEAD DR SS - D	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB6079	21 GARDINER DARIEN	A			1	
		PB6080	69 WEST DARIEN	A			1	
		PB6081	93 FITCH DARIEN	A			1	
		PB6082	17 DICKINSON DARIEN	A			1	
		PB6083	30 PEAR TREE POINT	A	Y		1	
		PB6084	180 PEAR TREE POINT	A	Y		1	
		PB6085	45 GOODWIVES RVR DA	A			3	
		PB6086	85 GOODWIVES RVR DAR	A			1	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0350011	AQUARION-DARIEN			C	18,737	P	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							6,844	

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB6087	11 BEACH DRIVE	A	Y	1		
		PB6088	5 PARK DARIEN	A		1		
		PB6089	6 BY DARIEN	A		1		
		PB6090	4 BY ROAD DARIEN	A		1		
		PB6091	158 MIDDLESEX DARIEN	A		1		
		PB6092	12 MAPLE DARIEN	A		1		
		PB6093	366 HOLOWTRE RDG DAR	A		1		
		PB6094	18 LONG NECK POINT	A	Y	1		
		PB6095	21 DUBOIS DARIEN	A		1		
		PB6096	3 DICKINSON DARIEN	A		1		
		PB6097	8 LAFORGE RD DARIEN	A		3		
		PB6098	24 CRISTIE HILL ROAD	A	Y	1		
		PB6099	24 CHARLES DARIEN	A		1		
		PB6100		A	Y	1		
		PB6101	13 PHILLIPS DARIEN	A		3		
		PB6102	7 HIGHLAND DARIEN	A		1		
		PB6103	14 EDGEWOOD DARIEN	A		1		
		PB6104	7 WOODS END DARIEN	A		1		
		PB6105	18 PINEBROOK LA DAR	A		1		
		PB6106	17 LAKESIDE DARIEN	A		1		
		PB6107	64 ANDREWS DRIVE	A	Y	1		
		PB6108	17 POND DARIEN	A		1		
		PB6109	2 MAYWOOD DARIEN	A		1		
		PB6110	2 ROCATON DARIEN	A		3		
		PB6111	5 CHESTNUT DARIEN	A		3		
		PB6112	19 BIRCH DARIEN	A		3		
		PB6113	10 COLONY DARIEN	A		1		
		PB6256	25 RAYMOND ST DAR	A		3		
		PB6257	12 CEDAR GATE RD DAR	A		3		
		PB6260	19 WILLIAM ST DAR	A		3		
		PB6270	6 WOODLAND DR DAR	A		3		
		PB6271	23 OUTLOOK DR DAR	A		3		
		PB6272	150 GOODWVES RVR DA	A		3		
		PB6273	61 ANDREWS DR DAR	A		3		
		PB6301	24 HALE LANE DARIEN	A		1		
		PB6303	58 ANDREWS DR DAR	A		3		
		PB6304	116 RAYMOND SR DAR	A		3		
		PB6306	5 QUEENS LAND DAR	A		3		
		PB6372	74 HOLLOWTREE RDG	A		3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0350011	AQUARION-DARIEN			C	18,737	P	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							6,844	

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PB6375	1 PHILLIPS LANE DARI	A		3		
		PB6836	105 LEROY AVE DARIEN	A		3		
		PB6841	5 WINDSOR ROAD DARIE	A		3		
		PB8099	14 EDMOND STREET	A	Y	1		
		PB8100	52 FAIRFIELD AVENUE	A	Y	1		
		PB8101	11 OAK SHADE AVENUE	A	Y	1		
		PB8102	12 OAK SHADE AVENUE	A	Y	1		
		PB8103	8 PARK PLACE	A	Y	1		
		PB8104	34 PARK PLACE	A	Y	1		
		PB8105	40 PARK PLACE	A	Y	1		
		PB8106	6 PINE STREET	A	Y	1		
		PB8107	60 RAYMOND STREET	A	Y	1		
		PB8109	5 WOODLAND DRIVE	A	Y	1		
		PB8110	21 WOODLAND DRIVE	A	Y	1		
		PB8111	8-A RIDGEVIEW AVE	A	Y	1		
		PB8112	23-A ANTHONY LANE	A	Y	1		
		PB8113	1 SILVER LAKES DRIVE	A	Y	1		
		PB8114	2 STONEWALL LANE	A	Y	1		
		PB8115	2 ST. NICHOLAS ROAD	A	Y	1		
		PB8116	2 IRONWOOD LANE	A	Y	1		
		PB8117	2 RED BARN ROAD	A	Y	1		
		PB8118	2 LITTLEBROOK ROAD	A	Y	1		
		PB8119	3 CLIFF AVE	A	Y	1		
		PB8120	4 DELLWOOD ROAD	A	Y	1		
		PB8121	4 ROCK SPRING LANE	A	Y	1		
		PB8122	4 LOCUST HILL ROAD	A	Y	1		
		PB8124	5 LEEDS LANE	A	Y	1		
		PB8125	5 HIGHLAND AVE	A	Y	1		
		PB8126	6 MOREHOUSE DRIVE	A	Y	1		
		PB8127	6 ROCK SPRING LANE	A	Y	1		
		PB8128	6 LITTLEBROOK ROAD	A	Y	1		
		PB8129	7 POINT O WOODS ROAD	A	Y	1		
		PB8130	7 ANDREWS DRIVE	A	Y	1		
		PB8131	8 RIDGEVIEW AVE	A	Y	1		
		PB8132	8 OVERBROOK LANE	A	Y	1		
		PB8133	8 ROCK SPRING LANE	A	Y	1		
		PB8134	8 OAK PARK AVE	A	Y	1		
		PB8135	9 POINT O WOODS ROAD	A	Y	1		
		PB8136	9 STONY BROOK ROAD	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0350011	AQUARION-DARIEN			C	18,737	P	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							6,844	

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

### Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		PB8137	9 PARK PLACE	A	Y	1		
		PB8138	10 ROCK SPRING LANE	A	Y	1		
		PB8139	12 TOKENEKE TRAIL	A	Y	1		
		PB8303	PB8303 - 14 EDMOND	A	Y			
		PB8304	40 PEACHTREE POINT	A	Y			
		PB8892	15 EDGEWOOD RD	A		1		
		PB8893	15 WEEDS LANDING	A		1		
		PB8894	15 FIVE MILE RIVER	A		1		
		PB8895	16 1/2 MAPLE ST	A		1		
		PB8896	17 RAYMOND HEIGHTS	A		1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - REWAK WELL	3	ENTRY POINT - REWAK	A				
1434	REWAK WELL	2	REWAK WELL	A				
44903	INTERCONNECTION - CT1030021 - FLAX HILL							
48251	INTERCONNECTION - CT0150011 - AWC MAIN							
48253	INTERCONNECTION - CT1350011 - STAMFORD							
49515	CHESTNUT STREET TANK 2							
49517	MANSFIELD TANK							
49519	CHESTNUT STREET PUMP STATION							
49521	OLD KINGS PUMP STATION							
49523	PARK LANE PUMP STATION							
49525	POST ROAD PUMP STATION							
49527	REWAK PUMP STATION							
49529	TALMADGE HILL PUMP STATION							
58	REWAK WELL STATION							
60644	REWAK CLEARWELL							
61575	INTERCONNECTION - CT0150011 - AWC MAIN							
61577	INTERCONNECTION - CT1350011 - STAMFORD							
61579	INTERCONNECTION - CT1350011 - STAMFORD							
61581	INTERCONNECTION - CT1350011 - STAMFORD							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0350011	AQUARION-DARIEN			C	18,737	P	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							6,844	

Towns Served: DARIEN, NEW CANAAN, NORWALK, STAMFORD

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HORN, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028

Water System Facility: **REWAK WELL STATION (WSF ID: 58)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
MEDD, DAVID	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
REPPUCCI, EDWARD	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026

### Contact Information

Name				Organization		Job Title			
Mr. John P. Walsh				Aquarion Water Company		Vice President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
835 Main Street			Mail Stop 700			Bridgeport		CT	06604
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-337-5852			203-337-5938			781-413-6175	jwalsh@aquarionwater.com		

Contact Role(s): **Legal Contact**

Name				Organization			Job Title		
Mr. Robert J. Ulrich				Aquarion Water Company of Ct			Vp-Supply & Utility		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
505 Huntington St.						Shelton		CT	06484
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-926-4320			203-929-5297			203-395-3205	rulrich@aquarionwater.com		

Contact Role(s): **Administrative Contact**

#### Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**