

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0460024	CHRIST CHURCH			NTNC	57	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 CHURCH ROAD					1			
Towns Served: EASTON								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Alkalinity (1927)		2 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule							
PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0460024	CHRIST CHURCH			NTNC	57	P	GW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
59 CHURCH ROAD		Connections		1			
Towns Served: EASTON							
Monitoring Requirements							
Water System Facility: ENTRY POINT (WSF ID: 00700)							
Organic Chemicals (VOCS)				1 routine (RT) per three years			
Sampling Point (Sampling Point ID)			Monitoring Period	Collection Period	Compliance Status		
ENTRY POINT (3)			1/1/23 - 12/31/25				
			1/1/26 - 12/31/28				
Monthly Water System Facility (WSF) Level Monitoring Requirements							
Water System Facility: ENTRY POINT (WSFID: 00700)							
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
pH	Entry Point pH Monitoring (PHRD)		Minimum: 7.0 PH		4		
Start Date: 5/1/2023		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		5/1/2025 - 5/31/2025		Y			
		6/1/2025 - 6/30/2025		Y			
		7/1/2025 - 7/31/2025		Y			
		8/1/2025 - 8/31/2025		Y			
		9/1/2025 - 9/30/2025					
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
pH	<spaces> ()		Maximum: 7.5 PH		4		
Start Date: 5/1/2023		Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		5/1/2025 - 5/31/2025					
		6/1/2025 - 6/30/2025					
		7/1/2025 - 7/31/2025					
		8/1/2025 - 8/31/2025					
		9/1/2025 - 9/30/2025					
Other Compliance Schedules							
Compliance Schedule Activity			Due Date		Achieved Date		
CROSS CONNECTION EXEMPTION			3/1/2026				
Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		CC001	KIT SNK NEW SNK	A	Y	2	Y
		CC002	KIT SNK OLD SNK	A	Y	2	Y
		CC003	RR BOYS ROOM	A	Y	2	Y
		CC004	RR GIRLS ROOM	A	Y	2	Y
		CC005	PRESCHOOL 1	A	Y	2	Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0460024	CHRIST CHURCH			NTNC	57	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 CHURCH ROAD					1			
Towns Served: EASTON								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
1739	CHRIST CHURCH TREATMENT PLANT							
20850	WELL	2	WELL	A				

Certified Operator Information

Water System Facility: CHRIST CHURCH TREATMENT PLANT (WSF ID: 1739)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

Contact Information

Name				Organization			Job Title		
Ms. Victoria Markanthony				Christ Church of Easton			Senior Warden		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
59 Church Rd						Easton		CT	06612
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-268-3569						203-551-4728	eastonparish1762@sbcglobal.net		

Contact Role(s): Legal Contact

Name				Organization			Job Title		
Mr. David McCann				Christ Church of Easton			Buildings & Grounds		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
59 Church Road						Easton		CT	06612
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-268-3569					fiddledm50@aol.com				

Contact Role(s): Administrative Contact

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0460054	CONGREGATIONAL CHURCH OF EASTON			NTNC	55	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
336 WESTPORT ROAD				1			
Towns Served: EASTON							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0460054	CONGREGATIONAL CHURCH OF EASTON	NTNC	55	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
336 WESTPORT ROAD				1			
Towns Served: EASTON							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)

1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)

1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)

1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2027	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CC001	KITCHEN SINK L	A	Y	2	Y	Y
		CC002	KITCHEN SINK R	A	Y	2		Y
		CC003	1ST FLR REST RM	A	Y	2		Y
		CC004	1ST FLR HAND SINK	A	Y	2		Y
		CC005	2ND FLR MENS RM	A	Y	2		Y
		CC006	2ND FLR WOMENS RM	A	Y	2		Y
		CC007	NURSERY SINK	A	Y	2		Y
		CC008	3RD FLR REST RM	A	Y	2		Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10884	WELL	2	WELL	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, ANDREW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0460054	CONGREGATIONAL CHURCH OF EASTON			NTNC	55	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
336 WESTPORT ROAD					1			
Towns Served: EASTON								

Contact Information

Name				Organization			Job Title		
Mr. Phillip A Doremus				Congregational Church Easton			Chair		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
PO Box 37						Easton		CT	06612
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
					philldoremus@gmail.com				

Contact Role(s): **Legal Contact**

Name				Organization		Job Title			
Ms. Katie O. Croarkin				Congregational Church Easton		Secretary			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
336 Westport Road			P.O. Box 37			Easton		CT	06612
Business Phone	Extension	Fax		Mobile Phone	Emergency Phone	Email Address			
203-261-2527					203-521-7845	cchurcheaston@gmail.com			

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule