

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0470021	SCHOOL HILL ASSOCIATION, INC.			C	77	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ELAINE DRIVE, BROAD BROOK, CT				31				
Towns Served: EAST WINDSOR								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/26	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Nitrate (1040)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Nitrite (1041)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Ethylene Dibromide (EDB) (2946)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470021	SCHOOL HILL ASSOCIATION, INC.			C	77	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ELAINE DRIVE, BROAD BROOK, CT			31				
Towns Served: EAST WINDSOR							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	9/22/2022	
CROSS CONNECTION EXEMPTION	3/1/2030	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	BETWEEN GAC FILTERS	5		A				
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSSTREAM	WITHIN 5 SERVICE CON	A				
		GWS002	5 ELAINE DRIVE-KITCH	A	Y	3	Y	Y
		GWS003	9 ELAINE DRIVE-KITCH	A	Y	3	Y	Y
		GWS004	20 ELAINE DRIVE-BATH	A	Y	3	Y	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0470021	SCHOOL HILL ASSOCIATION, INC.			C	77	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ELAINE DRIVE, BROAD BROOK, CT				31				
Towns Served: EAST WINDSOR								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		GWS005	6 HELENA DRIVE-KITCH	A	Y	3	Y	Y
		GWS006	34 WINDSORVILLE RD	A	Y	3	Y	Y
		GWS007	11 ELAINE DR	A	Y	3	Y	Y
		GWS008	24 ELAINE DR	A	Y	3	Y	Y
		GWS009	8 ELAINE DR	A	Y	3	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
359	SCHOOL HILL PUMP HOUSE							
52	WELL 1	2	WELL 1	A				
53007	PRESSURE STORAGE							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

Water System Facility: **SCHOOL HILL PUMP HOUSE (WSF ID: 359)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

Contact Information

Name				Organization				Job Title		
Ms. Susan Clavette				School Hill Assn., Inc.				President		
Mailing Address Line One			Mailing Address Line Two				City		State	Zip Code
26 Elaine Drive							Broad Brook		CT	06016
Business Phone		Extension	Fax		Mobile Phone		Emergency Phone	Email Address		
860-335-0864								schoolhillassociation@gmail.com		
Contact Role(s): Administrative Contact, Legal Contact										

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470021	SCHOOL HILL ASSOCIATION, INC.			C	77	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ELAINE DRIVE, BROAD BROOK, CT			31				
Towns Served: EAST WINDSOR							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0470031	WINDSORVILLE WATER ASSOCIATION			C	29	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WINDSORVILLE RD & APOTHECARIES HALL RD				13				
Towns Served: EAST WINDSOR								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/25		
	1/1/26 - 12/31/34		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0470031	WINDSORVILLE WATER ASSOCIATION			C	29	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WINDSORVILLE RD & APOTHECARIES HALL RD				13				
Towns Served: EAST WINDSOR								

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Lead and Copper M&R Violation	7/1/25 -	3	10/2/2026		10/12/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
			DOWNTSTREAM WITHIN 5 SERVICE CON	A				
			UPSTREAM WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
51	WELL 1	2	WELL 1	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type		Primary Source	
CT0470031	WINDSORVILLE WATER ASSOCIATION			C	29	P		GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
WINDSORVILLE RD & APOTHECARIES HALL RD				13					
Towns Served: EAST WINDSOR									

Contact Information

Name				Organization			Job Title		
Mr. Roger Bourgeois				Windsorville Association					
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 92						Broadbrook		CT	06016
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-834-1826					rjbourgeois@netzero.net				
Contact Role(s): Administrative Contact, Legal Contact, Owner									

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0470071	EAST WINDSOR HOUSING AUTHORITY			C	94	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1A PARK HILL				84				

Towns Served: EAST WINDSOR

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Nitrite (1041)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 9/30/24	1/1-9/30	Complete
Gross Beta Particle Activity (4100)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Tritium (4102)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Strontium-90 (4174)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0470071	EAST WINDSOR HOUSING AUTHORITY			C	94	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1A PARK HILL				84				
Towns Served: EAST WINDSOR								

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/28		Complete
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-001	COMMUNITY HALL KITC	A	Y	1		
		4-002	1ST LEVEL LAUNDRY	A	Y	1		
		4-003	DISTRIBUTION ROOM	A	Y		Y	
		4-004	MAINTENANCE GARAGE	A	Y			
		4-005	2ND LEVEL LAUNDRY	A	Y	1		
		4-006	3RD LEVEL LAUNDRY	A	Y	1		
		4-007	APARTMENT #66	A	Y	1	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0470071	EAST WINDSOR HOUSING AUTHORITY			C	94	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1A PARK HILL				84				
Towns Served: EAST WINDSOR								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
50	WELL 1	2	WELL 1	A				
53049	ATMOSPHERIC STORAGE							
61	WELL 2	2	WELL 2	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028 6/30/2026
NIGRO, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

Contact Information

Name			Organization			Job Title		
East Windsor Housing Authority								
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
Emergency Contact						Emergency Contact	CT	06000
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-623-8929								

Contact Role(s): **Owner**

Name			Organization			Job Title		
Ms. Marisa Prior			East Windsor Housing Authority			Executive Director		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
1A Park Hill						Broad Brook	CT	06016
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-623-8467		860-623-8554		860-463-4422	ewha1966@gmail.com			

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012) **100 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete

Asbestos (1094) **2 routine (RT) per nine years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		

Total Haloacetic Acids (2456) **4 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
29 S MAIN, S WINDSOR (3084)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
678 OLD POST RD, TOLLAND (3085)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
ISABELLA COURT PS (31905)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
CLUB HOUSE (MW001)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	

Total Trihalomethanes (2950) **4 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
149 ELLA GRASSO TNPK (3065A)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
ELSWRTH,26 RYE,BDBRK (3067)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
1275 JOHN FITCH, S WND SR (3081)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Trihalomethanes (2950) **4 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
201 LAKE ST, VERNON (3083)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	

Total Coliform (3100) **100 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Lead And Copper (PBCU) **60 routine (RT) per six months**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete

Lead And Copper (PBCU) **100 routine (RT) per six months**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		

Physical Parameters (PPS) **100 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)		100 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Water Quality Parameters Orthophosphate, Total Phosphate, To (WQ12)		50 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT - ROCKVILLE WTP (WSF ID: 00700)**

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - ROCKVILLE WTP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Water System Facility: ENTRY POINT - HUNT WELLFIELD (WSF ID: 00701)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-HUNT WELLFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Monitoring Requirements

Water System Facility: ENTRY POINT - HUNT WELLFIELD (WSF ID: 00701)

Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP-HUNT WELLFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: ENTRY POINT - POWDER HOLLOW WELL FIELD (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: ENTRY POINT - POWDER HOLLOW WELL FIELD (WSF ID: 00702)

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 1 (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - POWDER HOLLOW WELL FIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: ENTRY POINT - SPRING LOTS WELLFIELD (WSF ID: 00703)

Inorganic Chemicals (IOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 1 (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - SPRING LOTS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: ENTRY POINT - VERNON WELL 5 (WSF ID: 00709)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Monitoring Requirements

Water System Facility: ENTRY POINT - VERNON WELL 5 (WSF ID: 00709)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-VERNON WELL 5 (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Water System Facility: ENTRY POINT - WOODLAND PARK WELL (WSF ID: 00713)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Monitoring Requirements

Water System Facility: ENTRY POINT - WOODLAND PARK WELL (WSF ID: 00713)

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Gross Beta Particle Activity (4100)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Tritium (4102)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Strontium-90 (4174)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WOODLAND PARK (3)	4/1/25 - 6/30/25		Out of Service
	7/1/25 - 9/30/25		

Water System Facility: ENTRY POINT - PINE KNOB WELL (WSF ID: 00714)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Monitoring Requirements

Water System Facility: ENTRY POINT - PINE KNOB WELL (WSF ID: 00714)

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINE KNOB WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: ENTRY POINT - WEST SUFFIELD WELL (WSF ID: 00715)

Net Gross Alpha (4000) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: ENTRY POINT - WEST SUFFIELD WELL (WSF ID: 00715)

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEST SUFFIELD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: ENTRY POINT - O'BREADY (WSF ID: 00719)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-O'BREADY (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-O'BREADY (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-O'BREADY (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-O'BREADY (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: ENTRY POINT - O'BREADY (WSF ID: 00719)

Nitrate And Nitrite (NOX)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-O'BREADY (3)	4/1/25 - 6/30/25		Out of Service
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-O'BREADY (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-O'BREADY (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: SPRING LOTS WELL 3 (WSF ID: 1245)

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
WELL SPRING LOTS 3 (2)	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

E. Coli (3014)		1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
WELL SPRING LOTS 3 (2)	8/4/25 - 8/10/25		Complete	

Water System Facility: SPRING LOTS WELL 5 (WSF ID: 1247)

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SPRING LOTS WELL 5 (2)	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Monitoring Requirements

Water System Facility: **SPRING LOTS WELL 5 (WSF ID: 1247)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

E. Coli (3014)		1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SPRING LOTS WELL 5 (2)	8/4/25 - 8/10/25		Complete	

Water System Facility: **O'BREADY WELL (WSF ID: 1267)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
O'BREADY WELL (2)	5/1/25 - 5/31/25		Out of Service	
	6/1/25 - 6/30/25		Out of Service	
	7/1/25 - 7/31/25		Out of Service	
	8/1/25 - 8/31/25		Out of Service	
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

E. Coli (3014)		1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
O'BREADY WELL (2)	8/4/25 - 8/10/25		Out of Service	

Water System Facility: **POWDER HOLLOW WELL 1 (WSF ID: 1268)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
POWDER HOLLOW WELL 1 (2)	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Monitoring Requirements

Water System Facility: **POWDER HOLLOW WELL 1 (WSF ID: 1268)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
POWDER HOLLOW WELL 1 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: **HUNT WELL 5 (WSF ID: 1278)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 5 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 5 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: **HUNT WELL 6 (WSF ID: 1279)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 6 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: HUNT WELL 6 (WSF ID: 1279)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 6 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: HUNT WELL 8 (WSF ID: 1281)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 8 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 8 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: HUNT WELL 9 (WSF ID: 1282)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 9 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: **HUNT WELL 9 (WSF ID: 1282)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

E. Coli (3014)		1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
HUNT WELL 9 (2)	8/4/25 - 8/10/25		Complete	

Water System Facility: **PINE KNOB WELL (WSF ID: 168)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
PINE KNOB WELL (2)	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			

E. Coli (3014)		1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
PINE KNOB WELL (2)	8/4/25 - 8/10/25		Complete	

Water System Facility: **VERNON WELL 5 (WSF ID: 177)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
VERNON WELL 5 (2)	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: **VERNON WELL 5 (WSF ID: 177)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
VERNON WELL 5 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: **HUNT WELL 10 (WSF ID: 1937)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 10 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	E. Coli (3014)		1 triggered (TG) per period
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HUNT WELL 10 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: **POWDER HOLLOW WELL 4 (WSF ID: 1938)**

E. Coli (3014)		1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
PH WELL 4 (2)	5/1/25 - 5/31/25		Complete	
	6/1/25 - 6/30/25		Complete	
	7/1/25 - 7/31/25		Complete	
	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25			
	10/1/25 - 10/31/25			
	11/1/25 - 11/30/25			
	12/1/25 - 12/31/25			
	1/1/26 - 1/31/26			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: **POWDER HOLLOW WELL 4 (WSF ID: 1938)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PH WELL 4 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: **SHENIPSIT LAKE (WSF ID: 2077)**

Total Alkalinity (1927)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SHENIPSIT LAKE (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SHENIPSIT LAKE (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: **SHENIPSIT LAKE (WSF ID: 2077)**

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SHENIPSIT LAKE (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SHENIPSIT LAKE (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SHENIPSIT LAKE (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SHENIPSIT LAKE (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **WEST SUFFIELD WELL (WSF ID: 38)**

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WEST SUFFIELD WELL (2)	8/4/25 - 8/10/25		Complete

Water System Facility: **SPRING LOTS WELL 7 (WSF ID: 47835)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING LOTS WELL 7 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Monitoring Requirements

Water System Facility: **SPRING LOTS WELL 7 (WSF ID: 47835)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING LOTS WELL 7 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: **SPRING LOTS WELL 8 (WSF ID: 52905)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING LOTS WELL 8 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING LOTS WELL 8 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: **SPRING LOTS WELL 9 (WSF ID: 54961)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING LOTS WELL 9 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Monitoring Requirements

Water System Facility: **SPRING LOTS WELL 9 (WSF ID: 54961)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/26 - 4/30/26		

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SPRING LOTS WELL 9 (2)	8/4/25 - 8/10/25		Complete

Water System Facility: **POWDER HOLLOW WELL 5 (WSF ID: 59713)**

E. Coli (3014)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
POWDER HOLLOW WELL 5 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

E. Coli (3014)	1 triggered (TG) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
POWDER HOLLOW WELL 5 (2)	8/4/25 - 8/10/25		Complete

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT - ROCKVILLE WTP (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility: **ENTRY POINT - ROCKVILLE WTP (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3.0 MG/L	2
Start Date: 4/1/2025	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 5/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3.0 MG/L	2
Start Date: 5/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility: **ENTRY POINT - HUNT WELLFIELD (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3.0 MG/L	2
Start Date: 1/1/2006	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility: **ENTRY POINT - POWDER HOLLOW WELL FIELD (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.5 MG/L	Daily
Start Date: 6/1/2021	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Water System Facility: **ENTRY POINT - SPRING LOTS WELLFIELD (WSFID: 00703)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2008	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility: **ENTRY POINT - SPRING LOTS WELLFIELD (WSFID: 00703)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Water System Facility: **ENTRY POINT - VERNON WELL 5 (WSFID: 00709)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2024	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility: **ENTRY POINT - VERNON WELL 5 (WSFID: 00709)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Water System Facility: **ENTRY POINT - WOODLAND PARK WELL (WSFID: 00713)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)		Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)		Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023	Compliance History:		Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
	Offline	5/1/2025 - 5/31/2025	n/a	Y
	Offline	6/1/2025 - 6/30/2025	n/a	Y
	Offline	7/1/2025 - 7/31/2025	n/a	Y
	Offline	8/1/2025 - 8/31/2025	n/a	Y
		9/1/2025 - 9/30/2025		

Water System Facility: **ENTRY POINT - PINE KNOB WELL (WSFID: 00714)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.05 MG/L	Daily
Start Date: 8/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility: **ENTRY POINT - PINE KNOB WELL (WSFID: 00714)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Water System Facility: **ENTRY POINT - O'BREADY (WSFID: 00719)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 6/1/2023	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 5/1/2025 - 5/31/2025	n/a	Y
	Offline 6/1/2025 - 6/30/2025	n/a	Y
	Offline 7/1/2025 - 7/31/2025	n/a	Y
	Offline 8/1/2025 - 8/31/2025	n/a	Y
	9/1/2025 - 9/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility: **ENTRY POINT - O'BREADY (WSFID: 00719)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 6/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **ROCKVILLE WATER TREATMENT PLANT (WSFID: 60576)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 5/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 5/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility: **SOMERS PUMP STATION TREATMENT PLANT (WSFID: 63236)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Average: 1.5 MG/L	2
Start Date: 4/1/2025	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/3/2025
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	
CAP - ADDRESS DEFICIENCY	12/31/2027	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	RAW ENTRY POINT - WNDSR LKS CAISN WELLS	2	RAW ENRTY POINT	A				
00600	DISTRIBUTION SYSTEM	3050	RADISSN HTL 5/91,ENF	A	Y			Y
		3051	PRUDNCE CRANDL S,ENF	A	Y			
		3052	DUNK DON,651 ENF	A	Y		Y	
		3053	ENF AUTO TRM,941 ENF	A	Y			
		3054	ENF SAFETY CMP,ELM S	A	Y			Y
		3055	MARSHALLS 10 HAZ,ENF	A	Y			
		3056	CVS, 90 MAIN S,WL	A	Y			
		3057	AHLSTROM,1 ELM, WL	A	Y			
		3058	DARY MRT,245 ELLA,WL	A	Y			
		3059	SUF BOOSTER, SUF ST	A	Y			Y
		3060	CT WATER CO, EW	A	Y		Y	Y
		3061	CVS, 163 MTN RD, SUF	A	Y			Y
		3062	SWPD, 151 SND HL,SW	A	Y			Y
		3063	SUNDAE,845 SULL A,SW	A	Y			
		3064	(30643) CRESCENT LAK	A	Y			
		30643	31 LAKE DR, ENFIELD	A	Y			
		3065	BUDGET R-A-C,B/F,WL.	I	Y			Y
		3065A	149 ELLA GRASSO TNPK	A	Y			Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND. VERNON. WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2	DBPR
		3066	1 BRIDL PTH LN,RH,VN	A	Y				
		3067	ELSWRTH,26 RYE,BDBRK	A	Y			Y	Y
		3069	ENFIELD BOOSTER STA	A			Y		
		30801	60 ELM ST, VN	A		3			
		30802	55 TOLLAND GREN	A		3			
		30803	69 MOUNTAIN ST, ROCK	A		1			
		30804	120 PROSPECT ST,ROCK	A		3			
		30805	371 ELM ST,WIN LOCKS	A		N			
		30806	46 CENTER ST,WN LCKS	I		3			
		30807	71 SUFFIELD ST, WL	A		3			
		30808	25 OAK ST, SW	I		N			
		30809	107 RIVER RD, WL	A		N			
		3081	1275 JOHN FITCH, S W	A	Y			Y	Y
		30810	1 AYERSHIRE CT, SFD	A		N			
		30811	1680 MAPLETN AVE,SFD	A		1			
		30812	146 E GRAYLING, SF	A		2			
		30813	39 ARLINGTON RD,WL	A		3			
		30814	92 BRIAN RD, STH WIN	A		3			
		30815	3D SPRING CT,BRD BRK	I		N			
		30816	144 S CENTER ST, WL	A		3			
		30817	11 FIRST AVE, ENFLD	A		3			
		30818	36 VIRGINIA AVE,ENFD	A		3			
		30819	8 CIDERMILL RD. TOLL	A		3			
		3082	51 TOLLAND GRN, TOLL	A					Y
		30820	3 STONE STREET, ROCK	A		3			
		30821	75 GRAHAM RD. BB	A		1			
		30822	103 RIVER RD. WL	A		3			
		30823	241 N GRAND ST. WS	I		3			
		30824	46 TROMBLEY RD. EW	I		3			
		30825	144 E GRAYLING, SFD	A		2			
		30826	55 GRAHAM RD. BB	A		1			
		30827	21 FIRST AVE, ENF	A		1			
		30828	29 MARION ST. WL	A		3			
		30829	3A PASCO DR. EW	I		N			
		3083	201 LAKE ST, VERNON	A					Y
		30830	150 BERNADINO ENF	A		3			
		30831	15 NIEDERWERFER SW	A		2			
		30832	87 MEADOWLARK, VN	A		N			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2	DBPR
		30833	48 TROMBLEY RD, EW	A		3			
		30834	26 PINNEY ST, ELL	A		N			
		30835	56 MIDDLE RD, ELL	A		3			
		30836	1 ELEANOR RD. ENF	A	Y	3			
		30837	36 WHITON ST, ENF	I		3			
		30838	33 ST THOMAS ST, ENF	A		3			
		30839	85 OLD TOWN RD, VN	A		N			
		3084	29 S MAIN, S WINDSOR	A	Y			Y	Y
		30840	17 FIRST AVE, ENF	A		1			
		30841	16 ROBERT RD, ROCK	A		3			
		30842	1 SHARREN LN, ENF	A		3			
		30843	36 COOLIDGE ST, WL	A		3			
		30844	17 WASHINGTN AV, EN	I		N			
		30845	16 COOLIDGE ST, WL	I		3			
		30846	13 RIVERA DR, ENF	A		3			
		30847	5 HATHAWAY AV, EN	A		3			
		30848	22 BROADLEAF LN, EN	A		3			
		30849	96 DIBBLE HOLLOW, WL	I		N			
		3085	678 OLD POST RD, TOL	A					Y
		30850	49 LAUREL CIRCLE, EW	A		N			
		30851	47 WINKLER RD, EW	A		3			
		30852	17 KENT LN, SW	A		3			
		30853	41 WOODLAND TER SF	I		3			
		30854	154 ORCHARD ST, ELL	I		N			
		30855	34 GORDON AVE, ENF	A		3			
		30856	8A PASCO DR, EW	I		N			
		30857	142 GROVE ST, VN	I		N			
		30858	105 GROVE ST, VN	A		3			
		30859	44 WEST RD, SW	A		N			
		30860	8 MAIN ST, WL	I		N			
		30861	23 PEARL ST, WL	A		3			
		30862	53 NORTON RD, EW	A	Y	1			
		30863	2 BROCKWAY RD, ELL	A	Y	1			
		30864	8 GRANT RD, ELL	A	Y	1			
		30865	10 GRANT RD, ELL	A	Y	1			
		30866	57 HAYES AVE, ELL	A	Y	1			
		30867	119 PINNEY ST, ELL	A	Y	1			
		30868	123 PINNEY ST, ELL	A	Y	1			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND. VERNON. WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		30869	7 RIDGEVIEW DR, ELL	A	Y	1		
		30870	54 UPR BTCHR RD, ELL	A	Y	1		
		30871	26 WINDMILL RD, ELL	A	Y	1		
		30872	35 WINDMILL RD, ELL	A	Y	1		
		30873	52 WINDMILL RD, ELL	A	Y	1		
		30874	3 BOUVIER ST, ENF	A	Y	1		
		30875	45 BRIDGE LN, ENF	A	Y	1		
		30876	12 CARTIER RD, ENF	A	Y	1		
		30877	14 CARTIER RD, ENF	A	Y	1		
		30878	15 CARTIER RD, ENF	A	Y	1		
		30879	17 CARTIER RD, ENF	A	Y	1		
		30880	19 CARTIER RD, ENF	A	Y	1		
		30881	20 CARTIER RD, ENF	A	Y	1		
		30882	15 CIRCLE DR, ENF	A	Y	1		
		30883	10 CONN AVE A, ENF	A	Y	1		
		30884	86 COTTAGE RD, ENF	A	Y	1		
		30885	177 COTTAGE RD, ENF	A	Y	1		
		30886	179 COTTAGE RD, ENF	A	Y	1		
		30887	24 DANNUNZIO AV, ENF	A	Y	1		
		30888	2 DEBBIE LN, ENF	A	Y	1		
		30889	2 DOVER RD, ENF	A	Y	1		
		30890	4 DOVER RD, ENF	A	Y	1		
		30891	6 DOVER RD, ENF	A	Y	1		
		30892	8 DOVER RD, ENF	A	Y	1		
		30893	3 E FOREST DR, ENF	A	Y	1		
		30894	4 E FOREST DR, ENF	A	Y	1		
		30895	5 E FOREST DR, ENF	A	Y	1		
		30896	6 E FOREST DR, ENF	A	Y	1		
		30897	7 E FOREST DR, ENF	A	Y	1		
		30898	8 E FOREST DR, ENF	A	Y	1		
		30899	9 E FOREST DR, ENF	A	Y	1		
		30900	10 E FOREST DR, ENF	A	Y	1		
		30901	11 E FOREST DR, ENF	A	Y	1		
		30902	12 E FOREST DR, ENF	A	Y	1		
		30903	5 ELM AVE, ENF	A	Y	1		
		30904	222 ELM ST, ENF	A	Y	1		
		30905	1164 ENFIELD ST, ENF	A	Y	1		
		30906	1265 ENFIELD ST, ENF	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		30907	1465 1/2 ENF ST, ENF	A	Y	1		
		30908	49 FAIRVIEW AVE, ENF	A	Y	1		
		30909	19 FALCON CREST, ENF	A	Y	1		
		30910	20 FALCON CREST, ENF	A	Y	1		
		30911	21 FALCON CREST, ENF	A	Y	1		
		30912	22 FALCON CREST, ENF	A	Y	1		
		30913	23 FALCON CREST, ENF	A	Y	1		
		30914	24 FALCON CREST, ENF	A	Y	1		
		30915	26 FALCON CREST, ENF	A	Y	1		
		30916	7 FIRST AVE, ENF	A	Y	1		
		30917	16 FIRST AVE, ENF	A	Y	1		
		30918	20 FIRST AVE, ENF	A	Y	1		
		30919	7 GAMMELLO AVE, ENF	A	Y	1		
		30920	2 HILLYER DR, ENF	A	Y	1		
		30921	8 HILLYER DR, ENF	A	Y	1		
		30922	1 HOLLY LN, ENF	A	Y	1		
		30923	19 JONDOT DR, ENF	A	Y	1		
		30924	5 LEON ST, ENF	A	Y	1		
		30925	9 MARGARET ST, ENF	A	Y	1		
		30926	48 OAKWOOD ST, ENF	A	Y	1		
		30927	5 ABAR LN, SW	A	Y	1		
		30928	6 ABAR LN, SW	A	Y	1		
		30929	14 ABAR LN, SW	A	Y	1		
		30930	15 ABAR LN, SW	A	Y	1		
		30931	20 ABAR LN, SW	A	Y	1		
		30932	21 ABAR LN, SW	A	Y	1		
		30933	27 ABAR LN, SW	A	Y	1		
		30934	28 ABAR LM, SW	A	Y	1		
		30935	32 ABAR LN, SW	A	Y	1		
		30936	33 ABAR LN, SW	A	Y	1		
		30937	18 ALEXANDER PL, SW	A	Y	1		
		30938	24 ALEXANDER PL, SW	A	Y	1		
		30939	30 ALEXANDER PL, SW	A	Y	1		
		30940	33 ALEXANDER PL, SW	A	Y	1		
		30941	36 ALEXANDER PL, SW	A	Y	1		
		30942	39 ALEXANDER PL, SW	A	Y	1		
		30943	7 ANDREIS TRL, SW	A	Y	1		
		30944	11 ANDREIS TRL, SW	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND. VERNON. WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		30945	19 ANDREIS TRL, SW	A	Y	1		
		30946	20 ANDREIS TRL, SW	A	Y	1		
		30947	30 ANDREIS TRL, SW	A	Y	1		
		30948	31 ANDREIS TRL, SW	A	Y	1		
		30949	38 ANDREIS TRL, SW	A	Y	1		
		3095	BRADLEY BOOSTER,WL	A	Y			Y
		30950	43 ANDREIS TRL, SW	A	Y	1		
		30951	46 ANDREIS TRL, SW	A	Y	1		
		30952	53 ANDREIS TRL, SW	A	Y	1		
		30953	54 ANDREIS TRL, SW	A	Y	1		
		30954	65 ANDREIS TRL, SW	A	Y	1		
		30955	73 ANDREIS TRL, SW	A	Y	1		
		30956	74 ANDREIS TRL, SW	A	Y	1		
		30957	79 ANDREIS TRL, SW	A	Y	1		
		30958	80 ANDREIS TRL, SW	A	Y	1		
		30959	88 ANDREIS TRL, SW	A	Y	1		
		30960	93 ANDREIS TRL, SW	A	Y	1		
		30961	97 ANDREIS TRL, SW	A	Y	1		
		30962	98 ANDREIS TRL, SW	A	Y	1		
		30963	104 ANDREIS TRL, SW	A	Y	1		
		30964	105 ANDREIS TRL, SW	A	Y	1		
		30965	108 ANDREIS TRL, SW	A	Y	1		
		30966	354 AVERY ST, SW	A	Y	1		
		30967	571 AVERY ST, SW	A	Y	1		
		30968	10 BENJAMIN WAY, SW	A	Y	1		
		30969	20 BENJAMIN WAY, SW	A	Y	1		
		3097	BRADLEY FIELD TANKS	A	Y			
		30970	25 BENJAMIN WAY, SW	A	Y	1		
		30971	BRADLEY TANK 1, WL	A	Y			
		30972	BRADLEY TANK 2, WL	A	Y			
		30973	BRADLEY TANK 3, WL	A	Y			
		30974	40 BENJAMIN WAY, SW	A	Y	1		
		30975	29 BOURBON ST, SW	A	Y	1		
		30976	32 BOURBON ST, SW	A	Y	1		
		30977	37 BOURBON ST, SW	A	Y	1		
		30978	45 BOURBON ST, SW	A	Y	1		
		30979	50 BOURBON ST, SW	A	Y	1		
		3098	OLD PLANT SINK	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		30980	51 BOURBON ST, SW	A	Y	1		
		30981	57 BOURBON ST, SW	A	Y	1		
		30982	60 BOURBNO ST, SW	A	Y	1		
		30983	67 BOURBON ST, SW	A	Y	1		
		30984	68 BOURBON ST, SW	A	Y	1		
		30985	73 BOURBON ST, SW	A	Y	1		
		30986	76 BOURBON ST, SW	A	Y	1		
		30987	84 BOURBON ST, SW	A	Y	1		
		30988	85 BOURBON ST, SW	A	Y	1		
		30989	91 BOURBON ST, SW	A	Y	1		
		30990	94 BOURBON ST, SW	A	Y	1		
		30991	106 BOURBON ST, SW	A	Y	1		
		3099-1	21 ROSS WAY	A	Y			
		30992	111 BOURBON ST, SW	A	Y	1		
		3099-2	16 CHERRY ST	A	Y			
		30993	166 BOURBON ST, SW	A	Y	1		
		3099-3	23 PEARL STREET	A	Y			
		30994	171 BOURBON ST, SW	A	Y	1		
		3099-4	36 WHITON STREET	A	Y			
		30995	174 BOURBON ST, SW	A	Y	1		
		3099-5	8 MICHELLE DRIVE	A	Y			
		30996	184 BOURBON ST, SW	A	Y	1		
		3099-6	81 COLONIAL DRIVE	A	Y			
		30997	191 BOURBON ST, SW	A	Y	1		
		30998	199 BOURBON ST, SW	A	Y	1		
		30999	200 BOURBON ST, SW	A	Y	1		
		31000	203 BOURBON ST, SW	A	Y	1		
		31001	206 BOURBON ST, SW	A	Y	1		
		31002	10 BRMBLEBRAE RD, SW	A	Y	1		
		31003	20 BRMBLEBRAE RD, SW	A	Y	1		
		31004	28 BRMBLEBRAE RD, SW	A	Y	1		
		31005	41 BRMBLEBRAE RD, SW	A	Y	1		
		31006	53 BRMBLEBRAE RD, SW	A	Y	1		
		31007	56 BRMBLEBRAE RD, SW	A	Y	1		
		31008	11 BRIDLEWOOD RD, SW	A	Y	1		
		31009	32 BRIDLEWOOD RD, SW	A	Y	1		
		31010	41 BRIDLEWOOD RD, SW	A	Y	1		
		31011	44 BRIDLEWOOD RD, SW	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31012	56 BRIDLEWOOD RD, SW	A		1		
		31013	15 CADBURY LN, SW	A	Y	1		
		31014	19 CADBURY LN, SW	A	Y	1		
		31015	20 CADBURY LN, SW	A	Y	1		
		31016	27 CADBURY LN, SW	A	Y	1		
		31017	CTWC - NO WESTERN	A	Y			
		31018	35 CADBURY LN, SW	A	Y	1		
		31019	42 CADBURY LN, SW	A	Y	1		
		31020	45 CADBURY LN, SW	A	Y	1		
		31021	50 CADBURY LN, SW	A	Y	1		
		31022	53 CADBURY LN, SW	A	Y	1		
		31023	59 CADBURY LN, SW	A	Y	1		
		31024	66 CADBURY LN, SW	A	Y	1		
		31025	71 CADBURY LN, SW	A	Y	1		
		31026	72 CADBURY LN, SW	A	Y	1		
		31027	75 CADBURY LN, SW	A	Y	1		
		31028	81 CADBURY LN, SW	A	Y	1		
		31029	88 CADBURY LN, SW	A	Y	1		
		31030	91 CADBURY LN, SW	A	Y	1		
		31031	100 CADBURY LN, SW	A	Y	1		
		31032	108 CADBURY LN, SW	A	Y	1		
		31033	111 CADBURY LN, SW	A	Y	1		
		31034	75 BRN DR HILL, SFD	A	Y	1		
		31035	160 BRN DR HILL, SFD	A	Y	1		
		31036	25 BARRY PL, SFD	A	Y	1		
		31037	30 BARRY PL, SFD	A	Y	1		
		31038	35 BARRY PL, SFD	A	Y	1		
		31039	40 BARRY PL, SFD	A	Y	1		
		31040	60 BARRY PL, SFD	A	Y	1		
		31041	65 BARRY PL, SFD	A	Y	1		
		31042	60 BROOKSIDE DR, SFD	A	Y	1		
		31043	65 BROOKSIDE DR, SFD	A	Y	1		
		31044	85 BROOKSIDE DR, SFD	A	Y	1		
		31045	90 BROOKSIDE DR, SFD	A	Y	1		
		31046	100 BROOKSIDE DR, SFD	A	Y	1		
		31047	24 COWAN ST, SFD	A	Y	1		
		31048	25 COWAN ST, SFD	A	Y	1		
		31049	26 COWAN ST, SFD	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31051	61 DIANE LN, SFD	A	Y	1		
		31052	75 DIANE LN, SFD	A	Y	1		
		31053	90 DIANE LN, SFD	A	Y	1		
		31054	93 DIANE LN, SFD	A	Y	1		
		31055	102 DIANE LN, SFD	A	Y	1		
		31056	103 DANE LN, SFD	A	Y	1		
		31057	113 DIANE LN, SFD	A	Y	1		
		31058	116 DIANE LN, SFD	A	Y	1		
		31059	126 DIANE LN, SFD	A	Y	1		
		31060	839 EAST ST N, SFD	A	Y	1		
		31061	230 FAIR HILL, SFD	A	Y	1		
		31062	20 HCKLBRRY HLW, SFD	A	Y	1		
		31063	21 HCKLBRRY HLW, SFD	A	Y	1		
		31064	31 HCKLBRRY HLW, SFD	A	Y	1		
		31065	40 HCKLBRRY HLW, SFD	A	Y	1		
		31066	30 JCQULINE CIR, SFD	A	Y	1		
		31067	38 KILDEER LN, SFD	A	Y	1		
		31068	48 KILDEER LN, SFD	A	Y	1		
		31069	67 KILDEER LN, SFD	A	Y	1		
		31070	77 KILDEER LN, SFD	A	Y	1		
		31071	87 KILDEER LN, SFD	A	Y	1		
		31072	88 KILDEER LN, SFD	A	Y	1		
		31073	660 MPLETN AVE, SFD	A	Y	1		
		31074	1085 MPLETN AVE, SFD	A	Y	1		
		31075	1465 MPLETN AVE, SFD	A	Y	1		
		31076	190 MARBERN DR, SFD	A	Y	1		
		31077	945 MATHER ST, SFD	A	Y	1		
		31078	10 DOW ST, VN	A	Y	1		
		31079	9 ERIC CIR, VN	A	Y	1		
		31080	10 ERIC CIR, VN	A	Y	1		
		31081	12 ERIC CIR, VN	A	Y	1		
		31082	14 ERIC CIR, VN	A	Y	1		
		31083	16 ERIC CIR, VN	A	Y	1		
		31084	20 ERIC CIR, VN	A	Y	1		
		31085	23 ERIC CIR, VN	A	Y	1		
		31086	24 ERIC CIR, VN	A	Y	1		
		31087	26 ERIC CIR, VN	A	Y	1		
		31088	27 ERIC CIR, VN	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31089	13 HEATHER LN, VN	A	Y	1		
		31090	14 HEATHER LN, VN	A	Y	1		
		31091	52 KEVIN DR, VN	A	Y	1		
		31092	55 KEVIN DR, VN	A	Y	1		
		31093	56 KEVIN DR, VN	A	Y	1		
		31094	3 VASSAR ST, VN	A	Y	1		
		31095	7 VASSER ST, VN	A	Y	1		
		31096	9 VASSER ST, VN	A	Y	1		
		31097	35 WARREN AVE, VN	A	Y	1		
		31098	41 WARREN AVE, VN	A	Y	1		
		31099	47 WARREN AVE, VN	A	Y	1		
		31100	61 WARREN AVE, VN	A	Y	1		
		31101	94 WARREN AVE, VN	A	Y	1		
		31102	87 DEBORAH CIR, WL	A	Y	1		
		31103	91 DEBORAH CIR, WL	A	Y	1		
		31104	95 DEBORAH CIR, WL	A	Y	1		
		31105	99 DEBORAH CIR, WL	A	Y	1		
		31106	103 DEBORAH CIR, WL	A	Y	1		
		31107	516 ELM ST, WL	A	Y	1		
		31108	528 ELM ST, WL	A	Y	1		
		31109	10 JUBREY LN, WL	A	Y	1		
		31110	19 JUBREY LN, WL	A	Y	1		
		31111	20 LESLIE ST, WL	A	Y	1		
		31112	25 LESLIE ST, WL	A	Y	1		
		31113	29 LESLIE ST, WL	A	Y	1		
		31114	2 MAPLE AVE, WL	A	Y	1		
		31115	6 MAPLE AVE, WL	A	Y	1		
		31116	41 MARSHALL RD , WL	A	Y	1		
		31117	42 MARSHALL RD, WL	A	Y	1		
		31118	43 MARSHALL RD, WL	A	Y	1		
		31119	44 MARSHALL RD, WL	A	Y	1		
		31120	45 MARSHALL RD, WL	A	Y	1		
		31121	46 MARSHALL RD, WL	A	Y	1		
		31122	47 MARSHALL RD, WL	A	Y	1		
		31123	48 MARSHALL RD, WL	A	Y	1		
		31124	49 MARSHALL RD, WL	A	Y	1		
		31125	50 MARSHALL RD, WL	A	Y	1		
		31126	51 MARSHALL RD, WL	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND. VERNON. WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31127	52 MARSHALL RD, WL	A	Y	1		
		31128	54 MARSHALL RD, WL	A	Y	1		
		31129	92 MICHELLE DR, WL	A	Y	1		
		31130	93 MICHELLE DR, WL	A	Y	1		
		31131	96 MICHELLE DR, WL	A	Y	1		
		31132	97 MICHELLE DR, WL	A	Y	1		
		31133	393 NORTH ST , WL	A	Y	1		
		31134	395 NORTH ST, WL	A	Y	1		
		31135	113 ORCH HILL DR, WL	A	Y	1		
		31136	114 ORCH HILL DR, WL	A	Y	1		
		31137	118 ORCH HILL DR, WL	A	Y	1		
		31138	126 ORCH HILL DR, WL	A	Y	1		
		31139	130 ORCH HILL DR, WL	A	Y	1		
		31140	91 PAUL DR, WL	A	Y	1		
		31141	201 ADAMS HLL WY, EW	A	Y	2		
		31142	202 ADAMS HLL WY, EW	A	Y	2		
		31143	203 ADAMS HLL WY, EW	A	Y	2		
		31144	218 ADAMS HLL WY, EW	A	Y	2		
		31145	221 ADAMS HLL WY, EW	A	Y	2		
		31146	227 ADAMS HLL WY, EW	A	Y	2		
		31147	228 ADAMS HLL WY, EW	A	Y	2		
		31148	238 ADAMS HLL WY, EW	A	Y	2		
		31149	16 CHASSE DR, EW	A	Y	2		
		31150	10 DANIEL DR, EW	A	Y	2		
		31151	13 DANIEL DR, EW	A	Y	2		
		31152	5 DAVID DR, EW	A	Y	2		
		31153	7 DAVID DR, EW	A	Y	2		
		31154	9 DAVID DR, EW	A	Y	2		
		31155	10 DAVID DR, EW	A	Y	2		
		31156	12 DAVID DR, EW	A	Y	2		
		31157	16 DAVID DR, EW	A	Y	2		
		31158	17 DAVID DR, EW	A	Y	2		
		31159	20 DAVID DR, EW	A	Y	2		
		31160	107 GRNWDS LN, EW	A	Y	2		
		31161	108 GRNWDS LN, EW	A	Y	2		
		31162	119 GRNWDS LN, EW	A	Y	2		
		31163	129 GRNWDS LN, EW	A	Y	2		
		31164	131 GRNWDS LN, EW	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND. VERNON. WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31165	133 GRNWDS LN, EW	A	Y	2		
		31166	139 GRNWDS LN, EW	A	Y	2		
		31167	149 GRNWDS LN, EW	A	Y	2		
		31168	155 GRNWDS LN, EW	A	Y	2		
		31169	169 GRNWDS LN, EW	A	Y	2		
		31170	179 GRNWDS LN, EW	A	Y	2		
		31171	3 RVRVIEW DR A, EW	A	Y	2		
		31172	5 RVRVIEW DR A, EW	A	Y	2		
		31173	9 RVRVIEW DR A, EW	A	Y	2		
		31174	13 RVRVIEW DR A, EW	A	Y	2		
		31175	4 RVRVIEW DR B, EW	A	Y	2		
		31176	12 RVRVIEW DR B, EW	A	Y	2		
		31177	13 RVRVIEW DR B, EW	A	Y	2		
		31178	5 RVRVIEW DR C, EW	A	Y	2		
		31179	6 RVRVIEW DR C, EW	A	Y	2		
		31180	7 RVRVIEW DR C, EW	A	Y	2		
		31181	8 RVRVIEW DR C, EW	A	Y	2		
		31182	5 RVRVIEW DR D, EW	A	Y	2		
		31183	6 RVRVIEW DR D, EW	A	Y	2		
		31184	10 RVRVIEW DR D, EW	A	Y	2		
		31185	13 RVRVIEW DR D, EW	A	Y	2		
		31186	8 RVRVIEW DR E, EW	A	Y	2		
		31187	13 RVRVIEW DR E, EW	A	Y	2		
		31188	8 RVRVIEW DR G, EW	A	Y	2		
		31189	1 GRANT RD, ELL	A	Y	2		
		31190	20 BRKSIDE VLG, ENF	A	Y	2		
		31191	25 BRKSIDE VLG, ENF	A	Y	2		
		31192	29 BRKSIDE VLG, ENF	A	Y	2		
		31193	30 BRKSIDE VLG, ENF	A	Y	2		
		31194	31 BRKSIDE VLG, ENF	A	Y	2		
		31195	41 BRKSIDE VLG, ENF	A	Y	2		
		31196	42 BRKSIDE VLG, ENF	A	Y	2		
		31197	43 BRKSIDE VLG, ENF	A	Y	2		
		31198	42 CNDLWD CIR, ENF	A	Y	2		
		31199	12 CNDLWD DR, ENF	A	Y	2		
		31200	32 CNDLWD DR, ENF	A	Y	2		
		31201	72 HRTFRD AVE 1A, EN	A	Y	2		
		31202	1 THE LAURELS, ENF	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31203	2 THE LAURELS, ENF	A	Y	2		
		31204	3 THE LAURELS, ENF	A	Y	2		
		31205	4 THE LAURELS, ENF	A	Y	2		
		31206	5 THE LAURELS, ENF	A	Y	2		
		31207	6 THE LAURELS, ENF	A	Y	2		
		31208	7 THE LAURELS, ENF	A	Y	2		
		31209	8 THE LAURELS, ENF	A	Y	2		
		31210	11 THE LAURELS, ENF	A	Y	2		
		31211	12 THE LAURELS, ENF	A	Y	2		
		31212	15 THE LAURELS, ENF	A	Y	2		
		31213	18 THE LAURELS, ENF	A	Y	2		
		31214	20 THE LAURELS, ENF	A	Y	2		
		31215	21 THE LAURELS, ENF	A	Y	2		
		31216	22 THE LAURELS, ENF	A	Y	2		
		31217	24 THE LAURELS, ENF	A	Y	2		
		31218	26 THE LAURELS, ENF	A	Y	2		
		31219	32 THE LAURELS, ENF	A	Y	2		
		31220	35 THE LAURELS, ENF	A	Y	2		
		31221	37 THE LAURELS, ENF	A	Y	2		
		31222	43 THE LAURELS, ENF	A	Y	2		
		31223	47 THE LAURELS, ENF	A	Y	2		
		31224	49 THE LAURELS, ENF	A	Y	2		
		31225	57 THE LAURELS, ENF	A	Y	2		
		31226	59 THE LAURELS, ENF	A	Y	2		
		31227	62 THE LAURELS, ENF	A	Y	2		
		31228	64 THE LAURELS, ENF	A	Y	2		
		31229	65 THE LAURELS, ENF	A	Y	2		
		31230	71 THE LAURELS, ENF	A	Y	2		
		31231	72 THE LAURELS, ENF	A	Y	2		
		31232	73 THE LAURELS, ENF	A	Y	2		
		31233	76 THE LAURELS, ENF	A	Y	2		
		31234	78 THE LAURELS, ENF	A	Y	2		
		31235	81 THE LAURELS, ENF	A	Y	2		
		31236	91 THE LAURELS, ENF	A	Y	2		
		31237	93 THE LAURELS, ENF	A	Y	2		
		31238	125 THE LAURELS, ENF	A	Y	2		
		31239	131 THE LAURELS, ENF	A	Y	2		
		31240	147 THE LAURELS, ENF	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND. VERNON. WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31241	161 THE LAURELS, ENF	A	Y	2		
		31242	165 THE LAURELS, ENF	A	Y	2		
		31243	167 THE LAURELS, ENF	A	Y	2		
		31244	240 ALEWIFE LN, SFD	A	Y	2		
		31245	244 ALEWIFE LN, SFD	A	Y	2		
		31246	256 ALEWIFE LN, SFD	A	Y	2		
		31247	258 ALEWIFE LN, SFD	A	Y	2		
		31248	262 ALEWIFE LN, SFD	A	Y	2		
		31249	266 ALEWIFE LN, SFD	A	Y	2		
		31250	268 ALEWIFE LN, SFD	A	Y	2		
		31251	270 ALEWIFE LN, SFD	A	Y	2		
		31252	272 ALEWIFE LN, SFD	A	Y	2		
		31253	2 AMBLESIDE CT, SFD	A	Y	2		
		31254	5 AMBLESIDE CT, SFD	A	Y	2		
		31255	5 CANBORNE WAY, SFD	A	Y	2		
		31256	8 CANBORNE WAY, SFD	A	Y	2		
		31257	9 CANBORNE WAY, SFD	A	Y	2		
		31258	10 CANBORNE WAY, SFD	A	Y	2		
		31259	11 CANBORNE WAY, SFD	A	Y	2		
		31260	163 COHO LN, SFD	A	Y	2		
		31261	167 COHO LN, SFD	A	Y	2		
		31262	171 COHO LN, SFD	A	Y	2		
		31263	173 COHO LN, SFD	A	Y	2		
		31264	4 CURRYCROSS CT, SFD	A	Y	2		
		31265	5 CURRYCROSS CT, SFD	A	Y	2		
		31266	6 CURRYCROSS CT, SFD	A	Y	2		
		31267	10 DEEP BRK HRBR, SF	A	Y	2		
		31268	14 DEEP BRK HRBR, SF	A	Y	2		
		31269	24 DEEP BRK HRBR, SF	A	Y	2		
		31270	30 DEEP BRK HRBR, SF	A	Y	2		
		31271	2 DOWNING WAY, SFD	A	Y	2		
		31272	4 DOWNING WAY, SFD	A	Y	2		
		31273	5 DOWNING WAY, SFD	A	Y	2		
		31274	7 DOWNING WAY, SFD	A	Y	2		
		31275	8 DOWNING WAY, SFD	A	Y	2		
		31276	10 DOWNING WAY, SFD	A	Y	2		
		31277	15 DOWNING WAY, SFD	A	Y	2		
		31278	160 DUSKY LN, SFD	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31279	166 DUSKY LN, SFD	A	Y	2		
		31280	170 DUSKY LN, SFD	A	Y	2		
		31281	178 DUSKY LN, SFD	A	Y	2		
		31282	182 DUSKY LN, SFD	A	Y	2		
		31283	186 DUSKY LN, SFD	A	Y	2		
		31284	188 DUSKY LN, SFD	A	Y	2		
		31285	190 DUSKY LN, SFD	A	Y	2		
		31286	202 DUSKY LN, SFD	A	Y	2		
		31287	206 E BASS LN, SFD	A	Y	2		
		31288	214 E BASS LN, SFD	A	Y	2		
		31289	216 E BASS LN, SFD	A	Y	2		
		31290	222 E BASS LN, SFD	A	Y	2		
		31291	226 E BASS LN, SFD	A	Y	2		
		31292	112 E BLUE GLL, SFD	A	Y	2		
		31293	114 E BLUE GLL, SFD	A	Y	2		
		31294	116 E BLUE GLL, SFD	A	Y	2		
		31295	120 E BLUE GLL, SFD	A	Y	2		
		31296	136 E BLUE GLL, SFD	A	Y	2		
		31297	142 E GRYLNG, SFD	A	Y	2		
		31298	152 E GRYLNG, SFD	A	Y	2		
		31299	3 MAYBURY RD, SFD	A	Y	2		
		31300	11 MAYBURY RD, SFD	A	Y	2		
		31301	12 MAYBURY RD, SFD	A	Y	2		
		31302	123 MOUNTAIN RD, SFD	A	Y	2		
		31303	6 BAMFORTH RD 11, VN	A	Y	2		
		31304	6 BAMFORTH RD 18, VN	A	Y	2		
		31305	6 BAMFORTH RD 19, VN	A	Y	2		
		31306	6 BAMFORTH RD 5, VN	A	Y	2		
		31307	6 BAMFORTH RD 6, VN	A	Y	2		
		31308	6 BAMFORTH RD 8, VN	A	Y	2		
		31309	6 BAMFORTH RD 9, VN	A	Y	2		
		31310	444 CRICKET CIR, VN	A	Y	2		
		31311	451 CRICKET CIR, VN	A	Y	2		
		31312	453 CRICKET CIR, VN	A	Y	2		
		31313	458 CRICKET CIR, VN	A	Y	2		
		31314	450 CRICKET CIR, VN	A	Y	2		
		31315	43 FRANKLIN ST B, VN	A	Y	2		
		31316	413 LADYBUG LN, VN	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND. VERNON. WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31317	425 LADYBUG LN, VN	A	Y	2		
		31318	105 MAPLE AVE 1, VN	A	Y	2		
		31319	105 MAPLE AVE 10, VN	A	Y	2		
		31320	105 MAPLE AVE 12, VN	A	Y	2		
		31321	105 MAPLE AVE 13, VN	A	Y	2		
		31322	105 MAPLE AVE 14, VN	A	Y	2		
		31323	105 MAPLE AVE 15, VN	A	Y	2		
		31324	105 MAPLE AVE 16, VN	A	Y	2		
		31325	105 MAPLE AVE 17, VN	A	Y	2		
		31326	105 MAPLE AVE 18, VN	A	Y	2		
		31327	105 MAPLE AVE 19, VN	A	Y	2		
		31328	105 MAPLE AVE 2, VN	A	Y	2		
		31329	105 MAPLE AVE 20, VN	A	Y	2		
		31330	105 MAPLE AVE 21, VN	A	Y	2		
		31331	105 MAPLE AVE 22, VN	A	Y	2		
		31332	105 MAPLE AVE 23, VN	A	Y	2		
		31333	105 MAPLE AVE 24, VN	A	Y	2		
		31334	105 MAPLE AVE 25, VN	A	Y	2		
		31335	105 MAPLE AVE 27, VN	A	Y	2		
		31336	105 MAPLE AVE 28, VN	A	Y	2		
		31337	105 MAPLE AVE 29, VN	A	Y	2		
		31338	105 MAPLE AVE 3, VN	A	Y	2		
		31339	105 MAPLE AVE 30, VN	A	Y	2		
		31340	105 MAPLE AVE 31, VN	A	Y	2		
		31341	105 MAPLE AVE 32, VN	A	Y	2		
		31342	105 MAPLE AVE 36, VN	A	Y	2		
		31343	105 MAPLE AVE 37, VN	A	Y	2		
		31344	105 MAPLE AVE 39, VN	A	Y	2		
		31345	105 MAPLE AVE 4, VN	A	Y	2		
		31346	105 MAPLE AVE 40, VN	A	Y	2		
		31347	105 MAPLE AVE 41, VN	A	Y	2		
		31348	105 MAPLE AVE 42, VN	A	Y	2		
		31349	105 MAPLE AVE 43, VN	A	Y	2		
		31350	105 MAPLE AVE 44, VN	A	Y	2		
		31351	105 MAPLE AVE 45, VN	A	Y	2		
		31352	105 MAPLE AVE 46, VN	A	Y	2		
		31353	105 MAPLE AVE 5, VN	A	Y	2		
		31354	105 MAPLE AVE 7, VN	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31355	105 MAPLE AVE 8, VN	A	Y	2		
		31356	105 MAPLE AVE 9, VN	A	Y	2		
		31357	55 OLD TWN, VN	A	Y	2		
		31358	60 OLD TWN 100, VN	A	Y	2		
		31359	60 OLD TWN 102, VN	A	Y	2		
		31360	60 OLD TWN 118, VN	A	Y	2		
		31361	60 OLD TWN 119, VN	A	Y	2		
		31362	60 OLD TWN 124, VN	A	Y	2		
		31363	60 OLD TWN 127, VN	A	Y	2		
		31364	60 OLD TWN 128, VN	A	Y	2		
		31365	60 OLD TWN 129, VN	A	Y	2		
		31366	60 OLD TWN 141, VN	A	Y	2		
		31367	60 OLD TWN 154, VN	A	Y	2		
		31368	60 OLD TWN 155, VN	A	Y	2		
		31369	60 OLD TWN 157, VN	A	Y	2		
		31370	60 OLD TWN 159, VN	A	Y	2		
		31371	60 OLD TWN 162, VN	A	Y	2		
		31372	60 OLD TWN 164, VN	A	Y	2		
		31373	60 OLD TWN 165, VN	A	Y	2		
		31374	60 OLD TWN 167, VN	A	Y	2		
		31375	60 OLD TWN 168, VN	A	Y	2		
		31376	60 OLD TWN 172, VN	A	Y	2		
		31377	60 OLD TWN 174, VN	A	Y	2		
		31378	60 OLD TWN 179, VN	A	Y	2		
		31379	60 OLD TWN 187, VN	A	Y	2		
		31380	60 OLD TWN 193, VN	A	Y	2		
		31381	60 OLD TWN 195, VN	A	Y	2		
		31382	60 OLD TWN 199, VN	A	Y	2		
		31383	60 OLD TWN 3, VN	A	Y	2		
		31384	70 OLD TWN 302, VN	A	Y	2		
		31385	70 OLD TWN 319, VN	A	Y	2		
		31386	70 OLD TWN 320, VN	A	Y	2		
		31387	70 OLD TWN 322, VN	A	Y	2		
		31388	70 OLD TWN 323, VN	A	Y	2		
		31389	70 OLD TWN 328, VN	A	Y	2		
		31390	70 OLD TWN 330, VN	A	Y	2		
		31391	70 OLD TWN 338, VN	A	Y	2		
		31392	70 OLD TWN 343, VN	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31393	70 OLD TWN 350, VN	A	Y	2		
		31394	70 OLD TWN 357, VN	A	Y	2		
		31395	70 OLD TWN 369, VN	A	Y	2		
		31396	70 OLD TWN 381, VN	A	Y	2		
		31397	60 OLD TWN 57, VN	A	Y	2		
		31398	60 OLD TWN 59, VN	A	Y	2		
		31399	60 OLD TWN 64, VN	A	Y	2		
		31400	60 OLD TWN 65, VN	A	Y	2		
		31401	60 OLD TWN 67, VN	A	Y	2		
		31402	60 OLD TWN 70, VN	A	Y	2		
		31403	60 OLD TWN 72, VN	A	Y	2		
		31404	60 OLD TWN 76, VN	A	Y	2		
		31405	60 OLD TWN 82, VN	A	Y	2		
		31406	60 OLD TWN 83, VN	A	Y	2		
		31407	60 OLD TWN 9, VN	A	Y	2		
		31408	20 PROGRESS AVE B, V	A	Y	2		
		31409	401 TALCTVILLE 104, V	A	Y	2		
		31410	401 TALCTVILLE 107,	A	Y	2		
		31411	98 W MAIN ST, VN	A	Y	2		
		31412	94 WEST ST 10, VN	A	Y	2		
		31413	100 WEST ST 101, VN	A	Y	2		
		31414	100 WEST ST 105, VN	A	Y	2		
		31415	100 WEST ST 106, VN	A	Y	2		
		31416	35 CHURCH ST, WL	A	Y	2		
		31417	59 DOVE CT, WL	A	Y	2		
		31418	69 DOVE CT, WL	A	Y	2		
		31419	26 MEADOW LN, WL	A	Y	2		
		31420	30 MEADOW LN, WL	A	Y	2		
		31421	32 MEADOW LN, WL	A	Y	2		
		31422	102 ORCH HILL DR, WL	A	Y	2		
		31423	2 PARTRIDGE CT, WL	A	Y	2		
		31424	4 PARTRIDGE CT, WL	A	Y	2		
		31425	6 PARTRIDGE CT, WL	A	Y	2		
		31426	8 PARTRIDGE CT, WL	A	Y	2		
		31427	10 PARTRIDGE CT, WL	A	Y	2		
		31428	12 PARTRIDGE CT, WL	A	Y	2		
		31429	14 PARTRIDGE CT, WL	A	Y	2		
		31430	16 PARTRIDGE CT, WL	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31431	18 PARTRIDGE CT, WL	A	Y	2		
		31432	20 PARTRIDGE CT, WL	A	Y	2		
		31433	22 PARTRIDGE CT, WL	A	Y	2		
		31434	24 PARTRIDGE CT, WL	A	Y	2		
		31435	31 PHEASANT CT, WL	A	Y	2		
		31436	35 PHEASANT CT, WL	A	Y	2		
		31437	43 PHEASANT CT, WL	A	Y	2		
		31438	3 QUAIL CT, WL	A	Y	2		
		31439	5 QUAIL CT, WL	A	Y	2		
		31440	9 QUAIL CT, WL	A	Y	2		
		31441	19 QUAIL CT, WL	A	Y	2		
		31442	21 QUAIL CT, WL	A	Y	2		
		31443	MDBK APT 1	A	Y	N		
		31444	30 BENJAMIN WAY, SW	A	Y	1		
		31445	35 BENJAMIN WAY, SW	A	Y	1		
		31446	36 BENJAMIN WAY, SW	A	Y	1		
		31447	MDBK APT 2	A	Y	N		
		31448	MDBK APT 3	A		N		
		31449	MDBK APT 4	A	Y	N		
		31450	MDBK APT 5	A	Y	N		
		31451	MDBK APT 6	A	Y	N		
		31452	MDBK APT 7	A	Y	N		
		31453	MDBK APT 8	A	Y	N		
		31454	MDBK APT 9	A	Y	N		
		31455	MDBK APT 10	A	Y	N		
		31456	MDBK APT 11	A	Y	N		
		31457	MDBK APT 12	A	Y	N		
		31458	MDBK APT 13	A	Y	N		
		31459	MDBK APT 14	A	Y	N		
		31460	MDBK APT 15	A	Y	N		
		31461	MDBK APT 16	A	Y	N		
		31462	MDBK APT 17	A	Y	N		
		31463	MDBK APT 18	A	Y	N		
		31464	MDBK APT 19	A	Y	N		
		31465	MDBK APT 20	A	Y	N		
		31466	7 LEON ST, ENF7 LEON	A	Y	1		
		31467	13 TALCOTT AVE ROCK	A	Y	1		
		31468	21-23 TLCTT AV ROCK	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31469	47 HAMMOND ST ROCK	A	Y	2		
		31470	14 MORRISON ST ROCK	A	Y	1		
		31471	21 PLLSBRY HILL ROCK	A	Y	1		
		31472	22 PLLSBRY HILL ROCK	A	Y	1		
		31473	148 PROSPECT ST ROCK	A	Y	2		
		31474	43 THOMAS ST ROCK	A	Y	1		
		31475	106 UNION ST ROCK	A	Y	1		
		31476	127 UNION ST ROCK	A	Y	2		
		31477	38 WARD ST ROCK	A	Y	2		
		31478	39 WARD ST ROCK	A	Y	1		
		31479	763 MOUNTAIN RD SFD	A	Y	1		
		31480	113 BROOKLYN ST VN	A	Y	1		
		31481	174 E MAIN ST VN	A	Y	1		
		31482	13 WEST ST VN	A	Y	1		
		31483	82 WEST ST VN	A	Y	2		
		31484	63 KALISH AVENUE	A	Y			
		31485	55 ROOSEVELT BLVD	A	Y			
		31486	100 STRONG RD	A	Y			
		31487	300 SOUTH STREET	A	Y			
		31488	WST SUFF W. HOUSE	A	Y			
		31489	SUF BOOSTER 2 SS	A	Y			Y
		31490	99 FOUR BRDGS SS SMR	A	Y			Y
		3150	TOWN HALL 1 MAIN ST	A	Y		Y	
		3151	63 W MAIN ST	A	Y			
		3152	DKN DNT 22 W STRD RD	A	Y			
		3153	FOREST EDGE CONDOS	A	Y		Y	Y
		31801	44 TOLLAND AV APT 12	A		N		
		31802	44 TOLLAND AV APT 7	A		N		
		31803	50 FURNACE AV	A		3		
		31804	58 FURNACE AV	A		N		
		31805	38 EDGEWOOD ST	A		3		
		31806	25 HIGH ST	A		N		
		31807	13 BELLROSE ST	A		3		
		31808	122 W MAIN UNIT G	A		2		
		31809	48 HIGH ST	A		N		
		31810	58 EDGEWOOD ST	A		3		
		31812	43 HIGH STREET	A	Y	1		
		31813	13 ARNOLD LN	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31814	5 CLINTON ST	A	Y	1		
		31815	51 FURNACE AVE	A	Y	1		
		31816	69 PROSPECT ST	A	Y	1		
		31817	3 TOPSY DR	A	Y	1		
		31818	39 EDGEWOOD RD E	A	Y	2		
		31819	35A EDGEWOOD ST	A	Y	2		
		31820	35B EDGEWOOD ST	A	Y	2		
		31821	35C EDGEWOOD ST	A	Y	2		
		31822	35D EDGEWOOD ST	A	Y	2		
		31823	35E EDGEWOOD ST	A	Y	2		
		31824	35F EDGEWOOD ST	A	Y	2		
		31825	39A EDGEWOOD ST	A	Y	2		
		31826	39C EDGEWOOD ST	A	Y	2		
		31827	39D EDGEWOOD ST	A	Y	2		
		31828	39F EDGEWOOD ST	A	Y	2		
		31829	39G EDGEWOOD ST	A	Y	2		
		31830	43A EDGEWOOD ST	A	Y	2		
		31831	43B EDGEWOOD ST	A	Y	2		
		31832	43C EDGEWOOD ST	A	Y	2		
		31833	69-C1 FURNACE AVE	A	Y	2		
		31834	69-C2 FURNACE AVE	A	Y	2		
		31835	69-C4 FURNACE AVE	A	Y	2		
		31836	69-C5 FURNACE AVE	A	Y	2		
		31837	83-W2 FURNACE AVE	A	Y	2		
		31838	83-W3 FURNACE AVE	A	Y	2		
		31839	83-W4 FURNACE AVE	A	Y	2		
		31840	83-W5 FURNACE AVE	A	Y	2		
		31841	83-W6 FURNACE AVE	A	Y	2		
		31842	83-W7 FURNACE AVE	A	Y	2		
		31843	87-E1 FURNACE AVE	A	Y	2		
		31844	87-E3 FURNACE AVE	A	Y	2		
		31845	122A W MAIN ST	A	Y	2		
		31846	122B W MAIN ST	A	Y	2		
		31847	122C W MAIN ST	A	Y	2		
		31848	122D W MAIN ST	A	Y	2		
		31849	122E W MAIN ST	A	Y	2		
		31850	122F W MAIN ST	A	Y	2		
		31851	122H W MAIN ST	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND. VERNON. WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31852	122I W MAIN ST	A	Y	2		
		31853	122J W MAIN ST	A	Y	2		
		31854	122K W MAIN ST	A	Y	2		
		31855	122L W MAIN ST	A	Y	2		
		31856	122M W MAIN ST	A	Y	2		
		31857	122N W MAIN ST	A	Y	2		
		31858	2 BELLROSE ST	A	Y	3		
		31859	15 BRENDAN ST	A	Y	3		
		31860	23 BRENDAN ST	A	Y	3		
		31861	25 BRENDAN ST	A	Y	3		
		31862	27 BRENDAN ST	A	Y	3		
		31863	29 BRENDAN ST	A	Y	3		
		31864	30 BRENDAN ST	A	Y	3		
		31865	32 BRENDAN ST	A	Y	3		
		31866	10 BUCKLEY HWY	A	Y	3		
		31867	12 BUCKLEY HWY	A	Y	3		
		31868	14 BUCKLEY HWY	A		3		
		31869	14 CLINTON ST	A	Y	3		
		31870	5 CURTIS ST	A	Y	3		
		31871	11 CURTIS ST	A	Y	3		
		31872	6 DENNIS LN	A	Y	3		
		31873	55 FURNACE AVE	A	Y	3		
		31874	2 GEORGE ST	A	Y	3		
		31875	4 GEORGE ST	A	Y	3		
		31876	5 GEORGE ST	A	Y	3		
		31877	6 GEORGE ST	A	Y	3		
		31878	8 GEORGE ST	A	Y	3		
		31879	9 GEORGE ST	A	Y	3		
		31880	87 GRANT AVE	A	Y	3		
		31881	89 GRANT AVE	A	Y	3		
		31882	91 GRANT AVE	A	Y	3		
		31883	93 GRANT AVE	A	Y	3		
		31884	7 GREEN ST	A	Y	3		
		31885	15 HOWLAND AVE	A	Y	3		
		31886	7 MATTESEN LN	A	Y	3		
		31887	11 MOUNTAIN RD	A	Y	3		
		31888	6 OAK ST	A	Y	3		
		31889	5 ORCHARD ST	A	Y	3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		31890	12 PARKESS ST	A	Y	3		
		31891	18 PARKESS ST	A	Y	3		
		31892	64 PROSPECT ST	A	Y	3		
		31893	2 QUINN ST	A	Y	3		
		31894	7 QUINN ST	A	Y	3		
		31895	5 SUMMER ST	A	Y	3		
		31896	6 SUMMER ST	A	Y	3		
		31897	5 W END ST	A	Y	3		
		31898	18 W END ST	A	Y	3		
		31899	7 W STAFFORD RD	A	Y	3		
		31900	51 WEST ST	A	Y	3		
		31901	46 WILLINGTON AVE	A	Y	3		
		31902	64 WILLINGTON AVE	A	Y	3		
		31903	78 WILLINGTON AVE	A	Y	3		
		31904	82 WILLINGTON AVE	A	Y	3		
		31905	ISABELLA COURT PS	A	Y			Y Y
		4	GENERIC DISTRIBUTION	A	Y			
		4050	P.O., BROAD BROOK	A	Y			Y
		4150	TOWN HALL ROUTE 190	A	Y			Y
		4163	INTERCONNECT PIT 4 B	A	Y			
		48817	53 CIRCLE DR WL	A		1		
		49498	421 DENSLOW ST WL	A		1		
		49732	46 CENTER ST WL	A		1		
		51893	154 SUNSET ST WL	A		1		
		53313	43 E MAIN ST	A	Y	2		
		59967	754 AVERY ST SW	A		1		
		6050	MOBIL MRT 30/31,ROCK	A	Y			
		6051	WEST ST. PS, ROCKVL	A	Y			
		6052	SERAPHN FRD,R.83,RCK	A	Y			Y
		6053	AUTM C,115 WST R,ELL	A	Y			Y
		6054	WAPPING WOOD TSS,SW	A	Y			
		6055	P.O.,R.83,TALCTTVL	A	Y		Y	
		6056	TOWN HALL, ELLINGTON	I	Y			Y
		6057	TALLWD PRV PT, VRN	I	Y			
		6058	COMFRT,425 HFD TK,VN	A	Y			Y
		6059	SADDS ML SS, ELNGTN	A	Y			Y
		6060	ELLINGTON HIGH SCHOO	A	Y			
		6150	LIBRARY, TOLLND	A	Y			Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		6550	HERITAGE WOODS, TOLL	A	Y			Y
		72368	17 HOWARD DR V	A		1		
		76861	71-73 MOUNTAIN ST EL	A		2		
		76964	46 ELLINGTON AVE EL	A		1		
		77278	14 PARK PL V	A		1		
		77324	15 WEBSTER ST V	A		2		
		77384	28 PLEASANT ST V	A		1		
		77424	2 MINTERBURN CT V	A		2		
		77784	109 GROVE ST V	A		1		
		77787	103 GROVE ST V	A		1		
		78076	7 HALE ST EXT V	A		1		
		80533	41 SPRING ST V	A		1		
		80794	90-92 VILLAGE ST V	A		2		
		80987	6 OAK ST V	A		2		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW001	CLUB HOUSE	A	Y	N	Y	Y Y
		MW002	23 HILL POND	A	Y	3		
		MW003	30 OLDWOOD	A	Y	3		
		MW004	MAINTENANCE BLDG	A	Y	N		
		MW005	2 MAPLEWOOD	A	Y	3		
		MW006	8 RIDGE CIRCLE	A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - ROCKVILLE WTP	3	ENTRY POINT - ROCKVI	A				
00701	ENTRY POINT - HUNT WELLFIELD	3	EP-HUNT WELLFIELD	A				
00702	ENTRY POINT - POWDER HOLLOW WELL FIELD	3	EP - POWDER HOLLOW W	A				
00703	ENTRY POINT - SPRING LOTS WELLFIELD	3	EP - SPRING LOTS	A				
00709	ENTRY POINT - VERNON WELL 5	3	EP-VERNON WELL 5	A				
00713	ENTRY POINT - WOODLAND PARK WELL	3	EP-WOODLAND PARK	A				
00714	ENTRY POINT - PINE KNOB WELL	3	EP-PINE KNOB WELL	A				
00715	ENTRY POINT - WEST SUFFIELD WELL	3	EP-WEST SUFFIELD	A				
00719	ENTRY POINT - O'BREADY	3	EP-O'BREADY	A				
1245	SPRING LOTS WELL 3	2	WELL SPRING LOTS 3	A				
1247	SPRING LOTS WELL 5	2	SPRING LOTS WELL 5	A				
1267	O'BREADY WELL	2	O'BREADY WELL	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
1268	POWDER HOLLOW WELL 1	2	POWDER HOLLOW WELL 1	A				
1278	HUNT WELL 5	2	HUNT WELL 5	A				
1279	HUNT WELL 6	2	HUNT WELL 6	A				
1281	HUNT WELL 8	2	HUNT WELL 8	A				
1282	HUNT WELL 9	2	HUNT WELL 9	A				
1636	VERNON WELL 5	2	VERNON WELL #5 - R	A				
168	PINE KNOB WELL	2	PINE KNOB WELL	A				
169	WOODLAND PARK WELL	2	WOODLAND PARK WELL	A				
177	VERNON WELL 5	2	VERNON WELL 5	A				
1937	HUNT WELL 10	2	HUNT WELL 10	A				
1938	POWDER HOLLOW WELL 4	2	PH WELL 4	A				
2077	SHENIPSIT LAKE	1	SHENIPSIT LAKE	A				
30029	LAKE SHENIPSIT							
38	WEST SUFFIELD WELL	2	WEST SUFFIELD WELL	A				
47617	INTERCONNECTION - CT1429191 - TORRY RD							
47835	SPRING LOTS WELL 7	2	SPRING LOTS WELL 7	A				
51205	PROSPECT HILL STORAGE TANK							
51207	WAPPING WOOD (SOUTH WINDSOR) STANDPIPE 1							
51219	ELM ST TANK							
51221	MILDRED ST TANK							
51223	SUFFIELD INDUSTRIAL PARK TANK							
51225	TOLLAND (HERITAGE WOODS) STORAGE TANK							
51227	TOLLAND (HERITAGE WOODS) HD TANKS (2)							
51243	SUFFIELD - NORTH ST TANK							
51245	ENFIELD ST TANK -0.5 MG							
51247	ENFIELD ST TANK - 1.5 MG							
51249	BRAINARD ROAD TANK #1							
51251	SNIPSIC STREET TANK							
51253	ROCKVILLE WTP CLEARWELLS							
51255	SOUTH ST TANK							
51257	SUFFIELD BOOSTER STATION 1							
51259	SUFFIELD BOOSTER STATION 2							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
51261	SADDS MILL BOOSTER STATION							
51263	WEST ST BOOSTER STATION							
51265	TOLLAND BOOSTER STATION							
51267	OLD COUNTY RD BOOSTER STATION							
51269	ENFIELD ST BOOSTER STATION							
52905	SPRING LOTS WELL 8	2	SPRING LOTS WELL 8	A				
53579	WAPPING WOOD TANK 2							
54659	INTERCONNECTION - CT0770021 - PINE TREE							
54663	INTERCONNECTION - CT0640011 - ROUTE 5							
54665	INTERCONNECTION - CT0640011 - OLD COUNTY							
54669	INTERCONNECTION- CT0640011- SCHOEPHOESTER							
54961	SPRING LOTS WELL 9	2	SPRING LOTS WELL 9	A				
55943	SHAKER ROAD PUMP STATION							
59103	DAVID DRIVE BOOSTER PUMP STATION							
59582	TIMBER LANE TANKS (OLD ELLINGTON ACRES)							
59584	GULF ROAD TANK							
59586	BRAINARD ROAD TANK #2							
59713	POWDER HOLLOW WELL 5	2	POWDER HOLLOW WELL 5	A				
60576	ROCKVILLE WATER TREATMENT PLANT							
60781	TOLLAND HERITAGE WOODS BPS							
60846	GRAND LOFTS PUMP STATION							
60856	BRADLEY TANK #1							
60858	BRADLEY TANK #2							
60860	BRADLEY TANK #3							
612	O'BREADY WELL TREATMENT PLANT							
613	PINE KNOB WELL TP							
614	WOODLAND PARK WELL TP							
62045	SOMERS PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	
Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
62815	STAFFORD SPHEROID TANK							
63229	ISABELLA COURT PUMP STATION							
63230	ELLEN STREET STANDPIPE							
63231	FOREST EDGE PUMP STATION							
63232	HIGH LIFT PUMP STATION							
63233	STAFFORD SPRINGS WTP CLEARWELL 1							
63234	STAFFORD SPRINGS WTP CLEARWELL 2							
63236	SOMERS PUMP STATION TREATMENT PLANT	63236	SOMERS PUMP STATION	A				
71	HUNT WATER TREATMENT PLANT	3	EP - HUNT WTP	A				
74	POWDER HOLLOW WELLS							
77	SPRING LOTS TREATMENT PLANT							
XX700	ENTRY POINT - ROCKVILLE WTP	3X	EP-ROCKVILLE WTP	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LOWRY, PAUL C.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
LABIANCA, MICHAEL	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027

Water System Facility: HUNT WATER TREATMENT PLANT (WSF ID: 71)

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027

Water System Facility: POWDER HOLLOW WELLS (WSF ID: 74)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Certified Operator Information

Water System Facility: POWDER HOLLOW WELLS (WSF ID: 74)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027

Water System Facility: SPRING LOTS TREATMENT PLANT (WSF ID: 77)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027

Water System Facility: VERNON WELL 5 (WSF ID: 1636)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027

Water System Facility: O'BREADY WELL TREATMENT PLANT (WSF ID: 612)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027

Water System Facility: WOODLAND PARK WELL TP (WSF ID: 614)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027

Water System Facility: PINE KNOB WELL TP (WSF ID: 613)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LABIANCA, MICHAEL	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
HART, WILLIAM G.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0473011	CTWC - NORTHERN REG-WESTERN SYSTEM			C	101,313	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				932	68	6	36,348	

Towns Served: EAST GRANBY, EAST WINDSOR, ELLINGTON, ENFIELD, MANCHESTER, MANSFIELD, SOUTH WINDSOR, STAFFORD, SUFFIELD, TOLLAND, VERNON, WINDSOR LOCKS

Certified Operator Information

Water System Facility: **PINE KNOB WELL TP (WSF ID: 613)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027

Water System Facility: **ROCKVILLE WATER TREATMENT PLANT (WSF ID: 60576)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
MACKENN, TIMOTHY R	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2027
MEDER, NICHOLAS J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027

Contact Information

Name				Organization			Job Title		
Mr. Craig J. Patla				Connecticut Water Company			Vp, Service Delivery		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 West Main Street						Clinton		CT	06413
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-664-6140						800-391-1924	craig.patla@ctwater.com		

Contact Role(s): **Legal Contact, Owner**

Name				Organization			Job Title		
Mr. Paul C. Lowry				Connecticut Water Company			Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 W Main Street						Clinton		CT	06413
Business Phone	Extension	Fax	Mobile Phone		Emergency Phone	Email Address			
860-944-9655		860-654-1903			800-208-5700	ctwcdphadmin@ctwater.com			

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule