

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0550011	AQUARION-TYLER LAKE			C	142	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							57	

Towns Served: GOSHEN

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
49 TYLER LAKE (02362)	1/1/24 - 12/31/24	9/1-9/30	Complete
	1/1/25 - 12/31/25	9/1-9/30	Complete
	1/1/26 - 12/31/26	9/1-9/30	
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0550011	AQUARION-TYLER LAKE			C	142	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							57	

Towns Served: GOSHEN

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 1 (WSF ID: 131)

<b>E. Coli (3014)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule									
PWS ID	PWS Name				Classification		Population	Owner Type	Primary Source
CT0550011	AQUARION-TYLER LAKE				C		142	P	GW
Local Address (where applicable)				Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
								57	
Towns Served: GOSHEN									
Monitoring Requirements									
Water System Facility: WELL 1 (WSF ID: 131)									
E. Coli (3014)				1 routine (RT) per month					
Sampling Point (Sampling Point ID)				Monitoring Period		Collection Period		Compliance Status	
				11/1/25 - 11/30/25					
				12/1/25 - 12/31/25					
				1/1/26 - 1/31/26					
				2/1/26 - 2/28/26					
				3/1/26 - 3/31/26					
				4/1/26 - 4/30/26					
Monthly Water System Facility (WSF) Level Monitoring Requirements									
Water System Facility: ENTRY POINT (WSFID: 00700)									
Analyte		Monitoring Requirement (Summary Type)			Operating Limit			Samples Req/Month	
Chlorine		Entry Point Chlorine Residual Monitoring (CHLR)			Minimum: 0.2 MG/L			Daily	
Start Date: 5/1/2021		Compliance History:			Operating Limit		Monitoring		
		Monitoring Period			Compliance Status:		Compliance Status:		
		5/1/2025 - 5/31/2025							
		6/1/2025 - 6/30/2025							
		7/1/2025 - 7/31/2025							
		8/1/2025 - 8/31/2025							
		9/1/2025 - 9/30/2025							
Other Compliance Schedules									
Compliance Schedule Activity					Due Date		Achieved Date		
CROSS CONNECTION EXEMPTION					3/1/2023				
CERTIFY LEAD SL NOTIFICATION					7/1/2025		4/21/2025		
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE					12/29/2025				
MAIL/HAND DELIVER NOTICE TO CONSUMERS					12/31/2025				
CROSS CONNECTION SURVEY REPORT					3/1/2026				
CERTIFY LEAD SL NOTIFICATION					7/1/2026				
Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2	DBPR
00600	DISTRIBUTION SYSTEM	00004	TL HEIGHTS DIST	A	Y				
		02362	49 TYLER LAKE	A	Y				Y
		4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSSTREAM	WITHIN 5 SERVICE CON	A					
		PB6892	56 TYLER LAKE HTS RD	A		3			
		PB6893	11 TYLER LAKE HTS EX	A		3			
		PB6894	62 TYLER LAKE HTS RD	A		3			
		PB6895	75 TYLER LAKE HTS RD	A		3			

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0550011	AQUARION-TYLER LAKE			C	142	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						57	

Towns Served: GOSHEN

### Water System Facility and Sampling Point Inventory

<i>Water System</i> <b>Facility ID</b>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		PB6896	61 TYLER LAKE HTS RD	A		3		
		PB6897	37 TYLER LAKE HTS RD	A		3		
		PB8852	15 TYLER LAKE HEIGHT	A		3		
		PB8853	21 TYLER LAKE HEIGHT	A		3		
		PB8854	29 TYLER LAKE HEIGHT	A		3		
		PB8855	41 TYLER LAKE HEIGHT	A		3		
		PB8856	17 CENTER ROAD	A		3		
		PB8857	3 PARK ROAD	A		3		
		PB8858	9 PARK ROAD	A		3		
		PB8859	532 SHARON TURNPIKE	A		3		
		PB8860	566 SHARON TURNPIKE	A		3		
		PB9090	25 TYLER LAKE HEIGHT	A		3		
		TYLER002	23 PARK ROAD	I	Y	3		
		TYLER003	22 PARK RD. EXT.	I	Y	3		
		TYLER004	45 TYLER LAKE HTS	I	Y	3		
		TYLER005	27 TYLER LAKE HTS.	I	Y	3		
		TYLER006	541 SHARON TURNPIKE	I	Y	3		
		TYLER008	10 TYLER LAKE HGHTS	I	Y	3		
		TYLER009	6 TYLER LAKE HGHTS	I	Y	3		
		TYLER010	29 TYLER LAKE HTS EX	I	Y	3		
		TYLER011	25 TYLER LAKE HTS EX	I	Y	3		
		TYLER012	21 TYLER LAKE HTS EX	I	Y	3		
		TYLER013	19 TYLER LAKE HTS EX	I	Y	3		
		TYLER014	15 TYLER LAKE HTS EX	I	Y	3		
		TYLER016	13 TYLER LAKE HTS EX	I	Y	3		
		TYLER017	9 TYLER LAKE HTS EX	I	Y	3		
		TYLER018	20 TYLER LAKE HTS EX	I	Y	3		
		TYLER019	22 TYLER LAKE HTS RD	I	Y	3		
		TYLER020	24 TYLER LAKE HGHTS	I	Y	3		
		TYLER021	26 TYLER LAKE HTS RD	I	Y	3		
		TYLER022	28 TYLER LAKE HTS RD	I	Y	3		
		TYLER023	30 TYLER LAKE HTS RD	I	Y	3		
		TYLER024	34 TYLER LAKE HTS RD	I	Y	3		
		TYLER025	36 TYLER LAKE HTS RD	I	Y	3		
		TYLER026	40 TYLER LAKE HTS RD	I	Y	3		
		TYLER027	44 TYLER LAKE HTS RD	I	Y	3		
		TYLER028	46 TYLER LAKE HTS RD	I	Y	3		
		TYLER029	54 TYLER LAKE HTS RD	I	Y	3		
		TYLER031	58 TYLER LAKE HTS RD	I	Y	3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0550011	AQUARION-TYLER LAKE			C	142	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							57	

Towns Served: GOSHEN

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		TYLER032	60 TYLER LAKE HTS RD	I	Y	3		
		TYLER034	64 TYLER LAKE HTS RD	I	Y	3		
		TYLER036	69 TYLER LAKE HTS RD	I	Y	3		
		TYLER037	65 TYLER LAKE HTS RD	I	Y	3		
		TYLER039	57 TYLER LAKE HTS RD	I	Y	3		
		TYLER041	39 TYLER LAKE HTS RD	I	Y	3		
		TYLER043	35 TYLER LAKE HTS RD	I	Y	3		
		TYLER046	9 TYLER LAKE HTS RD	I	Y	3		
		TYLER048	27 CENTER ROAD	I	Y	3		
		TYLER050	19 PARK ROAD	I	Y	3		
		TYLER051	12 PARK ROAD EXT	I	Y	3		
		TYLER052	13 PARK ROAD EXT	I	Y	3		
		TYLER053	544 SHARON TURNPIKE	I	Y	3		
		TYLER054	550 SHARON TURNPIKE	I	Y	3		
		TYLER055	552 SHARON TURNPIKE	I	Y	3		
		TYLER056	556 SHARON TURNPIKE	I	Y	3		
		TYLER057	560 SHARON TURNPIKE	I	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
131	WELL 1	2	WELL 1	A				
61632	ATMOSPHERIC STORAGE							
62123	TREATMENT PLANT							

### Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 62123)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GAGNON, MATTHEW B.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027 3/31/2027
HUMES, DANIEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2028 6/30/2028
GEDDES, HOLLY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027

### Contact Information

Name				Organization		Job Title			
Mr. John P. Walsh				Aquarion Water Company		Vice President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
835 Main Street			Mail Stop 700			Bridgeport		CT	06604
Business Phone		Extension	Fax		Mobile Phone		Emergency Phone	Email Address	
203-337-5852			203-337-5938				781-413-6175	jwalsh@aquarionwater.com	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0550011</b>	<b>AQUARION-TYLER LAKE</b>	<b>C</b>	<b>142</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					57
Towns Served: GOSHEN					
Contact Role(s): <b>Legal Contact</b>					
Name		Organization		Job Title	
<b>Mr. Robert J. Ulrich</b>		Aquarion Water Company of Ct		Vp-Supply & Utility	
Mailing Address Line One		Mailing Address Line Two		City	State
505 Huntington St.				Shelton	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com
Contact Role(s): <b>Administrative Contact</b>					
<p><b>Please note the following:</b></p> <ol style="list-style-type: none"> <li>1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.</li> <li>2. If a Collection Period is specified, all water quality samples must be collected during the specified period.</li> <li>3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.</li> </ol>					

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0550321	VILLAGE MARKET PLACE			C	462	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 TORRINGTON ROAD				21	7			
Towns Served: GOSHEN								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/25 - 12/31/27	6/1-9/30	
	1/1/28 - 12/31/30	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Chloride (1017)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0550321	VILLAGE MARKET PLACE			C	462	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 TORRINGTON ROAD				21	7			
Towns Served: GOSHEN								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Chloride (1017)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Nickel (1036)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0550321	VILLAGE MARKET PLACE			C	462	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 TORRINGTON ROAD				21	7			
Towns Served: GOSHEN								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 12/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 1/1/2007	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
SUBMIT CCR TO THE DEPARTMENT	6/30/2022	
SUBMIT CCR CERTIFICATION FORM	8/9/2022	
SUBMIT CCR CERTIFICATION FORM	8/9/2024	
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		VMP1	GOSHENETTE DINER	I	Y	N		
		VMP10	FARMERS INS	A	Y	N		
		VMP2	STUDIO G	A	Y	N		
		VMP3	VILLAGE MKTPL STR	A	Y	N		
		VMP4	GOSHEN HDWR STORE	I	Y	N		
		VMP5	M GREENBURG & ASSO	A	Y	N	Y	
		VMP6	HILTZ & BOWLING OFCE	A	Y	N		
		VMP7	APT1	A	Y	N		
		VMP8	GSN DINER LADY SINK	A		N		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0550321	VILLAGE MARKET PLACE			C	462	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
59 TORRINGTON ROAD			21	7			
Towns Served: GOSHEN							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		VMP9	GSN DINER KIT SINK	A	Y	N		
00700	ENTRY POINT	3	ENTRY POINT	A				
1826	WELL 1	2	WELL 1	A				
37326	ATMOSPHERIC STORAGE							
55980	VFD PUMP							
659	WELL 1 TREATMENT PLANT							

### Certified Operator Information

**Water System Facility:** WELL 1 TREATMENT PLANT (WSF ID: 659)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRELA, GEORGE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026

### Contact Information

Name				Organization			Job Title		
Mr. Chris Sanders				Goshen Housing Trust, Inc			President		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 511						Goshen		CT	06756
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-307-1122							csanders@goshenhousingtrust.org		

**Contact Role(s):** Administrative Contact, Legal Contact, Owner

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**