

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570062	GREENWICH AMERICAN CENTER			NTNC	800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 AMERICAN LANE					2			

Towns Served: GREENWICH

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KITCHEN SALAD PREP (102)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ANNEX MENS ROOM (101)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/28	6/1-9/30	
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570062	GREENWICH AMERICAN CENTER			NTNC	800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 AMERICAN LANE					2			
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL 39 (WSF ID: 10258)

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0570062	GREENWICH AMERICAN CENTER			NTNC	800	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 AMERICAN LANE				2			
Towns Served: GREENWICH							

### Monitoring Requirements

Water System Facility: WELL 39 (WSF ID: 10258)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 39 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 14 (WSF ID: 49409)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 14 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: .2 MG/L	Daily	
Start Date: 1/1/2002	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	5/1/2025 - 5/31/2025			
	6/1/2025 - 6/30/2025			
	7/1/2025 - 7/31/2025			
	8/1/2025 - 8/31/2025			

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570062	GREENWICH AMERICAN CENTER			NTNC	800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 AMERICAN LANE					2			
Towns Served: GREENWICH								

Towns Served: GREENWICH

**Water System Facility: ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: .2 MG/L	Daily
<b>Start Date:</b> 1/1/2002	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
9/1/2025 - 9/30/2025			

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
ADDRESS CONTAMINATION	11/10/2023	
CONSULT WITH THE DEPARTMENT	6/12/2025	5/14/2025
ADDRESS CONTAMINATION	9/10/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	101	ANNEX MENS ROOM	A				Y
		101 ANNEX M	GENERATED BY BATCH	A	Y			
		102	KITCHEN SALAD PREP	A	Y		Y	Y
		102 KITCHEN	GENERATED BY BATCH	A	Y			
		103	3E MENS ROOM	A		N		
		103 3E MENS	GENERATED BY BATCH	A	Y			
		104	2E LADIES ROOM	A		N		
		104 2E LADI	GENERATED BY BATCH	A	Y			
		105	1E MENS ROOM	A		N		
		105 1E MENS	GENERATED BY BATCH	A	Y			
		106	T/L EAST MENS ROOM	A		N		
		106 T/L EAS	GENERATED BY BATCH	A	Y			
		107	3W LADIES ROOM	A		N		
		107 3W LADI	GENERATED BY BATCH	A	Y			
		108	2W MENS ROOM	A		N		
		108 2W MENS	GENERATED BY BATCH	A	Y			
		109	1W LADIES ROOM	A		N		
		110	T/L WEST MENS ROOM	A		N		
		110 T/L MEN	GENERATED BY BATCH	A	Y			
		1W LADIES R	GENERATED BY BATCH	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10258	WELL 39	2	WELL 39	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570062	GREENWICH AMERICAN CENTER			NTNC	800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 AMERICAN LANE					2			
Towns Served: GREENWICH								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
1702	GREENWICH AMERICAN TREATMENT PLANT							
49409	WELL 14	2	WELL 14	A				
55557	ATMOSPHERIC STORAGE TANK							
55559	BOOSTER PUMPS							

### Certified Operator Information

**Water System Facility:** GREENWICH AMERICAN TREATMENT PLANT (WSF ID: 1702)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HILL, ROBERT C.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2027

### Contact Information

Name		Organization		Job Title	
Mrs. Linda Enes		Tishman Speyer		Property Manager	
Mailing Address Line One		Mailing Address Line Two		City	State Zip Code
1 American Lane, Suite 301				Greenwich	CT 06831
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-861-4400				203-667-3877	lenes@tishmanspeyer.com

**Contact Role(s):** Administrative Contact, Legal Contact, Owner

Name		Organization		Job Title	
Mr. Peter Schmitt		Tishman Speyer		Chief Engineer	
Mailing Address Line One		Mailing Address Line Two		City	State Zip Code
1 American Lane, Suite 301				Greenwich	CT 06831
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-861-4400				203-667-3647	pschmitt@tishmanspeyer.com

**Contact Role(s):** Legal Contact, Owner

Name		Organization		Job Title	
Mr. Christian Schnaufer		Tishman Speyer		Director_Prpty Opera	
Mailing Address Line One		Mailing Address Line Two		City	State Zip Code
45 Rockefeller Plaza				New York	NY 10111
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
646-483-0907					cschnaufer@tishmanspeyer.com

**Contact Role(s):** Legal Contact, Owner

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570062	GREENWICH AMERICAN CENTER			NTNC	800	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
1 AMERICAN LANE			Connections		2			
Towns Served: GREENWICH								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570142	ROUND HILL COMMUNITY CHURCH			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
395 ROUND HILL ROAD				3				
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		Complete
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570142	ROUND HILL COMMUNITY CHURCH			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
395 ROUND HILL ROAD				3				
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		1 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 6/30/25		Complete
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	4
Start Date: 5/1/2008		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	
		7/1/2025 - 7/31/2025	
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SWTS 1: PWS TO RECOMMEND SOWT	6/29/2025	
CCTS 1: PWS TO RECOMMEND OCCT	6/30/2025	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570142	ROUND HILL COMMUNITY CHURCH			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
395 ROUND HILL ROAD				3				
Towns Served: GREENWICH								

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SWTS 2: DWS REVIEW & APPROVAL OF SOWT	12/29/2025	
CCTS 2: DWS REVIEW & APPROVAL OF OCCT	12/31/2025	
CROSS CONNECTION EXEMPTION	3/1/2026	

### Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
pH M&R Violation	11/1/14 - 11/30/14	3	1/9/2016		1/19/2016	
Lead and Copper TT Violation	6/30/25 -	2	9/12/2025		9/22/2025	
Lead and Copper TT Violation	7/1/25 -	2	9/12/2025		9/22/2025	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		RH001	KIT SINK COM CTR DBL	A	Y	2	Y	
		RH002	KIT SINK COM CTR SNG	A	Y	2	Y	
		RH003	KIT SINK COM CTR TRP	A	Y	2	Y	
		RH004	RR COMM CTR MR L	A	Y	2	Y	
		RH005	RR COMM CTR MR R	A	Y	2	Y	
		RH006	RR COMM CTR LR L	A	Y	2	Y	
		RH007	RR COMM CTR LR R	A	Y	2	Y	
		RH008	RR CHURCH MR L	A	Y	2	Y	
		RH009	RR CHURCH MR R	A	Y	2	Y	
		RH010	RR CHURCH LR R	A	Y	2	Y	
		RH011	RR CHURCH LR L	A	Y	2	Y	
		RH012	CHURCH SCHOOL SINK	A	Y	2	Y	
		RH013	RR CHURCH NURSERY SC	A	Y	2	Y	
		RH014	KIT SNK CHURCH	A	Y	2	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20054	WELL	2	WELL	A				
54359	TREATMENT SYSTEM FOR PH							
61326	ATMOSPHERIC STORAGE TANK 1							
61328	ATMOSPHERIC STORAGE TANK 2							
61330	ATMOSPHERIC STORAGE TANK 3							

### Certified Operator Information

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570142	ROUND HILL COMMUNITY CHURCH			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
395 ROUND HILL ROAD				3				
Towns Served: GREENWICH								

### Certified Operator Information

**Water System Facility:** TREATMENT SYSTEM FOR PH (WSF ID: 54359)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, PAUL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

### Contact Information

Name		Organization		Job Title		
Ms. Lynda C. Kinney		Round Hill Community Church		Administrator		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
395 Round Hill Road				Greenwich	CT	06831
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-869-1091		203-869-6927		203-788-1773	church@roundhillcommunitychurch.org	

**Contact Role(s):** Administrative Contact

Name		Organization		Job Title		
Mr. Joseph Huley		Round Hill Community Church		Chairman		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
395 Round Hill Rd				Greenwich	CT	06831
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-869-1091					JHULEY@OPTONLINE.NET	

**Contact Role(s):** Legal Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570202	WHITBY SCHOOL			NTNC	350	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
969 LAKE AVENUE				3				

Towns Served: GREENWICH

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CAEDMON KITCHEN (WS001)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
<b>Lead And Copper (PBCU)</b>		<b>10 routine (RT) per six months</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
<b>Nitrate (1040)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
<b>Nitrite (1041)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570202	WHITBY SCHOOL			NTNC	350	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
969 LAKE AVENUE				3				
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Nitrite (1041)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26		
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.32 MG/L	Continuous
<b>Start Date:</b> 11/1/2014	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.35 MG/L	2
<b>Start Date:</b> 11/1/2017	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570202	WHITBY SCHOOL			NTNC	350	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
969 LAKE AVENUE				3				
Towns Served: GREENWICH								

**Water System Facility: ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.6 MG/L	2
Start Date: 11/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	4
Start Date: 11/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 7.7 PH	4
Start Date: 11/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 11/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SAMPLING SITE PLAN	11/30/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570202	WHITBY SCHOOL			NTNC	350	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
969 LAKE AVENUE				3				
Towns Served: GREENWICH								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WS001	CAEDMON KITCHEN	A	Y	N		Y
		WS003	CUSTODIAL ROOM 306	A	Y	N		
		WS004	FOUNDERS STONE ROOM	A	Y	N		
		WS005	FOUNDERS KITCHEN	A	Y	N		
		WS006	RENAISSANCE 2ND FL M	A	Y	N		
		WS007	GYM 2ND FL RR SINK	A	Y	N		
		WS008	GYM BOYS RM LEFT SK	A		N		
		WS009	GYM BOYS RM RIGHT SK	A		N		
		WS010	CAEDMON BOYS RM SK	A	Y	N		
		WS011	CAEDMON GIRLS RM SK	A	Y	N		
		WS012	CAEDMON UNISEX RR SK	A	Y	N		
		WS013	DISTRIBUTION SYSTEM	A	Y	N		
		WS014	FOUNDERS GIRLS RM SK	A	Y	N		
		WS015	FOUNDERS KITCHEN SK	A	Y	N		
		WS016	RENAISSANCE 1ST FL M	A	Y	N		
		WS017	RENAISSANCE 1ST FL L	A	Y	N		
		WS018	ART ROOM LFT SNK	A	Y	N		
		WS019	ART ROOM RT SNK	A	Y	N		
00700	ENTRY POINT	3	ENTRY POINT	A				
10260	WELL 2	2	WELL 2	A				
50212	ATMOSPHERIC TANK							
50214	HYDROPNEUMATIC TANK							
60730	WELL 3	2	WELL 3	A				
60732	WELL 3 TREATMENT PLANT							
941	WELL 2 TREATMENT PLANT							
XX700	ENTRY POINT	3X	ENTRY POINT	A				

### Certified Operator Information

**Water System Facility:** WELL 2 TREATMENT PLANT (WSF ID: 941)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570202	WHITBY SCHOOL			NTNC	350	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
969 LAKE AVENUE				3				
Towns Served: GREENWICH								

### Certified Operator Information

**Water System Facility: WELL 3 TREATMENT PLANT (WSF ID: 60732)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

### Contact Information

Name		Organization		Job Title		
<b>Mr. Thomas F. Coleman</b>		Whitby School		Dir of Facilities		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
969 Lake Avenue				Greenwich	CT	06830
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-869-8464	129	203-869-9445		203-561-9491	tcoleman@whitbyschool.org	

**Contact Role(s):** Administrative Contact

Name		Organization		Job Title		
<b>Ms. Simone Becker</b>		Whitby School		Head of Schools		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
969 Lake Avenue				Greenwich	CT	06830
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-869-8464					sbecker@whitbyschool.org	

**Contact Role(s):** Legal Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570212	PARKWAY SCHOOL			NTNC	275	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
141 LOWER CROSS ROAD				2				
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Alkalinity (1927)		2 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		10 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Nitrate (1040)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Nitrite (1041)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570212	PARKWAY SCHOOL			NTNC	275	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
141 LOWER CROSS ROAD				2				

Towns Served: GREENWICH

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Water System Facility: WELL #2 (WSF ID: 53226)

<b>E. Coli (3014)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
<b>Per and Polyfluoroalkyl Substances (PFAS)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	1/1/24 - 12/31/24		Complete

Water System Facility: WELL #3 (WSF ID: 53228)

<b>E. Coli (3014)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #3 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
<b>Per and Polyfluoroalkyl Substances (PFAS)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #3 (2)	1/1/24 - 12/31/24		Complete

### Optimal Water Quality Corrosion Control Parameters

Water System Facility: DISTRIBUTION SYSTEM (WSFID: 00600)

<b>Start Date:</b>	<b>Analyte</b>	<b>Operating Limit</b>
11/1/2018	pH	Minimum: 7.0 PH

### Monthly Water System Facility (WSF) Level Monitoring Requirements

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570212	PARKWAY SCHOOL			NTNC	275	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
141 LOWER CROSS ROAD				2				

Towns Served: GREENWICH

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	Daily
Start Date: 12/1/2016	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 7.7 PH	Daily
Start Date: 11/1/2018	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2027	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		Y	
		7EAST	7 E CLASSROOM SINK	I		N		
		CAFETERIA	GENERATED BY BATCH	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PS001	1W CLASSROOM SINK	A	Y	2	Y	
		PS002	2N CLASSROOM SINK	A	Y	2	Y	
		PS003	3 S CLASSROOM SINK	A	Y	2	Y	
		PS004	3 W CLASSROOM SINK	A	Y	2	Y	
		PS005	4 E CLASSROOM SINK	A	Y	2	Y	
		PS006	4N CLASSROOM SINK	A	Y	2	Y	
		PS007	4 SA CLASSROOM SINK	A	Y	2	Y	
		PS008	4 WEST CLASSROOM SIN	A	Y	2	Y	
		PS009	5S CLASSROOM SINK	A	Y	2	Y	
		PS010	7 EAST	A	Y	2	Y	
		PS011	8 EAST CLASSROOM SIN	A	Y	2	Y	
		PS012	8S CLASSROOM SINK	A	Y	2	Y	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570212	PARKWAY SCHOOL			NTNC	275	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
141 LOWER CROSS ROAD				2				
Towns Served: GREENWICH								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		PS013	ART ROOM SINK	A	Y	2	Y	
		PS014	BOYS ROOM SINK	A	Y	2	Y	
		PS015	CAF WATER FOUNTAIN	A	Y	2	Y	
		PS016	GIRLS ROOM SINK	A	Y	2	Y	
		PS017	TEACHERS LOUNGE SINK	A	Y	2	Y	
		PS018	ART ROOM SNK 1	A	Y	2	Y	
		PS019	ART ROOM SNK 2	A	Y	2	Y	
		PS020	ART ROOM SNK 3	A	Y	2	Y	
		PS021	ART ROOM SNK 4	A	Y	2	Y	
		PS022	KIT SNK R	A	Y	2	Y	
		PS023	KIT SNK MIDDLE	A	Y	2	Y	
		PS024	KIT SNK L	A	Y	2	Y	
		PS025	2S CLASSROOM	A	Y	2	Y	
		PS026	4 E CLASSROOM	A	Y	2		
		PS027	5N CLASSROOM	A	Y	2	Y	
		PS028	KITCHEN DISHWASHING	I		N		
		PS029	NURSE'S OFFICE SINK	A		2		
		PS030	KITCHEN HAND WASH	A	Y	2	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
53226	WELL #2	2	WELL #2	A				
53228	WELL #3	2	WELL #3	A				
63057	IN-BETWEEN FILTERS							
963	TREATMENT PLANT							

### Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 963)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027
YOUNG, RICHARD	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CONDITIONA	6/30/2026

### Contact Information

Name				Organization		Job Title			
Mr. Daniel Watson				Greenwich Public Schools		Dir. of Facilities			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
290 Greenwich Avenue						Greenwich		CT	06830
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
203-625-7437							daniel_watson@greenwich.k12.ct.us		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0570212</b>	<b>PARKWAY SCHOOL</b>	<b>NTNC</b>	<b>275</b>	<b>L</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
141 LOWER CROSS ROAD		2			
Towns Served: GREENWICH					
Contact Role(s): <b>Administrative Contact</b>					
Name		Organization		Job Title	
<b>Dr. Toni Jones</b>		Greenwich Public Schools		Superintendent	
Mailing Address Line One		Mailing Address Line Two		City	State
290 Greenwich Avenue				Greenwich	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-625-7486		203-625-7401		203-625-7450	toni_jones@greenwich.k12.ct.us
Contact Role(s): <b>Legal Contact</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570262	SUTTON LAND, LLC			NTNC	150	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1041-1073 NORTH STREET				3				
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/26	6/1-9/30	
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: <b>ENTRY POINT (WSF ID: 00700)</b>			
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570262	SUTTON LAND, LLC			NTNC	150	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1041-1073 NORTH STREET				3				
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		NSSC 001	MARKET HAND SINK-F	A	Y	1	Y	Y
		NSSC 002	PIZZA RR	A	Y	1	Y	Y
		NSSC 003	FLW SHOP UTIL SINK	A	Y	1	Y	Y
		NSSC 004	PHARM RR	A	Y	1	Y	Y
		NSSC 005	GRACE RR	A	Y	1	Y	Y
		NSSC 006	LIQUOR STORE RR	A	Y	1		
		NSSC 007	MARKET HAND SINK-M	A	Y	1		
		NSSC 008	MARKET HAND SINK-B	A	Y	1		
		NSSC 009	MARKET DISH SHINK	A	Y	1		
		NSSC 010	MARKET MENS ROOM	A	Y	1		
		NSSC 011	MARKET LADIES ROOM	A	Y	1		
		NSSC 012	HOT TUB SHOP RR	A	Y	1		
		NSSC 013	COMPUTER SHOP RR	A	Y	1		
		NSSC 014	DESIGN STUDIO	A	Y	1		
		NSSC 015	PIZZA KITCH SINK	A	Y	1		
		NSSC 016	CLEANERS RR	A	Y	1		
		NSSC 017	CUSTOM KITCHEN RR	A	Y	1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10263	WELL	2	WELL	A				
1260	NORTH STREET TREATMENT PLANT							
60868	ATMOSPHERIC TANKS							

### Certified Operator Information

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570262	SUTTON LAND, LLC			NTNC	150	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1041-1073 NORTH STREET				3				
Towns Served: GREENWICH								

### Certified Operator Information

**Water System Facility:** NORTH STREET TREATMENT PLANT (WSF ID: 1260)

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, PAUL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025

### Contact Information

Name				Organization			Job Title		
Mr. Stanford Guy Sutton				Sutton Land, LLC			Agent of Service		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
87 Greenwich Avenue						Greenwich		CT	06830
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-661-5226							suttonland87@yahoo.com		

**Contact Role(s):** Administrative Contact, Legal Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0575023	FAIRVIEW COUNTRY CLUB			NTNC	435	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1241 KING STREET				1			
Towns Served: GREENWICH							

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Chlorine Residual (1012)		3 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	6/1/25 - 6/30/25		
Chlorine Residual (1012)		4 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SNACK BAR (FCC033)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
Total Trihalomethanes (2950)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
#7 T BATHROOM (FCC032)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 5/31/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Total Coliform (3100)		3 repeat (RP) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/31/25 - 6/5/25		Complete
Total Coliform (3100)		3 temporary routine (TR) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	6/1/25 - 6/30/25		
Lead And Copper (PBCU)		5 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0575023	FAIRVIEW COUNTRY CLUB			NTNC	435	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1241 KING STREET					1			
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Arsenic (1005)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Chloride (1017)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Nitrate (1040)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Nitrite (1041)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Ethylene Dibromide (EDB) (2946)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0575023	FAIRVIEW COUNTRY CLUB			NTNC	435	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1241 KING STREET					1			
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

**Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)** 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Organic Chemicals (VOCS)** 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL #1 (WSF ID: 10267)

**E. Coli (3014)** 1 triggered (TG) per period

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	5/30/25 - 6/5/25		Complete

**E. Coli (3014)** 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #1 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: WELL #2 (WSF ID: 10268)

**E. Coli (3014)** 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #2 (2)	4/1/25 - 6/30/25		Out of Service
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: .2 MG/L	Daily
Start Date: 1/1/2002	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0575023	FAIRVIEW COUNTRY CLUB			NTNC	435	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1241 KING STREET					1			
Towns Served: GREENWICH								

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		FCC001	KIT SNK DOUBLE OLD	A	Y	2	Y	
		FCC002	KIT SNK TRPL SNK OLD	A	Y	2	Y	
		FCC003	KIT SNK SINGLE OLD	A	Y	2	Y	
		FCC004	KIT HAND SNK OLD	A	Y	2	Y	
		FCC005	BAR SINK OLD	A	Y	2	Y	
		FCC006	KIT HAND SNK NEW	A	Y	2	Y	
		FCC007	KIT SNK SML SING NEW	A	Y	2	Y	
		FCC008	KIT SNK LRG SING NEW	A	Y	2	Y	
		FCC009	KIT SNK TRP SK L NEW	A	Y	2	Y	
		FCC010	KIT SNK TRP SK R NEW	A	Y	2	Y	
		FCC011	SLOP SINK F1	A	Y	2	Y	
		FCC012	BAR HAND SINK NEW L	A	Y	2	Y	
		FCC013	BAR HAND SINK NEW R	A	Y	2	Y	
		FCC014	BAR SINK TRIPLE NEW	A	Y	2	Y	
		FCC015	RR LADY ROOM 1F L	A	Y	2	Y	
		FCC016	RR LADY RM 1F M	A	Y	2	Y	
		FCC017	RR LADY ROOM 1F R	A	Y	2	Y	
		FCC018	RR MENS RM 1F L	A	Y	2	Y	
		FCC019	RR MENS RM 1F R	A	Y	2	Y	
		FCC020	LAUNDRY RM DBL SINK	A	Y	2	Y	
		FCC021	BSMTFOODPREP SINGSNK	A	Y	2	Y	
		FCC022	RR BASEMENT	A	Y	2	Y	
		FCC023	RR LADY ROOM LWR LVL	A	Y	2	Y	
		FCC024	BOILER ROOM SINK	A	Y	2	Y	
		FCC025	RR 7 T	A	Y	2	Y	
		FCC026	SNACK BAR SINK	A	Y	2	Y	
		FCC027	SINK BASEMENT	A	Y	2	Y	
		FCC028	KITCHEN SINK	A	Y	2	Y	
		FCC029	BAR TWO	A	Y	2	Y	
		FCC030	LADIES LOCKERROOM	A	Y	2	Y	
		FCC031	SINK BOILER ROOM	A	Y	2	Y	
		FCC032	#7 T BATHROOM	A	Y	2	Y	Y
		FCC033	SNACK BAR	A	Y	2	Y	Y

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0575023	FAIRVIEW COUNTRY CLUB			NTNC	435	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1241 KING STREET					1			
Towns Served: GREENWICH								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10267	WELL #1	2	WELL #1	A				
10268	WELL #2	2	WELL #2	A				
45109	TREATMENT PLANT							
60867	ATM TANK							

### Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 45109)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

### Contact Information

Name				Organization			Job Title		
Mr. John M. Perella				Fairview Country Club			Faculty Director		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1241 King Street						Greenwich		CT	06831
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-531-6200		205	203-531-4477				john@fairviewcountryclub.org		

Contact Role(s): **Administrative Contact, Legal Contact**

#### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0579043	FIRST CHURCH OF ROUND HILL			NTNC	60	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
464 ROUND HILL ROAD AND JOHN STREET			1				
Towns Served: GREENWICH							

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		Complete
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Iron (1028)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0579043	FIRST CHURCH OF ROUND HILL			NTNC	60	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
464 ROUND HILL ROAD AND JOHN STREET			1				
Towns Served: GREENWICH							

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Iron (1028)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Manganese (1032)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Lead And Copper (PBCU)		1 routine (RT) per six months	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0579043	FIRST CHURCH OF ROUND HILL			NTNC	60	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
464 ROUND HILL ROAD AND JOHN STREET			Connections	1				
Towns Served: GREENWICH								

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SAMPLING SITE PLAN	1/22/2024	
CROSS CONNECTION EXEMPTION	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		FCRH-BB	BOYS BATHROOM	A	Y	N		
		FCRH-GB	GIRLS BATHROOM	A	Y	N		
		FCRH-K	KITCHEN	A	Y	N		
		FCRH-LB	LADIES BATHROOM	A	Y	N		
		FCRH-MB	MENS BATHROOM	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
62082	NEW WELL	2	NEW WELL	A				
62084	TREATMENT PLANT							

### Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 62084)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, ANDREW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

### Contact Information

Name				Organization		Job Title			
Reverend Leo Curry				First Church of Round Hill		Pastor			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
464 Round Hill Road						Greenwich		CT	06831
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-629-3876							fcroundhill@outlook.com		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

#### Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0579123	BRUNSWICK SCHOOL (UPPER MIDDLE)			NTNC	295	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1275 KING STREET				3				
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KITCHEN SINK GRND FL (DIST1KIT)	1/1/24 - 12/31/24	8/1-8/31	Complete
	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
2ND FLOR N. PANTRY (SAMP3NPANT2)	1/1/24 - 12/31/24	8/1-8/31	Complete
	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>2,4-D (2105)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0579123	BRUNSWICK SCHOOL (UPPER MIDDLE)			NTNC	295	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1275 KING STREET				3				
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Continuous
Start Date: 12/1/2019		Compliance History:	Monitoring
		Monitoring Period	Compliance Status:
		5/1/2025 - 5/31/2025	Y
		6/1/2025 - 6/30/2025	Y
		7/1/2025 - 7/31/2025	Y
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0579123	BRUNSWICK SCHOOL (UPPER MIDDLE)			NTNC	295	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1275 KING STREET				3				
Towns Served: GREENWICH								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DIST1KIT	KITCHEN SINK GRND FL	A	Y			Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		GARBAT2	GARAGE BATHROOM	P				
		GARFILT1	GARAGE FILTRATON RM	P				
		GROUNDFIT2	FITNESS CNTR PANTRY	P	Y			
		OUTBLDG	PUMP HOUSE TAP	P				
		SAMP1NPANT1	1ST FLR. N. PANTRY	P				
		SAMP2SPANT1	1ST FLR. S. PANTRY	P				
		SAMP3NPANT2	2ND FLOR N. PANTRY	A				Y
		SAMP4SPANT2	2ND FLR S. PANTRY	P				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WELL1SAMP	WELL#1 PUMP HOUSE	P				
		WELL2SAMP	WELL #2 PUMP HOUSE	P				
		WELL3SAMP	WELL #3 PUMP HOUSE	P				
		WELL4SAMP	WELL #4 PUMP HOUSE	P				
00700	ENTRY POINT	3	ENTRY POINT	A				
10270	WELL #1	2	WELL	A				
10841	WELL #2	2	WELL #2	A				
10842	WELL #3	2	WELL #3	A				
59302	WELL #4	2	WELL #4	A				
61182	ATMOSPHERIC STORAGE							
967	TREATMENT PLANT							

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
WITTENZELLNER, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2027
HARKINS, STUART A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028

**Water System Facility: TREATMENT PLANT (WSF ID: 967)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
WITTENZELLNER, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2027
HARKINS, STUART A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type		Primary Source	
CT0579123	BRUNSWICK SCHOOL (UPPER MIDDLE)			NTNC	295	P		GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
1275 KING STREET				3					

Towns Served: GREENWICH

### Contact Information

Name				Organization			Job Title		
Mr. Thomas Philip				Brunswick Middle School			Head Master		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
100 Maher Ave						Greenwich		CT	06831
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-625-5800				203-625-5800	Thomas_Philip@brunswickschool.org				

Contact Role(s): **Owner**

Name				Organization			Job Title		
Mr. Charles J. Redahan				Brunswick Middle School			Maintenance Super.		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1232 King Street						Greenwich		CT	06831
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-625-5877	5877	203-625-5816		203-223-2526	credahan@brunswickschool.org				

Contact Role(s): **Administrative Contact**

Name				Organization			Job Title		
Mrs. Kathleen Harrington				Brunswick School, Inc.			Cfo & Business Mangr		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
100 Maher Road						Greenwich		CT	06830
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-625-5815			203-625-5816			203-223-2526	kharrington@brunswickschool.org		

Contact Role(s): **Legal Contact**

#### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570164	STANWICH CLUB			NTNC	130	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
888 NORTH STREET					10			
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		Complete
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570164	STANWICH CLUB			NTNC	130	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
888 NORTH STREET					10			
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		SC01	KITCHEN-1 ENTRY PT	A	Y	2		Y
		SC02	KITCHEN-2	A	Y	2		Y
		SC03	MANAGERS MEN RM CLUB	A	Y	2		Y
		SC04	MANAGERS KITCHEN	A	Y	2		Y
		SC05	MANAGERS BATHROOM	A	Y	2		Y
		SC06	CLUB W LDY RM L SNK	A	Y	2		Y
		SC07	CLUB W LDY RM R SNK	A	Y	2		Y
		SC08	CLUB W MENS RM L SNK	A	Y	2		Y
		SC09	CLUB W MENS RM R SNK	A	Y	2		Y
		SC10	CLUB E LDY RM L SNK	A	Y	2		Y

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570164	STANWICH CLUB			NTNC	130	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
888 NORTH STREET			Connections		10			
Towns Served: GREENWICH								

Towns Served: GREENWICH

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		SC11	CLUB E LDY RM R SNK	A	Y	2		Y
		SC12	CLUB E MENS RM L SNK	A	Y	2		Y
		SC13	CLUB E MENS RM R SNK	A	Y	2		Y
		SC14	CLUB MAIN BAR SNK	A	Y	2		Y
		SC15	CLB MEN LCK RM L SNK	A	Y	2		Y
		SC16	CLB MEN LCK RM R SNK	A	Y	2		Y
		SC17	CLB LAD LCK RM R SNK	A	Y	2		Y
		SC18	CLB LAD LCK RM L SNK	A	Y	2		Y
		SC19	DORM 1 FL MENS BATH	A	Y	2		Y
		SC20	DORM 1 FL LADYS BATH	A	Y	2		Y
		SC21	DORM 2 FL MENS BATH	A	Y	2		Y
		SC22	DORM 2 FL LADYS BATH	A	Y	2		Y
		SC23	PRO SHOP REST RM SNK	A	Y	2		Y
		SC24	MEETING HSE KIT SNK	A	Y	2		Y
		SC25	MEETING HSE MENS SNK	A	Y	2		Y
		SC26	MEETING HSE LADY SNK	A	Y	2		Y
		SC27	POOL HSE MENS L SNK	A	Y	2		Y
		SC28	POOL HSE MENS R SNK	A	Y	2		Y
		SC29	POOL HSE LADY L SNK	A	Y	2		Y
		SC30	POOL HSE LADY R SNK	A	Y	2		Y
		SC31	TENNIS MENS RM SNK	A	Y	2		Y
		SC32	TENNIS LADYS RM SNK	A	Y	2		Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10259	WELL 1	2	WELL1	A				
55971	ATMOSPHERIC STORAGE TANKS							
60102	WELL 2	2	WELL 2	A				
62877	TREATMENT PLANT							

### Certified Operator Information

**Water System Facility:** TREATMENT PLANT (WSF ID: 62877)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

### Contact Information

Name		Organization	Job Title		
Mr. Guy D'ambrosio		Stanwich Country Club	General Manager		
Mailing Address Line One	Mailing Address Line Two		City	State	Zip Code
888 North Street			Greenwich	CT	06831

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0570164</b>	<b>STANWICH CLUB</b>	<b>NTNC</b>	<b>130</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
888 NORTH STREET			10		
Towns Served: GREENWICH					
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-869-0555	225				gdambrosio@stanwich.com
Contact Role(s): <b>Administrative Contact, Legal Contact</b>					
<p><b>Please note the following:</b></p> <ol style="list-style-type: none"> <li>1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.</li> <li>2. If a Collection Period is specified, all water quality samples must be collected during the specified period.</li> <li>3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.</li> </ol>					

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570184	TAMARACK COUNTRY CLUB			NTNC	130	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
55 LOCUST ROAD					1			
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
<b>Asbestos (1094)</b>		<b>1 routine (RT) per nine years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Haloacetic Acids (2456)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MAINT GARAGE SINK (TCC020)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
<b>Total Trihalomethanes (2950)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SINK KITCHEN POOL (TCC015)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
<b>Total Coliform (3100)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
<b>Lead And Copper (PBCU)</b>		<b>5 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
<b>Physical Parameters (PPS)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570184	TAMARACK COUNTRY CLUB			NTNC	130	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
55 LOCUST ROAD					1			
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: WELL 1 (WSF ID: 10822)

E. Coli (3014)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0570184	TAMARACK COUNTRY CLUB			NTNC	130	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
55 LOCUST ROAD			Connections		1			
Towns Served: GREENWICH								

### Monitoring Requirements

Water System Facility: WELL 1 (WSF ID: 10822)

**E. Coli (3014)** 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 3/31/26		

Water System Facility: WELL 2 (WSF ID: 51937)

**E. Coli (3014)** 1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2006	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2027	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BCSINK	BATH CLUB SNK	A	Y	N	Y	
		BCSINKL	BATH CLUB SNK L	A	Y	N	Y	
		BCSINKM	BATH CLUB SNK M	A	Y	N	Y	
		BSHS	BAR HAND SINK	A	Y	N	Y	
		BSSS	BAR SINK SINGLE SNK	A	Y	N	Y	
		DAYCAMPSNK	DAY CAMP SNK	A	Y	N	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		KSACRTFPTRL	KS ALACRT FP TRP L	A	Y	N	Y	
		KSACRTFPTRR	KS ALACRT FP TRP R	A	Y	N	Y	
		KSACRTHSCOF	KS ALACRT HS COF STA	A	Y	N	Y	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0570184	TAMARACK COUNTRY CLUB			NTNC	130	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
55 LOCUST ROAD				1			
Towns Served: GREENWICH							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		KSACRTSING	KS ALACRT SINGLE SNK	A	Y	N	Y	
		KSMANKHSB	KS MAIN KIT HANDSK B	A	Y	N	Y	
		KSMANKHSF	KS MAIN KIT HANDSK F	A	Y	N	Y	
		KSMANKTDBL	KS MAIN KIT DBL SK	A	Y	N	Y	
		KSMANKTRPL	KS MAIN KIT TRP L	A	Y	N	Y	
		KSMANKTRPR	KS MAIN KIT TRP R	A	Y	N	Y	
		KSPool	KS POOL	A	Y	N	Y	
		POOLHSEFONT	POOL HSE FOUNTAIN	A	Y	N	Y	
		RRLRLWLS	RR LADY L WALL L SNK	A	Y	N	Y	
		RRLRLWRS	RR LADY L WALL R SNK	A	Y	N	Y	
		RRLRRWLS	RR LADY R WALL L SNK	A	Y	N	Y	
		RRLRRWRS	RR LADY R WALL R SNK	A	Y	N	Y	
		RRMRLWLS	RR MENS L WALL L SNK	A	Y	N	Y	
		RRMRLWRS	RR MENS L WALL R SNK	A	Y	N	Y	
		RRMRRWLS	RR MENS R WALL L SNK	A	Y	N	Y	
		RRMRRWRS	RR MENS R WALL R SNK	A	Y	N	Y	
		TCC001	1ST SINK BASE CLUB	A	Y	N		
		TCC002	SINK BASE CLUB	A	Y	N		
		TCC003	SINK BATH BASE CLUB	A	Y	N		
		TCC004	SINK LG KITCHEN CLUB	A	Y	N		
		TCC005	SINK SM KITCHEN CLUB	A	Y	N		
		TCC006	SINK BATH CLUB	A	Y	N		
		TCC007	SINK BATH CLUB	A	Y	N		
		TCC008	SINK KITCHEN POOL	A	Y	N		
		TCC009	FOUNTAIN POOLHOUSE	A	Y	N		
		TCC010	SINK DAYCAMP	A	Y	N		
		TCC011	SINK M BROOM POOL	A	Y	N		
		TCC012	SINK W BR POOL	A	Y	N		
		TCC013	SINK W BR POOL	A	Y	N		
		TCC014	SINK KITCHEN POOL	A	Y	N		
		TCC015	SINK KITCHEN POOL	A	Y	N		Y
		TCC016	SINK BATH CLUB	A	Y	N		
		TCC017	SINK BATH CLUB	A	Y	N		
		TCC018	SINK BATH CLUB	A	Y	N		
		TCC019	SINK LAUNDRY CLUB	A	Y	N		
		TCC020	MAINT GARAGE SINK	A		N		Y
		TCC023	RR MENS L WALL R SNK	A	Y	N		
		TCC024	RR MENS L WALL L SNK	A	Y	N		
		TCC025	RR MENS R WALL R SNK	A	Y	N		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0570184	TAMARACK COUNTRY CLUB			NTNC	130	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
55 LOCUST ROAD				1			
Towns Served: GREENWICH							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		TCC026	RR MENS R WALL L SNK	A	Y	N		
		TCC027	RR LADY R WALL L SNK	A	Y	N		
		TCC028	RR LADY R WALL R SNK	A	Y	N		
		TCC029	RR LADY L WALL R SNK	A	Y	N		
		TCC030	RR LADY L WALL L SNK	A	Y	N		
		TCC031	BAR HAND SINK	A	Y	N		
		TCC032	BAR SINK SINGLE SNK	A	Y	N		
		TCC033	KS MAIN KIT TRP L	A	Y	N		
		TCC034	KS MAIN KIT TRP R	A	Y	N		
		TCC035	KS MAIN KIT HANDSK F	A	Y	N		
		TCC036	KS MAIN KIT HANDSK B	A	Y	N		
		TCC037	KS MAIN KIT DBL SK	A	Y	N		
		TCC038	KS ALACRT HS COF STA	A	Y	N		
		TCC039	KS ALACRT FP TRP L	A	Y	N		
		TCC040	KS ALACRT FP TRP R	A	Y	N		
		TCC041	KS ALACRT SINGLE SNK	A	Y	N		
		TCC042	BATH CLUB SNK M	A	Y	N		
		TCC043	BATH CLUB SNK L	A	Y	N		
		TCC044	DAY CAMP SNK	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10822	WELL 1	2	WELL 1	A				
51937	WELL 2	2	WELL 2	A				
51940	TREATMENT PLANT							
51941	ATMOSPHERIC TANK							

### Certified Operator Information

**Water System Facility:** TREATMENT PLANT (WSF ID: 51940)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2027

### Contact Information

Name				Organization		Job Title			
Mr. Brian P. Gillespie				Tamarack Country Club		General Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
55 Locust Road						Greenwich		CT	06831
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-531-7300		121	203-531-9558			914-830-5310	brian@tamarackcountryclub.com		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0570184</b>	<b>TAMARACK COUNTRY CLUB</b>	<b>NTNC</b>	<b>130</b>	<b>P</b>	<b>GW</b>

Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
55 LOCUST ROAD			1			

Towns Served: GREENWICH

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

***End of schedule***