

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			187				

Towns Served: GUILFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		2 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
Asbestos (1094)		2 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
DOGHOUSE QUIDNET COURT (DH-QC)	1/1/24 - 12/31/24	8/1-8/31	Complete
	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
Total Trihalomethanes (2950)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
DOGHOUSE POLPIS LANE (DH-PL)	1/1/24 - 12/31/24	8/1-8/31	Complete
	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
Total Coliform (3100)		2 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		20 routine (RT) per six months	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		2 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			187				

Towns Served: GUILFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		2 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT - LOWER (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			187				

Towns Served: GUILFORD

### Monitoring Requirements

Water System Facility: ENTRY POINT - LOWER (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: ENTRY POINT - UPPER (WSF ID: 00702)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - UPPER (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				187				

Towns Served: GUILFORD

### Monitoring Requirements

Water System Facility: WELL 2 (WSF ID: 724)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 3 (WSF ID: 725)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 3 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 4 (WSF ID: 726)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 4 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				187				

Towns Served: GUILFORD

### Monitoring Requirements

Water System Facility: WELL 4 (WSF ID: 726)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 5 (WSF ID: 727)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 5 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 4B (WSF ID: 728)

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 4B (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL 6 (WSF ID: 729)

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			187				

Towns Served: GUILFORD

### Monitoring Requirements

Water System Facility: WELL 6 (WSF ID: 729)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 6 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - LOWER (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
Start Date: 7/1/2013	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	5/1/2025 - 5/31/2025			
	6/1/2025 - 6/30/2025			
	7/1/2025 - 7/31/2025			
	8/1/2025 - 8/31/2025			
	9/1/2025 - 9/30/2025			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.88 MG/L	2	
Start Date: 6/1/2022	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	5/1/2025 - 5/31/2025			
	6/1/2025 - 6/30/2025			
	7/1/2025 - 7/31/2025			
	8/1/2025 - 8/31/2025			
	9/1/2025 - 9/30/2025			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 4.4 MG/L	2	
Start Date: 6/1/2022	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	5/1/2025 - 5/31/2025			

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			187				

Towns Served: GUILFORD

### Water System Facility: ENTRY POINT - LOWER (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 4.4 MG/L	2
Start Date: 6/1/2022	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

### Water System Facility: ENTRY POINT - UPPER (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2013	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.56 MG/L	2
Start Date: 6/1/2022	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 2.8 MG/L	2
Start Date: 6/1/2022	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				187				

Towns Served: GUILFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DH-MT	DOGHOUSE MOHAWK TRAI	A	Y	N	Y	
		DH-PL	DOGHOUSE POLPIS LANE	A	Y	N		Y
		DH-QC	DOGHOUSE QUIDNET COU	A	Y	N	Y	Y
		DH-WT	DOGHOUSE WAIWINET TR	A	Y	N		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MILL 10	BUILDING 27 UNIT 10	A	Y	N		
		MILL 12	BUILDING 27 UNIT 12	A	Y	N		
		MILL 14	BUILDING 27 UNIT 14	A	Y	N		
		MILL 16	BUILDING 27 UNIT 16	A	Y	N		
		MOHAWK 28	BUILDING 36 UNIT 28	A	Y	N		
		MOHAWK 30	BUILDING 36 UNIT 30	A	Y	N		
		MOHAWK 32	BUILDING 36 UNIT 32	A	Y	N		
		MOHAWK 33	BUILDING 35 UNIT 33	A	Y	N		
		MOHAWK 34	BUILDING 36 UNIT 34	A	Y	N		
		MOHAWK 35	BUILDING 35 UNIT 35	A	Y	N		
		MOHAWK 36	BUILDING 36 UNIT 36	A	Y	N		
		MOHAWK 37	BUILDING 35 UNIT 37	A	Y	N		
		MOHAWK 38	BUILDING 36 UNIT 38	A	Y	N		
		MOHAWK 39	BUILDING 35 UNIT 39	A	Y	N		
		MOHAWK 40	BUILDING 29 UNIT 40	A	Y	N		
		MOHAWK 41	BUILDING 28 UNIT 41	A	Y	N		
		MOHAWK 42	BUILDING 29 UNIT 42	A	Y	N		
		MOHAWK 43	BUILDING 28 UNIT 43	A	Y	N		
		MOHAWK 44	BUILDING 29 UNIT 44	A	Y	N		
		MOHAWK 45	BUILDING 28 UNIT 45	A	Y	N		
		MOHAWK 46	BUILDING 29 UNIT 46	A	Y	N		
		MOHAWK 47	BUILDING 28 UNIT 47	A	Y	N		
		MOHAWK 48	BUILDING 29 UNIT 48	A	Y	N		
		MOHAWK 49	BUILDING 34 UNIT 49	A	Y	N		
		MOHAWK 50	BUILDING 29 UNIT 50	A	Y	N		
		MOHAWK 51	BUILDING 34 UNIT 51	A	Y	N		
		MOHAWK 52	BUILDING 29 UNIT 52	A	Y	N		
		MOHAWK 53	BUILDING 34 UNIT 53	A	Y	N		
		MOHAWK 54	BUILDING 31 UNIT 54	A	Y	N		
		MOHAWK 55	BUILDING 34 UNIT 55	A	Y	N		
		MOHAWK 56	BUILDING 31 UNIT 56	A	Y	N		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			187				

Towns Served: GUILFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MOHAWK 57	BUILDING 33 UNIT 57	A	Y	N		
		MOHAWK 58	BUILDING 31 UNIT 58	A	Y	N		
		MOHAWK 59	BUILDING 33 UNIT 59	A	Y	N		
		MOHAWK 60	BUILDING 31 UNIT 60	A	Y	N		
		MOHAWK 61	BUILDING 33 UNIT 61	A	Y	N		
		MOHAWK 62	BUILDING 31 UNIT 62	A	Y	N		
		MOHAWK 63	BUILDING 33 UNIT 63	A	Y	N		
		MOHAWK 64	BUILDING 31 UNIT 64	A	Y	N		
		MOHAWK 65	BUILDING 33 UNIT 65	A	Y	N		
		MOHAWK 66	BUILDING 30 UNIT 66	A	Y	N		
		MOHAWK 68	BUILDING 30 UNIT 68	A		N		
		MOHAWK 70	BUILDING 30 UNIT 70	A	Y	N		
		MOHAWK 72	BUILDING 30 UNIT 72	A	Y	N		
		MOHAWK 74	BUILDING 30 UNIT 74	A	Y	N		
		MOHAWK 76	BUILDING 30 UNIT 76	A	Y	N		
		MOHAWK 78	BUILDING 30 UNIT 78	A	Y	N		
		MOHAWK 80	BUILDING 30 UNIT 80	A	Y	N		
		MOHAWK 82	BUILDING 30 UNIT 82	A	Y	N		
		MOHAWK 84	BUILDING 32 UNIT 84	A	Y	N		
		MOHAWK 86	BUILDING 32 UNIT 86	A	Y	N		
		MOHAWK 90	BUILDING 32 UNIT 90	A	Y	N		
		MOHAWK 92	BUILDING 32 UNIT 92	A	Y	N		
		MOHAWK 94	BUILDING 32 UNIT 94	A	Y	N		
		POLPIS 1	BUILDING 14 UNIT 1	A	Y	N		
		POLPIS 10	BUILDING 15 UNIT 10	A	Y	N		
		POLPIS 11	BUILDING 17 UNIT 11	A	Y	N		
		POLPIS 12	BUILDING 15 UNIT 12	A	Y	N		
		POLPIS 13	BUILDING 17 UNIT 13	A	Y	N		
		POLPIS 14	BUILDING 15 UNIT 14	A	Y	N		
		POLPIS 15	BUILDING 17 UNIT 15	A	Y	N		
		POLPIS 16	BUILDING 15 UNIT 16	A	Y	N		
		POLPIS 17	BUILDING 17 UNIT 17	A	Y	N		
		POLPIS 19	BUILDING 17 UNIT 19	A	Y	N		
		POLPIS 21	BUILDING 16 UNIT 21	A	Y	N		
		POLPIS 23	BUILDING 16 UNIT 23	A	Y	N		
		POLPIS 25	BUILDING 16 UNIT 25	A	Y	N		
		POLPIS 3	BUILDING 14 UNIT 3	A	Y	N		
		POLPIS 5	BUILDING 14 UNIT 5	A	Y	N		
		POLPIS 7	BUILDING 14 UNIT 7	A	Y	N		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				187				

Towns Served: GUILFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		POLPIS 8	BUILDING 15 UNIT 8	A	Y	N		
		POLPIS 9	BUILDING 17 UNIT 9	A	Y	N		
		QUIDNET 30	BUILDING 25 UNIT 30	A	Y	N		
		QUIDNET 32	BUILDING 25 UNIT 32	A	Y	N		
		QUIDNET 34	BUILDING 25 UNIT 34	A	Y	N		
		QUIDNET 36	BUILDING 25 UNIT 36	A	Y	N		
		QUIDNET 40	BUILDING 26 UNIT 40	A	Y	N		
		QUIDNET 42	BUILDING 26 UNIT 42	A	Y	N		
		QUIDNET 44	BUILDING 26 UNIT 44	A	Y	N		
		QUIDNET 46	BUILDING 26 UNIT 46	A	Y	N		
		QUIDNET 48	BUILDING 26 UNIT 48	A	Y	N		
		QUIDNET 50	BUILDING 26 UNIT 50	A	Y	N		
		SAGINAW 28	BUILDING 22 UNIT 28	A	Y	N		
		SAGINAW 30	BUILDING 22 UNIT 30	A	Y	N		
		SAGINAW 31	BUILDING 22 UNIT 31	A	Y	N		
		SAGINAW 32	BUILDING 22 UNIT 32	A	Y	N		
		SAGINAW 36	BUILDING 22 UNIT 36	A	Y	N		
		SAGINAW 38	BUILDING 22 UNIT 38	A	Y	N		
		SAGINAW 40	BUILDING 23 UNIT 40	A	Y	N		
		SAGINAW 42	BUILDING 23 UNIT 42	A	Y	N		
		SAGINAW 44	BUILDING 23 UNIT 44	A	Y	N		
		SAGINAW 46	BUILDING 23 UNIT 46	A	Y	N		
		SAGINAW 48	BUILDING 23 UNIT 48	A	Y	N		
		SAGINAW 50	BUILDING 23 UNIT 50	A	Y	N		
		SAGINAW 52	BUILDING 24 UNIT 52	A	Y	N		
		SAGINAW 54	BUILDING 24 UNIT 54	A	Y	N	Y	
		SAGINAW 56	BUILDING 24 UNIT 56	A	Y	N	Y	
		SP9	BLDG #17 UNIT #13	A	Y			
		UNIT 13	UNIT 13, BLDG 17	A	Y	1		
		UNIT 17	UNIT 117, BLDG 21	A	Y	1		
		UNIT 27	UNIT 27, BLDG 8	A	Y	1		
		UNIT 33	UNIT 33, BLDG 35	A	Y	1		
		UNIT 34	UNIT 34, BLDG 36	A	Y	1	Y	
		UNIT 36	UNIT 36, BLDG 24	A	Y	1	Y	
		UNIT 43	UNIT 43 BLDG 28	A	Y	1		
		UNIT 45	UNIT #45 KITCHEN SIN	A	Y			
		UNIT 48	UNIT 48, BLDG 25	A	Y	1	Y	
		UNIT 49	UNIT 49, BLDG 34	A	Y	1		
		UNIT 50	UNIT 50, BLDG 25	A	Y	1	Y	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			187				

Towns Served: GUILFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		UNIT 54	UNIT 54, BLDG 23	A	Y	1	Y	
		UNIT 56	UNIT 56, BLDG 23	A	Y	1	Y	
		UNIT 7	UNIT 7, BLDG 3	A	Y	1	Y	
		UNIT 74	UNIT 74, BLDG 9	A	Y	1		
		UNIT 76	UNIT 76, BLDG 30	A	Y	1		
		UNIT 80	UNIT 80, BLDG 30	A	Y	1		
		UNIT 84	UNIT 84, BLDG 32	A	Y	1	Y	
		UNIT 97	UNIT 97, BLDG 18	A	Y	1		
		UNIT117	BLDG 21, UNIT 117 UP	A	Y			
		UNIT98	UNIT #98 KITCHEN SIN	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		W COURT 13	BUILDING 8 UNIT 17	A	Y	N		
		W COURT 14	BUILDING 4 UNIT 14	A	Y	N		
		W COURT 16	BUILDING 4 UNIT 16	A	Y	N		
		W COURT 18	BUILDING 4 UNIT 18	A	Y	N		
		W COURT 19	BUILDING 8 UNIT 19	A	Y	N		
		W COURT 20	BUILDING 4 UNIT 20	A	Y	N		
		W COURT 21	BUILDING 8 UNIT 21	A	Y	N		
		W COURT 22	BUILDING 4 UNIT 22	A	Y	N		
		W COURT 23	BUILDING 8 UNIT 23	A	Y	N		
		W COURT 24	BUILDING 4 UNIT 24	A	Y	N		
		W COURT 25	BUILDING 8 UNIT 25	A	Y	N		
		W COURT 26	BUILDING 4 UNIT 26	A	Y			
		W COURT 27	BUILDING 8 UNIT 27	A	Y	N		
		W COURT 28	BUILDING 4 UNIT 28	A	Y	N		
		W COURT 30	BUILDING 5 UNIT 30	A	Y	N		
		W COURT 32	BUILDING 5 UNIT 32	A	Y	N		
		W COURT 34	BUILDING 5 UNIT 34	A	Y	N		
		W COURT 36	BUILDING 5 UNIT 36	A	Y	N		
		W COURT 38	BUILDING 5 UNIT 38	A	Y	N		
		W COURT 40	BUILDING 5 UNIT 40	A	Y	N		
		W COURT 42	BUILDING 6 UNIT 42	A	Y			
		W COURT 44	BUILDING 6 UNIT 44	A	Y	N		
		W COURT 46	BUILDING 6 UNIT 46	A	Y	N		
		W COURT 48	BUILDING 6 UNIT 48	A	Y	N		
		W COURT 50	BUILDING 7 UNIT 50	A	Y	N		
		W COURT 52	BUILDING 7 UNIT 52	A	Y			
		W COURT 54	BUILDING 7 UNIT 54	A	Y	N		
		W COURT 56	BUILDING 7 UNIT 56	A	Y	N		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			187				

Towns Served: GUILFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		W COURT 58	BUILDING 7 UNIT 58	A	Y	N		
		W COURT 60	BUILDING 7 UNIT 60	A	Y	N		
		W TRAIL 100	BUILDING 19 UNIT 100	A	Y	2		
		W TRAIL 101	BUILDING 18 UNIT 101	A	Y	N		
		W TRAIL 102	BUILDING 19 UNIT 102	A	Y	2		
		W TRAIL 103	BUILDING 18 UNIT 103	A	Y	N		
		W TRAIL 104	BUILDING 20 UNIT 104	A	Y	2		
		W TRAIL 105	BUILDING 18 UNIT 105	A	Y	N		
		W TRAIL 106	BUILDING 20 UNIT 106	A	Y	2		
		W TRAIL 107	BUILDING 18 UNIT 107	A	Y	N		
		W TRAIL 108	BUILDING 20 UNIT 106	A	Y	2		
		W TRAIL 109	BUILDING 18 UNIT 109	A	Y	N		
		W TRAIL 110	BUILDING 20 UNIT 110	A	Y	2		
		W TRAIL 111	BUILDING 18 UNIT 111	A	Y	N		
		W TRAIL 112	BUILDING 20 UNIT 112	A	Y	2		
		W TRAIL 113	BUILDING 21 UNIT 113	A	Y	2		
		W TRAIL 114	BUILDING 20 UNIT 114	A	Y	2		
		W TRAIL 115	BUILDING 21 UNIT 115	A	Y	2		
		W TRAIL 117	BUILDING 21 UNIT 117	A	Y	2		
		W TRAIL 119	BUILDING 21 UNIT 119	A	Y	2		
		W TRAIL 62	BUILDING 10 UNIT 62	A	Y	N		
		W TRAIL 64	BUILDING 10 UNIT 64	A	Y	N		
		W TRAIL 66	BUILDING 10 UNIT 66	A	Y	N		
		W TRAIL 68	BUILDING 10 UNIT 68	A	Y	N		
		W TRAIL 70	BUILDING 10 UNIT 70	A	Y	N		
		W TRAIL 72	BUILDING 10 UNIT 72	A	Y	N		
		W TRAIL 74	BUILDING 9 UNIT 74	A	Y	N		
		W TRAIL 76	BUILDING 9 UNIT 76	A	Y	N		
		W TRAIL 78	BUILDING 9 UNIT 78	A	Y	N		
		W TRAIL 80	BUILDING 11 UNIT 80	A	Y	N		
		W TRAIL 82	BUILDING 11 UNIT 82	A	Y	N		
		W TRAIL 84	BUILDING 11 UNIT 84	A	Y	N		
		W TRAIL 86	BUILDING 11 UNIT 86	A	Y	N		
		W TRAIL 88	BUILDING 12 UNIT 88	A	Y	N		
		W TRAIL 90	BUILDING 12 UNIT 90	A	Y	N		
		W TRAIL 92	BUILDING 12 UNIT 92	A	Y	N		
		W TRAIL 94	BUILDING 12 UNIT 94	A	Y	N		
		W TRAIL 95	BUILDING 18 UNIT 95	A	Y	N		
		W TRAIL 96	BUILDING 19 UNIT 96	A	Y	2		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0600041	QUONNIPAUG HILLS - MAIN SYSTEM			C	564	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				187				

Towns Served: GUILFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		W TRAIL 97	BUILDING 18 UNIT 97	A	Y	N		
		W TRAIL 98	BUILDING 19 UNIT 98	A	Y	2		
		W TRAIL 99	BUILDING 18 UNIT 99	A	Y	N		
00700	ENTRY POINT - LOWER	3	ENTRY POINT	A				
00702	ENTRY POINT - UPPER	3	ENTRY POINT - UPPER	A				
50066	ATMOSPHERIC TANK - LOWER							
53224	BOOSTER PUMPING FACILITIES - LOWER							
53232	UPPER PUMPHOUSE BOOSTERS							
57770	ATMOSPHERIC TANK - UPPER							
57771	HYDROPNEUMATIC TANK - UPPER							
58372	TREATMENT PLANT - UPPER							
58374	TREATMENT PLANT - LOWER							
724	WELL 2	2	WELL 2	A				
725	WELL 3	2	WELL 3	A				
726	WELL 4	2	WELL 4	A				
727	WELL 5	2	WELL 5	A				
728	WELL 4B	2	WELL 4B	A				
729	WELL 6	2	WELL 6	A				

### Certified Operator Information

Water System Facility: **TREATMENT PLANT - UPPER (WSF ID: 58372)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028
WITTENZELLNER, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2027

Water System Facility: **TREATMENT PLANT - LOWER (WSF ID: 58374)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028
WITTENZELLNER, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2027

### Contact Information

Name	Organization	Job Title
Mr. William P. Krygier	Empire Property Mgmt. Corp.	Property Manager
Mailing Address Line One	Mailing Address Line Two	City State Zip Code

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0600041</b>	<b>QUONNIPAUG HILLS - MAIN SYSTEM</b>	<b>C</b>	<b>564</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
		187			
Towns Served: GUILFORD					
625 East Main Street			Branford		CT 06405
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-488-9500		203-488-6290		203-488-6245	maintenance@epmc.co
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>					
Name			Organization		Job Title
<b>Ms. Brenda Macdonald</b>			Quonnipaug Hills Mgmt Corp		President
Mailing Address Line One		Mailing Address Line Two		City	State Zip Code
44 Quidnet Court				Guilford	CT 06437
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
Contact Role(s): <b>Legal Contact</b>					
<b>Please note the following:</b> <ol style="list-style-type: none"> <li>1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.</li> <li>2. If a Collection Period is specified, all water quality samples must be collected during the specified period.</li> <li>3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.</li> </ol>					

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0606011	QUONNIPAUG HILLS - SECTION I			C	27	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			9				

Towns Served: GUILFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/6/25 - 8/11/25		Complete
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0606011	QUONNIPAUG HILLS - SECTION I			C	27	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			9				

Towns Served: GUILFORD

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: WELL 1 (WSF ID: 730)

<b>E. Coli (3014)</b>		<b>1 triggered (TG) per period</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>		
WELL 1 (2)	8/5/25 - 8/11/25		Complete		

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2029	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		QH001	UNIT 1 KITCHEN	A	Y	N	Y	Y
		QH002	UNIT 2 KITCHEN	A	Y	N	Y	Y
		QH003	UNIT 3 KITCHEN	A	Y	N	Y	Y
		QH004	UNIT 4 KITCHEN	A	Y	N	Y	Y
		QH005	UNIT 5 KITCHEN	A	Y	N	Y	Y

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0606011	QUONNIPAUG HILLS - SECTION I			C	27	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			9				

Towns Served: GUILFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		QH006	UNIT 6 KITCHEN	A	Y	N	Y	Y
		QH007	UNIT 7 KITCHEN	A	Y	N	Y	Y
		QH008	UNIT 8 KITCHEN	A	Y	N	Y	Y
		QH009	UNIT 9 KITCHEN	A	Y	N	Y	Y
		QH010	PUMP ROOM	A		N	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
52341	HYDROPNEUMATIC TANK							
52342	ATMOSPHERIC STORAGE							
730	WELL 1	2	WELL 1	A				

### Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HARKINS, STUART A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028
WITTENZELLNER, ROBERT	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2027

### Contact Information

Name				Organization		Job Title		
Mr. William P. Krygier				Empire Property Mgmt. Corp.		Property Manager		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
625 East Main Street						Branford	CT	06405
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address	
203-488-9500			203-488-6290			203-488-6245	maintenance@epmc.co	

Contact Role(s): Administrative Contact

Name				Organization		Job Title			
Mr. Paul Mei				Quonnipaug Hills Corporation		President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
117 Wauwinet Trail						Guilford		CT	06437
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-457-1938						203-488-9500			

Contact Role(s): Legal Contact

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0606011</b>	<b>QUONNIPaug HILLS - SECTION I</b>	<b>C</b>	<b>27</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
		<b>9</b>			
Towns Served: GUILFORD					
Name		Organization		Job Title	
<b>625 Partners LLC</b>					
Mailing Address Line One		Mailing Address Line Two		City	State
115 Boston Post Rd				Madison	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
Contact Role(s): <b>Owner</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		40 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
Chlorine Residual (1012)		52 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/8/25 - 5/13/25		Complete
	5/22/25 - 5/27/25		Complete
	5/28/25 - 6/2/25		Complete
	5/28/25 - 6/2/25		Complete
Total Coliform (3100)		40 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN PUMP STAT (1045)	4/1/25 - 6/30/25	6/1-6/30	Complete
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WESTBROOK FIRE DEPT (1046)	1/1/26 - 3/31/26	3/1-3/31	
	4/1/25 - 6/30/25	6/1-6/30	Complete
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	
CTWC OFFICE, 93WMAIN (1054)	1/1/26 - 3/31/26	3/1-3/31	
	4/1/25 - 6/30/25	6/1-6/30	Complete
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	
SAYBROOK CONVALESCENT (1067)	1/1/26 - 3/31/26	3/1-3/31	
	4/1/25 - 6/30/25	6/1-6/30	Complete
	7/1/25 - 9/30/25	9/1-9/30	
	10/1/25 - 12/31/25	12/1-12/31	
	1/1/26 - 3/31/26	3/1-3/31	

Lead And Copper (PBCU)		30 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	

Physical Parameters (PPS)		40 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **CLINTON WELL WTP ENTRY POINT (WSF ID: 00701)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/23 - 12/31/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: CLINTON WELL WTP ENTRY POINT (WSF ID: 00701)

<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>		<b>2 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Organic Chemicals (VOCS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-CLINTON WELL TP (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Water System Facility: FIVE FIELDS WELL WTP ENTRY POINT (WSF ID: 00702)

<b>Net Gross Alpha (4000)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Uranium (4006)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Combined Radium-226/228 (4010)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
<b>Inorganic Chemicals (IOCS)</b>		<b>1 routine (RT) per three years</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/24 - 12/31/26		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: FIVE FIELDS WELL WTP ENTRY POINT (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-FIVE FIELDS WELL (3)	1/1/26 - 12/31/28		

Water System Facility: GUILFORD WELL WTP ENTRY POINT (WSF ID: 00703)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/23 - 12/31/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: **GUILFORD WELL WTP ENTRY POINT (WSF ID: 00703)**

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-GUILFORD WELL TP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **MACKENZIE WTP ENTRY POINT (WSF ID: 00704)**

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MACKENZIE WTP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: MACKENZIE WTP ENTRY POINT (WSF ID: 00704)

Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26		

Water System Facility: PINWOOD WELL WTP ENTRY POINT (WSF ID: 00705)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINWOOD WELL (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINWOOD WELL (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINWOOD WELL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINWOOD WELL (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINWOOD WELL (3)	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-PINWOOD WELL (3)	1/1/26 - 12/31/28		

Water System Facility: SAYBROOK WELL WTP ENTRY POINT (WSF ID: 00707)

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: SAYBROOK WELL WTP ENTRY POINT (WSF ID: 00707)

Gross Beta Particle Activity (4100)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Man-Made Beta Particle & Photon Emitters (4101)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Tritium (4102)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Strontium-90 (4174)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-SAYBROOK WELL TP (3)	1/1/26 - 12/31/28		
Water System Facility: WEISS WELL WTP ENTRY POINT (WSF ID: 00708)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/23 - 12/31/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: WEISS WELL WTP ENTRY POINT (WSF ID: 00708)

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-WEISS WELL TP (3)	1/1/26 - 12/31/28		
Water System Facility: HOLBROOK WELL WTP ENTRY POINT (WSF ID: 00710)			
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: **HOLBROOK WELL WTP ENTRY POINT (WSF ID: 00710)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - HOLBROOK WELL WTP (3)	4/1/25 - 6/30/25		
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **MACKENZIE WATER TREATMENT PLANT (WSF ID: 103)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - MACKENZIE TP (5)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **CLINTON WELL (WSF ID: 1238)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CLINTON WELL (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: **CLINTON WELL (WSF ID: 1238)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	11/1/25 - 11/30/25		

Water System Facility: **WEISS WELL (WSF ID: 1242)**

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WEISS WELL (2)	5/7/25 - 5/13/25		Complete
	5/21/25 - 5/27/25		Complete
	5/27/25 - 6/2/25		Complete

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WEISS WELL (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **GUILFORD WELL (WSF ID: 1406)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GUILFORD WELL (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **PINEWOOD WELL 2 (WSF ID: 1409)**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: **PINEWOOD WELL 2 (WSF ID: 1409)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PINEWOOD WELL 2 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **HOLBROOK WELL (WSF ID: 1411)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
HOLBROOK WELL (2)	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		
	7/1/25 - 7/31/25		Out of Service
	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **SAYBROOK WELL 1 (WSF ID: 1412)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SAYBROOK WELL 1 (2)	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

Water System Facility: **KELSEYTOWN RESERVOIR (WSF ID: 2082)**

Total Alkalinity (1927)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: **KELSEYTOWN RESERVOIR (WSF ID: 2082)**

Total Alkalinity (1927)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
2,4-D (2105)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
KELSEYTOWN RES (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
KELSEYTOWN RES (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
KELSEYTOWN RES (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
KELSEYTOWN RES (1)	1/1/24 - 12/31/24		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Monitoring Requirements

Water System Facility: **KELSEYTOWN RESERVOIR (WSF ID: 2082)**

Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KELSEYTOWN RES (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **MACKENZIE WATER TREATMENT PLANT (WSFID: 103)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 10/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 1/1/2023	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **MACKENZIE WATER TREATMENT PLANT (WSFID: 103)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025	Y		
6/1/2025 - 6/30/2025	Y		
7/1/2025 - 7/31/2025	Y		
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025			
6/1/2025 - 6/30/2025			
7/1/2025 - 7/31/2025			
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 10/1/2012			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025			
6/1/2025 - 6/30/2025			
7/1/2025 - 7/31/2025			
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 10/1/2003			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025	Y		
6/1/2025 - 6/30/2025	Y		
7/1/2025 - 7/31/2025	Y		
8/1/2025 - 8/31/2025	Y		
9/1/2025 - 9/30/2025			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 10/1/2003			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025	Y		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility: MACKENZIE WATER TREATMENT PLANT (WSFID: 103)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 10/1/2003			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	

### Water System Facility: SAYBROOK WELL TREATMENT PLANT (WSFID: 104)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline	n/a	Y
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		
Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK							
Water System Facility: SAYBROOK WELL TREATMENT PLANT (WSFID: 104)							
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
pH	Entry Point pH Monitoring (PHRD)		Minimum: 7.0 PH		Daily		
Start Date:	1/1/2004	Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		6/1/2025 - 6/30/2025					
		7/1/2025 - 7/31/2025					
		8/1/2025 - 8/31/2025					
		9/1/2025 - 9/30/2025					
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)		Minimum: 0.1 MG/L		2		
Start Date:	1/1/2004	Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		5/1/2025 - 5/31/2025					
		6/1/2025 - 6/30/2025					
		7/1/2025 - 7/31/2025					
		8/1/2025 - 8/31/2025					
		9/1/2025 - 9/30/2025					
Water System Facility: CLINTON WELL TREATMENT PLANT (WSFID: 106)							
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)		Minimum: 0.2 MG/L		Daily		
Start Date:	1/1/2004	Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		5/1/2025 - 5/31/2025					
		6/1/2025 - 6/30/2025					
		7/1/2025 - 7/31/2025					
		8/1/2025 - 8/31/2025					
		9/1/2025 - 9/30/2025					
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)		Minimum: 0.55 MG/L		Daily		
Start Date:	1/1/2023	Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
		5/1/2025 - 5/31/2025					
		6/1/2025 - 6/30/2025					
		7/1/2025 - 7/31/2025					
		8/1/2025 - 8/31/2025					
		9/1/2025 - 9/30/2025					
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)		Maximum: 0.85 MG/L		Daily		
Start Date:	1/1/2023	Compliance History:		Operating Limit	Monitoring		
		Monitoring Period		Compliance Status:	Compliance Status:		
Offline		5/1/2025 - 5/31/2025		n/a		Y	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **CLINTON WELL TREATMENT PLANT (WSFID: 106)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 10/1/2012			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **WEISS WELL TREATMENT PLANT (WSFID: 108)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
Compliance History:	Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **WEISS WELL TREATMENT PLANT (WSFID: 108)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 10/1/2012	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **FIVE FIELDS WELL TREATMENT PLANT (WSFID: 109)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility: FIVE FIELDS WELL TREATMENT PLANT (WSFID: 109)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	Offline 5/1/2025 - 5/31/2025	n/a	Y
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

### Water System Facility: GUILFORD WELL TREATMENT PLANT (WSFID: 110)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2004			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **GUILFORD WELL TREATMENT PLANT (WSFID: 110)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 1/1/2004	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 10/1/2012	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **HOLBROOK WELL TREATMENT PLANT (WSFID: 50317)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **HOLBROOK WELL TREATMENT PLANT (WSFID: 50317)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
6/1/2025 - 6/30/2025			
7/1/2025 - 7/31/2025			
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025			
6/1/2025 - 6/30/2025			
7/1/2025 - 7/31/2025			
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
Offline 5/1/2025 - 5/31/2025	n/a		Y
Offline 6/1/2025 - 6/30/2025	n/a		Y
Offline 7/1/2025 - 7/31/2025	n/a		Y
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 6/1/2005			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025			
6/1/2025 - 6/30/2025			
7/1/2025 - 7/31/2025			
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			

Water System Facility: **PINEWOOD WELL TREATMENT PLANT (WSFID: 62148)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 1.0 MG/L	Daily
Start Date: 6/1/2021			
Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:	
5/1/2025 - 5/31/2025			

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

Water System Facility: **PINEWOOD WELL TREATMENT PLANT (WSFID: 62148)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 1.0 MG/L	Daily
Start Date: 6/1/2021	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 6/1/2021	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
L1 ASSESSMENT (MULTIPLE TC+)	6/24/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/3/2025
RESPOND TO SANITARY SURVEY	10/2/2025	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM		C	33,975	P	SW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	1045	KELSEYTOWN PUMP STAT	A	Y			Y
		1046	WESTBROOK FIRE DEPT	A	Y			Y
		1050	GUILFORD HESS 1162 B	I	Y			
		1050A	GUILFORD MOBIL 1164	A	Y			
		1051	GFD TIRE, 655 BPR	A	Y			
		1052	HAMMO FORD, 191 BPR	A	Y			
		1053	HENNYPENNY 646 BPR M	A	Y			
		1054	CTWC OFFICE, 93WMAIN	A	Y			Y
		1055	GLNWD MKT, 153 GLWD	A	Y			
		1056	DUNKN DNTS, 215 BPR	A	Y			
		1057	WBK MOBIL, 779 BPR	A	Y			
		1058	LAGASSE SV, 2051 BPR	A	Y			Y
		1059	SAYBRK BSTR 1651 BPR	A	Y			
		1060	HENNY PENNY 1090 BPR	A	Y			
		1061	CHUCKY STR 685 BPR	A	Y			
		1062	SAYBRK FORD 1 FRD DR	A	Y			
		1063	TOMS SERV	A	Y			
		1064	GRSMN CHV 300 MSX TP	A	Y			
		1065	SACHEM HD TANK	A	Y			
		1066	CLR/PWD RED PIT	A	Y			
		1067	SAYBROOK CONVALESCEN	A	Y			Y
		1069	DISTRIBUTION SYSTEM	A	Y			
		1070	24-70 VALLEY SHORE	A			Y	
		10801	36 WLDWD DR MAD	A		1		
		10802	15 HIGH ST CLN	I				
		10803	125 KELSEYTOWN RD CL	A		3		
		10804	138 N COVE RD OS	A		3		
		10805	110 N COVE RD OS	A		3		
		10806	33 FAIR ST GFD	A		1		
		10807	413 SPNCR PL RD WBK	A		1		
		10808	35 COMMERCE DR CLN	I				
		10809	14 BRKSD LN MAD	A		3		
		10810	34 HFD AVE OS	A		3		
		10811	15 PEARL ST GFD	A		1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10812	19 FAIR ST GFD	A		1		
		10813	35 SHERWOOD TER OS	A		1		
		10814	95 FAIR ST GFD	A		1		
		10815	412 SCHOOLSIDE GFD	A		1		
		10816	8 PROSPECT ST MAD	A		3		
		10817	25 ELMWOOD ST OSD	A		3		
		10818	23 ARGAIL DR WBK	A		1		
		10819	29 MENNKTSK AVE OS	I				
		10820	164 LIL STNRD BCH WB	A		3		
		10821	857 BPR WBK	A		3		
		10822	28 WILLARD AV OS	A		1		
		10823	26 BASSETT LN MD	A		3		
		10824	33 HIGH ST CLN	A		1		
		10825	43 NECK RD MAD	A		3		
		10826	431 SPNCR PL RD WBK	A		1		
		10827	29 IRON WORKS RD CL	A		1		
		10828	32 STATE ST GFD	A		1		
		10829	49 CHURCH ST GFD	A		3		
		10830	82 HIGHWOODS RD GFD	A		3		
		10831	5 SANDCREEK DR, OS	A	Y	1		
		10832	29 Sherwood Terr, Sb	A	Y			
		10833	138 N Cove Rd, Sbk	A	Y			
		10834	4 AIRLINE RD CLN	A	Y	1		
		10835	12 AIRLINE RD CLN	A	Y	1		
		10836	16 AIRLINE RD CLN	A	Y	1		
		10837	19 BARGATE RD CLN	A	Y	1		
		10838	16 BEACH PARK RD CLN	A	Y	1		
		10839	34 BRICKYARD RD CLN	A	Y	1		
		10840	36 BRICKYARD RD CLN	A	Y	1		
		10841	38 BRICKYARD RD CLN	A	Y	1		
		10842	44 BRICKYARD RD CLN	A	Y	1		
		10843	48 BRICKYARD RD CLN	A	Y	1		
		10844	20 CARRIAGE DR CLN	A	Y	1		
		10845	22 CARRIAGE DR CLN	A	Y	1		
		10846	24 CARRIAGE DR CLN	A	Y	1		
		10847	27 CARRIAGE DR CLN	A	Y	1		
		10848	28 CARRIAGE DR CLN	A	Y	1		
		10849	29 CARRIAGE DR CLN	A	Y	1		
		10850	30 CARRIAGE DR CLN	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10851	31 CARRIAGE DR CLN	A	Y	1		
		10852	32 CARRIAGE DR CLN	A	Y	1		
		10853	33 CARRIAGE DR CLN	A	Y	1		
		10854	38 CARRIAGE DR CLN	A	Y	1		
		10855	39 CARRIAGE DR CLN	A	Y	1		
		10856	40 CARRIAGE DR CLN	A	Y	1		
		10857	42 CARRIAGE DR CLN	A	Y	1		
		10858	27 E SHORE DR CLN	A	Y	1		
		10859	66 E SHORE DR CLN	A	Y	1		
		10860	20 FAIRY DELL RD CLN	A	Y	1		
		10861	22 FAIRY DELL RD CLN	A	Y	1		
		10863	36 FAIRY DELL RD CLN	A	Y	1		
		10864	79 FAIRY DELL RD CLN	A	Y	1		
		10865	80 FAIRY DELL RD CLN	A	Y	1		
		10866	82 FAIRY DELL RD CLN	A	Y	1		
		10867	84 FAIRY DELL RD CLN	A	Y	1		
		10868	57 BPR GFD	A	Y	1		
		10869	2751 BPR GFD	A	Y	1		
		10870	279 BOSTON ST GFD	A	Y	1		
		10871	311 BOSTON ST GFD	A	Y	1		
		10872	313 BOSTON ST GFD	A	Y	1		
		10873	315 BOSTON ST GFD	A	Y	1		
		10874	317 BOSTON ST GFD	A	Y	1		
		10875	31 CHRST PHR LN GFD	A	Y	1		
		10876	46 CHRST PHR LN GFD	A		1		
		10877	53 CHRST PHR LN GFD	A	Y	1		
		10878	67 CHRST PHR LN GFD	A	Y	1		
		10879	47 COACH LAMP LN GFD	A	Y	1		
		10880	454 COLONIAL RD GFD	A	Y	1		
		10881	6 CORNWALL LN GFD	A	Y	1		
		10882	11 CORNWALL LN GFD	A	Y	1		
		10883	20 CORNWALL LN GFD	A	Y	1		
		10884	23 CORNWALL LN GFD	A	Y	1		
		10885	39 CORNWALL LN GFD	A	Y	1		
		10886	41 CORNWALL LN GFD	A	Y	1		
		10887	42 CORNWALL LN GFD	A	Y	1		
		10888	47 CORNWALL LN GFD	A	Y	1		
		10889	51 CORNWALL LN GFD	A	Y	1		
		10890	58 CORNWALL LN GFD	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10891	63 CORNWALL LN GFD	A	Y	1		
		10892	70 CORNWALL LN GFD	A	Y	1		
		10893	75 CORNWALL LN GFD	A	Y	1		
		10894	81 CORNWALL LN GFD	A	Y	1		
		10895	92 CORNWALL LN GFD	A	Y	1		
		10896	94 CORNWALL LN GFD	A	Y	1		
		10897	96 CORNWALL LN GFD	A	Y	1		
		10898	99 CORNWALL LN GFD	A	Y	1		
		10899	75 COVENTRY WAY GFD	A	Y	1		
		10900	80 COVENTRY WAY GFD	A	Y	1		
		10901	96 COVENTRY WAY GFD	A	Y	1		
		10902	101 COVENTRY WAY GFD	A	Y	1		
		10903	118 COVENTRY WAY GFD	A	Y	1		
		10904	123 COVENTRY WAY GFD	A	Y	1		
		10905	21 CRABAPPLE LN GFD	A	Y	1		
		10906	28 CRABAPPLE LN GFD	A	Y	1		
		10907	46 CRABAPPLE LN GFD	A	Y	1		
		10908	55 CRABAPPLE LN GFD	A	Y	1		
		10909	144 DRIFTWOOD LN GFD	A	Y	1		
		10910	190 DRIFTWOOD LN GFD	A	Y	1		
		10911	218 DRIFTWOOD LN GFD	A	Y	1		
		10912	221 DRIFTWOOD LN GFD	A	Y	1		
		10913	232 DRIFTWOOD LN GFD	A	Y	1		
		10914	240 DRIFTWOOD LN GFD	A	Y	1		
		10915	77 FAIR ST GFD	A	Y	1		
		10916	40 HPMEADOE CIR GFD	A	Y	1		
		10917	17 LNG HLL FRM GFD	A	Y	1		
		10918	22 LNG HLL FRM GFD	A	Y	1		
		10919	23 LNG HLL FRM GFD	A	Y	1		
		10920	25 LNG HLL FRM GFD	A	Y	1		
		10921	26 LNG HLL FRM GFD	A	Y	1		
		10922	27 LNG HLL FRM GFD	A	Y	1		
		10923	28 LNG HLL FRM GFD	A	Y	1		
		10924	29 LNG HLL FRM GFD	A	Y	1		
		10925	30 LNG HLL FRM GFD	A	Y	1		
		10926	31 LNG HLL FRM GFD	A	Y	1		
		10927	32 LNG HLL FRM GFD	A	Y	1		
		10928	33 LNG HLL FRM GFD	A	Y	1		
		10929	34 LNG HLL FRM GFD	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		
Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10930	35 LNG HLL FRM GFD	A	Y	1		
		10931	38 LNG HLL FRM GFD	A	Y	1		
		10932	40 LNG HLL FRM GFD	A	Y	1		
		10933	41 LNG HLL FRM GFD	A	Y	1		
		10934	42 LNG HLL FRM GFD	A	Y	1		
		10935	35 LNG HLL FRM GFD	A	Y	1		
		10936	44 LNG HLL FRM GFD	A	Y	1		
		10937	45 LNG HLL FRM GFD	A	Y	1		
		10938	46 LNG HLL FRM GFD	A	Y	1		
		10939	47 LNG HLL FRM GFD	A	Y	1		
		10940	48 LNG HLL FRM GFD	A	Y	1		
		10941	49 LNG HLL FRM GFD	A	Y	1		
		10942	54 LNG HLL FRM GFD	A	Y	1		
		10943	1470 LNG HLL FRM GFD	A	Y	1		
		10944	116 MICHAEL DR GFD	A	Y	1		
		10945	118 MICHAEL DR GFD	A	Y	1		
		10946	125 MICHAEL DR GFD	A	Y	1		
		10947	11 MICHELLE LN GFD	A	Y	1		
		10948	20 MICHELLE LN GFD	A	Y	1		
		10949	28 MICHELLE LN GFD	A	Y	1		
		1095	4 APOGEE LANE WBK	A	Y			
		10950	33 MICHELLE LN GFD	A	Y	1		
		10951	47 MICHELLE LN GFD	A	Y	1		
		10952	52 MICHELLE LN GFD	A	Y	1		
		10953	59 MICHELLE LN GFD	A	Y	1		
		10954	71 MICHELLE LN GFD	A	Y	1		
		10955	100 MIRROR LN GFD	A	Y	1		
		10956	149 MIRROR LN GFD	A	Y	1		
		10957	21 MUSTANG DR GFD	A	Y	1		
		10958	30 MUSTANG DR GFD	A	Y	1		
		10959	42 MUSTANG DR GFD	A	Y	1		
		10960	47 MUSTANG DR GFD	A	Y	1		
		10961	59 MUSTANG DR GFD	A	Y	1		
		10962	64 MUSTANG DR GFD	A	Y	1		
		10963	67 MUSTANG DR GFD	A	Y	1		
		10964	75 MUSTANG DR GFD	A	Y	1		
		10965	53 ACORN RD MAD	A	Y	1		
		10966	60 ACORN RD MAD	A	Y	1		
		10967	62 ACORN RD MAD	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		10968	66 ACORN RD MAD	A	Y	1		
		10969	67 ACORN RD MAD	A	Y	1		
		10970	72 ACORN RD MAD	A	Y	1		
		10971	73 ACORN RD MAD	A	Y	1		
		10972	78 ACORN RD MAD	A	Y	1		
		10973	79 ACORN RD MAD	A	Y	1		
		10974	88 ACORN RD MAD	A	Y	1		
		10975	95 ACORN RD MAD	A		1		
		10976	100 ACORN RD MAD	A	Y	1		
		10977	101 ACORN RD MAD	A	Y	1		
		10978	103 ACORN RD MAD	A	Y	1		
		10979	104 ACORN RD MAD	A	Y	1		
		10980	105 ACORN RD MAD	A	Y	1		
		10981	110 ACORN RD MAD	A	Y	1		
		10982	111 ACORN RD MAD	A	Y	1		
		10983	116 ACORN RD MAD	A	Y	1		
		10984	117 ACORN RD MAD	A	Y	1		
		10985	123 ACORN RD MAD	A	Y	1		
		10986	129 ACORN RD MAD	A	Y	1		
		10987	24 BEACH RD E OS	A	Y	1		
		10988	16 HOMESTEAD ST OS	A	Y	1		
		10989	40 INGHAM HILL RD	A	Y	1		
		10990	44 INGHAM HILL RD OS	A	Y	1		
		10991	66 INGHAM HILL RD OS	A	Y	1		
		10992	45 KNOLLWOOD DR OS	A	Y	1		
		10993	1 N COVE CIR OS	A	Y	1		
		10994	2 N COVE CIR OS	A	Y	1		
		10995	94 N COVE RD OS	A	Y	1		
		10996	132 N COVE RD OS	A	Y	1		
		10997	75 OLD POST RD OS	A	Y	1		
		10998	100 OLD POST RD OS	A	Y	1		
		10999	11 OSPREY RD OS	A	Y	1		
		11000	15 OSPREY RD OS	A	Y	1		
		11001	1 SAND CREEK DR OS	A	Y	1		
		11002	2 SAND CREEK DR OS	A	Y	1		
		11003	3 SAND CREEK DR OS	A	Y	1		
		11004	4 SAND CREEK DR OS	A	Y	1		
		11005	6 SAND CREEK DR OS	A	Y	1		
		11006	4 SCHENKER AVE OS	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM		C	33,975	P	SW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		11007	28 SRS AV A FL PK OS	A	Y	1		
		11008	6 THOMPSON RD OS	A	Y	1		
		11009	8 THOMPSON RD OS	A	Y	1		
		11010	9 THOMPSON RD OS	A	Y	1		
		11011	10 THOMPSON RD OS	A	Y	1		
		11012	2 THMPSN RD LEFT OS	A	Y	1		
		11013	2 TRAILS END OS	A	Y	1		
		11014	3 TRAILS END OS	A	Y	1		
		11015	5 TRAILS END OS	A	Y	1		
		11016	6 VINCENT AVE OS	A	Y	1		
		11017	12 VINCENT AVE OS	A	Y	1		
		11018	9 WARD PL OS	A		1		
		11019	2 WHITNEY AVE OS	A	Y	1		
		11020	24 WHITNEY AVE OS	A	Y	1		
		11021	8 WINDSOR CT W OS	A	Y	1		
		11022	14 CHPMN BCH RD WBK	A	Y	1		
		11023	28 CHPMN BCH RD WBK	A	Y	1		
		11024	32 ECKFORD AVE WBK	A	Y	1		
		11025	4 ELM AVE WBK	A	Y	1		
		11026	73 HNTRS RDG RD WBK	A	Y	1		
		11027	89 HNTRS RDG RD WBK	A	Y	1		
		11028	94 HNTRS RDG RD WBK	A	Y	1		
		11029	97 HNTRS RDG RD WBK	A	Y	1		
		11030	16 PND MDW RD WBK	A	Y	1		
		11031	273 SPNC PLNS RD WBK	A	Y	1		
		11032	8 FRY DLL RD A CLN	A	Y	2		
		11033	10 FRY DLL RD A CLN	A	Y	2		
		11034	14 FRY DLL RD A CLN	A	Y	2		
		11035	16 FRY DLL RD A CLN	A	Y	2		
		11036	18 FRY DLL RD A CLN	A	Y	2		
		11037	8 FRY DLL RD B CLN	A	Y	2		
		11038	10 FRY DLL RD B CLN	A	Y	2		
		11039	14 FRY DLL RD B CLN	A	Y	2		
		11040	16 FRY DLL RD B CLN	A	Y	2		
		11041	18 FRY DLL RD B CLN	A	Y	2		
		11042	1 BRANTWOOD DR MAD	A		2		
		11043	2 BRANTWOOD DR MAD	A	Y	2		
		11044	3 BRANTWOOD DR MAD	A	Y	2		
		11045	4 BRANTWOOD DR MAD	A		2		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM		C	33,975	P	SW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		11046	5 BRANTWOOD DR MAD	A	Y	2		
		11047	6 BRANTWOOD DR MAD	A	Y	2		
		11048	7 BRANTWOOD DR MAD	A	Y	2		
		11049	8 BRANTWOOD DR MAD	A	Y	2		
		11050	9 BRANTWOOD DR MAD	A	Y	2		
		11051	10 BRANTWOOD DR MAD	A	Y	2		
		11052	11 BRANTWOOD DR MAD	A	Y	2		
		11053	12 BRANTWOOD DR MAD	A	Y	2		
		11054	13 BRANTWOOD DR MAD	A	Y	2		
		11055	14 BRANTWOOD DR MAD	A	Y	2		
		11056	15 BRANTWOOD DR MAD	A	Y	2		
		11057	16 BRANTWOOD DR MAD	A	Y	2		
		11058	17 BRANTWOOD DR MAD	A	Y	2		
		11059	18 BRANTWOOD DR MAD	A	Y	2		
		11060	19 BRANTWOOD DR MAD	A	Y	2		
		11061	20 BRANTWOOD DR MAD	A	Y	2		
		11062	21 BRANTWOOD DR MAD	A	Y	2		
		11063	22 BRANTWOOD DR MAD	A	Y	2		
		11064	23 BRANTWOOD DR MAD	A	Y	2		
		11065	24 BRANTWOOD DR MAD	A	Y	2		
		11066	25 BRANTWOOD DR MAD	A	Y	2		
		11067	26 BRANTWOOD DR MAD	A	Y	2		
		11068	27 BRANTWOOD DR MAD	A	Y	2		
		11069	28 BRANTWOOD DR MAD	A	Y	2		
		11070	29 BRANTWOOD DR MAD	A	Y	2		
		11071	30 BRANTWOOD DR MAD	A	Y	2		
		11072	31 BRANTWOOD DR MAD	A	Y	2		
		11073	32 BRANTWOOD DR MAD	A	Y	2		
		11074	33 BRANTWOOD DR MAD	A	Y	2		
		11075	34 BRANTWOOD DR MAD	A	Y	2		
		11076	35 BRANTWOOD DR MAD	A	Y	2		
		11077	36 BRANTWOOD DR MAD	A		2		
		11078	37 BRANTWOOD DR MAD	A	Y	2		
		11079	38 BRANTWOOD DR MAD	A	Y	2		
		11080	39 BRANTWOOD DR MAD	A	Y	2		
		11081	40 BRANTWOOD DR MAD	A	Y	2		
		11082	41 BRANTWOOD DR MAD	A	Y	2		
		11083	42 BRANTWOOD DR MAD	A	Y	2		
		11084	43 BRANTWOOD DR MAD	A	Y	2		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name		Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM		C	33,975	P	SW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		11085	44 BRANTWOOD DR MAD	A	Y	2		
		11086	45 BRANTWOOD DR MAD	A	Y	2		
		11087	46 BRANTWOOD DR MAD	A	Y	2		
		11088	47 BRANTWOOD DR MAD	A	Y	2		
		11089	48 BRANTWOOD DR MAD	A	Y	2		
		11090	49 BRANTWOOD DR MAD	A	Y	2		
		11091	50 BRANTWOOD DR MAD	A	Y	2		
		11092	51 BRANTWOOD DR MAD	A	Y	2		
		11093	52 BRANTWOOD DR MAD	A	Y	2		
		11094	1 ESTERLY FARMS MAD	A	Y	2		
		11095	2 ESTERLY FARMS MAD	A	Y	2		
		11096	3 ESTERLY FARMS MAD	A	Y	2		
		11097	25 SUNSET RD 10C OS	A	Y	2		
		11098	25 SUNSET RD 11C OS	A	Y	2		
		11099	25 SUNSET RD 12C OS	A	Y	2		
		11100	25 SUNSET RD 13C OS	A	Y	2		
		11101	25 SUNSET RD 14C OS	A	Y	2		
		11102	25 SUNSET RD 16D OS	A	Y	2		
		11103	25 SUNSET RD 17D OS	A	Y	2		
		11104	25 SUNSET RD 18D OS	A	Y	2		
		11105	25 SUNSET RD 19D OS	A	Y	2		
		11106	25 SUNSET RD 1A OS	A	Y	2		
		11107	25 SUNSET RD 20D OS	A	Y	2		
		11108	25 SUNSET RD 2A OS	A	Y	2		
		11109	25 SUNSET RD 3A OS	A	Y	2		
		11110	25 SUNSET RD 4A OS	A	Y	2		
		11111	25 SUNSET RD 5A OS	A	Y	2		
		11112	25 SUNSET RD 6B OS	A	Y	2		
		11113	25 SUNSET RD 7B OS	A	Y	2		
		11114	25 SUNSET RD 8B OS	A	Y	2		
		11115	25 SUNSET RD 9B OS	A	Y	2		
		11116	47 BROADWAY S 1 WBK	A	Y	2		
		11117	45 BROADWAY S 2 WBK	A	Y	2		
		11118	47 BROADWAY S 2 WBK	A	Y	2		
		11119	45 BROADWAY S RT WBK	A	Y	2		
		11120	OBED SAMPLE STATION	A	Y			
		11121	FORD SAMPLE STATION	A	Y			
		11122	OBPR SAMPLE STATION	A	Y			
		11123	6 CAUSEWAY RD CLN	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		11124	58 COMMERCE 1A CLN	A	Y	1		
		11125	85 COMMERCE ST CLN	A	Y	1		
		11126	89 COMMERCE ST CLN	A	Y	1		
		11127	109 COMMERCE ST CLN	A	Y	1		
		11128	101 E MAIN ST CLN	A	Y	1		
		11129	129 E MAIN ST CLN	A	Y	1		
		11130	56 GLENWOOD RD CLN	A	Y	1		
		11131	63 GROVE ST CLN	A	Y	1		
		11132	75 GROVE ST CLN	A	Y	1		
		11133	77 GROVE ST CLN	A	Y	1		
		11134	23 GROVEWAY CLN	A	Y	1		
		11135	28 GROVEWAY CLN	A	Y	1		
		11136	45 GROVEWAY CLN	A	Y	1		
		11137	43 HAMMOCK RD CLN	A	Y	1		
		11138	49 HAMMOCK RD CLN	A	Y	1		
		11139	59 HIGH ST CLN	A	Y	1		
		11140	60 HIGH ST CLN	A	Y	1		
		11141	66 HIGH ST CLN	A	Y	1		
		11142	101 HIGH ST CLN	A	Y	1		
		11143	110 HIGH ST CLN	A	Y	1		
		11144	52 JOHN ST CLN	A	Y	1		
		11145	2 OAK RIDGE DR CLN	A	Y	1		
		11146	120 A SHORE A CLN	A	Y	1		
		11147	162 SHORE RD CLN	A	Y	1		
		11148	165 SHORE RD CLN	A	Y	1		
		11149	24 SOLS POINT RD CLN	A	Y	1		
		11150	21 WATERSIDE LN CLN	A	Y	1		
		11151	25 WATERSIDE LN CLN	A	Y	1		
		11152	182 BOSTON ST GFD	A	Y	1		
		11153	245 BOSTON ST GFD	A	Y	1		
		11154	35 BSTN POST RD GFD	A	Y	1		
		11155	95 BSTN POST RD GFD	A	Y	1		
		11156	101 BSTN POST RD GFD	A	Y	1		
		11157	196 CHURCH ST GFD	A	Y	1		
		11158	47 FAIR ST GFD	A	Y	1		
		11159	64 FAIR ST GFD	A	Y	1		
		11160	85 FAIR ST GFD	A	Y	1		
		11161	90 FAIR ST GFD	A	Y	1		
		11162	2 GRAVES AVE GFD	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		11163	42 GRAVES AVE GFD	A	Y	1		
		11164	17 HIGH ST GFD	A	Y	1		
		11165	258 LWR WTR ST GFD	A	Y	1		
		11166	73 MEADOW ST GFD	A	Y	1		
		11167	15 S FAIR ST GFD	A	Y	1		
		11168	43 S FAIR ST GFD	A	Y	1		
		11169	98 STATE ST GFD	A	Y	1		
		11170	110 STATE ST GFD	A	Y	1		
		11171	44 SUMMER ST GFD	A	Y	1		
		11172	46 SUMMER ST GFD	A	Y	1		
		11173	15 UNION ST GFD	A	Y	1		
		11174	19 UNION ST GFD	A	Y	1		
		11175	90 UNION ST GFD	A	Y	1		
		11176	105 UNION ST GFD	A	Y	1		
		11177	158 WHITFIELD ST GFD	A	Y	1		
		11178	387 WHITFIELD ST GFD	A	Y	1		
		11179	485 WHITFIELD ST GFD	A	Y	1		
		11180	101 BSTN POST RD MAD	A	Y	1		
		11181	109 BSTN POST RD MAD	A	Y	1		
		11182	390 BSTN POST RD MAD	A	Y	1		
		11183	463 BSTN POST RD MAD	A	Y	1		
		11184	519 BSTN POST RD MAD	A	Y	1		
		11185	530 BSTN POST RD MAD	A	Y	1		
		11186	880 BSTN POST RD MAD	A	Y	1		
		11187	32 GROVE AVE MAD	A	Y	1		
		11188	78 HARTFORD AVE MAD	A	Y	1		
		11189	86 HARTFORD AVE MAD	A	Y	1		
		11190	15 LIBERTY ST MAD	A	Y	1		
		11191	41 LIBERTY ST MAD	A	Y	1		
		11192	54 LIBERTY ST MAD	A	Y	1		
		11193	87 MIDDLE BCH E MAD	A	Y	1		
		11194	5 NECK RD MAD	A	Y	1		
		11195	86 NECK RD MAD	A	Y	1		
		11196	27 PARKER LN MAD	A	Y	1		
		11197	33 WILDWOOD AVE MAD	A	Y	1		
		11198	100 CHKR BCH RD OS	A	Y	1		
		11199	297 MAIN ST OS	A	Y	1		
		11200	376 MAIN ST OS	A	Y	1		
		11201	19 RED BIRD TRL OS	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		11202	37 RIVER ST OS	A	Y	1		
		11203	162 GROVE BCH S WBK	A	Y	1		
		11204	150 LTL STNRD BCH WB	A	Y	1		
		11205	176 MAGNA LN WBK	A	Y	1		
		11206	128 S MAIN ST WBK	A	Y	1		
		11207	209 SALT ISLAND RD	A	Y	1		
		11208	243 SEASIDE AVE WBK	A	Y	1		
		11209	19 STN HDG RD WBK	A	Y	1		
		11210	97 COMMERCE ST CLN	A	Y	2		
		11211	81 A COMMERCE A CLN	A	Y	2		
		11212	125 E MAIN ST CLN	A	Y	2		
		11213	130 E MAIN ST CLN	A	Y	2		
		11214	3 LIBERTY ST CLN	A	Y	2		
		11215	84 A SHORE A CLN	A	Y	2		
		11216	102 F SHORE F CLN	A	Y	2		
		11217	128 BOSTON ST GFD	A	Y	2		
		11218	208 BOSTON ST GFD	A	Y	2		
		11219	22 S FAIR ST GFD	A	Y	2		
		11220	48 STATE ST GFD	A	Y	2		
		11221	22 WILDWOOD AVE MAD	A	Y	2		
		11222	18 COTTAGE PL OS	A	Y	2		
		11223	7 ESSEX RD OS	A	Y	2		
		11224	45 SLT ISLND RD WBK	A	Y	2		
		11225	189 SEASIDE FT WBK	A	Y	2		
		11226	20 NINETY ROD RD	A	Y			
		11227	89 GROVE STREET	A	Y			
		11228	7 WEST ROAD	A	Y			
		11229	24 PLYMOUTH CT	A	Y			
		11230	LONGHILL BOOSTER	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	CLINTON WELL WTP ENTRY POINT	3	EP-CLINTON WELL TP	A				
00702	FIVE FIELDS WELL WTP ENTRY POINT	3	EP-FIVE FIELDS WELL	A				
00703	GUILFORD WELL WTP ENTRY POINT	3	EP-GUILFORD WELL TP	A				
00704	MACKENZIE WTP ENTRY POINT	3	EP-MACKENZIE WTP	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00705	PINEWOOD WELL WTP ENTRY POINT	3	EP-PINEWOOD WELL	A				
00707	SAYBROOK WELL WTP ENTRY POINT	3	EP-SAYBROOK WELL TP	A				
00708	WEISS WELL WTP ENTRY POINT	3	EP-WEISS WELL TP	A				
00710	HOLBROOK WELL WTP ENTRY POINT	3	EP - HOLBROOK WELL W	A				
103	MACKENZIE WATER TREATMENT PLANT	3	EP - MACKENZIE WTP	A				
		5	CFE - MACKENZIE TP	A				
104	SAYBROOK WELL TREATMENT PLANT	3	EP SAYBROOK WELL TP	A				
106	CLINTON WELL TREATMENT PLANT	3	EP - CLINTON WELL TP	A				
108	WEISS WELL TREATMENT PLANT	3	EP WEISS WELL TP	A				
109	FIVE FIELDS WELL TREATMENT PLANT	3	EP - FIVE FIELDS TP	A				
110	GUILFORD WELL TREATMENT PLANT	3	EP -GUILFORD WELL TP	A				
1238	CLINTON WELL	2	CLINTON WELL	A				
1242	WEISS WELL	2	WEISS WELL	A				
1406	GUILFORD WELL	2	GUILFORD WELL	A				
1409	PINEWOOD WELL 2	2	PINEWOOD WELL 2	A				
1411	HOLBROOK WELL	2	HOLBROOK WELL	A				
1412	SAYBROOK WELL 1	2	SAYBROOK WELL 1	A				
1963	FIVE FIELDS WELL 2A	2	FIVE FIELD WELL NEW	A				
2081	KILLINGWORTH RESERVOIR	1	RESERVOIR	A				
2082	KELSEYTOWN RESERVOIR	1	KELSEYTOWN RES	A				
30036	KELSYTOWN RESERVOIR							
49761	INTERCONNECTION - CT0930011 - RWA							
50317	HOLBROOK WELL TREATMENT PLANT							
50321	LONG HILL PUMP STATION							
50323	SAYBROOK PUMP STATION							
50325	BISHOP (LONG HILL) STORAGE TANK							
50329	OBED HEIGHTS TANK							
50331	SACHEMS HEAD TANK							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		
Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
52049	MACKENZIE CLEARWELL 1							
52051	MACKENZIE CLEARWELL 2							
52057	KELSEYTOWN PUMP STATION							
52059	MACKENZIE PUMP STATION							
57299	PEQUOT TANK							
61727	RIDGE ROAD TANK							
61731	INTERCONNECTION CT0261031 TO CT0680011							
62148	PINEWOOD WELL TREATMENT PLANT							

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROSS, ROBERT F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027
DISTEFANO, RONALD M	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2028

**Water System Facility: MACKENZIE WATER TREATMENT PLANT (WSF ID: 103)**

**Facility Classification:** CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SCHAFER, KRISTEN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
GOTTSCALL, KIMBERLY A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027
CIMINO, ANTHONY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027

**Water System Facility: SAYBROOK WELL TREATMENT PLANT (WSF ID: 104)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

**Water System Facility: CLINTON WELL TREATMENT PLANT (WSF ID: 106)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0608011	CTWC - SHORELINE REGION-GUILFORD SYSTEM			C	33,975	P	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				15,885	1,581	38		

Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK

### Certified Operator Information

**Water System Facility: WEISS WELL TREATMENT PLANT (WSF ID: 108)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028 3/31/2027
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

**Water System Facility: FIVE FIELDS WELL TREATMENT PLANT (WSF ID: 109)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 6/30/2028
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

**Water System Facility: GUILFORD WELL TREATMENT PLANT (WSF ID: 110)**

**Facility Classification:** CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 6/30/2028
MEDER, NICHOLAS J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 6/30/2027

**Water System Facility: HOLBROOK WELL TREATMENT PLANT (WSF ID: 50317)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 6/30/2028
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

**Water System Facility: PINWOOD WELL TREATMENT PLANT (WSF ID: 62148)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028 3/31/2027
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

### Contact Information

Name				Organization			Job Title		
Mr. Craig J. Patla				Connecticut Water Company			Vp, Service Delivery		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 West Main Street						Clinton		CT	06413
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-664-6140						800-391-1924	craig.patla@ctwater.com		

**Contact Role(s):** Legal Contact, Owner

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0608011</b>	<b>CTWC - SHORELINE REGION-GUILFORD SYSTEM</b>	<b>C</b>	<b>33,975</b>	<b>P</b>	<b>SW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
			15,885	1,581	38
Towns Served: CLINTON, GUILFORD, MADISON, OLD SAYBROOK, WESTBROOK					
Name		Organization		Job Title	
<b>Mr. Gerald McDermott</b>		The Connecticut Water Company		Manager, Service Del	
Mailing Address Line One		Mailing Address Line Two		City	State
93 West Main Street				Clinton	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-664-6125					ctwcdphadmin@ctwater.com
Contact Role(s): <b>Administrative Contact</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***