

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0650102	HARTLAND ELEM SCH & TOWN BLDGS			NTNC	300	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
30 SOUTH ROAD				3				
Towns Served: HARTLAND								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Alkalinity (1927)		2 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		10 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT - WELL 2 & 3 (WSF ID: 00701)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 3 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 2 & 3 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0650102	HARTLAND ELEM SCH & TOWN BLDGS	NTNC	300	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
30 SOUTH ROAD		3			
Towns Served: HARTLAND					

Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 2 & 3 (WSF ID: 00701)

Organic Chemicals (VOCS)

1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELLS 2 & 3 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Optimal Water Quality Corrosion Control Parameters

Water System Facility: DISTRIBUTION SYSTEM (WSFID: 00600)

Start Date:	Analyte	Operating Limit
7/1/2024	pH	Minimum: 7.2 PH
1/1/2019		Maximum: 7.8 PH

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 2 & 3 (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.4 PH	Daily
Start Date: 1/1/2017	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 7.8 PH	Daily
Start Date: 1/1/2019	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 10/3/2025

Page 2

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0650102	HARTLAND ELEM SCH & TOWN BLDGS			NTNC	300	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
30 SOUTH ROAD				3				
Towns Served: HARTLAND								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		ART1	ART ROOM	A	Y	2	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		HARTEL 006	ROOM 3	A	Y	2	Y	
		HARTEL 007	ROOM 4	A	Y	2	Y	
		HARTEL 008	ROOM 6	A	Y	2	Y	
		HARTEL 009	ROOM 11	A	Y	2	Y	
		HARTEL 010	ROOM 13	A	Y	2	Y	
		HARTEL 011	ROOM 14	A	Y	2	Y	
		HARTEL 012	ROOM 16	A	Y	2	Y	
		HARTEL 013	ROOM 19	A	Y	2	Y	
		HARTEL 014	ROOM 20	A	Y	2	Y	
		HARTEL 015	ROOM 22	A	Y	2	Y	
		HARTEL 016	ROOM 23	A	Y	2	Y	
		HARTEL 017	TOWN HALL KITCHEN	A	Y	2	Y	
		HARTEL 018	BOYS ROOM 1	A	Y	2	Y	
		HARTEL 019	BOYS ROOM 2	A	Y	2	Y	
		HARTEL 020	HANDICAP BATH	A	Y	2	Y	
		JANITOR1	JANITOR CLOSET	A	Y	2	Y	
		KIT1	KITCHEN	A	Y	2	Y	
		LOUNGE1	TEACHERS LOUNGE	A	Y	2	Y	
		STORAGE4	STORAGE DOOR N	A	Y	2	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT - WELL 2 & 3	3	EP - WELLS 2 & 3	A				
10291	WELL 2	2	WELL 2	A				
11059	TREATMENT PLANT							
53930	WELL 3	2	WELL 3	A				
53932	ATMOSPHERIC TANK							
53934	HYDRO TANK							

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 11059)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2025
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2025
KILBOURN, JORDAN H	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0650102	HARTLAND ELEM SCH & TOWN BLDGS			NTNC	300	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
30 SOUTH ROAD				3				
Towns Served: HARTLAND								

Contact Information

Name				Organization			Job Title		
Ms. Imma Canelli				Heartland Elm School & Town			Superintendent		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
30 South Rd						Hartland		CT	06027
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-653-0295			860-644-8528				icanelli@hartlandschool.com		

Contact Role(s): **Administrative Contact**

Name				Organization		Job Title			
Dr. Scott Levan				Town of Hartland		Second Selectman			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
Town Hall			22 South Road			East Hartland		CT	06027
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-653-6800						860-798-2259	scottmlevan@gmail.com		

Contact Role(s): **Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule