

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0710011	CAREFREE HOMEOWNERS ASSOCIATION			C	172	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			41				

Towns Served: LEBANON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
21-38 FIRST STREET (2138F)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
Total Trihalomethanes (2950)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
56-71 CARRIAGE DRIVE (5671C)	1/1/24 - 12/31/24	7/1-7/31	Complete
	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
Total Coliform (3100)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0710011	CAREFREE HOMEOWNERS ASSOCIATION			C	172	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				41				

Towns Served: LEBANON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0710011	CAREFREE HOMEOWNERS ASSOCIATION			C	172	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				41				

Towns Served: LEBANON

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25			
	1/1/26 - 3/31/26			

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.4 MG/L	Continuous	
Start Date: 3/1/2016	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	5/1/2025 - 5/31/2025	Y		
	6/1/2025 - 6/30/2025	Y		
	7/1/2025 - 7/31/2025	Y		
	8/1/2025 - 8/31/2025	Y		
	9/1/2025 - 9/30/2025			
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily	
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring	
	Monitoring Period	Compliance Status:	Compliance Status:	
	5/1/2025 - 5/31/2025			
	6/1/2025 - 6/30/2025			
	7/1/2025 - 7/31/2025			
	8/1/2025 - 8/31/2025			
	9/1/2025 - 9/30/2025			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	10F	10 FIRST STREET	A	Y	3	Y	Y
		11F	11 FIRST STREET	A	Y	3	Y	Y
		1402E	1402 EXETER ROAD	A	Y	3	Y	Y
		1406E	1406 EXETER ROAD	A	Y	3	Y	Y
		1412E	1412 EXETER ROAD	A	Y	3	Y	Y
		1418E	1418 EXETER ROAD	A	Y	3	Y	Y
		1424E	1424 EXETER ROAD	A		3	Y	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0710011	CAREFREE HOMEOWNERS ASSOCIATION			C	172	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			41				

Towns Served: LEBANON

Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		1428E	1428 EXETER ROAD	A		3	Y	Y
		16F	16 FIRST STREET	A	Y	3	Y	Y
		17F	17 FIRST STREET	A	Y	3	Y	Y
		19C	19 CARRIAGE DRIVE	A	Y	3	Y	Y
		20F	20 FIRST STREET	A	Y	3	Y	Y
		2138F	21-38 FIRST STREET	A				Y
		21F	21 FIRST STREET	A	Y	3	Y	Y
		22C	22 CARRIAGE DRIVE	A	Y	3	Y	Y
		26F	26 FIRST STREET	A	Y	3	Y	Y
		27C	27 CARRIAGE DRIVE	A	Y	3	Y	Y
		27F	27 FIRST STREET	A	Y	3	Y	Y
		28C	28 CARRIAGE DRIVE	A	Y	3	Y	Y
		32F	32 FIRST STREET	A	Y	3	Y	Y
		33C	33 CARRIAGE DRIVE	A	Y	3	Y	Y
		33F	33 FIRST STREET	A		3	Y	Y
		37F	37 FIRST STREET	A		3	Y	Y
		38C	38 CARRIAGE STREET	A	Y	3	Y	Y
		38F	38 FIRST STREET	A		3	Y	Y
		39C	39 CARRIAGE DRIVE	A	Y	3	Y	Y
		4	DISTRIBUTION SYSTEM	A	Y			
		4-1	FIRST ST. #27 RESTRO	A	Y			
		41F	41 FIRST STREET	A	Y	3	Y	Y
		42C	42 CARRIAGE DRIVE	A	Y	3	Y	Y
		44F	44 FIRST STREET	A		3	Y	Y
		45C	45 CARRIAGE DRIVE	A	Y	3	Y	Y
		47F	47 FIRST STREET	A	Y	3	Y	Y
		49C	49 CARRIAGE DRIVE	A	Y	3	Y	Y
		50C	50 CARRIAGE DRIVE	A	Y	3	Y	Y
		50F	50 FIRST STREET	A	Y	3	Y	Y
		51F	51 FIRST STREET	A		3	Y	Y
		54F	54 FIRST STREET	A		3	Y	Y
		54S	54 SECOND STREET	A		3		
		5671C	56-71 CARRIAGE DRIVE	A				Y
		56C	56 CARRIAGE DRIVE	A	Y	3	Y	Y
		57C	57 CARRIAGE DRIVE	A	Y	3	Y	Y
		61C	61 CARRIAGE DRIVE	A	Y	3	Y	Y
		67C	67 CARRIAGE DRIVE	A	Y	3	Y	Y
		71C	71 CARRIAGE DRIVE	A	Y	3	Y	Y
		79C	79 CARRIAGE DRIVE	A	Y	3	Y	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0710011	CAREFREE HOMEOWNERS ASSOCIATION			C	172	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				41				

Towns Served: LEBANON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1073	WELL 1	2	WELL 1	A				
1074	WELL 4	2	WELL 4	A				
1075	WELL 5	2	WELL 5	A				
1727	WELL 3	2	WELL 3	A				
403	TREATMENT PLANT							
57506	ATMOSPHERIC STORAGE							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

Water System Facility: **TREATMENT PLANT (WSF ID: 403)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

Contact Information

Name				Organization		Job Title			
Ms. Carolanne Vining				Carefree Homeowners Assn		President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
27 1St Street						Lebanon		CT	06249
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-944-6374						860-365-4020	carolannepinto@gmail.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0710021	AQUARION-LEBANON			C	149	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
49 FRANCIS DRIVE							58	
Towns Served: LEBANON								

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
DIANNE DRIVE DS TAP (05810)	1/1/21 - 12/31/29		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
DIANNE DRIVE DS TAP (05810)	1/1/24 - 12/31/24	8/16-8/23	Complete
	1/1/25 - 12/31/25	8/16-8/23	Complete
	1/1/26 - 12/31/26	8/16-8/23	
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0710021	AQUARION-LEBANON			C	149	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
49 FRANCIS DRIVE						58	
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **LEBANON TREATMENT PLANT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **LEBANON TREATMENT PLANT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.5 MG/L	Continuous
Start Date: 4/1/2011	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0710021	AQUARION-LEBANON			C	149	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
49 FRANCIS DRIVE							58	
Towns Served: LEBANON								

Water System Facility: **LEBANON TREATMENT PLANT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.5 MG/L	Continuous
Start Date: 4/1/2011		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		7/1/2025 - 7/31/2025	Y
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Compliance Status:
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	
		7/1/2025 - 7/31/2025	
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/21/2025
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	05810	DIANNE DRIVE DS TAP	A	Y		Y	Y
		06279	11 NORMAN RD SS	A	Y		Y	Y
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB6208	47 RITA DR	A		3		
		PB6209	54 RITA DR	A		3		
		PB6210	54 FRANCIS LEBANON	A		1		
		PB6211	114 FRANCIS DR	A		3		
		PB6212	1238 TRUMBULL HW	A		3		
		PB6317	61 RITA DR	A	Y	N		
		PB6318	64 FRANCIS DR	A		3		
		PB6320	53 RITA DR	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	LEBANON TREATMENT PLANT	3	ENTRY POINT	A				
49656	ATMOSPHERIC TANK							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0710021	AQUARION-LEBANON			C	149	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
49 FRANCIS DRIVE							58	
Towns Served: LEBANON								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
49659	HYDROPNEUMATIC TANK							
499	LEBANON WELL 2	2	LEBANON WELL 2	A				

Certified Operator Information

Water System Facility: **LEBANON TREATMENT PLANT (WSF ID: 00700)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CHARNETSKI, MICHAEL R.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 6/30/2026
GARDNER, DAVID C.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
SORENSEN, KEVIN T.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
ROGERS, JUSTUS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027 9/30/2026

Contact Information

Name				Organization		Job Title			
Mr. John P. Walsh				Aquarion Water Company		Vice President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
835 Main Street			Mail Stop 700			Bridgeport		CT	06604
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-337-5852			203-337-5938			781-413-6175	jwalsh@aquarionwater.com		

Contact Role(s): **Legal Contact**

Name				Organization		Job Title		
Mr. Robert J. Ulrich				Aquarion Water Company of Ct		Vp-Supply & Utility		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
505 Huntington St.						Shelton	CT	06484
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address	
203-926-4320			203-929-5297			203-395-3205	rulrich@aquarionwater.com	

Contact Role(s): **Administrative Contact**

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0711001	VILLAGE HILL APARTMENTS			C	36	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			12				

Towns Served: LEBANON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0711001	VILLAGE HILL APARTMENTS	C	36	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			12				
Towns Served: LEBANON							

Monitoring Requirements

Water System Facility: WELL 1 (WSF ID: 1093)

E. Coli (3014)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		VH01	UNIT 1 - KS	A	Y	1	Y	Y
		VH02	UNIT 2 - KS	A	Y	1		
		VH03	UNIT 3 - KS	A	Y	1		
		VH04	UNIT 4 - KS	A	Y	1		
		VH05	UNIT 5 - KS	A	Y	1		
		VH06	UNIT 6 - KS	A	Y	1		
		VH07	UNIT 7 - KS	A	Y	1		
		VH08	UNIT 8 - KS	A	Y	1		
		VH09	UNIT 9 - KS	A	Y	1		
		VH10	UNIT 10 - KS	A	Y	1		
		VH11	UNIT 11 - KS	A	Y	1		
		VH12	UNIT 12 - KS	A	Y	1		
00700	ENTRY POINT	3	ENTRY POINT	A				
1093	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 10/3/2025

Page 11

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0711001	VILLAGE HILL APARTMENTS			C	36	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				12				

Towns Served: LEBANON

Contact Information

Name				Organization			Job Title		
Mr. Donald Tedford				Tedford Real Estate					
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
P.O. Box 111						Willimantic		CT	06226
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-428-3240						959-210-1406	tedfordrealestate@gmail.com		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0711071	CTWC - LEBANON ELDERLY DIV.			C	67	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: LEBANON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SAMPLE STATION (LEBE026)	1/1/24 - 12/31/24	9/1-9/30	Complete
	1/1/25 - 12/31/25	9/1-9/30	
	1/1/26 - 12/31/26	9/1-9/30	
Total Trihalomethanes (2950)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
21-24 DOC MANNING (LEBE027)	1/1/24 - 12/31/24	9/1-9/30	Complete
	1/1/25 - 12/31/25	9/1-9/30	
	1/1/26 - 12/31/26	9/1-9/30	
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0711071	CTWC - LEBANON ELDERLY DIV.			C	67	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: LEBANON

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per six years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.6 MG/L	Continuous
Start Date: 8/1/2019	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0711071	CTWC - LEBANON ELDERLY DIV.			C	67	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: LEBANON

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.6 MG/L	Continuous
Start Date: 8/1/2019	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
9/1/2025 - 9/30/2025			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CERTIFY LEAD SL NOTIFICATION	7/1/2025	9/3/2025
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		52850	LEBANON ELDERLY DIST	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LEBE001	1 DOC MANNING DR	A	Y	N		
		LEBE002	2 DOC MANNING DR	A	Y	N		
		LEBE003	3 DOC MANNING DR	A	Y	N		
		LEBE004	4 DOC MANNING DR	A	Y	N		
		LEBE005	5 DOC MANNING DR	A	Y	N		
		LEBE006	6 DOC MANNING DR	A	Y	N		
		LEBE007	7 DOC MANNING DR	A	Y	N		
		LEBE008	8 DOC MANNING DR	A	Y	N		
		LEBE009	9 DOC MANNING DR	A	Y	N		
		LEBE010	10 DOC MANNING DR	A	Y	N		
		LEBE011	11 DOC MANNING DR	A	Y	N		
		LEBE012	12 DOC MANNING DR	A	Y	N		
		LEBE013	13 DOC MANNING DR	A	Y	N		
		LEBE014	14 DOC MANNING DR	A	Y	N		
		LEBE015	15 DOC MANNING DR	A	Y	N		
		LEBE016	16 DOC MANNING DR	A	Y	N		
		LEBE017	17 DOC MANNING DR	A	Y	N		
		LEBE018	18 DOC MANNING DR	A	Y	N		
		LEBE019	19 DOC MANNING DR	A	Y	N		
		LEBE020	20 DOC MANNING DR	A	Y	N		
		LEBE021	21 DOC MANNING DR	A	Y	N		
		LEBE022	22 DOC MANNING DR	A	Y	N		
		LEBE023	23 DOC MANNING DR	A	Y	N		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0711071	CTWC - LEBANON ELDERLY DIV.			C	67	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				24				

Towns Served: LEBANON

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		LEBE024	24 DOC MANNING DR	A	Y	N		
		LEBE025	COMMUNITY CENTER	A	Y	N		
		LEBE026	SAMPLE STATION	A	Y	N		Y
		LEBE027	21-24 DOC MANNING	A				Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1094	WELL #2	2	WELL 1	A				
1095	WELL #3	2	WELL 2	A				
52218	ATMOSPHERIC STORAGE TANKS							
52222	LEBANON ELDERLY BOOSTERS							
61634	TREATMENT PLANT							

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 61634)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SEHL, ROBERT	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 3/31/2028
SWEET, BRYAN S	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

Contact Information

Name				Organization		Job Title			
Mr. Craig J. Patla				Connecticut Water Company		Vp, Service Delivery			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 West Main Street						Clinton		CT	06413
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-664-6140						800-391-1924	craig.patla@ctwater.com		

Contact Role(s): **Legal Contact, Owner**

Name				Organization		Job Title			
Mr. Paul C. Lowry				Connecticut Water Company		Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
93 W Main Street						Clinton		CT	06413
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-944-9655			860-654-1903			800-208-5700	ctwcdphadmin@ctwater.com		

Contact Role(s): **Administrative Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0711071	CTWC - LEBANON ELDERLY DIV.			C	67	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			24				

Towns Served: LEBANON

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule