

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0790142	MARLBOROUGH CONGREGATIONAL CHURCH			NTNC	97	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
35 SOUTH MAIN STREET				3				
Towns Served: MARLBOROUGH								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0790142	MARLBOROUGH CONGREGATIONAL CHURCH			NTNC	97	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
35 SOUTH MAIN STREET			3				
Towns Served: MARLBOROUGH							

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)

1 routine (RT) per three years

Sampling Point (Sampling Point ID)

Monitoring Period

Collection Period

Compliance Status

1/1/26 - 12/31/28

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7 PH	4
Start Date: 1/1/2002	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2027	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		JOHNSON RD	9 JOHNSON ROAD	A	Y	3		
		MCCEP	ENTRY POINT	A				
		MCCLK1	LOW KITCHEN SINK 1	A	Y			
		MCCLK2	LOW KITCHEN SINK 2	A	Y	2		
		MCCLK3	LOW KITCHEN SINK 3	A	Y			
		MCCLMR1	LOWER MEN'S ROOM 1	A	Y			
		MCCLMR2	LOWER MEN'S ROOM 2	A	Y			
		MCCLWR1	LOWER WOMEN'S 1	A	Y			
		MCCLWR2	LOWER WOMEN'S 2	A	Y			
		MCCUK	UPPER KITCHEN SINK	A	Y	2		
		MCCUMR	UPPER MEN'S ROOM	A	Y	2		
		MCCUWR	UPPER WOMEN'SW ROOM	A	Y			
		MCLK4	LOW KITCHEN SINK 4	A	Y	2		
		RAW WELL #1	WELL #1	I				
		UPSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0790142	MARLBOROUGH CONGREGATIONAL CHURCH			NTNC	97	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
35 SOUTH MAIN STREET				3				
Towns Served: MARLBOROUGH								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
10381	WELL #1	2	WELL #1	A				
1345	MARLBOROUGH CONG CHURCH TREATMENT PLANT							

Certified Operator Information

Water System Facility: MARLBOROUGH CONG CHURCH TREATMENT PLANT (WSF ID: 1345)								
Facility Classification: CLASS 1 TREATMENT PLANT								
Operator Name	Operator Type	Certification(s)	Certification Expiration					
PEELING, DAVID	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027					

Contact Information

Name				Organization			Job Title		
Reverend Bob Faulhaber Jr.				Marlborough Cong. Church			Senior Pastor		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
35 South Main Street						Marlborough		CT	06447
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-295-9050									
Contact Role(s): Legal Contact									
Name				Organization			Job Title		
Mr. David Peeling				Marlborough Cong. Church					
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
138 South Rd						Marlborough		CT	06447
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
203-859-8746						860-295-9050	peeling0822@gmail.com		
Contact Role(s): Administrative Contact									

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0791152	THE DIVERSIFIED GROUP			NTNC	65	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
369 NORTH MAIN STREET					2			
Towns Served: MARLBOROUGH								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0791152	THE DIVERSIFIED GROUP			NTNC	65	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
369 NORTH MAIN STREET				2			
Towns Served: MARLBOROUGH							

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2028	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-1	3RD FLOOR LADIES ROO	A	Y	1	Y	
		4-10	JANITOR ROOM	A	Y	1		
		4-2	3RD FLOOR CONFERENCE	I	Y			
		4-3	2ND FLOOR LADIES ROO	A	Y	1		
		4-4	MEN S LOCKER ROOM	A	Y	1		
		4-5	KITCHEN	A	Y	1	Y	
		4-6	WOMENS LOCKER ROOM	A	Y	1		
		4-7	2ND FLOOR MENS ROOM	A	Y	1	Y	
		4-8	2ND FLR HANDICAP RM	A	Y	1		
		4-9	3RD FLR MENS ROOM	A	Y	1	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10382	WELL	2	WELL	A				
907	TREATMENT PLANT							

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 907)**

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FILANDA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028

Contact Information

Name				Organization			Job Title		
Ms. Melissa Bosse				The Diversified Group			Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
369 North Main Street						Marlborough		CT	06447
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-295-6503			860-295-6529				mbosse@diversifiedgb.com		
Contact Role(s): Administrative Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0791152	THE DIVERSIFIED GROUP	NTNC	65	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
369 NORTH MAIN STREET				2	
Towns Served: MARLBOROUGH					
Name		Organization		Job Title	
Mr. Daniel Soucier		The Diversified Group		Owner	
Mailing Address Line One		Mailing Address Line Two		City	State
369 North Main Street				Marlborough	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-295-6504					dsoucier@diversifiedgb.com
Contact Role(s): Legal Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0791162	DISCOVERY ZONE LEARNING CNTR MARLBOROUGH			NTNC	70	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
152 HEBRON ROAD				1				
Towns Served: MARLBOROUGH								

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27	1/1-12/31	
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0791162	DISCOVERY ZONE LEARNING CNTR MARLBOROUGH			NTNC	70	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
152 HEBRON ROAD				1				
Towns Served: MARLBOROUGH								

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2025	
CROSS CONNECTION EXEMPTION	3/1/2027	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION GENERIC	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LBB-1	BATH NO.1 SINK	A	Y	1		
		LBB-2	BATH NO.2 SINK	A	Y	1		
		LBB-3	BATH NO.3 SINK	A	Y	1		
		LBB-4	BATH NO.4 SINK	A	Y	1		
		LBCR-5	DZM-1	A	Y			
		LBRC-5	REAR COUNTER NO.5	A	Y	1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10383	WELL	2	WELL	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028 6/30/2026
NIGRO, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

Contact Information

Name				Organization				Job Title		
Ms. Robin L. Green				Discovery Zone Learning Center				Owner		
Mailing Address Line One			Mailing Address Line Two				City		State	Zip Code
2 Orlando Dr							Columbia		CT	06237
Business Phone		Extension	Fax		Mobile Phone		Emergency Phone	Email Address		
860-228-8885		860	860-228-2032				860-295-1151	robin@dzlckids.org		
Contact Role(s): Administrative Contact, Legal Contact, Owner										

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0791162	DISCOVERY ZONE LEARNING CNTR MARLBOROUGH			NTNC	70	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
152 HEBRON ROAD			1				
Towns Served: MARLBOROUGH							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0790134	NOVANTA IMS			NTNC	50	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
370 NORTH MAIN STREET				1			
Towns Served: MARLBOROUGH							

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	
	1/1/26 - 12/31/26	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0790134	NOVANTA IMS			NTNC	50	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
370 NORTH MAIN STREET			Connections		1			
Towns Served: MARLBOROUGH								

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26		

Water System Facility: WELL 1 (WSF ID: 10906)

E. Coli (3014) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		FBF02	WOMENS BR FRONT	A	Y	N		
		FBR04	WOMENS BR REAR	A	Y	N		
		IMS001	KITCHEN SINK	A	Y	N	Y	
		IMS0010	KITCHENETTE SINK	A	Y	N		
		IMS002	FEMALE BATHROOM	A	Y	N	Y	
		IMS003	MANUFACTURING SINK	A	Y	N	Y	
		IMS004	MALE BATHROOM	A	Y	N	Y	
		IMS005	GUEST BATHROOM	A	Y	N	Y	
		IMS006	EXTERIOR FAUCT WEST	P				
		IMS007	FAUCET BY DIAPHRAM	A	Y	N	Y	
		IMS008	UTILITY RM OFFICE	A	Y	N		
		IMS009	UTILITY RM MANUFACT	A	Y	N		
		KS01	KITCHEN SINK	A	Y	N	Y	
		KS06	KITCHENETTE SINK	A	Y	N	Y	
		MBF03	MENS BR FRONT	A	Y	N		
		MBR05	MENS BR REAR	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10906	WELL 1	2	WELL 1	A				
57554	TREATMENT PLANT							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0790134	NOVANTA IMS			NTNC	50	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
370 NORTH MAIN STREET				1			
Towns Served: MARLBOROUGH							

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 57554)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FILANDA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028

Contact Information

Name				Organization		Job Title			
Mr. David Coutu				Djc Holdings, Inc		Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
37 Meeks Pt Road						East Hampton		CT	06424
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-690-3867			860-295-6107			860-267-1371	david.coutu@snet.net		

Contact Role(s): Legal Contact, Owner

Name				Organization			Job Title			
Mr. Jim Henderschedt							Facility Manager			
Mailing Address Line One			Mailing Address Line Two				City		State	Zip Code
370 North Main St.							Marlborough		CT	06447
Business Phone		Extension	Fax		Mobile Phone		Emergency Phone		Email Address	
860-365-3965									jhenderschedt@imshome.com	

Contact Role(s): Administrative Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0791253	LITTLE PEOPLE'S PLAY PLACE			NTNC	68	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
8 - 10 SARAH LANE					1			
Towns Served: MARLBOROUGH								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/17/25 - 7/22/25		Complete
Total Coliform (3100)		3 temporary routine (TR) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Di(2-Ethylhexyl) - Phthalate (2039)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0791253	LITTLE PEOPLE'S PLAY PLACE			NTNC	68	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
8 - 10 SARAH LANE					1			
Towns Served: MARLBOROUGH								

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS) 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) 1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: WELL (WSF ID: 10761)

E. Coli (3014) 1 triggered (TG) per period

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL (2)	7/16/25 - 7/22/25		Complete

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2029	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		LP1	TODDLER ROOM SINK	A		1		
		LP10	IPR FRONT SINK	A		1		
		LP2	PRE TODDLER SINK	A	Y	1		
		LP3	INFANT	A	Y	1		
		LP4	PRESCHOOL BACK SINK	A	Y	1		
		LP5	PRESCHOOL BATH SINK	A	Y	1		
		LP6	PRESCHOOL BATH SINK	A	Y	1		
		LP7	PRESCHOOL SINK FRONT	A	Y	1		
		LP8	IPR LEFT SINK	A	Y	1		
		LP9	IPR RIGHT SINK	A	Y	1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10761	WELL	2	WELL	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type		Primary Source	
CT0791253	LITTLE PEOPLE'S PLAY PLACE			NTNC	68	P		GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
8 - 10 SARAH LANE					1				
Towns Served: MARLBOROUGH									

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
52003	HYDROPNEUMATIC TANK							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: **SMALL WATER SYSTEM**

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Contact Information

Name		Organization		Job Title	
Mr. Robert Kelsey		Little People's Play Place		Owner	
Mailing Address Line One		Mailing Address Line Two		City	State Zip Code
2 Jamies Way				Oakdale	CT 06370
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-581-3489				860-324-4774	kelsonofitch@gmail.com

Contact Role(s): **Owner**

Name		Organization		Job Title	
Ms. Ashley N. Lee		Little People's Play Place		Assistant Director	
Mailing Address Line One		Mailing Address Line Two		City	State Zip Code
8 -10 Sarah Ln				Marlborough	CT 06447
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-467-6046					littlepeoplesplayplace@gmail.com

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule