

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)		60 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
Chlorine Residual (1012)		63 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
500 SOUTH BROAD ST (MWDAS500)	1/1/20 - 12/31/28		Complete
Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/13/25 - 5/18/25		Complete
Total Coliform (3100)		60 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
25 SCHWINKS DR (MWDBACT033)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
130 HIGH HILL RD (MWDBACT036)	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
528 JOHNSON AVE (MWDBB100)	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
343 WEST MAIN ST (MWDBB300)	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
285 PRESTON AVE (MWDBH200)	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
168 CHAMBERLAIN HWY (MWDEL200)	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
55 MICHAEL DR (MWDEL300)	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
664 WEST MAIN ST (MWDM1000)	10/1/25 - 12/31/25	11/1-11/30	
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/25 - 6/30/25	5/1-5/31	Complete
	7/1/25 - 9/30/25	8/1-8/31	Complete
Lead And Copper (PBCU)		60 routine (RT) per six months	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		60 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)	60 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: MERIMERE WTP ENTRY POINT (WSF ID: 00700)

Dibromochloropropane (DBCP) (2931)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Ethylene Dibromide (EDB) (2946)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Net Gross Alpha (4000)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/24 - 12/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: MERIMERE WTP ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - MERIMERE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: ELMERE WTP ENTRY POINT (WSF ID: 00701)

Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - ELMERE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: ELMERE WTP ENTRY POINT (WSF ID: 00701)

Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - ELMERE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: BROAD BROOK WTP ENTRY POINT (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BROAD BROOK (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: BRADLEY HUBBARD WTP ENTRY POINT (WSF ID: 00703)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **BRADLEY HUBBARD WTP ENTRY POINT (WSF ID: 00703)**

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - BRADLEY HUBBARD (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **EVANSVILLE WTP ENTRY POINT (WSF ID: 00704)**

Nickel (1036)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: EVANSVILLE WTP ENTRY POINT (WSF ID: 00704)

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - EVANSVILLE (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: MULE WELL WTP ENTRY POINT (WSF ID: 00705)

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: MULE WELL WTP ENTRY POINT (WSF ID: 00705)

**Nitrate And Nitrite (NOX)** 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

**Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)** 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**Organic Chemicals (VOCS)** 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - MULE WELL (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: COLUMBUS PARK WELL WTP ENTRY POINT (WSF ID: 00706)

**Net Gross Alpha (4000)** 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Uranium (4006)** 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Combined Radium-226/228 (4010)** 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Inorganic Chemicals (IOCS)** 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**Nitrate And Nitrite (NOX)** 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

**Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)** 2 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - COLUMBUS PARK (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: COLUMBUS PARK WELL WTP ENTRY POINT (WSF ID: 00706)

Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - COLUMBUS PARK (3)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: PLATT LINCOLN WTP ENTRY POINT (WSF ID: 00707)

Dibromochloropropane (DBCP) (2931)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PLATT LINCOLN (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Ethylene Dibromide (EDB) (2946)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PLATT LINCOLN (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PLATT LINCOLN (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PLATT LINCOLN (3)	1/1/23 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **PLATT LINCOLN WTP ENTRY POINT (WSF ID: 00707)**

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - PLATT LINCOLN (3)	4/1/25 - 6/30/25		Out of Service
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **COLUMBUS PARK WELL (WSF ID: 1356)**

E. Coli (3014)		1 triggered (TG) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
COLUMBUS PARK WELL (2)	5/12/25 - 5/18/25		Out of Service
E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
COLUMBUS PARK WELL (2)	6/1/25 - 6/30/25		Out of Service
	7/1/25 - 7/31/25		Out of Service
	8/1/25 - 8/31/25		Out of Service
	9/1/25 - 9/30/25		

Water System Facility: **PLATT WELL (WSF ID: 1357)**

E. Coli (3014)		1 triggered (TG) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
PLATT WELL (2)	5/12/25 - 5/18/25		Out of Service
E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
PLATT WELL (2)	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		Out of Service

Water System Facility: **LINCOLN WELL (WSF ID: 1358)**

E. Coli (3014)		1 triggered (TG) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LINCOLN WELL (2)	5/12/25 - 5/18/25		Out of Service
E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LINCOLN WELL (2)	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		Out of Service

Water System Facility: **EVANSVILLE AVENUE WEST WELL (WSF ID: 1359)**

E. Coli (3014)		1 triggered (TG) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EVANSVILLE AVENUE WE (2)	5/12/25 - 5/18/25		Out of Service

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: EVANSVILLE AVENUE WEST WELL (WSF ID: 1359)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EVANSVILLE AVENUE WE (2)	5/1/25 - 5/31/25		Out of Service
	6/1/25 - 6/30/25		Out of Service
	7/1/25 - 7/31/25		Out of Service
	8/1/25 - 8/31/25		Out of Service
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: EVANSVILLE AVENUE EAST WELL (WSF ID: 1360)

E. Coli (3014)		1 triggered (TG) per period	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EVANSVILLE AVENUE EA (2)	5/12/25 - 5/18/25		Complete

  

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EVANSVILLE AVENUE EA (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: BROAD BROOK WATER TREATMENT PLANT (WSF ID: 150)

Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
CFE - BROAD BROOK TP (5)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **BROAD BROOK WATER TREATMENT PLANT (WSF ID: 150)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **MERIMERE WATER TREATMENT PLANT (WSF ID: 152)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - MERIMERE WTP (5)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **ELMERE WATER TREATMENT PLANT (WSF ID: 153)**

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - ELMERE WTP (5)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: ELMERE WATER TREATMENT PLANT (WSF ID: 153)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/26 - 4/30/26		

Water System Facility: BRADLEY HUBBARD WATER TREATMENT PLANT (WSF ID: 154)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - BRADLEY WTP (5)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: BRADLEY HUBBARD RESERVOIR (WSF ID: 2139)

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BRADLEY HUBBARD RES (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **BRADLEY HUBBARD RESERVOIR (WSF ID: 2139)**

Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BRADLEY HUBBARD RES (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BRADLEY HUBBARD RES (1)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BRADLEY HUBBARD RES (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BRADLEY HUBBARD RES (1)	1/1/24 - 12/31/24		Out of Service
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Water System Facility: MERIMERE RESERVOIR (WSF ID: 2141)			
Total Alkalinity (1927)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: MERIMERE RESERVOIR (WSF ID: 2141)

Total Alkalinity (1927)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
MERIMERE RESERVOIR (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: MERIMERE RESERVOIR (WSF ID: 2141)

Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MERIMERE RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: BROAD BROOK RESERVOIR (WSF ID: 2142)

Total Alkalinity (1927)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: **BROAD BROOK RESERVOIR (WSF ID: 2142)**

<b>Total Coliform (3100)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 3/31/26		
<b>Surface Water Inorganic Chemicals (RIOCI)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
<b>Surface Water Color and Turbidity (RPPS)</b>		<b>1 routine (RT) per quarter</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
<b>Surface Water Pesticides (RSOC)</b>		<b>1 routine (RT) per year</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
BROAD BROOK RES (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **ELMERE RESERVOIR (WSF ID: 2145)**

<b>Total Alkalinity (1927)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
<b>Total Organic Carbon (2920)</b>		<b>1 routine (RT) per month</b>	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Monitoring Requirements

Water System Facility: ELMERE RESERVOIR (WSF ID: 2145)

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ELMERE RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: MERIMERE WTP ENTRY POINT (WSFID: 00700)

<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **MERIMERE WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **ELMERE WTP ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **ELMERE WTP ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **BROAD BROOK WTP ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **BROAD BROOK WTP ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **BRADLEY HUBBARD WTP ENTRY POINT (WSFID: 00703)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **BRADLEY HUBBARD WTP ENTRY POINT (WSFID: 00703)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2004	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **EVANSVILLE WTP ENTRY POINT (WSFID: 00704)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	
Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD							
Water System Facility: EVANSVILLE WTP ENTRY POINT (WSFID: 00704)							
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)		Minimum: 0.2 MG/L		Daily		
Start Date:	6/1/2005	Compliance History: Monitoring Period		Operating Limit Compliance Status:	Monitoring Compliance Status:		
		6/1/2025 - 6/30/2025					
		7/1/2025 - 7/31/2025					
		8/1/2025 - 8/31/2025					
		9/1/2025 - 9/30/2025					
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)		Minimum: 0.55 MG/L		Daily		
Start Date:	5/1/2023	Compliance History: Monitoring Period		Operating Limit Compliance Status:	Monitoring Compliance Status:		
		5/1/2025 - 5/31/2025					
		6/1/2025 - 6/30/2025					
		7/1/2025 - 7/31/2025					
		8/1/2025 - 8/31/2025					
		9/1/2025 - 9/30/2025					
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)		Maximum: 0.85 MG/L		Daily		
Start Date:	5/1/2023	Compliance History: Monitoring Period		Operating Limit Compliance Status:	Monitoring Compliance Status:		
		5/1/2025 - 5/31/2025		Y			
		6/1/2025 - 6/30/2025		Y			
		7/1/2025 - 7/31/2025		Y			
		8/1/2025 - 8/31/2025		Y			
		9/1/2025 - 9/30/2025					
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
pH	Entry Point pH Monitoring (PHRD)		Minimum: 6.8 PH		Daily		
Start Date:	7/1/2003	Compliance History: Monitoring Period		Operating Limit Compliance Status:	Monitoring Compliance Status:		
		5/1/2025 - 5/31/2025					
		6/1/2025 - 6/30/2025					
		7/1/2025 - 7/31/2025					
		8/1/2025 - 8/31/2025					
		9/1/2025 - 9/30/2025					
Analyte	Monitoring Requirement (Summary Type)		Operating Limit		Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)		Minimum: 0.75 MG/L		2		
Start Date:	7/1/2003	Compliance History: Monitoring Period		Operating Limit Compliance Status:	Monitoring Compliance Status:		
		5/1/2025 - 5/31/2025					
		6/1/2025 - 6/30/2025					

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **EVANSVILLE WTP ENTRY POINT (WSFID: 00704)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **MULE WELL WTP ENTRY POINT (WSFID: 00705)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.5 MG/L	Continuous
Start Date: 6/1/2020	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
Start Date: 7/1/2003	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **MULE WELL WTP ENTRY POINT (WSFID: 00705)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
Start Date: 7/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 1/1/2004			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **COLUMBUS PARK WELL WTP ENTRY POINT (WSFID: 00706)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 6/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.85 PH	Daily
Start Date: 7/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630		
Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTINGTON, WALLINGFORD								
Water System Facility: COLUMBUS PARK WELL WTP ENTRY POINT (WSFID: 00706)								
Analyte	Monitoring Requirement (Summary Type)			Operating Limit		Samples Req/Month		
pH	Entry Point pH Monitoring (PHRD)			Minimum: 6.85 PH		Daily		
Start Date:	7/1/2003	Compliance History:		Operating Limit		Monitoring		
		Monitoring Period		Compliance Status:		Compliance Status:		
		7/1/2025 - 7/31/2025						
		8/1/2025 - 8/31/2025						
		9/1/2025 - 9/30/2025						
Analyte	Monitoring Requirement (Summary Type)			Operating Limit		Samples Req/Month		
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)			Minimum: 0.75 MG/L		2		
Start Date:	1/1/2004	Compliance History:		Operating Limit		Monitoring		
		Monitoring Period		Compliance Status:		Compliance Status:		
		5/1/2025 - 5/31/2025						
		6/1/2025 - 6/30/2025						
		7/1/2025 - 7/31/2025						
		8/1/2025 - 8/31/2025						
		9/1/2025 - 9/30/2025						
Water System Facility: PLATT LINCOLN WTP ENTRY POINT (WSFID: 00707)								
Analyte	Monitoring Requirement (Summary Type)			Operating Limit		Samples Req/Month		
Chlorine	Entry Point RDC (EPRD)			Minimum: 0.55 MG/L		Continuous		
Start Date:	7/1/2025	Compliance History:		Operating Limit		Monitoring		
		Monitoring Period		Compliance Status:		Compliance Status:		
		7/1/2025 - 7/31/2025		Y				
		8/1/2025 - 8/31/2025		Y				
		9/1/2025 - 9/30/2025						
Analyte	Monitoring Requirement (Summary Type)			Operating Limit		Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)			Minimum: 0.55 MG/L		Daily		
Start Date:	5/1/2023	Compliance History:		Operating Limit		Monitoring		
		Monitoring Period		Compliance Status:		Compliance Status:		
		5/1/2025 - 5/31/2025						
		6/1/2025 - 6/30/2025						
		7/1/2025 - 7/31/2025						
		8/1/2025 - 8/31/2025						
		9/1/2025 - 9/30/2025						
Analyte	Monitoring Requirement (Summary Type)			Operating Limit		Samples Req/Month		
Fluoride	Entry Point Fluoride Monitoring (FLRD)			Maximum: 0.85 MG/L		Daily		
Start Date:	5/1/2023	Compliance History:		Operating Limit		Monitoring		
		Monitoring Period		Compliance Status:		Compliance Status:		
	Offline	5/1/2025 - 5/31/2025		n/a		Y		
	Offline	6/1/2025 - 6/30/2025		n/a		Y		
		7/1/2025 - 7/31/2025		Y				
		8/1/2025 - 8/31/2025		Y				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **PLATT LINCOLN WTP ENTRY POINT (WSFID: 00707)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.1 PH	Daily
<b>Start Date:</b> 7/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.75 MG/L	2
<b>Start Date:</b> 7/1/2003	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Water System Facility: **BROAD BROOK WATER TREATMENT PLANT (WSFID: 150)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **BROAD BROOK WATER TREATMENT PLANT (WSFID: 150)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Water System Facility: **MERIMERE WATER TREATMENT PLANT (WSFID: 152)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility: MERIMERE WATER TREATMENT PLANT (WSFID: 152)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	9/1/2025 - 9/30/2025		

### Water System Facility: ELMERE WATER TREATMENT PLANT (WSFID: 153)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 8/1/2020			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

### Water System Facility: BRADLEY HUBBARD WATER TREATMENT PLANT (WSFID: 154)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

Water System Facility: **BRADLEY HUBBARD WATER TREATMENT PLANT (WSFID: 154)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	4/11/2025	4/11/2025
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	5/16/2025	5/13/2025
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	5/16/2025	5/13/2025
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	5/16/2025	5/13/2025
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	5/16/2025	5/13/2025
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	5/16/2025	2/13/2025
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	5/16/2025	5/13/2025
SUBMIT CCR TO THE DEPARTMENT	6/30/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	11/13/2024
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	7/30/2025	7/31/2025
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	7/30/2025	7/1/2025
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	7/30/2025	7/31/2025
SUBMIT CCR CERTIFICATION FORM	8/9/2025	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	9/28/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	7/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	
CAP - ADDRESS DEFICIENCY	12/30/2026	

### Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification Required</i>	<i>Public Notification Performed</i>	<i>PN Certification Due to DPH</i>	<i>PN Certification Received</i>
E. Coli M&R Violation	4/1/24 - 4/30/24	3	5/29/2025		6/8/2025	

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00500	LINCOLN WELL - TOWER EFFLUENT							
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MWDAS500	500 SOUTH BROAD ST	A			Y	
		MWDBACT020	269 MAIN ST S MERIDN	I	Y			
		MWDBACT021	214 EVANSVILLE AVE	A	Y			
		MWDBACT022	220 COE AVE	A	Y			
		MWDBACT023	528 JOHNSON AVE	A	Y			
		MWDBACT024	583 WEST MAIN ST	A	Y			
		MWDBACT025	168 CHAMBERLAIN HWY	I	Y			
		MWDBACT026	474 CHAMBERLAIN HWY	I	Y			
		MWDBACT027	260 SHERMAN AVE	I	Y			
		MWDBACT028	10 BEE ST	A	Y			
		MWDBACT029	766 NORTH COLONY RD	A	Y			
		MWDBACT030	2090 NO BROAD ST	A	Y			
		MWDBACT030X	1966 NO. BROAD ST	I	Y			
		MWDBACT031	61 PRATT ST	A	Y			
		MWDBACT032	117 PARKER AVE	A	Y			
		MWDBACT033	25 SCHWINKS DR	A	Y			Y
		MWDBACT034	121 GRAVEL ST	A	Y			
		MWDBACT035	1101 EAST MAIN ST	A	Y			
		MWDBACT036	130 HIGH HILL RD	A	Y			Y
		MWDBACT037	22 EAST RD	A	Y			
		MWDBACT038	285 PRESTON AVE	I	Y			
		MWDBACT039	1248 SO. BROAD ST	I	Y			
		MWDBACT040	1258 SOUTH BROAD ST	A	Y	N		
		MWDBACT041	329 CHAMBERLAIN HWY	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							17,630	
Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDBB100	528 JOHNSON AVE	A				Y
		MWDBB200	269 MAIN ST S MERIDN	A				
		MWDBB300	343 WEST MAIN ST	A				Y
		MWDBB400	61 PRATT ST	A				
		MWDBBE00	1285 SO MERIDEN RD	I				Y
		MWDBH100	538 PRESTON AVE	A				
		MWDBH200	285 PRESTON AVE	A				Y
		MWDBH300	390 BEE ST	A				
		MWDBH400	1295 EAST MAIN ST	A				
		MWDBHE00	800 WESTFIELD RD	A				
		MWDEL100	66 KENSINGTON AVE	A				
		MWDEL200	168 CHAMBERLAIN HWY	A				Y
		MWDEL300	55 MICHAEL DR	A				Y
		MWDEL400	1966 NO BROAD ST	A				
		MWDELE00	658 CHAMBERLAIN HWY	A				
		MWDETP10	1248 SO BROAD ST	A				
		MWDETP20	125 SCOTT ST	A				
		MWDETP30	22 EAST RD	A				
		MWDLC001	16 AKRON ST	A		2		
		MWDLC002	41 CASS ST	A		1		
		MWDLC003	98 HORTON AVE	A		3		
		MWDLC004	37 MONTOWESE DR	A		1		
		MWDLC005	210 CATHERINE DR	A		1		
		MWDLC005OLD	106 NEW CHESHIRE RD	I		N		
		MWDLC006	42 OLD FARM DR	A		1		
		MWDLC007	253 RESERVOIR AV	A		3		
		MWDLC008	333 RESERVOIR AV	A		3		
		MWDLC009	102 SCHOONER LN	A		3		
		MWDLC010	53 FOURTH ST	I		2		
		MWDLC011	38 SURRY DR	A		3		
		MWDLC012	455 WESTFIELD RD	A		1		
		MWDLC013	340 HICKS AV	A		3		
		MWDLC014	76 BAILY AVE	I		2		
		MWDLC015	6 ARTIZAN ST	A		3		
		MWDLC016	99 BRIARWOOD DR	A		3		
		MWDLC017	22 KIM LN	A		2		
		MWDLC018	70 SMITHFIELD AVE	A		3		
		MWDLC019	3 KIRKLAND PL	A		3		
		MWDLC020	27 NORTH ST	I		2		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							17,630	
Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDLC021	8 OAKLAND CT	A		2		
		MWDLC022	66 NANCY LN	A		3		
		MWDLC023	32 PROSPECT TER	A		3		
		MWDLC024	31 CASTLE DR	A		3		
		MWDLC025	246 GWEN RD	A		3		
		MWDLC026	405 KENSINGTON	A		3		
		MWDLC027	870 NORTH COLONY RD	A		3		
		MWDLC028	660 NORTH COLONY RD	A		2		
		MWDLC029	375 BROWNSTONE RIDGE	I		1		
		MWDLC030	604 GRACEY AVE	A		1		
		MWDLC030OLD	570 BROWNSTONE RIDGE	I		3		
		MWDLC031	26 LORI LN	A		1		
		MWDLC031OLD	25 SUZY CT	I		N		
		MWDLC032	93 O'BRIEN DR	A		1		
		MWDLC033	28 NEWTON ST	A		1		
		MWDLC034	6 NORRIE PL	A		3		
		MWDLC035	32 PARKER AV NORTH	A		2		
		MWDLC036	498 PARKER AVE	A		1		
		MWDLC036OLD	215 SOUTH COLONY ST	I		N		
		MWDLC037	145 PETTIT DR	A		1		
		MWDLC037OLD	110 POMEROY AVE	I		3		
		MWDLC038	25 STEVENSON RD	A		3		
		MWDLC040	336 ELM ST	A		3		
		MWDLC041	425 POMEROY AVE	A		3		
		MWDLC042	177 THORPE AVE	A		1		
		MWDLC043	112 STEVENSON RD	A		3		
		MWDLC044	110 DRYDEN DR	A		3		
		MWDLC045	74 CYNROSE PL	A		1		
		MWDLC046	156 METACOMET DR	A		1		
		MWDLC046OLD	3 ABBEY LANE	I		1		
		MWDLC047	26 ALLEN AVE	I		1		
		MWDLC048	92 DRAPER AVE	A		1		
		MWDLC049	91 GOODSPEED AVE	A		3		
		MWDLC050	63 PRESTON AVE	A		3		
		MWDLC051	220 WESTVIEW RD	A		1		
		MWDLC052	312 GRAVEL ST	A		3		
		MWDLC053	34 TREMONT ST	I		1		
		MWDLC054	153 PETTIT DR	A		1		
		MWDLC054OLD	108 WILLIS AVE	I		3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDLC055	165 NATCHAUG DR	A		3		
		MWDLC056	70 FIESTA HEIGHTS	A		3		
		MWDLC057	10 KEATS RD	A		3		
		MWDLC058	20 MILDRED RD	A		3		
		MWDLC059	438 YALE AVE	A		3		
		MWDLC060	116 VETERAN ST	A		1		
		MWDLC061	76 SAGE HILL RD	A		1		
		MWDLC062	258 NO. WALL ST.	A		3		
		MWDLC062OLD	99 ALANBY DR	I		3		
		MWDLC063	142 GODEK HILL RD.	A		1		
		MWDLC063OLD	41 SO THIRD ST	I		2		
		MWDLC064	71 ARLINGTON NO.	A		1		
		MWDLC064OLD	64 MURRAY ST	I		1		
		MWDLC065	89 BETHANN CIRCLE	A		1		
		MWDLC066	18 STEPHEN DR	A		1		
		MWDLC066OLD	26 KENNEDY DR	I		N		
		MWDLC067	162 HILLCREST AVE	A		3		
		MWDLC068	52 CARL ST	A		3		
		MWDLC069	336 CROWN ST	I		3		
		MWDLC070	55 SHELLEY RD	A		3		
		MWDLC071	102 WILLIAMS ST	A		1		
		MWDLC072	104 WHITNEY DR	A		1		
		MWDLC072OLD	58 JEROME AVE	I		3		
		MWDLC073	132 STEVENSON RD	A		1		
		MWDLC074	39 HILLWOOD LA	I		3		
		MWDLC075	38 FARM HILL RD	A		3		
		MWDLC076	55 EATON AVE	A		3		
		MWDLC077	181 DANA LANE	I	Y	3		
		MWDLC077OLD	156 METACOMET DR	I		2		
		MWDLC078	67 SPERRY LANE	A	Y	1		
		MWDLC078OLD	258 N WALL ST	I		3		
		MWDLC079	35 FAIR STREET	A	Y	1		
		MWDLC079OLD	142 GODEK HILL RD	I		1		
		MWDLC080	57 DEBBIE DRIVE	I	Y	N		
		MWDLC080OLD	71 ARLINGTON NO	I		1		
		MWDLC081	62 FAIRWAY DRIVE	A	Y	1		
		MWDLC081OLD	MWDLC 081	I	Y			
		MWDLC082	439 SOUTH CURTIS	A		2		
		MWDLC083	30 PINEHURST DR	I		3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDLC084	24 ROCKLEDGE DR	A		3		
		MWDLC085	11 HILL TOP RD	A	Y	1		
		MWDLC086	89 SYLVAN VALLEY RD	A	Y	1		
		MWDLC087	165 AMITY ST	A	Y	1		
		MWDLC088	27 ANTONIO AVE	A	Y	1		
		MWDLC089	19 RIDGEVIEW RD	A	Y	1		
		MWDLC090	100 BARR ROAD	A	Y	1		
		MWDLC091	240 HICKS AV	A	Y	1		
		MWDLC092	607 GRACEY AV	A	Y	1		
		MWDLC093	36 BLUEBERRY LN	A	Y	1		
		MWDLC094	398 BRADLEY AVE	A	Y	1		
		MWDLC095	28 BRIAN CT	A	Y	1		
		MWDLC096	555 GRACEY AV	A	Y	1		
		MWDLC097	366 GRACEY AV	A		1		
		MWDLC098	74 CAREY AVE	A	Y	1		
		MWDLC099	62 SILVER LAKE RD	A		1		
		MWDLC100	242 CARRIAGE DR EAST	A	Y	1		
		MWDLC101	1672 NORTH COLONY RD	A	Y	1		
		MWDLC102	1404 NORTH COLONY RD	A	Y	1		
		MWDLC103	111 CATHERINE DR	A	Y	1		
		MWDLC104	1261 NORTH COLONY RD	A	Y	1		
		MWDLC105	301 COLUMBUS AVE	A	Y	1		
		MWDLC106	200 DRYDEN DR	A	Y	1		
		MWDLC107	45 NANCY LN	A	Y	1		
		MWDLC108	78 EAST VIEW TER	A	Y	1		
		MWDLC109	202 EATON AVE	A	Y	1		
		MWDLC110	42 EMPIRE AVE	A	Y	1		
		MWDLC111	29 CATHERINE DR	A	Y	1		
		MWDLC112	192 FINCH AVE	A		1		
		MWDLC113	266 GRACEY AVE	A	Y	1		
		MWDLC114	1359 OLD NO COLONY R	A	Y	1		
		MWDLC115	47 PARKER RD	A	Y	1		
		MWDLC116	40 PASCO ST	A	Y	1		
		MWDLC117	35 PEARL ST	A	Y	1		
		MWDLC118	28 EMPIRE AVE	A	Y	1		
		MWDLC119	187 WOODLAND ST	A	Y	1		
		MWDLC120	91 ROLLING HILLS DR	A	Y	1		
		MWDLC121	46 BLUEBERRY LN	A		1		
		MWDLC122	512 SO CURTIS ST	A		1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDLC123	28 REM DR	A	Y	1		
		MWDLC124	672 BROWNSTONE RIDGE	A	Y	1		
		MWDLC125	61 SUNSET DR	A	Y	1		
		MWDLC126	89 SYLVAN VALLEY RD	A	Y	1		
		MWDLC127	54 VALE AVE	A	Y	1		
		MWDLC128	91 ROLLING HILLS DR	A	Y	1		
		MWDLC129	105 RIVERSIDE DR	A	Y	1		
		MWDLC130	160 CORRIGAN AV	A	Y	1		
		MWDLC131	67 WILDWOOD RD	A	Y	1		
		MWDLC132	43 HOBSON AV	A	Y	1		
		MWDLC133	20 LOU ANN TER	A	Y	1		
		MWDLC134	274 YALE AVE	A	Y	1		
		MWDLC135	141 VALLEY VIEW DR	A		1		
		MWDLC136	290 BEE ST	A		1		
		MWDLC137	4 MONTOWESE DR	A		1		
		MWDLC138	162 SAGAMORE RD	A		1		
		MWDLC139	347 BALDWIN AV	A		1		
		MWDLC140	10 PARKVIEW ST	A		1		
		MWDLC141	44 GODEK HILL RD	A		1		
		MWDLC142	52 GODEK HILL RD	A		1		
		MWDLC143	66 GODEK HILL RD	A		1		
		MWDLC144	40 DAVIS ST	A		1		
		MWDLC145	106 MIDLAND DR	A		1		
		MWDLC146	185 MILLER AVE	A		1		
		MWDLC147	166 STEPHEN DR	A		1		
		MWDLC148	70 STEPHEN DR	A		1		
		MWDLC149	59 OAK RIDGE DR	A		1		
		MWDLC150	59 O'BRIAN DR	A		1		
		MWDLC151	826 PADDOCK AV	A		1		
		MWDLC152	27 PALMER DR	A		1		
		MWDLC153	164 MILLBROOK RD	A		1		
		MWDLC154	104 CARRIAGE DR EAST	A		1		
		MWDLC155	88 ISABELLE DR	A		1		
		MWDLC156	176 CART PATH	A		1		
		MWDLC157	21 DIVOT DR	A		1		
		MWDLC158	66 DOGLEG DR	A		1		
		MWDLC159	30 EAGLE CT	A		1		
		MWDLC160	71 FAIRWAY DR	A		1		
		MWDLC161	265 FAIWAY DR	A		1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							17,630	
Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		MWDLC162	473 MURDOCK AV	A		1		
		MWDLC163	47 PRANN CT	A		1		
		MWDLC164	77 ROYAL OAK	A		1		
		MWDLC165	261 ROYAL OAK	A		1		
		MWDLC166	38 TUXIS CIR	A		1		
		MWDLC167	32 ALLEN AVE	A		1		
		MWDM1000	664 WEST MAIN ST	A				Y
		MWDM2000	412 WEST MAIN ST	A				
		MWDM3000	15 LINCOLN ST	A				
		MWDM4000	142 EAST MAIN ST	A				
		MWDME000	78 RESERVOIR RD	A				
		MWDPL500	540 WEST MAIN ST	A				
		MWDTT001	585 MAIN ST	A				
		MWDTT002	168 CHAMBERLAIN HWY	A				
		MWDTT003	167 LEWIS AVE	A				
		MWDTT004	105 MILLER ST	A				
		MWDTT005	281 EAST MAIN ST	A				
		MWDTT006	50 YALE AVE	A				
		MWDTT007	61 TULIP DR	A				
		MWDTT008	692 EAST MAIN ST	A				
		MWDTT009	1966 NO BROAD ST	A				
		MWDTT010	553 NORTH COLONY RD	A				
		MWDTT011	341 SO BROAD ST	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	MERIMERE WTP ENTRY POINT	3	EP - MERIMERE	A				
00701	ELMERE WTP ENTRY POINT	3	EP - ELMERE	A				
00702	BROAD BROOK WTP ENTRY POINT	3	EP - BROAD BROOK	A				
00703	BRADLEY HUBBARD WTP ENTRY POINT	3	EP - BRADLEY HUBBARD	A				
00704	EVANSVILLE WTP ENTRY POINT	3	EP - EVANSVILLE	A				
00705	MULE WELL WTP ENTRY POINT	3	EP - MULE WELL	A				
00706	COLUMBUS PARK WELL WTP ENTRY POINT	3	EP - COLUMBUS PARK	A				
00707	PLATT LINCOLN WTP ENTRY POINT	3	EP - PLATT LINCOLN	A				
1355	MULE WELL	2	MULE WELL	A				
1356	COLUMBUS PARK WELL	2	COLUMBUS PARK WELL	A				
1357	PLATT WELL	2	PLATT WELL	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
1358	LINCOLN WELL	2	LINCOLN WELL	A				
1359	EVANSVILLE AVENUE WEST WELL	2	EVANSVILLE AVENUE WE	A				
1360	EVANSVILLE AVENUE EAST WELL	2	EVANSVILLE AVENUE EA	A				
150	BROAD BROOK WATER TREATMENT PLANT	5	CFE - BROAD BROOK TP	A				
151	PLATT LINCOLN TREATMENT STATION	5	IESWTR - PLATT EP	A				
152	MERIMERE WATER TREATMENT PLANT	5	CFE - MERIMERE WTP	A				
153	ELMERE WATER TREATMENT PLANT	5	CFE - ELMERE WTP	A				
154	BRADLEY HUBBARD WATER TREATMENT PLANT	5	CFE - BRADLEY WTP	A				
155	EVANSVILLE WATER TREATMENT PLANT	5	IESWTR - EVANSVIL EP	A				
156	MULE TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
157	COLUMBUS PARK WELL TREATMENT STATION	5	IESWTR - COLUMBUS EP	A				
2139	BRADLEY HUBBARD RESERVOIR	1	BRADLEY HUBBARD RES	A				
2140	KENMERE RESERVOIR	1	KENMERE RESERVOIR	A				
2141	MERIMERE RESERVOIR	1	MERIMERE RESERVOIR	A				
2142	BROAD BROOK RESERVOIR	1	BROAD BROOK RES	A				
2143	HALLMERE RESERVOIR	1	RESERVOIR	A				
2144	STOCKING BROOK DIVERSION	1	RESERVOIR	A				
2145	ELMERE RESERVOIR	1	ELMERE RESERVOIR	A				
2146	MALONEY CANAL DIVERSION	1	RESERVOIR	A				
2147	MCKONE CANAL DIVERSION	1	RESERVOIR	A				
30040	BRADLEY HUBBARD RESERVOIR							
30041	MERIMERE RESERVOIR							
30042	ELMERE RESERVOIR							
30043	BROAD BROOK RESERVOIR							
45119	INTERCONNECTION - CT0930011 - RWA							
49588	JOHNSON AVE TANK							
49590	CARPENTER AVE ATMOSPHERIC TANK							
49592	FLEMING ROAD TANK							
49594	ELMERE TANK							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
49596	MERIMERE TANK							
49598	COLLINSDALE TANK 1							
49600	COLLINSDALE TANK 2							
49602	SCHWINKS HILL TANK 1							
49604	SCHWINKS HILL TANK 2							
49606	CARPENTER AVE PRESSURE TANK 1							
49608	CARPENTER AVE PRESSURE TANK 2							
49610	BROAD BROOK CLEARWELL							
49612	BRADLEY-HUBBARD TANK							
49614	FINCH AVE PUMP STATION							
49616	JOHNSON AVE PUMP STATION							
49618	EAST ROAD PUMP STATION							
49620	CARPENTER AVE PUMP STATION							
49622	PARKER AVE PUMP STATION							
49624	SCHWINK DRIVE PUMP STATION							
49626	COLLINSDALE PUMP STATION							
53151	JOHNSON AVE EAST TANK							
53153	JOHNSON AVE WEST TANK							
59159	PLATT LINCOLN CLEARWELL							
59163	EVANSVILLE CLEARWELL							
59916	BROAD BROOK WTP BACKWASH SUPPLY TANK							
62377	ELMERE WTP CLEARWELL							

### Certified Operator Information

**Water System Facility:** DISTRIBUTION SYSTEM (WSF ID: 00600)

**Facility Classification:** CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
TERAPANE, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2028
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
CARON, SCOTT A	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2027

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Certified Operator Information

**Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
SEGALINE, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2027
PAVELKOPS, SCOTT P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2028
QUILTY, JOSEPH	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2027
BOSTROM, PARTRICK	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2028

**Water System Facility: BROAD BROOK WATER TREATMENT PLANT (WSF ID: 150)**

**Facility Classification:** CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRADY, SEAN P	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
ROBERTS, CHAD M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
CARON, SCOTT A	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
PAVELKOPS, SCOTT P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2028
GOLEBIEWSKI, CONNOR A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2028
CAMARA, JAMES M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
MORDARSKI, CHRISTOPHER M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2025

**Water System Facility: PLATT LINCOLN TREATMENT STATION (WSF ID: 151)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRADY, SEAN P	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2028
CARON, SCOTT A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Certified Operator Information

**Water System Facility: PLATT LINCOLN TREATMENT STATION (WSF ID: 151)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PAVELKOPS, SCOTT P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027 3/31/2027
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2028
GOLEBIEWSKI, CONNOR A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2027 6/30/2028
CAMARA, JAMES M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
MORDARSKI, CHRISTOPHER M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2025

**Water System Facility: MERIMERE WATER TREATMENT PLANT (WSF ID: 152)**

**Facility Classification:** CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARON, SCOTT A	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028 9/30/2028
GRADY, SEAN P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026 3/31/2027
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 3/31/2026
PAVELKOPS, SCOTT P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027 3/31/2027
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2028
GOLEBIEWSKI, CONNOR A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2027 6/30/2028
CAMARA, JAMES M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
MORDARSKI, CHRISTOPHER M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2025

**Water System Facility: ELMERE WATER TREATMENT PLANT (WSF ID: 153)**

**Facility Classification:** CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARON, SCOTT A	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2028 6/30/2028
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2026 12/31/2027

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Certified Operator Information

**Water System Facility: ELMERE WATER TREATMENT PLANT (WSF ID: 153)**

**Facility Classification:** CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PAVELKOPS, SCOTT P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027 3/31/2027
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2028
GOLEBIEWSKI, CONNOR A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2027 6/30/2028
CAMARA, JAMES M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
MORDARSKI, CHRISTOPHER M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2025

**Water System Facility: BRADLEY HUBBARD WATER TREATMENT PLANT (WSF ID: 154)**

**Facility Classification:** CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
ROBERTS, CHAD M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2028 6/30/2028
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
CARON, SCOTT A	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 3/31/2026
PAVELKOPS, SCOTT P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027 3/31/2027
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2028
GOLEBIEWSKI, CONNOR A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2027 6/30/2028
CAMARA, JAMES M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
MORDARSKI, CHRISTOPHER M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2025

**Water System Facility: EVANSVILLE WATER TREATMENT PLANT (WSF ID: 155)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GRADY, SEAN P	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2028 6/30/2028
CARON, SCOTT A	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 3/31/2026

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Certified Operator Information

**Water System Facility: EVANSVILLE WATER TREATMENT PLANT (WSF ID: 155)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PAVELKOPS, SCOTT P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027 3/31/2027
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2028
GOLEBIEWSKI, CONNOR A	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2028 9/30/2027
CAMARA, JAMES M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
MORDARSKI, CHRISTOPHER M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2025

**Water System Facility: MULE TREATMENT STATION (WSF ID: 156)**

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARON, SCOTT A	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
ROBERTS, CHAD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028 9/30/2028
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 3/31/2026
PAVELKOPS, SCOTT P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027 3/31/2027
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2028
GOLEBIEWSKI, CONNOR A	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2028 9/30/2027
CAMARA, JAMES M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
MORDARSKI, CHRISTOPHER M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2025

**Water System Facility: COLUMBUS PARK WELL TREATMENT STATION (WSF ID: 157)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
CARON, SCOTT A	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026 3/31/2027
ROBERTS, CHAD M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2028 6/30/2028
GRADY, SEAN P	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2027 12/31/2026
ROVILLO, STEVEN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2027 3/31/2026

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0800011	MERIDEN WATER DIVISION			C	58,441	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						17,630	

Towns Served: BERLIN, CHESHIRE, MERIDEN, SOUTHTON, WALLINGFORD

### Certified Operator Information

**Water System Facility: COLUMBUS PARK WELL TREATMENT STATION (WSF ID: 157)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
PAVELKOPS, SCOTT P	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027 3/31/2027
PETER, ROBERT F	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	3/31/2028
GOLEBIEWSKI, CONNOR A	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2027 6/30/2028
CAMARA, JAMES M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2027
MORDARSKI, CHRISTOPHER M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2025

### Contact Information

Name				Organization		Job Title			
Mr. William C. Norton				City of Meriden		Director-Public Util			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
117 Parker Avenue						Meriden		CT	06450
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-630-4256			203-630-4285				wnorton@meridenct.gov		

**Contact Role(s): Administrative Contact**

Name				Organization		Job Title			
Mr. Brian Daniels				City of Meriden		City Manager			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
142 East Main Street						Meriden		CT	06450
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-630-4123			203-630-4274				bdaniels@meridenct.gov		

**Contact Role(s): Legal Contact**

#### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**