

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0830032	PRATT & WHITNEY			NTNC	2,800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
AIRCRAFT ROAD				1				
Towns Served: MIDDLETOWN								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		3 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
Asbestos (1094)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		Complete
Total Haloacetic Acids (2456)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
B220 COL R2 MENS RM (DW0029)	1/1/24 - 12/31/24	8/1-8/31	Complete
	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
Total Trihalomethanes (2950)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
B94 MAINT. BUILDING (DW0001)	1/1/24 - 12/31/24	8/1-8/31	Complete
	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
Total Coliform (3100)		3 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		20 routine (RT) per six months	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0830032	PRATT & WHITNEY			NTNC	2,800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
AIRCRAFT ROAD				1				
Towns Served: MIDDLETOWN								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Lead And Copper (PBCU) **10 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 12/31/26	6/1-9/30	

Physical Parameters (PPS) **3 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Inorganic Chemicals (IOCS) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		Complete

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and PCBs-Phase II (SOC2) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Pesticides, Herbicides and PCBs-Phase V (SOC5) **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0830032	PRATT & WHITNEY			NTNC	2,800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
AIRCRAFT ROAD				1				
Towns Served: MIDDLETOWN								

Monitoring Requirements

Water System Facility: WELL 7 (WSF ID: 10400)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 7 (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL B (WSF ID: 10401)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL B (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: WELL A (WSF ID: 10402)

E. Coli (3014)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL A (2)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0830032	PRATT & WHITNEY			NTNC	2,800	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
AIRCRAFT ROAD			Connections	1				
Towns Served: MIDDLETOWN								

Monitoring Requirements

Water System Facility: **WELL A (WSF ID: 10402)**

E. Coli (3014) 1 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: .2 MG/L	Daily
Start Date: 1/1/2002	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 2/1/2014	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	COMBINED RAW WATER DISCHARGE	5	COMBINED RAW WATER	A				
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSIDE	WITHIN 5 SERVICE CON	A				
		DW0001	B94 MAINT. BUILDING	A	Y	2		Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0830032	PRATT & WHITNEY			NTNC	2,800	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
AIRCRAFT ROAD			Connections	1				
Towns Served: MIDDLETOWN								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		DW0001LCR	B94 MAINT. BUILDING	I	Y			
		DW0002	B110 PLNTPROKITCH	A	Y	2		
		DW0002LCR	B110 PLNTPROKITCHEN	I	Y			
		DW0003	B130-2 N.BANK MENS RM	A	Y	2		
		DW0003LCR	B130-2 N. BANK MEN'S	I	Y			
		DW0004	B130-1 MENS RM CENTER	A	Y	2		
		DW0004LCR	B130-1 MEN'S ROOM CE	I	Y			
		DW0005	B140 OFFICE NW MEN RM	A	Y	2		
		DW0005LCR	B140 OFFICE NW MEN'S	I	Y			
		DW0006	B140 TRAINSCHOOL MRM	A	Y	2		
		DW0006LCR	B140 TRAINSCHOOL MRM	I	Y			
		DW0007	B150 CTRBLKHSEWMS RM	A		2		
		DW0007LCR	B150 CTRBLKHSEWMS RM	I	Y			
		DW0008	B150 MENS RM COL G3	A	Y	2		Y
		DW0008LCR	B150 MEN'S ROOM, G3	I	Y			
		DW0009	B150 MENS RM COL G14	A	Y	2		Y
		DW0009LCR	B150 MEN'S ROOM, G14	I	Y			
		DW0010	B200 DW AREA SINK	A		2		
		DW0010LCR	B200 DW AREA SINK	I	Y			
		DW0011	B200CNTRISLAND SINK	A		2		
		DW0011LCR	B200 CENTER ISLAND S	I	Y			
		DW0012	B200 COLD PREP AREA	A		2		
		DW0012LCR	B200 COLD PREP AREA	I	Y			
		DW0013	B220A COL D2 MENS RM	A	Y	2		Y
		DW0013LCR	B220A COL D2 MEN'S R	I	Y			
		DW0014	B220-2E.MEZZ COL R1	A		2		
		DW0014LCR	B220-2 E. MEZZ, COL	I	Y			
		DW0015	B220 MENS RM COL L13	A		2		
		DW0015LCR	B220 MEN'S ROOM, K13	I	Y			
		DW0016	B220 MENS RM COL R13	A	Y	2		Y
		DW0016LCR	B220 MEN'S ROOM, R13	I	Y			
		DW0017	B220 MENS RM COL X10	A		2		
		DW0017LCR	B220 MEN'S ROOM, X10	I	Y			
		DW0018	B220 MENS RM COL B14	A	Y	2		
		DW0018LCR	B220 MEN'S ROOM, B14	I	Y			
		DW0019	B290-1 WMS RM	A		2		
		DW0020	B310-1 B2 KITCHEN	A	Y	2		
		DW0020LCR	B290-1 WMS RM	I	Y			
		DW0021	B331-2 MENS ROOM	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0830032	PRATT & WHITNEY			NTNC	2,800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
AIRCRAFT ROAD				1				
Towns Served: MIDDLETOWN								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		DW0021LCR	B310-1 B2 KITCHEN	I	Y			
		DW0022	B410 COL E17 MENS RM	A	Y	2		
		DW0022LCR	B331-2 MEN'S ROOM	I	Y			
		DW0023	B410 TST CELL 3-4 BT	A	Y	2		
		DW0023LCR	B410 COL E17 MEN'S R	I	Y			
		DW0024	B440 MENS ROOM	A		2		
		DW0025	B110 F&S KITCHEN	A	Y			
		DW0025LCR	B440 MEN'S ROOM	I	Y			
		DW0026	B130 F12 MENRM LOBBY	A	Y			
		DW0027	B200 COL F3 MENS RM	A	Y			
		DW0028	B220 COL K13 MENS RM	A	Y			Y
		DW0029	B220 COL R2 MENS RM	A	Y			Y
		DW0030	B230 MENS RM	A	Y			
		DW0031	B280 MENS RM	A	Y			
		DW0032	B290-1 COL A3 MEN RM	A	Y			
		DW0033	B295 BATHROOM	A	Y			
		DW0034	B330-1 MENS RM	A	Y			
		DW0035	B425 COL B1 BTH RM	A	Y			
		DW0036	B440 1ST FL KITCHEN	A	Y			
		DW0037	ASBESTOS B150 J10	A	Y		Y	
		DW0038	B220 COL K13 MENS RM	I	Y			
		DW0039	B220 COL R2 MENS RM	I	Y			Y
		DW0040	B220 COL R13 MENS RM	I	Y			
		DW0041	B230 MENS RM	I	Y			
		DW0042	B280 MENS RM	I	Y			
		DW0043	B290-1 COL A3 MENS R	I	Y			
		DW0044	B295 BATHROOM	I	Y			
		DW0045	B310-1 B2 KITCHEN	I	Y			
		DW0046	B330-1 MENS RM	I	Y			
		DW0047	B331-2 MENS RM	I	Y			
		DW0048	B410 COL E17 MENS RM	I	Y			
		DW0049	B410 TST CELL 3-4 BT	I	Y			
		DW0050	B425 COL B1 BTH RM	I	Y			
		DW0051	B440 1ST FL KITCHEN	I			Y	
		DW0052	ASBESTOS B150 G8	I	Y		Y	
		DW0053	B410 COL E23	I	Y			
		DW0054	B425 COL B1	I	Y			
		DW0055	B440 1ST FL COL B8	I	Y			
		DW0056	B440 1ST FL COL D6	I	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0830032	PRATT & WHITNEY			NTNC	2,800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
AIRCRAFT ROAD				1				
Towns Served: MIDDLETOWN								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		DW0057	B450 COL D1	I	Y			
		DW0061	ASBESTOS B150 G3	I	Y		Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1031	PRATT TREATMENT STATION							
10400	WELL 7	2	WELL 7	A				
10401	WELL B	2	WELL B	A				
10402	WELL A	2	WELL A	A				
62333	ATMOSPHERIC STORAGE							
62336	ATMOSPHERIC STORAGE							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
UHLAN, ERICH S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027

Water System Facility: PRATT TREATMENT STATION (WSF ID: 1031)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
UHLAN, ERICH S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027

Contact Information

Name		Organization			Job Title		
Mr. Erich Uhlán		Facilities And Services			Director		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
400 Main Street					East Hartford	CT	06118
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-565-0824					erich.uhlan@prattwhitney.com		

Contact Role(s): Legal Contact

Name		Organization			Job Title		
Miss Susana Valentin					Facility Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
1 Aircraft Road					Middletown	CT	06457
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-704-7524					susana.valentin@prattwhitney.com		

Contact Role(s): Administrative Contact

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0830032	PRATT & WHITNEY			NTNC	2,800	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
AIRCRAFT ROAD				1				
Towns Served: MIDDLETOWN								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule