

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		30 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	8/1/25 - 8/31/25		Complete
Chlorine Residual (1012)		31 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
67 LONGVIEW ST (NLDPU022A)	1/1/21 - 12/31/29		
Total Coliform (3100)		30 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		4 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PEQUOT HOSE CO (NLDPU002)	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	
	1/1/26 - 3/31/26	1/1-1/31	
FIRE HQ BANK STREET (NLDPU003)	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	
	1/1/26 - 3/31/26	1/1-1/31	
CONN COLLEGE (NLDPU004)	4/1/25 - 6/30/25	4/1-4/30	Complete
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	
	1/1/26 - 3/31/26	1/1-1/31	
GAM OCEAN BEACH (NLDPU050X)	4/1/25 - 6/30/25	4/1-4/30	Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP) 4 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	
	1/1/26 - 3/31/26	1/1-1/31	

Lead And Copper (PBCU) 30 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	

Physical Parameters (PPS) 30 routine (RT) per month

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: **LAKE KONOMOC WTP ENTRY POINT (WSF ID: 00701)**

Net Gross Alpha (4000) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010) 1 routine (RT) per three years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: LAKE KONOMOC WTP ENTRY POINT (WSF ID: 00701)

Inorganic Chemicals (IOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSF ID: 199)

Total Organic Carbon (2920)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE- LAKE KONOMOC TP (5)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		

Water System Facility: LAKE KONOMOC RESERVOIR (WSF ID: 2162)

Total Alkalinity (1927)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: LAKE KONOMOC RESERVOIR (WSF ID: 2162)

Total Alkalinity (1927)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Total Organic Carbon (2920)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: LAKE KONOMOC RESERVOIR (WSF ID: 2162)

Surface Water Color and Turbidity (RPPS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 3/31/26		

Surface Water Pesticides (RSOC) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSFID: 199)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 10/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSFID: 199)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 1/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.2 MG/L	2
Start Date: 1/1/2005			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 10/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 10/1/2003			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025	Y	
	6/1/2025 - 6/30/2025	Y	
	7/1/2025 - 7/31/2025	Y	
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	5/23/2025
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		NLDPU001	NLWPC	A	Y			
		NLDPU002	PEQUOT HOSE CO	A	Y			Y
		NLDPU003	FIRE HQ BANK STREET	A	Y			Y
		NLDPU004	CONN COLLEGE	A	Y			Y
		NLDPU005	109 CRYSTAL AVE.	A	Y			
		NLDPU006	107 COLMAN ST.	A	Y			
		NLDPU007	LOMBARDI AUTO	A	Y			
		NLDPU008	L & M HOSPITAL	A	Y			
		NLDPU009	120 BROAD STREET	A	Y			
		NLDPU010	20 NAMEAUG ST	A	Y	N		Y
		NLDPU013	29 WEST ST.	A	Y	1		
		NLDPU014	41 WOODLAWN ROAD	A	Y	1		
		NLDPU015	298 CRYSTAL AVE.	I	Y	1		
		NLDPU016	552 OCEAN AVE.	A	Y	1		
		NLDPU017	46 SUMMIT AVE.	A	Y	1		
		NLDPU018	311 VAUXHALL ST. ALT	A	Y	1		
		NLDPU021	22 ADDISON ST.	A	Y	1		
		NLDPU022	150 ASHCRAFT RD.	I	Y	1	Y	
		NLDPU022A	67 LONGVIEW ST	A			Y	
		NLDPU023	34 CHAPEL DR.	I	Y	1		
		NLDPU024	278 CRYSTAL AVE.	I	Y	1		
		NLDPU025	12 FINCH AVE.	A	Y	1		
		NLDPU026	83 THAMES ST.	A	Y	1		
		NLDPU028	20 FINCH AVE.	A	Y	1		
		NLDPU029	113 RIVERVIEW AVE.	A	Y	1		
		NLDPU030	366 VAUXHALL ST.	I	Y	1		
		NLDPU033	959 PEQUOT AVE.	A	Y	1		
		NLDPU034	17 THAMES ST.	A	Y	1		
		NLDPU035	88 VAUXHALL ST.	I	Y	1		
		NLDPU040	310 VAUXHALL ST.	I	Y	1		
		NLDPU041	200 LEDYARD ST.	I	Y	1		
		NLDPU042	95 THAMES ST.	A	Y	1		
		NLDPU043	273 OCEAN AVE.	A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		NLDPU044	123 VAUXHALL ST.	A	Y	1		
		NLDPU045	US COAST GUARD	A	Y	N		
		NLDPU046	20 PENNY LN	A	Y	1		
		NLDPU047	22 PENNY LN	A	Y	1		
		NLDPU048	25 PENNY LN	A	Y	1		
		NLDPU049	611 OCEAN AVE B2	A	Y	1		
		NLDPU050	WOW OCEAN BEACH	I				Y
		NLDPU050X	GAM OCEAN BEACH	A				Y
		NLDPU051	226 THAMES ST	A	Y	1		
		NLDPU052	19 STARR ST	A	Y	1		
		NLDPU053	11 WALDEN AVE	A	Y	1		
		NLDPU054	30 GORTON ST	A	Y	1		
		NLDPU055	91 BLINMAN ST	A	Y	1		
		NLDPU056	999 BANK ST	A	Y	1		
		NLDPU057	38 GLENWOOD AVE	A	Y	1		
		NLDPU058	1182 OCEAN AVE	A	Y	1		
		NLDPU059	30 DARROW ST	A	Y	1		
		NLDPU060	32 HARRIS RD	A	Y	1		
		NLDPU061	611 OCEAN AVE A2	A	Y	1		
		NLDPU062	501 BAYONET ST	A	Y	1		
		NLDPU063	40 CENTER ST	A	Y	1		
		NLDPU064	32 CAPE ANN CT	A	Y	1		
		NLDPU065	80 BECKWITH ST	A	Y	1		
		NLDPU066	999 BANK ST	A	Y	1		
		NLDPU067	68 FEDERAL ST	A	Y	1		
		NLDPU068	36 BELDEN ST	A	Y	1		Y
		NLDPU069	171 LOWER BLVD	A	Y	1		
		NLDPU070	320 CONNECTICUT AVE	A	Y	1		
		NLDPU071	557 MONTAUK AVE	A	Y	1		
		NLDPU072	767 MONTAUK AVE	A	Y	1		
		NLDPU073	44 THAMES ST	A	Y	1		
		NLDPU074	298 VAUXHALL ST	A	Y	1		
		NLDPU075	52 SHERMAN ST	A	Y	1		
		NLDPU076	95 COLMAN ST	A	Y	1		
		NLDPU077	18 FARMINGTON AVE	A	Y	1		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	LAKE KONOMOC WTP ENTRY POINT	3	EP - LAKE KONOMOC TP	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
199	LAKE KONOMOC WATER TREATMENT PLANT	5	CFE- LAKE KONOMOC TP	A				
2162	LAKE KONOMOC RESERVOIR	1	LAKE KONOMOC RESERVO	A				
2163	BARNES RESERVOIR	1	RESERVOIR	A				
2164	BOGUE BROOK RESERVOIR	1	RESERVOIR	A				
2165	FAIRY LAKE RESERVOIR	1	RESERVOIR	A				
2166	BECKWITH POND	1	RESERVOIR	A				
2167	GREAT SWAMP DIVERSION	1	RESERVOIR	A				
2169	HUNTS BROOK DIVERSION	1	RESERVOIR	A				
30065	GREAT SWAMP DIVERSION							
30070	LAKE KONOMOC INTAKE							
49682	WILLIAMS STREET PUMP STATION							
53892	LAKE KONOMOC WTP CLEARWELL							
53894	BECKWITH POND RAW WATER PUMP STATION							
53896	TREMONT STREET STORAGE TANK							
53898	MANATUCK HILL STORAGE TANK							
53902	LAKE KONOMOC WTP PUMP STATION							
53904	LAKE KONOMOC WTP RAW WATER PUMP STATION							
54140	GREAT SWAMP DIVERSION PUMP STATION							
58948	INTERCONNECTION - CT0450011 - EAST LYME							
61782	CT COLLEGE HYDRO TANK							
61805	BECKWITH ROAD PUMP STATION							
61807	INDUSTRIAL DRIVE PUMP STATION							
61809	DAYTON PLACE PUMP STATION							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

<i>Operator Name</i>	<i>Operator Type</i>	<i>Certification(s)</i>	<i>Certification Expiration</i>
BROWNE, KEITH T	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
		WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027

Water System Facility: **LAKE KONOMOC WATER TREATMENT PLANT (WSF ID: 199)**

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BROWNE, KEITH T	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2027
		WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
MCVICKER, JONATHAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2026
		WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026

Contact Information

Name		Organization		Job Title		
Mr. Thomas Londregan		City of New London		City Attorney		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
38 Huntington Street				New London	CT	06320
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-447-3171						

Contact Role(s): **Legal Contact**

Name		Organization		Job Title		
Mr. Michael Passero		City of New London		Mayor		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
181 State Street				New London	CT	06230
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-447-5201		860-447-7971		860-625-7516	mpassero@newlondonct.org	

Contact Role(s): **Owner**

Name		Organization		Job Title		
Mr. Derek N Palmerone		Veolia Water		Water Treatment Mng		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
1153 Hartford Turnpike				Waterford	CT	05385
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-405-6475				860-405-6475	derek.palmerone@veolia.com	

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.