

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1069023	ATLAS COMMONS			NTNC	100	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
215 ELM STREET, OLD SAYBROOK							2	
Towns Served: OLD SAYBROOK								

Monitoring Requirements

Water System Facility: DISTRIBUTION (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/32		Complete
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 12/31/26	6/1-9/30	
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1069023	ATLAS COMMONS			NTNC	100	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
215 ELM STREET, OLD SAYBROOK			Connections				2	
Towns Served: OLD SAYBROOK								

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	4
Start Date: 12/1/2023		Compliance History:	Monitoring Compliance Status:
		Monitoring Period	Compliance Status:
		5/1/2025 - 5/31/2025	
		6/1/2025 - 6/30/2025	
		7/1/2025 - 7/31/2025	
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION	4	DISTRIBUTION	A	Y			
		DOWNSTREAM	5 SERVICE CONNECTION	A	Y			
		ECHOR	ECHO	A	Y	N	Y	Y
		EXAM1L	EXAM 1L - CONSULT	A	Y	N	Y	Y
		EXAM1R	EXAM 1R	A	Y	N	Y	Y
		EXAM2L	EXAM 2L	A	Y	N	Y	Y
		EXAM2R	EXAM 2R	A	Y	N	Y	Y
		EXAM3L	EXAM 3L	A	Y	N	Y	Y
		EXAM3R	EXAM 3R	A	Y	N	Y	Y
		EXAM4L	EXAM 4L	A	Y	N	Y	Y
		EXAM5L	EXAM 5L	A	Y	N	Y	Y
		EXAM6L	EXAM 6L	A	Y	N	Y	Y
		PBR	PATIENT BATH	A	Y	N	Y	Y
		SBR	STAFF BATH	A	Y	N	Y	Y
		SLR	STAFF LOUNGE	A	Y	N	Y	Y
		TMNTBATH	TREATMENT BATH	A	Y	N	Y	Y
		TMNTHAND	TREATMENT HAND	A	Y	N	Y	Y
		UPSTREAM	5 SERVICE CONNECTION	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
62879	WELL 1	2	WELL 1	A				
62881	WELL 2	2	WELL 2	A				
62885	ATM TANK							
62887	ATLAS WTP							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1069023	ATLAS COMMONS			NTNC	100	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
215 ELM STREET, OLD SAYBROOK			Connections				2	
Towns Served: OLD SAYBROOK								

Certified Operator Information

Water System Facility: **ATLAS WTP (WSF ID: 62887)**

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

Contact Information

Name				Organization		Job Title			
Mr. Michael C. Picard				215/213 Elm LLC		Agent			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
30 Northeast Industrial Road						Branford		CT	06405
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-483-9013						203-530-5530	mpicard@atlasoutdoor.com		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule