

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120322	POMFRET COMMUNITY SCHOOL			NTNC	500	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
20 POMFRET STREET					2			
Towns Served: POMFRET								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		10 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120322	POMFRET COMMUNITY SCHOOL			NTNC	500	L	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
20 POMFRET STREET			Connections		2			
Towns Served: POMFRET								

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PCS 001	NURSE QUARTERS	A	Y	2	Y	
		PCS 002	TEACHERS WORK RM	A	Y	2		
		PCS 003	KITCHEN AREA	A	Y	2		
		PCS 004	LIBRARY	A	Y	2		
		PCS 005	GIRLS LOCKER ROOM	A	Y	2		
		PCS 006	PRIMARY WING GIRLS	A	Y	2		
		PCS 007	ART ROOM	A	Y	2		
		PCS 008	M.S.GIRLS LAV	A	Y	2		
		PCS 009	PRE K SINK	A	Y	2		
		PCS 010	ROOM 107	A	Y	2		
		PCS 011	ADULTS ONLY BATH	A	Y	2		
		PCS 012	KITCHEN PREP SINK	A	Y	2		
		PCS 013	ROOM 113	A	Y	2		
		PCS 014	WOMENS LOBBY BATH	A	Y	2		
		PCS 015	ROOM 109	A	Y	2		
		PCS 016	ROOM 101	A	Y	2		
		PCS 017	ROOM 104	A	Y	2		
		PCS 018	ROOM 102	A	Y	2		
		PCS 019	ROOM 110	A	Y	2		
		PCS 020	4TH GRADES BOYS LAV	A	Y	2		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10518	WELL #1	2	WELL	A				
61610	WELL #3	2	WELL #3	A				
62846	ATMOSPHERIC STORAGE							
62847	BOOSTER PUMPS							

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120322	POMFRET COMMUNITY SCHOOL			NTNC	500	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
20 POMFRET STREET					2			
Towns Served: POMFRET								

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
NIGRO, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

Contact Information

Name				Organization			Job Title		
Ms. Crystal L. Sutter				Pomfret Board of Education			Business Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
20 Pomfret Street						Pomfret Center		CT	06259
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-928-2718		301	860-928-3839				sutter.c@pomfretcommunityschool.org		

Contact Role(s): **Administrative Contact**

Name				Organization			Job Title		
Mr. Michael Cummings				Pomfret Community School			Superintendent		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
20 Pomfret Street						Pomfret		CT	06259
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-928-2718							cummings.m@pomfretcommunityschool.org		

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120392	NEW ENGLAND LABORERS ACADEMY - MAIN SYS			NTNC	151	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 97 & MURDOCK ROAD				5				
Towns Served: POMFRET								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Lead And Copper (PBCU)		10 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Arsenic (1005)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1120392	NEW ENGLAND LABORERS ACADEMY - MAIN SYS	NTNC	151	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
ROUTE 97 & MURDOCK ROAD		5			
Towns Served: POMFRET					

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Arsenic (1005)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Inorganic Chemicals (IOCS)

1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)

1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)

1 (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)

1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)

1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7 PH	4
Start Date: 1/1/2002	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	5/1/2025 - 5/31/2025		
	6/1/2025 - 6/30/2025		
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SWTS 2: DWS REVIEW & APPROVAL OF SOWT		
CCTS 5: PWS OCCT INSTALLATION		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 10/3/2025

Page 5

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120392	NEW ENGLAND LABORERS ACADEMY - MAIN SYS			NTNC	151	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 97 & MURDOCK ROAD				5				
Towns Served: POMFRET								

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CCTS 2: DWS REVIEW & APPROVAL OF OCCT		
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW001	MENS ROOM	A	Y	N		
		MW001-1F	MENS RM 1ST FLOOR	A	Y	N		
		MW001-3F	MENS RM 3RD FLOOR	A	Y	N		
		MW002	LADIES ROOM 2ND FLOOR	A	Y			
		MW002-2F	LADIES RM 2ND FLOOR	I	Y	N		
		MW003	KITCHEN 1ST FLOOR	A	Y			
		MW003-1F	KITCHEN 1ST FLOOR	A	Y	N		
		MW003-2F	KITCHEN 2ND FLOOR	A	Y	N		
		MW005	MENS ROOM NEW BLDG	A	Y			
		MW006	REAR MENS ROOM NEW B	A	Y			
		MW007	ED BLDG-MENS RM	A	Y			
		MW008	ED BLDG-WOMENS RM	A	Y			
		MW009	KITCHENETTE NEW BLDG	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1447	NELTA PLANT - WELL # 4							
28741	WELL # 4	2	WELL # 4	A				
55244	ATMOSPHERIC TANK							
60933	WELL # 5	2	WELL #5	A				
60935	TREATMENT PLANT - WELL # 5							
60937	PUMP STATION							

Certified Operator Information

Water System Facility: NELTA PLANT - WELL # 4 (WSF ID: 1447)			
Facility Classification: CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120392	NEW ENGLAND LABORERS ACADEMY - MAIN SYS			NTNC	151	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 97 & MURDOCK ROAD				5				
Towns Served: POMFRET								

Certified Operator Information

Water System Facility: TREATMENT PLANT - WELL # 5 (WSF ID: 60935)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027

Contact Information

Name		Organization		Job Title		
Mr. Joseph M. Sabitoni		Ne Laborer Train Academy		Director		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
Route 97 & Murdock Road		P. O. Box 77		Pomfret Center	CT	06259
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-974-1455		860-974-3249		860-213-9012	jsabitoni@neltact.org	

Contact Role(s): Administrative Contact, Legal Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120402	FIBEROPTICS TECHNOLOGY (NEW)			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 QUASSETT RD				2				

Towns Served: POMFRET

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT1120402	FIBEROPTICS TECHNOLOGY (NEW)	NTNC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 QUASSETT RD			2				
Towns Served: POMFRET							
Monitoring Requirements							
Water System Facility: ENTRY POINT (WSF ID: 00700)							
Organic Chemicals (VOCS)			1 routine (RT) per year				
Sampling Point (Sampling Point ID)			Monitoring Period	Collection Period	Compliance Status		
			1/1/25 - 12/31/25		Complete		
			1/1/26 - 12/31/26				
Other Compliance Schedules							
Compliance Schedule Activity			Due Date	Achieved Date			
RESPOND TO SANITARY SURVEY			2/20/2025				
CROSS CONNECTION SURVEY REPORT			3/1/2029				
Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		NEW.001	TANK	P	Y		
		NEW.002	OFFICE BUBBLER	P	Y	1	
		NEW.003	LADIES SINK	P	Y	1	
		NEW.004	MENS SINK	P	Y	1	
		NEW.005	MEETING RM SINK	P	Y	1	
		NEW.006	PROD AREA BUBBLER	P		1	
	UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A			
10521	WELL 2	2	WELL 2	A			
11291	TREATMENT PLANT						
Certified Operator Information							
Water System Facility: TREATMENT PLANT (WSF ID: 11291)							
Facility Classification: CLASS 1 TREATMENT PLANT							
Operator Name	Operator Type	Certification(s)	Certification Expiration				
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027				
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027				
NAPIERATA, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027				
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027				
ENGLE, ROGER D.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026				
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026				
LAFRAMBOISE, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026				
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026				
STARK, TYLER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2028				
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 10/3/2025

Page 9

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120402	FIBEROPTICS TECHNOLOGY (NEW)			NTNC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 QUASSETT RD				2				

Towns Served: POMFRET

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
NAPIERATA, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027
ENGLE, ROGER D.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
LAFRAMBOISE, ERIC	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
STARK, TYLER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2028
		WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

Contact Information

Name				Organization			Job Title		
Mr. Keith Knowlton				Fiberoptics Technology Inc.			Vice President		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1 Fiber Road			P.O. Box 286			Pomfret		CT	06258
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-928-0443		860-928-7664			kknowlton@fiberoptix.com				

Contact Role(s): **Owner**

Name				Organization			Job Title		
Mr. Kevin R. Lambert				Fiberoptics Technology Inc.			Facility Maint Mgr		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
PO Box 286			1 Quassett Rd			Pomfret		CT	06258
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-928-0443		177	860-928-7664			860-428-0053	klambert@fiberoptix.com		

Contact Role(s): **Administrative Contact**

Name				Organization			Job Title		
Mr. William Bailey				Fiberoptics Technology Inc			Ceo		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1 Quassett Rd			PO Box 286			Pomfret		CT	06258
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-928-0443	128	860-928-7664			bbailey@fiberoptix.com				

Contact Role(s): **Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1120402	FIBEROPTICS TECHNOLOGY (NEW)			NTNC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 QUASSETT RD			2				
Towns Served: POMFRET							

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120422	LOOS & CO - WELL #1			NTNC	130	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 101 & 16A, 24, 28 MASHAMOQUET					4			
Towns Served: POMFRET								

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule									
PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source		
CT1120422	LOOS & CO - WELL #1			NTNC	130	P	GW		
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
ROUTE 101 & 16A, 24, 28 MASHAMOQUET					4				
Towns Served: POMFRET									
Monitoring Requirements									
Water System Facility: ENTRY POINT (WSF ID: 00700)									
Organic Chemicals (VOCS)				1 routine (RT) per year					
Sampling Point (Sampling Point ID)			Monitoring Period		Collection Period		Compliance Status		
			1/1/26 - 12/31/26						
Water System Facility: DRILLED WELL 1 (WSF ID: 10523)									
E. Coli (3014)				1 routine (RT) per quarter					
Sampling Point (Sampling Point ID)			Monitoring Period		Collection Period		Compliance Status		
DRILLED WELL 1 (2)			4/1/25 - 6/30/25				Complete		
			7/1/25 - 9/30/25				Complete		
			10/1/25 - 12/31/25						
			1/1/26 - 3/31/26						
Other Compliance Schedules									
Compliance Schedule Activity				Due Date		Achieved Date			
CROSS CONNECTION SURVEY REPORT				3/1/2020					
CROSS CONNECTION SURVEY REPORT				3/1/2021					
CROSS CONNECTION SURVEY REPORT				3/1/2022					
RESPOND TO SANITARY SURVEY				3/2/2022					
CROSS CONNECTION SURVEY REPORT				3/1/2023					
CROSS CONNECTION SURVEY REPORT				3/1/2024					
CROSS CONNECTION SURVEY REPORT				3/1/2025					
CROSS CONNECTION SURVEY REPORT				3/1/2026					
Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP	Stage 2 DBPR
00500	BETWEEN GAC FILTERS								
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		4-1	OFFICE- MEN S BR	I	Y				
		4-10	J MAIN BREAKROOM	A	Y	N			
		4-2	OFFICE SINK BREAK RO	I	Y				
		4-3	FACTORY-CT- MEN S RO	I	Y				
		4-4	FACTORY- RM- MEN S R	I	Y				
		4-5	FACTORY- NB- MEN S R	I	Y				
		4-6	MAIN OFFICE CAFE	A	Y	N			
		4-7	MAIN PLANT CAFE	A	Y	N			
		4-8	FURN DEPT CAFE	A	Y	N			
		4-9	J MAIN OFF SINK	A	Y	N			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120422	LOOS & CO - WELL #1			NTNC	130	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 101 & 16A, 24, 28 MASHAMOQUET					4			
Towns Served: POMFRET								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
10523	DRILLED WELL 1	2	DRILLED WELL 1	A				
1449	WELL #1 TREATMENT PLANT							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027
NAPIERATA, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027

Contact Information

Name		Organization		Job Title		
Mr. Russell Cox		Loos & Co		Controller		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
16B Mashamoquet Road				Pomfret Center	CT	06259
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-630-4230		860-928-0880			russell.cox@loosco.com	

Contact Role(s): **Legal Contact**

Name		Organization		Job Title		
Mr. Timothy D. Brown		Loos & Company Inc		Safety Coordinator		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
16 B Mashamoquet Rd				Pomfret Center	CT	06259
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-630-4220				860-931-6431	tim.brown@loosco.com	

Contact Role(s): **Administrative Contact**

Please note the following:

- The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
- If a Collection Period is specified, all water quality samples must be collected during the specified period.
- Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120443	FIBEROPTICS TECHNOLOGY (OLD)			NTNC	50	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 FIBER ROAD				1				
Towns Served: POMFRET								

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120443	FIBEROPTICS TECHNOLOGY (OLD)			NTNC	50	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 FIBER ROAD				1				
Towns Served: POMFRET								

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2020	
CROSS CONNECTION SURVEY REPORT	3/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2022	
CROSS CONNECTION SURVEY REPORT	3/1/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
RESPOND TO SANITARY SURVEY	2/20/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-1	Main Floor Bubbler N	A	Y			
		4-10	Sink Up Stairs Rest	A	Y			
		4-2	Break Room	A	Y			
		4-3	Office Bubblerm	A	Y			
		4-4	Office Ladies Room	A	Y			
		4-5	Office Men s Room	A	Y			
		4-6	Scope Upstairs Rest	A	Y			
		4-7	Scope Break Room	A	Y			
		4-8	DISTRIBUTION SYSTEM	A	Y			
		4-9	Machine Shop Bubbler	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		OLD.001	1ST FL RESTROOM SINK	P		2		
		OLD.002	2ND FL RESTROOM SINK	P	Y	2		
		OLD.003	2ND FL SINK	P	Y	2		
		OLD.004	MACH SHP BUBBLER	P	Y	2		
		OLD.005	PROD AREA SINK	P	Y	2		
		OLD.006	TANK	P				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10524	WELL #1	2	WELL #1	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)			
Facility Classification: SMALL WATER SYSTEM			
Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1120443	FIBEROPTICS TECHNOLOGY (OLD)			NTNC	50	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
1 FIBER ROAD				1				

Towns Served: POMFRET

Contact Information

Name				Organization			Job Title		
Mr. Keith Knowlton				Fiberoptics Technology Inc.			Vice President		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1 Fiber Road			P.O. Box 286			Pomfret		CT	06258
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-928-0443		860-928-7664			kknowlton@fiberoptix.com				

Contact Role(s): **Owner**

Name				Organization			Job Title		
Mr. Kevin R. Lambert				Fiberoptics Technology Inc.			Facility Maint Mgr		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
PO Box 286			1 Quassett Rd			Pomfret		CT	06258
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-928-0443		177	860-928-7664			860-428-0053	klambert@fiberoptix.com		

Contact Role(s): **Administrative Contact**

Name				Organization		Job Title			
Mr. William Bailey				Fiberoptics Technology Inc		Ceo			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
1 Quassett Rd			PO Box 286			Pomfret		CT	06258
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-928-0443	128	860-928-7664			bbailey@fiberoptix.com				

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1129083	THE OWLS NEST DAY SCHOOL			NTNC	38	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
189 POMFRET STREET					1			
Towns Served: POMFRET								

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/33		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1129083	THE OWLS NEST DAY SCHOOL			NTNC	38	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
189 POMFRET STREET				1			
Towns Served: POMFRET							

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2029	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		OWL001	KID'S BATHROOM	A	Y	N		
		OWL002	MIDDLE ROOM SINK	A	Y	N		
		OWL003	PRESCHOOL BATHROOM	A	Y	N		
		OWL004	INFANT ROOM SINK	A	Y	N		
		OWL005	PRETODDLER ROOM SINK	A	Y	N		
		OWL006	WOMEN'S BATHROOM	A	Y	N		
		OWL007	EMPLOYEE BATHROOM	A	Y	N		
		OWL008	STORAGE CLOSET SINK	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
59503	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
WITTENZELLNER, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2027
HARKINS, STUART A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028

Contact Information

Name				Organization		Job Title		
Mr. John Modica				Jupiter Investments 2, LLC				
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P. O. Box 500						Putnam	CT	06260
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-916-3402					jmodicamd@aol.com			

Contact Role(s): **Legal Contact, Owner**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1129083	THE OWLS NEST DAY SCHOOL	NTNC	38	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
189 POMFRET STREET				1	
Towns Served: POMFRET					
Name		Organization		Job Title	
Ms. Kristen Corsetti		The Owls Nest Day School		Business Owner	
Mailing Address Line One		Mailing Address Line Two		City	State
189 Pomfret St.				Pomfret Center	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-928-0410			401-919-2979		Theowlsnestdayschool@yahoo.com
Contact Role(s): Administrative Contact, Legal Contact					

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule