

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1230092	SCOTLAND ELEMENTARY SCHOOL			NTNC	200	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
68 BROOK ROAD				1				
Towns Served: SCOTLAND								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT- WELLS 1 & 2 (WSF ID: 00701)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WELL 2 (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WELL 2 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WELL 2 (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WELL 2 (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP- WELL 2 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1230092	SCOTLAND ELEMENTARY SCHOOL			NTNC	200	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
68 BROOK ROAD				1				
Towns Served: SCOTLAND								

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	001	GYM KITCHEN SINK	P	Y	2		
		002	TEACHER LOUNGE	P	Y	2		
		003	KINDERGARTEN	P	Y	2		
		004	BOILER ROOM (WELL)	P	Y	2		
		005	BOILER RM (TANK)	P	Y	2		
		4	DISTRIBUTION SYSTEM	A	Y			
		4-3	Room #7	A	Y			
		4-5	Room #2	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT- WELLS 1 & 2	3	EP- WELL 2	A				
10573	WELL #1	2	WELL #1	A				
55353	WELL #2	2	WELL #2	A				
55355	GAC FILTERS	3	ENTRY POINT	A				
55357	6K GAL ATM STORAGE							
55359	BOOSTER PUMPS (3)							

### Certified Operator Information

Water System Facility: GAC FILTERS (WSF ID: 55355)			
Facility Classification: CLASS 1 TREATMENT PLANT			
Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027

### Contact Information

Name				Organization		Job Title			
Ms. Valerie Bruneau				Scotland Elementary School		Superintendent			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
68 Brook Road			P.O. Box 97			Scotland		CT	06264
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-423-0064							VBruneau@scotlandes.org		
Contact Role(s): Administrative Contact									

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1230092</b>	<b>SCOTLAND ELEMENTARY SCHOOL</b>	<b>NTNC</b>	<b>200</b>	<b>L</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
68 BROOK ROAD		1			
Towns Served: SCOTLAND					
Name		Organization		Job Title	
<b>Mr. Gary Greenberg</b>		Town of Scotland		First Selectman	
Mailing Address Line One		Mailing Address Line Two		City	State
9 Devotion Road		P.O. Box 122		Scotland	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-456-7797	1				firstselectman@scotlandct.org
Contact Role(s): <b>Legal Contact</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***