

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1320024	MESSIAH LUTHERAN CHURCH			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
300 BUCKLAND ROAD					1			
Towns Served: SOUTH WINDSOR								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate (1040)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Nitrite (1041)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	9/30/2023	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
22219	WELL	2	WELL	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1320024	MESSIAH LUTHERAN CHURCH			NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
300 BUCKLAND ROAD				1			
Towns Served: SOUTH WINDSOR							

Contact Information

Name				Organization			Job Title		
Mr. Bryan H. Gran				Messiah Evangelical Lutheran			President		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
300 Buckland Road						South Windsor		CT	06074
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-644-2110							Secretary@melcct.necoxmail.com		
Contact Role(s): Administrative Contact, Legal Contact									

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1320124	FAIRWAY MINIATURE GOLF AND BATTING CAGES			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
75 SPIELMAN ROAD					2			
Towns Served: SOUTH WINDSOR								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Physical Parameters (PPS) **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX) **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
55152	POINT WELL	2	WELL 1	A				

Contact Information

Name				Organization			Job Title		
Mr. Richard L. Tonucci				Fairway Mini Golf&Batting Cage					
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
75 Spielman Road						South Windsor		CT	06074
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-289-5021						860-673-6554	rbtonucci@gmail.com		
Contact Role(s): Administrative Contact, Legal Contact, Owner									
Name				Organization			Job Title		
Ms. Bernice A. Tonucci				Fairway Mini Golf&Batting Cage			Owner		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
75 Spielman Road						South Windsor		CT	06074
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-289-5021							www.fairwayminiaturegolf.com		
Contact Role(s): Owner									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1320124	FAIRWAY MINIATURE GOLF AND BATTING CAGES			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
75 SPIELMAN ROAD					2			
Towns Served: SOUTH WINDSOR								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule