

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1489013	TILCON CONNECTICUT INC. - WALLINGFORD			NTNC	30	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 68				1				
Towns Served: WALLINGFORD								

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Lead And Copper (PBCU)		5 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
Organic Chemicals (VOCS)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1489013	TILCON CONNECTICUT INC. - WALLINGFORD			NTNC	30	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 68				1				
Towns Served: WALLINGFORD								

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
CROSS CONNECTION SURVEY REPORT	3/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2022	
CROSS CONNECTION SURVEY REPORT	3/1/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MW001	WASH ROOM	A	Y	2	Y	Y
		MW002	LOCKER ROOM	A	Y	2		
		MW003	WELDING SHOP	A	Y	2		
		MW004	NEW BAY FAUCET	A	Y	2		
		MW005	OLD BAY FAUCET	A	Y	2		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10642	WELL	2	WELL	A				

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
RADICCHI, PAUL J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2027

Contact Information

Name				Organization			Job Title		
Mr. Chris Costello				Tilcon Connecticut Inc			Env Mngr		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
642 Blackrock Ave						New Britain		CT	06050
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-224-6048				203-214-9092		ccostello@tilcon-inc.com			
Contact Role(s): Administrative Contact, Legal Contact									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1489013	TILCON CONNECTICUT INC. - WALLINGFORD			NTNC	30	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
ROUTE 68				1				
Towns Served: WALLINGFORD								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1489033	SOUTH BROAD STREET SERVICE AREA			NTNC	250	L	SWP	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
					3			

Towns Served: WALLINGFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete

Asbestos (1094) 1 routine (RT) per nine years

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/33		Complete

Total Coliform (3100) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Lead And Copper (PBCU) 1 routine (RT) per year

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
DIAMOND REST ROOM (WWD0049)	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	

Physical Parameters (PPS) 1 routine (RT) per quarter

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		

Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
-------------------------------------	-----------------	----------------------

CROSS CONNECTION SURVEY REPORT

3/1/2025

Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTEAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WWD0049	DIAMOND REST ROOM	A	Y	2	Y	
		WWD0050	KOHL'S MENS ROOM	A	Y	2	Y	
		WWD0051	KOHL'S WOMANS ROOM	A	Y	2	Y	
		WWD0052	KOHL'S BREAK ROOM	A	Y	2	Y	
		WWD0053	HARBOR F BREAK ROOM	A	Y	2	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1489033	SOUTH BROAD STREET SERVICE AREA			NTNC	250	L	SWP
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				3			

Towns Served: WALLINGFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		WWD0054	SALLYS REST ROOM	A	Y	2	Y	
		WWD0055	ALDI'S BREAK ROOM	A	Y	2	Y	
00700	ENTRY POINT	3	ENTRY POINT	A				
45198	INTERCONNECTION - CT0800011 - MERIDEN							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
PAWLOWSKI, JAY	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		WATER TREATMENT PLANT OPERATOR IN TRAINING	6/30/2028

Contact Information

Name				Organization			Job Title		
Mr. Neil H. Amwake				Town of Wallingford			General Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
377 South Cherry St						Wallingford		CT	06492
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-949-2670			203-949-2678			860-922-6286	neil.amwake@wallingfordct.gov		

Contact Role(s): **Legal Contact, Owner**

Name				Organization			Job Title		
Mr. Shelby P Jackson Iv				Town of Wallingford Water Div			Water Quality Inspct		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
13 Circle Drive						Wallingford		CT	06492
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-949-2666					860-863-6872		nehydrologics1@gmail.com		

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.