

Connecticut Department of Public Health Drinking Water Section									
Water Quality Monitoring and Compliance Schedule									
PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source	
CT1490134	WARREN TOWN CENTER				NC	100	P	GW	
Local Address (where applicable)				Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
4 CORNWALL ROAD						1			
Towns Served: WARREN									
Monitoring Requirements									
Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)									
Total Coliform (3100)					1 routine (RT) per quarter				
Sampling Point (Sampling Point ID)				Monitoring Period		Collection Period		Compliance Status	
Select from Inventory of Active Sampling Points				4/1/25 - 6/30/25				Complete	
				7/1/25 - 9/30/25					
				10/1/25 - 12/31/25					
				1/1/26 - 3/31/26					
Physical Parameters (PPS)					1 routine (RT) per quarter				
Sampling Point (Sampling Point ID)				Monitoring Period		Collection Period		Compliance Status	
Select from Inventory of Active Sampling Points				4/1/25 - 6/30/25				Complete	
				7/1/25 - 9/30/25					
				10/1/25 - 12/31/25					
				1/1/26 - 3/31/26					
Water System Facility: ENTRY POINT (WSF ID: 00700)									
Nitrate And Nitrite (NOX)					1 routine (RT) per year				
Sampling Point (Sampling Point ID)				Monitoring Period		Collection Period		Compliance Status	
ENTRY POINT (3)				1/1/24 - 12/31/24				Complete	
				1/1/25 - 12/31/25					
				1/1/26 - 12/31/26					
Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
			DOWNSTEAM WITHIN 5 SERVICE CON	A					
			UPSTREAM WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
22487	WELL	2	WELL	A					
61234	TREATMENT PLANT								
Contact Information									
Name				Organization			Job Title		
Mr. John Favreau				Warren Town Center LLC					
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
53 Windy Ridge Rd						Warren		CT	06757
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
860-868-5353		860-868-5353		646-573-7973	johnfavreau@warrentowncenter.com				
Contact Role(s): Administrative Contact, Legal Contact, Owner									

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1490134	WARREN TOWN CENTER			NC	100	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
4 CORNWALL ROAD					1			
Towns Served: WARREN								

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1490174	THE WASHINGTON CLUB			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
20 NORTH SHORE ROAD							1	
Towns Served: WARREN								

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		

Physical Parameters (PPS)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	5/1/25 - 5/31/25		Complete
	6/1/25 - 6/30/25		Complete
	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24	5/1-9/30	Complete
	1/1/25 - 12/31/25	5/1-9/30	Complete
	1/1/26 - 12/31/26	5/1-9/30	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	7/6/2019	
CROSS CONNECTION SURVEY REPORT	3/1/2020	
CROSS CONNECTION SURVEY REPORT	3/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2022	
CROSS CONNECTION SURVEY REPORT	3/1/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
SAMPLING SITE PLAN	3/17/2025	
RESPOND TO SANITARY SURVEY	3/28/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1490174	THE WASHINGTON CLUB			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
20 NORTH SHORE ROAD							1	
Towns Served: WARREN								

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00700	ENTRY POINT	3	ENTRY POINT	A				
23113	NEW WELL	2	NEW WELL	A				

Contact Information

Name				Organization			Job Title		
Mr. Paul A Smith III				Washington Club			General Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
92 Green Hill Road						Washington		CT	06793
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-868-0376		1				914-419-3302	gm@washingtonclub.net		

Contact Role(s): **Administrative Contact**

Name				Organization			Job Title		
Mr. Matt Grabel				Washington Club			Controller		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
PO Box 400						Washington Depot		CT	06794
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-868-0376		1					controller@washingtonclub.net		

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule