

Connecticut Department of Public Health Drinking Water Section									
Water Quality Monitoring and Compliance Schedule									
PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source	
CT1540074	KINGDOM HALL OF JEHOVAHS WITNESS				NC	25	P	GW	
Local Address (where applicable)				Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
179 GROVE BEACH					1				
Towns Served: WESTBROOK									
Monitoring Requirements									
Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)									
Total Coliform (3100)					1 routine (RT) per quarter				
Sampling Point (Sampling Point ID)				Monitoring Period		Collection Period		Compliance Status	
Select from Inventory of Active Sampling Points				4/1/25 - 6/30/25				Complete	
				7/1/25 - 9/30/25				Complete	
				10/1/25 - 12/31/25					
				1/1/26 - 3/31/26					
Physical Parameters (PPS)					1 routine (RT) per quarter				
Sampling Point (Sampling Point ID)				Monitoring Period		Collection Period		Compliance Status	
Select from Inventory of Active Sampling Points				4/1/25 - 6/30/25				Complete	
				7/1/25 - 9/30/25				Complete	
				10/1/25 - 12/31/25					
				1/1/26 - 3/31/26					
Water System Facility: ENTRY POINT (WSF ID: 00700)									
Nitrate And Nitrite (NOX)					1 routine (RT) per year				
Sampling Point (Sampling Point ID)				Monitoring Period		Collection Period		Compliance Status	
ENTRY POINT (3)				1/1/24 - 12/31/24				Complete	
				1/1/25 - 12/31/25				Complete	
				1/1/26 - 12/31/26					
Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
23040	WELL #1	2	WELL #1	A					
Contact Information									
Name				Organization			Job Title		
Mr. Eric Bohman									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
PO Box 780						Westbrook		CT	06498
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone		Email Address	
860-669-9484								woodonwater@icloud.com	
Contact Role(s): Administrative Contact, Legal Contact									

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1540074	KINGDOM HALL OF JEHOVAHS WITNESS			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
179 GROVE BEACH					1			
Towns Served: WESTBROOK								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

***End of schedule***