

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule										
PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source		
CT1590024	THE 798 SILAS DEANE HIGHWAY, LLC				NC	25	P	GW		
Local Address (where applicable)				Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
						1				
Towns Served: WETHERSFIELD										
Monitoring Requirements										
Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)										
Total Coliform (3100)					1 routine (RT) per quarter					
Sampling Point (Sampling Point ID)					Monitoring Period		Collection Period		Compliance Status	
Select from Inventory of Active Sampling Points					4/1/25 - 6/30/25				Complete	
					7/1/25 - 9/30/25					
					10/1/25 - 12/31/25					
					1/1/26 - 3/31/26					
Physical Parameters (PPS)					1 routine (RT) per quarter					
Sampling Point (Sampling Point ID)					Monitoring Period		Collection Period		Compliance Status	
Select from Inventory of Active Sampling Points					4/1/25 - 6/30/25				Complete	
					7/1/25 - 9/30/25					
					10/1/25 - 12/31/25					
					1/1/26 - 3/31/26					
Water System Facility: ENTRY POINT (WSF ID: 00700)										
Nitrate And Nitrite (NOX)					1 routine (RT) per quarter					
Sampling Point (Sampling Point ID)					Monitoring Period		Collection Period		Compliance Status	
ENTRY POINT (3)					4/1/25 - 6/30/25				Complete	
					7/1/25 - 9/30/25					
					10/1/25 - 12/31/25					
					1/1/26 - 3/31/26					
Water System Facility and Sampling Point Inventory										
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR		
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y					
		DOWNSTREAM	WITHIN 5 SERVICE CON	A						
		UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A						
22534	WELL	2	WELL	A						
Contact Information										
Name				Organization			Job Title			
Ms. Dianne S Lombardo				The 798 Silas Deane Hwy LLC						
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code	
137 New Bolton Rd						Manchester		CT	06040	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address					
860-875-8804										
Contact Role(s):		Administrative Contact, Legal Contact, Owner								

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1590024	THE 798 SILAS DEANE HIGHWAY, LLC			NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1			

Towns Served: WETHERSFIELD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule